APPENDIX H

REACTOR PRESSURE VESSEL DESIGN SUMMARY REPORT

MONTICELLO NUCLEAR GENERATING PLANT MONTICELLO, MINNESOTA UNIT 1

NOTE: The effects of increasing reactor power to 2004 MWt were evaluated in Task Report T0302, Reactor Vessel Integrity - Stress and Fatigue Evaluation, to ensure that the reactor vessel components continue to comply with the existing structural requirements of the ASME Section III Boiler and Pressure Vessel Code. Reference "Task Report T0302, Reactor Vessel Integrity-Stress and Fatigue Evaluation," (Monticello calculation number 11-223), for further information.

TABLE OF CONTENTS

DESIGN REQUIREMENTS	H.1-1
EXHIBITS:	
1. RPV Purchase Specifications 21A1112	1-1
2. Manufacturer's Data Report and Vessel Certification	2-1
3. Tensile Tests - Specimens of 80% Plate Thickness	3-1
4. Summary Stress Report	4-1
5. Vessel Fabrication and Assembly Report	5-1
6. Independent Stress Analysis Report	6-1
7. Reactor Vessel Design Specification (Repair)	7-1
8. Reactor Vessel System Cycling (Stress Report)	8-1
9. Reactor Vessel Rapid Cycling (Stress Report)	9-1

PAGE

86-061

ľ)

DESIGN AND FABRICATION REQUIREMENTS

The Monticello reactor vessel was designed, fabricated, inspected, and tested in accordance with the American Society of Mechanical Engineers Boiler and Pressure Vessel Code Section III, Nuclear Vessels 1965 Edition and Addenda to and including Summer 1966 Addenda, and the following additions:

- 1. ASME SA533 plate and Inconel material per Summer 1967 Addenda.
- 2. Main closure flange material per Code Case 1332-3.
- 3. Studs and nuts material for main closure flanges per Code Case 1335-2.
- 4. Main closure flange and stud shank transition radius per Code Case 1366.
- 5. Bearing stresses for stabilizer brackets and coefficients of thermal expansion per Winter 1967 Addenda.
- 6. Magnetic particle and liquid penetrant examination per Winter 1966 Addenda.

The date of the contract between the Buyer, General Electric Company, Atomic Power Equipment Department, San Jose, California and the Seller, Chicago Bridge and Iron Company, San Francisco, California, was July 18, 1966. There are no deviations to the formal code throughout the design, fabrication, inspection and testing of the reactor vessel.

Design fabrication, inspection, and test requirements in addition to those required by the B&PV code were required by the Buyer's vessel purchase specification 21All12 (Exhibit 1). These include but are not limited to the following pertinent inspections and/or tests:

- Established specific maximum nil ductility transition temperatures for the main closure flanges and the shell and head materials connecting to these flanges (+10°F NDT temperature) and elsewhere (+40°F NDT temperature).
- 2. A fabrication test program on vessel shell material which included testing of large size tensile specimens (80% of the vessel wall thickness in diameter) both plain and welded samples. (See Exhibit 3).
- 3. Provisions are made for determining the effects of nuclear radiation upon the reactor vessel structural materials by supplying specimens of the vessel material to be exposed to the core irradiation at the vessel wall inside of the vessel.

Pertinent certifications are contained in Exhibit 2, <u>Manufacturer's</u> Data Report and Vessel Certification, Chicago Bridge & Iron Company.

The surmary of results of the detailed stress analysis is contained in Exhibit 4.

Plans for the vessel fabrication and assembly were described in Amendment 2 to the FDSAR, "Design Fabrication and Erection of the Reactor Vessel." Actual fabrication and assembly was in accord with Section IV of Amendment 2 except for minor modifications as listed in Exhibit 5 of this report.

The GE quality control of the reactor vessel was essentially as described by General Electric Quality Control Plan, Section IV of Amendment 2 to the FDSAR, except the Domestic Turnkey Projects organization of General Electric Co. also made an independent QC audit.

A detailed seismic analysis of the Reactor Pressure Vessel was prepared by John Blume & Associates and was included in Appendix A along with other seismic analyses.

In 1977, repairs were made to the reactor pressure vessel feedwater nozzles and safe ends to minimize damage to the feedwater nozzles due to thermal cycling. The repairs consisted of removing cladding from the nozzle blend radius and bore and the installation of a feedwater sparger interference fit thermal sleeve with a piston ring seal. These design changes invalidated the "Summary of Stress Analysis for the feedwater Nozzles" shown on page 4-14 of Exhibit 4. Details of this repair and design are contained in Exhibit 7.

Also in 1977, a design change modified the CRD return line because of its susceptibility to intergranular stress corrosion cracking. The 3" CRD return line and the reactor vessel nozzle safe-end forging were removed and the nozzle was capped using a 4" diameter schedule 120 pipe cap. This design change eliminated the imposed mechanical loading for the nozzle, creating a much less severe condition than the nozzle was originally designed for. As a result of this modification, the "Summary of Stress Analysis for the 3" CRDHSR Nozzle" shown on page 4-18 of Exhibit 4, is invalidated. Details of the modification and new stress analyses are contained in design change 77M069.

In 1981, new feedwater nozzle safe ends featuring a tuning fork design with a welded in thermal sleeve were installed and a section of piping upstream of each nozzle was replaced with piping of a different material. These modifications were performed to provide a significant reduction in thermal cycling of the feedwater nozzle area. The new stress analyses that replaced the "Summary of Stress Analysis for the Feedwater Nozzle" shown on page 4-14 of Exhibit 4, are contained in Exhibit 8 and Exhibit 9.

In 1984 several modifications were incorporated to provide greater resistance to intergranular stress corrosion cracking.

The core differential pressure and standby liquid control safe end was replaced using a safe end of similar design, but with different materials. The new stress analyses are contained in General Electric Stress Report No. 23A4115, included in Design Change No. 83Z049C.

H.1-2

REV 7 12/88

The jet pump instrumentation safe end and penetration seal was replaced with the jet pump instrumentation nozzle penetration seal, using low carbon 316 to replace the original ASTM A508 Class II material. The new stress analyses are contained in General Electric Stress Report No. 23A1939, also included in Design Change No. 83Z049C.

The core differential pressure and standby liquid control, and the jet pump instrumentation modifications invalidated the "Summary of Stress Analysis for Core Differential Pressure and Liquid Control Nozzle, Head Cooling Spray and Instrumentation Nozzles, Vent Nozzle, Instrumentation Nozzles, Jet Pump Instrumentation Nozzles, Drain Nozzle, High Pressure Seal Leak Detector Nozzle and Low Pressure Seal Leak Detector Nozzle" shown on page 4-28 of Exhibit 4.

Also, in 1984, a corrosion resistant cladding overlay was applied to the inside diameter of the RV head vent nozzle and RV head cooling spray and instrumentation nozzles. The weld overlay of 308L isolated the IGSCC susceptible existing weld butter located in the weld residual stress area from the reactor coolant. As documented in General Electric Stress Report No. 23A4280, part of Design Change No. 84Z068, stress calculations performed originally at this location are still valid.

The recirculation inlet and outlet nozzles were both modified during the 1984 outage. General Electric Stress Report No. 23A1627, part of Design Change No. 83Z049A, documents the analysis of the redesign and replacement of the recirculation inlet nozzle safe end and thermal sleeve, including the attachment weld and the weld overlay to the recirculation inlet nozzle. This design change invalidated the "Summary of Stress Analysis for Recirculation Inlet Nozzle" shown on page 4-22 of Exhibit 4.

Bechtel Stress Report No. SR-10040-SS2 (Rev. 3), also part of Design Change No. 83Z049A, documents the analysis of the replacement of the recirculation outlet nozzle safe end fitting, a forged and machined component made of SA 358 Type 316 stainless steel. The "Summary of Stress Analysis in Recirculation Outlet" shown on page 4-24 of Exhibit 4 has been invalidated by this change.

In 1986, new core spray safe ends featuring a tuning fork design with a thermal sleeve were installed along with a section of piping upstream at each nozzle. This modification was performed to minimize the chance of IGSCC from occurring in the Core Spray System. The new stress analyses is documented by Bechtel Document 301-P-5.

Also in 1986, the CRD return nozzle, previously capped in 1977, was again modified. The purpose of the modification was to remove that portion of the existing weld butter layer susceptible to IGSCC, and re-clad the weld prep area with corrosion resistant cladding and install a new nozzle cap. General Electric Stress Report No. 23A5553, included as part of Design Change No. 86Z016, documents the analysis.

H.1-3

REV 7 12/88

THIS PAGE INTENTIONALLY LEFT BLANK

and the second second

.

.

REV 7 12/88

. _ _

.

.

EXHIBIT 1

REACTOR PRESSURE VESSEL PURCHASE SPECIFICATION 21A-1112

•

· •• ·

.

1-1

NUCLEAR ENERGY DIVISION

ELECTRIC

GENERAL

Document	No.	21A1112,	Rev. ⁶	
	-			

General Electric Class

TRANSMITTAL

PROJECT(S) MONTICELLO TITLE OF REACTOR PRESSURE VESSES DOCUMENT TYPE OF [] PURCHASE SPECIFICATION REPLACES DOCUMENT:[] SYSTEM DESIGN SPECIFICATION DOCUMENT NO. [] INSTALLATION SPECIFICATION [] PIPING OR COOLING SYSTEM INVOLVED MAR - 5 1969 RESPONSIBLE ENGINEER DR HEISING ISSUED BY JA MAST DATE REFERENCES MASTER PARTS LIST (MPL) NOS. 21A9821 - Stud Tensioner SPECIFICATIONS 21A1050 - Std. Requirements for Reactor Servicing Tools 107C5305 - Preparation of Nozzles DRAWINGS 885D911 - Bolting 886D482 - Reactor Vessel 117B1550 - 1/4" Tensile Test Specimen 117B1549 - Charpy Impact Specimen REVISION RECORD REVISED PER (XX, ECN, XXX.) #960 SHEETS AFFECTED 16 - 21 and Attachment E REVISION IDENTIFIED WITH COMMENTS:

		DISTRIB	UTION		
NAME	MAIL CODE	COPIES	NAME	MAIL CODE	COPIES
DR HEISING	743	1			
RL CALL	743	1	1		
AC DE LOACH	621	1			
GRU	742	1			}
Alexander	366	6+2R			1
Wolf	377	2			
Vassar	350	1 .			
Skarpelos	359	1	t l		1
Lingafelter	350	1			
	375	1			
	591	1			l
	595	1			ł
	624	1			
	711	1			
	722	1			
	723	1 3 1			
	743	3			
	761	1			· ·
	v				
				1	
		ł			
	I.	l.	41	1	10/4/68

1-2

GENERAL 🍘 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

IC .	SPECIAL MONTICE		T		
	SPEC. NO.	21A111	.2	REV. NO.	6
	SH NO.	-		ON SHEET	2

PURCHASE SPECIFICATION

TITLE

REACTOR PRESSURE VESSEL

TABLE OF CONTENTS

PARA	TITLE	PAGE
1.0	SCOPE	2
2.0	RESPONSIBILITY	2
3.0	GENERAL DESCRIPTION	2
4.0	CODES	3
5.0	DESIGN REQUIREMENTS	4
6.0	DESIGN ANALYSIS	7
7.0	CONSTRUCTION	10
8.0	MATERIALS	14
9.0	FABRICATION	19
10.0	INSPECTION AND TEST	2 2
11.0	SHIPMENT	32
12.0	SUBMITTALS	32
	ATTACHMENT A - INSTRUCTION MANUAL, DRAWING & DATA REQUIREMENTS	L .
	ATTACHMENT B - MATERIAL TESTS AND TEST SPECIMENS	
	ATTACHMENT C - DESIGN ANALYSIS SCHEDULE FOR REACT PRESSURE VESSEL FOR MONTICELLO POW STATION	
	ATTACHMENT D - TEMPERATURE TRANSIENTS	
	ATTACHMENT E - CERTIFICATION OF DESIGN SPECIFICAT	ION

MAR - 5 1959 DR HEISING 3-4-69 ISSUED: JA MAST

. . . .

GENERAL 🌚 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

SPEC. NO. 21A1112 REV. NO 6 SH NO. 2 CONT ON SHEET 3

1.0 <u>SCOPE</u>

- 1.1 This specification defines the engineering requirements of the equipment specified herein.
- 1.2 The work done by the Seller in accordance with this specification shall include all necessary design, development, analysis, drawings, evaluation of materials and fabrication methods, shop fabrication, shipment, field erection, inspection, and testing.

2.0 RESPONSIBILITY

The Seller shall accept full responsibility for his work and for compliance with this specification. Review or approval of drawings, procedures, data or specifications by the Buyer with regard to general design and controlling dimensions does not constitute acceptance of any designs, materials or equipment which will not fulfill the functional or performance requirements established by the purchase contract.

3.0 GENERAL DESCRIPTION

- 3.1 The reactor vessel will be used as a pressure container supporting the steam generating core in the Monticello Nuclear Power Station to be located near Monticello, Minnesota.
- 3.2 The equipment to be furnished in accordance with this specification shall be one reactor pressure vessel assembly with a removable head and nozzles and certain internal support structures, arranged as shown on Drawing 886D482 complete with:
- 3.2.1 Attachments for thermal insulation, vessel and core supports, brackets or legs for lifting and handling of the vessel head, and mounts for outside surface thermocouples.
- 3.2.2 One set of necessary special tools required to remove and replace the reactor vessel head. The set of tools shall include: four hydraulic stud tensioners, stud elongation measuring device, stud and nut wrenches, one set of stud thread protectors, three head guide caps, one bushing wrench, one stud sling. Stud tensioners shall be in accordance with Specifices: a 21A9821 and shall include a lifting device that properly spaces the tensioners over the bolt circle.

1-4

GENERAL 🐨 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

SPEC. NO. 21A1112 REV. NO. 6 SM NO. 3 CONT ON SHEET 4

- 3.2.3 One set of necessary special tools required to install and remove the reactor vessel head seals with manual contact. This set of tools shall include a protective cover for the reactor vessel shell flange seal surface.
- 3.2.4 Metal boxes for the hand tools. Boxes shall be suitable for handling with a crane and/or fork lift truck.
- 3.2.5 One lot of reactor vessel material test plate and material test specimens in accordance with Attachment B.
- 3.2.6 Shipping skids for those portions of the Reactor Vessel which are shop fabricated.

4.0 CODES

- 4.1 The reactor vessel shall be designed, fabricated, inspected, tested and stamped in accordance with the American Society of Mechanical Engineers (ASME), Boiler and Pressure Vessel Code, Section III, applicable requirements for Class A Vessels as defined therein, interpretations of the ASME Boiler and Pressure Vessel Code, and all laws, rules and regulations of the State of Minnesota in effect on the date of the contract.
- 4.2 Deviations from the applicable codes or regulations shall be avoided. Where a conflict exists among the codes or regulations, the Seller shall bring this to the Buyer's attention. It shall be the responsibility of the Seller to obtain resolution and disposition of deviation with the Buyer and other appropriate parties and authorities.
- 4.3 The intent of this specification is to supplement the requirements of the codes specified herein and to encompass the means whereby the design objective is satisfied.
- 4.4 All standards and material specifications shall be per latest revision in effect on the date of the contract.

ISSUED:			
MAR	- 5	1969	

GENERAL 🌚 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. SH NO. 4 CONT ON SHEET

5.0 DESIGN REQUIREMENTS

5.1 Operating Conditions

5.1.1 Internal Pressure

Design Pressure: 1250 psig at bottom of the reactor vessel Normal Operating Pressure: 1000 psig at top of reactor vessel

5.1.2 Temperature

Design Temperature: 575°F Normal Operating Temperature: 546°F

5.1.3 Reactor Core and Internal Weight

The weight of the reactor core and internal structure, centers of gravity and distribution of loadings are shown on Drawing 886D482.

5.1.4 Water Weight

The weight of water contained in the vessel for various conditions of operation are presented on Drawing 886D482.

5.1.5 Pipe Reactions

The Buyer shall provide the Seller with the pipe reactions which the connecting piping will apply to all nozzles with a nominal size larger than the reactor vessel wall thickness and those nozzles which in addition are subjected to significant thermal cycling. The reactions will be limited by the Buyer such that the combined stress as due to pipe reactions and design pressure in the vessel shell at the nozzle attachment will not exceed the design stress allowed by the ASME Code, Section III. These pipe reactions shall be used in the detailed stress analysis required by the Code and performed by the Seller. This analysis shall include the thin section of the nozzle in the vicinity of the weld preparation for connecting piping, any bi-metal weld and shall take into account the nozzle cladding.

5.1.6 Control Rod Drive Weight and Reaction

The momentary reactions which are suddenly applied to each control rod drive housing in the vessel bottom head are presented on Drawing 886D482.

1-

6

MAR	-5	1969	

GENERAL 🍪 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 5 CONT ON SHEET 6

ISSUED:

MAR - 5 1969

5.1.7 <u>Steady State Thermal Conditions</u>

Steady state were imperatures will be computed by the Buyer for no more than twelve locations on the reactor vessel. The locations will include the head and shell closure flanges, the shell adjacent to the reactor core, the bottom head and major nozzles including the control rod drive nozzles. Temperature gradients through the shell wall adjacent to the portion of the reactor core peak flux zone will be computed by the Buyer and furnished to the Seller.

5.1.8 Cyclic Loading

The thermally induced stresses which result from the transients listed in Attachment D shall be computed for the components listed. The cyclic stress ranges which result from these and the following conditions shall be evaluated in a fatigue analysis according to the ASME Code Section III.

The additional conditions are:

- a) Zero stress condition
- b) Isothermal condition at 546°F and 1000 psi inside vessel.
- c) Isothermal conditions at 70°F and 1000 psi inside vessel 120 cycles.
- d) For the closure flanges and bolting the cold bolt-up condition
- 120 cycles. Earthquake Loads

Earthquake loads shall be taken into account in accordance with the criteria and load presented on Drawing 886D482.

5.2 Design Considerations

5.2.1 <u>Design Objective</u>

5.1.9

The objective shall be to design and fabricate this reactor vessel to have a useful life of forty years under operating conditions specified by the Buyer.

5.2.2 <u>Reactor Vessel Supports</u>

Reactor Vessel supports, internal supports, their attachments and adjacent shell shall be designed to take maximum combined loads including control rod drive reactions, earthquake loads, and jet reaction thrusts as defined on Drawing 886D482. There shall be no gross yielding of the reactor vessel supports causing permanent displacement under these conditions.

5.2.3 Stress Concentrations

Care shall be taken in design and fabrication to minimize stress concentrations at changes in sections or penetrations. Fillet radii shall be equal to at least half the thickness of the thinner of the two sections being joined. If reinforcement for openings (except the control rod drive and in-core flux monitor nozzles) requires local vessel shell added thickness, such reinforcement shall extend at least 1-1/2 times the diameter of the opening from the center of the opening. These requirements are not to be construed as a waiver for evaluating the stresses for use in the analysis for cyclic operation.

GENERAL 🌚 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 6 CONT ON SHEET 7

5.2.4 <u>Corrosion Allowance</u>

Exterior exposed ferritic surfaces of pressure-containing parts including heads, shell, flanges and nozzles shall have a minimum corrosion allowance of 1/16 inch. The interior surface of carbon or low alloy steel parts exposed to the reactor coolant shall also have a minimum corrosion allowance of 1/16 inch. If the main closure head is left unclad, its interior surface shall also have a minimum corrosion allowance of 1/16 inch.

5.2.5 Main Closure Seal

The reactor pressure vessel main closure seal shall be a double seal designed to have no detectable leakage through the inner or outer member at all operating conditions. These conditions include, but are not limited to: (a) cold hydrostatic pressure test at the design pressure, (b) heating to design pressure and temperature at a rate of 100°F/hr., maximum, (c) operating for extended periods of several months duration at operating conditions, and (d) cooling at a rate of 100°F/hr., maximum.

5.2.6 Design Stress

Design stress values used in the calculations shall be as contained in ASME Section III and applicable interpretations of ASME Boiler and Pressure Vessel Code for materials covered therein. The design stress values for ASME, Section III calculations for other materials approved by the Buyer in accordance with Paragraph 8.1 of this specification shall be determined per Appendix II, ASME Code, Section III.

5.2.7 <u>Dimensional Control</u>

Seller shall show the method of controlling measuring and maintaining alignment and location of control rod drive penetrations with the vessel and core supports.

5.2.8 The reactor shall be designed to minimize retention pockets and crevices.

GENERAL 🐲 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

SPEC. NO.	21A11	12	REV.	NO. 6	
SH NO.	7	CONT	ON SP	EET	8

6.0 DESIGN ANALYSIS

6.1 <u>Requirements</u>

The Seller and the Buyer shall perform the design calculations and analyses as required by the applicable Standards and Codes indicated in Section 4.0. The requirements of Article 4, ASME Code, Section III, shall be fulfilled. The division of responsibility for the analyses shall be in accordance with paragraph 6.1.3. The analysis required shall be performed in two divisions as follows:

6.1.1 Stress Analysis

A stress analysis shall be performed in accordance with Section N-430, ASME Code Section III. Calculations shall be performed in accordance with paragraph N-431 to verify that the minimum wall thickness is provided. A detailed stress analysis shall be performed in accordance with paragraph N-432. This analysis shall take into account all combinations of loads in conjunction with metal temperatures, as indicated in Section 5.0 above, and Drawing 886D482 within the Design Stress Criteria of ASME Code Section III, Article 4.

6.1.2 Analysis for Cyclic Operation

An analysis shall be performed in accordance with Section N-415 of the ASME Code, Section III, to determine that the vessel is suitable for the cyclic loading conditions of paragraph 5.1.8 above. This analysis shall also be performed within the design stress criteria of Section III, Article 4, to establish whether the design objective in paragraph 5.2.1 above is reached. The analysis will be used to determine the adequacy of any required thermal baffling used to control or limit thermal stresses and to place safe operating limits on the cyclic conditions imposed on the vessel where it is reasonable to control them, as in the start-up heating rate and shut-down cooling rate.

6.1.3 Division of Responsibility

The Seller and the Buyer shall perform jointly the design analysis required by this specification.

6.1.3.1

The seller shall perform calculations to satisfy limits on primary general membrane stress $(P_{\rm M})$, primary local membrane stress $(P_{\rm L})$, primary bending $(P_{\rm B})$, and secondary membrane plus bending stresses (except thermal stresses) (Q) from specified steady state conditions. Also included are calculations necessary to reinforce openings per Paragraph N-450, except the calculations necessary to satisfy the cyclic conditions and Paragraph N-451 (b) which are the responsibility of the Buyer.

MAR - 5 1969

GENERAL 🍘 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 8 CONT ON SHEET 9

6.1.3.2

The Buyer shall perform the transient and steady state thermal analysis and the analysis for cyclic operation on all components requiring such analysis. These analyses will provide the stress categories Q and F of Paragraph N-414, ASME Section III. This type of analysis will cover but not necessarily be limited to the following parts of the reactor vessel:

- a. Emergency cooling nozzles (safe end and thermal sleeve)
- b. Feedwater nozzles (safe end and thermal sleeve)
- c. Control rod drive hydraulic system return nozzle (safe end and thermal sleeve)
- d. Vessel Support Skirt
- e. Refueling bellows support skirt
- f. Closure flanges
- g. Bolting
- h. Control rod drive penetration
- 6.1.3.3

The analyses which are the responsibility of the Buyer but are made with the Sellers assistance, shall be checked and signed by the Buyer.


6.1.3.4

The Seller shall fulfill the requirements of Paragraph 4.0 Codes, and produce the summary report required by Paragraph 6.8. The Buyer shall prepare its portions in suitable form for reproduction.

6.2 Calculation of Stresses

The detailed structural analysis required to meet the requirements of 6.1 shall be made for the stresses resulting from internal pressure, external and internal loadings, and the effects of steady and fluctuating temperatures and loads for regions given in 6.3 which involve changes of shape, structural discontinuities, and points of concentrated loadings.

Where dimensions and loading conditions permit, the adequacy of structural elements will be verified by comparison with completely analyzed elements. The calculations shall include a complete



GENERAL 🌆 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. Q CONT ON SHEET 10

analysis of stresses under stead state and transient conditions to determine suitability of the design with respect to the allowable stress given in ASME Code, Section III, and to determine the operational limitations with respect to fatigue of the reactor vessel materials over the life of the reactor vessel (Design Objective) using the loading conditions supplied by the Buyer.

6.3 Parts of the Reactor Vessel Assembly to be Analyzed

The parts of the reactor vessel to be analyzed shall include: head closure, bottom head, shell adjacent to reactor core, reactor vessel supports and stabilizers, supports for reactor vessel internals, control rod drive penetration, feedwater nozzle, poison nozzle, emergency core cooling nozzles, drive system return nozzle, and all nozzles 10" or larger in size.

6.4 Closure Head Seal Calculation

To assure meeting sealing requirements of the main closure seal as specified in paragraph 5.2.5 above, the relative rotations of the flanges shall be calculated. These rotations shall be used to demonstrate analytically satisfactory seal performance using the following assumptions:

- 6.4.1 The mating surfaces of the flanges shall be assumed rigid.
- 6.4.2 The rotation shall be assumed to cause contact over the minimum area which will sustain the loading between the faces when stressed to the yield strength at the metal temperature.
- 6.4.3 The flange faces shall be assumed to diverge from the contact area, specified in paragraph 6.4.2, through the angle of calculated relative rotation less any radial taper machined on the face(s) to accommodate the flange rotations.
- 6.4.4 It may be assumed that the seal will be maintained if, at both O-ring seal locations, the separation between flanges is less than the minimum elastic spring-back of the O-ring.

6.5 <u>Calculations</u>

The calculations shall be clear and in sufficient detail to permit independent checking. Specific references shall be given for all formulas and methods used or the formulas and methods shall be derived independently. Calculation shall be submitted to the Buyer for approval.

GENERAL 🌚 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

MAR - 5 1969

6.6 Descriptions of Computer Programs

If computer programs are used to obtain solutions to design problems, the Seller shall furnish the Buyer the description of each different computer program used. These descriptions shall be furnished with the first issue of the design calculations incorporating such programs. The computer program description shall include computer type, program capabilities, assumptions, limitations and statement of availability.

6.7 <u>Measurement Reports</u>

Measured values of strain, deflections or stresses resulting from tests on models or actual reactor vessels shall be supplied to the Buyer by the Seller. These reports shall include all information necessary to duplicate the conditions required to obtain the results reported.

6.8 Summary Report

After completion of the reactor vessel design, the Seller shall furnish the Buyer additional copies of all calculations plus a summary report of results of all computations. Each copy shall be bound in a suitable paper binding and indexed.

7.0 CONSTRUCTION

The reactor vessel body including all components which contain pressure including the shell, lower and upper heads shall be made of rolled plate and/or forgings welded with full penetration welds throughout except as noted in 7.3.5. The shell and head flange and nozzles shall be forged.

7.1 Shell and Heads

7.1.1 Longitudinal and circumferential weld joints in the reactor vessel shall be oriented so as not to intersect openings or penetrations, wherever practical. Circumferential weld seams should avoid regions of highest neutron flux in the core region, if practical. The region of highest neutron flux occurs between the mid-plane and top of the core.

GENERAL TELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 11 CONT ON SHEET 12

7.1.2 Bottom Head

The section of the bottom head which encompasses the penetrations for the control rod drives and in-core flux monitors shall be either a single forging or dished plate, if practical. If this is not practical and a weldment is used, the orientation of the weld sections shall as far as practical minimize the number of intersections of weld seams with penetrations.

7.1.3 Top Head

The top head shall be either a single forging or dished plate or shall be fabricated of sections welded together, with the orientation of the weld seams such that no seams intersect openings or penetrations.

7.1.4 <u>Weld Joints</u>

Weld joints shall be designed to facilitate a maximum of radiographic examination per the ASME Boiler and Pressure Vessel Code, Section III, paragraph N-624.

7.2 Head Closure

- 7.2.1 Assembly and Disassembly
- 7.2.1.1 The head closure shall be designed for removal and reassembly, using 4 or more hydraulic stud tensioners.
- 7.2.1.2 It shall be the design objective to replace and remove the head within 16 hours elapsed time. Specifically, the cycle shall include placing the head over the studs, tightening the studs to operating bolt-up loads, unbolting and removal of the head over the studs. It is expected that 120 such cycles will be performed during the life of the reactor vessel.

7.2.2 <u>Seals</u>

- 7.2.2.1 The head seal shall be a double seal with a vent between the seals through which leakage of the inner ring can be detected. The seal vent shall be designed for full design pressure of the reactor vessel.
- 7.2.2.2 The seal shall be metal O-ring type with pressure equalizing vents on I.D.
- 7.2.2.3 The grooves for the O-rings shall be placed in the reactor head flange. Suitable fasteners shall be provided to hold the O-rings in the grooves during head removal and assembly operations.

GENERAL 🛞 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 12 CONT ON SHEET 13

7.2.2.4 Provisions shall be made for installation of a low pressure leak detection system outside of the second seal, and may be outside of the bolt circle. The provisions shall include a vent through the vessel flange with extended 1" nipple and socket weld fitting and either a shallow groove or other suitable backing to retain a soft asbestos braided packing. There shall be no protruding parts of this low pressure seal beyond the 0.D. of the head and vessel flange.

7.2.3 Bolting

- 7.2.3.1 Studs shall be used to secure the reactor vessel head. Stud, nut and bushing threads shall be in accordance with Drawing 885D911.
- 7.2.3.2 The stud bolt holes in the reactor vessel flange shall be bushed with removable bushings. Keys shall be provided for each bushing to prevent rotation of the bushings when removing studs.
- 7.2.3.3 Spherical washers shall be used with the stude to minimize bending of the stude.
- 7.2.3.4 It shall be possible to remove and replace the head with the studs installed. To facilitate head removal and replacement, three special guide caps shall be provided to couple onto three studs. The lengths of the guiding surfaces of the guide caps shall be staggered so that the shorter of the three guide caps shall extend above the top of the installed studs for a minimum distance of 4 inches. The length of the three guide caps shall be staggered in 3-inch minimum increments. The internal threads of the guide caps shall be similar to the stud nuts threads. The upper end of the guide caps shall be provided with a conical lead-in taper and a horizontal through-hole bored to accommodate a round bar for wrenching.
- 7.2.3.5 Flange hole, bushing, and stud designs shall be such that the studs stand perpendicular to the flange surface when the studs and bushings are bottomed in the holes to facilitate removal and replacement of vessel head over studs as called for in Paragraph 7.2.3.4.
- 7.2.3.6 The surface of all threads in the studs, nuts and bushings shall be given a phosphate coating to act as a rust inhibitor and to assist in retaining lubricant on the surfaces. An approved lubricant should be applied to the stud threads as soon as possible after coating.

GENERAL 🌑 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 13 CONT ON SHEET 12

ISSUED:

MAR - 5 1969

- 7.2.3.7 A stud sling for the main closure studs shall be provided. The stud sling shall include a swivel and counter-weight spring to support the weight of the stud during turning of stud into vessel flange. Studs are to be provided with a wrenching surface accessible when suspended on sling.
- 7.2.3.8 All main load-carrying, threads and spherical washers shall be assembled only after cleaning, gaging, and lubricating. In no case during fabrication or testing shall these parts be assembled without lubricant. Only thread lubricant approved by the Buyer shall be used.
- 7.2.4 Flanges
- 7.2.4.1 The top head flange surface shall be machined or the area around each stud hole spot faced. Spot facings shall be complete and extend beyond washer 0.D. to accommodate maximum eccentricity of stud in head flange bolt hole. The top head-flange surface, with or without spot facings, must accommodate and provide proper bearing area for the stud tensioner feet.
- 7.3 <u>Nozzle Ends</u>
- 7.3.1 The ends of all nozzles other than flanged nozzles shall be prepared for welding in accordance with Drawing 107C5305. Nozzle safe ends are considered to be part of the vessel, not part of the connecting piping but in no case shall the safe end wall thickness be less than the wall thickness of the connecting pipe.
- 7.3.2 Where thermal sleeve nozzles are specified to a nominal size, the size of the pipe through the nozzle as well as the nozzle external end shall be the nominal size specified for the nozzle. Thermal sleeves shall be supplied by the Seller.
- 7.3.3 The Buyer will furnish information on the wall thickness, t_p, of all piping connections and will set the inner bore diameter including tolerances and allowances of the connecting piping will follow ASA Standards. The Buyer will use the formulas and allowable stresses of B31.1 for establishing the required piping wall thicknesses. Nozzle safe end wall thickness shall be governed by Drawing 107C5305 and will in general be greater than required by Section III.

GENERAL 🌚 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 14 CONT ON SHEET 15

- 7.3.4 Details of the transition weld preparation shall be submitted to the Buyer for approval.
- 7.3.5 Nozzles of 3" nominal size or larger shall be full penetration welded to the vessel. Nozzles less than 3" nominal size may be partial penetration welded if permitted by ASME Code, Section III.
- 7.4 The vessel top head nozzles shall be provided with 1500 pound weld neck flanges with small groove facing. Mating 1500 pound flanges with small tongue facing, gaskets and a complete set of studs and nuts shall also be provided. The loose flanges for the 6 inch instrument nozzles shall be blind, the remainder shall be weld neck. The flanges and gaskets shall be in accordance with ASA Standards B16.5. The threads on studs and nuts shall be 8-pitch series in accordance with ASA Standard B1.1.
- 7.5 Reactor Vessel Supports
- 7.5.1 External and internal supports shall be provided as an integral part of the reactor vessel. The location and design of the supports shall be such that stresses in the reactor vessel and supports will be within ASME Code limits due to reactions at these supports. The design pressure differential across the core shroud support shall be 100 psi (higher pressure under the support) occurring at the vessel design temperature. The design of the core shroud support shall also take into account the restraining effect of the components attached to the support and the weight and earthquake loading as shown on Drawing 886D482.
- 7.5.3 The drain nozzle shall extend 12 to 16" below the bottom of the reactor vessel and shall be of the full penetration design.
- 7.6 External Attachments
- 7.6.1 Brackets to support insulation shall be provided on the exterior of the reactor vessel in accordance with Drawing 886D482
- 7.6.2 Provisions shall be made for the attachment of thermocouples in mounts on the reactor vessel exterior as specified on Drawing 886D482.

8.0 <u>MATERIALS</u>

8.1 All materials to be used shall be indicated on the Seller's drawings. The Seller shall submit for the Buyer's approval, all material selections and material purchasing specifications.

GENERAL 🐨 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

8.2 Records

The Seller shall maintain complete records showing use of all materials so that it will be possible to relate every component of the finished reactor vessel to the original certification of the material and the fabrication history of the component. The Seller shall prepare a summary of the heat number, chemical composition and mechanical properties for each reactor vessel component.

8.3 Forgings

Low alloy steel forgings for pressure parts shall be made in accordance with ASTM A508 in accordance with ASME Code Case 1332-3, Paragraph 5. Nozzles which are partial penetration welded as specified in 7.3.5 may be nickel-chromium-iron forgings made in accordance with ASME SB-166 modified in accordance with Code Case 1336. The molten steel shall be vacuum treated prior to, or during, the pouring of the ingot in order to remove objectionable gases, particularly hydrogen.

8.4 Plate

Plate for pressure parts shall be in accordance with ASTM A533, Class I Grade B, Firebox Quality, in accordance with ASME Code Case 1339-2. Plate ingots shall be produced by vacuum degassed pouring.

8.5 <u>Castings</u>

The use of castings will be considered by the Buyer but specific Buyer approval shall be required. Castings for pressure parts shall be made in accordance with ASME SA-356, Grade 10, Code Case 1333, Paragraph 1.

8.6 Material for pressure parts shall be selected and worked to produce as fine a grain size as practical. It shall be an objective of the fabrication technique to retain a grain size of 5 or finer in all material. Grain size shall be determined by the method in ASME E112.

8.7 <u>Heat Treatment</u>

Heat treatment of carbon and low alloy steel pressure parts shall consist of normalizing and then tempering at not less than 1200°F. For section thickness over 3 inches nominal, heat treatment shall consist of accelerated cooling from the austenitizing temperature to below the martensite finish temperature followed by tempering at not less than 1200°F to obtain tensile and impact properties comparable to those developed by normalizing and tempering section thickness of less than 3 in. nominal.

8.8 <u>Mechanical Properties</u>

The low alloy steel forgings, plate and castings for pressure parts shall be tested in accordance with Paragraph 10.3 and shall have the mechanical properties required therein in addition to those required by the applicable ASME Specification.

1-18

GENERAL 🛞 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SM NO. 16 CONT ON SMEET 17

8.9 Studs, Nuts, Bushings, and Washers for Main Vessel Closure

- 8.9.1 Studs shall conform to ASTM A540, Grades B23 or B24 and ASME Code Case 1335-2, Paragraph 4, Class 3, 4 or 5.
- 8.9.2 Nuts, bushings and washers shall conform to ASTM A540, Grades B23 or B24, and Code Case 1335-2, Paragraph 4, Class 3, 4, or 5 but to suit the stud material used. It shall be the objective to have a minimum difference in hardness of 5 Rockwell C points from the stud material.
- 8.9.3 Hardness and impact properties shall meet the requirements of paragraph 10.3.2.5.

8.10 Cladding Material

All internal carbon and low alloy steel surfaces of the reactor vessel including the closure head and closure head flange mating surfaces, shell flange and mating surface, shell, bottom head, nozzles for connecting stainless steel piping, and internal attachments shall be clad with weld overlay meeting the following requirements:

- 8.10.1 Weld overlay cladding shall be a minimum of 0.125 inches total thickness. The finished surface shall have a composition equivalent to ASTM A371, Type ER308 or A240 Type 304 except the carbon content shall not exceed 0.08%.
- 8.10.2 Cladding in the "as-clad" condition is acceptable, provided the resulting surface finish does not interfere with the ultrasonic and liquid penetrant test requirements.
- 8.10.3 The sealing surfaces of the reactor vessel head and shell flanges shall be weld overlay clad with austenitic stainless steel which consists of a minimum of two layers and a minimum of 0.25 inch total thickness. The first layer shall be deposited with an analysis equivalent to ASTM A371, Type ER309. The second and sub-sequent layers shall have a composition equivalent to ASTM A371, Type ER308, except the carbon content shall not exceed 0.08%. Minimum thickness of 1/4 inch shall apply after all machining, including area under groove.

8.11 Attachments

8.11.1 Internal attachments other than the weld clad ferritic attachments shall be annealed stainless steel, Type 304 per ASTM A240 or ASTM A276, or Type F304 per ASTM A182. The core support structure shall be stainless steel clad low alloy or carbon steel, solid nickelchromium-iron alloy per ASME SB166, 167, or 168, or annealed stainless steel, Type 304 per ASTM A240 or ASTM A276, or Type F304 per ASTM A182.

GENERAL 🕦 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 17 CONT ON SHEET 18

8.11.2 External attachments to the reactor vessel shall be of the same material as the reactor vessel base material, or shall be of a material which has mechanical and impact properties compatible with the base material. Where welds must be made to the attachments in the field, the material selected shall not require pre-heat or post-weld heat treatment.

8.12 Nozzle Safe Ends and Flanges

- 8.12.1 Nozzle ends for austenitic pipe shall be ASTM A336, Class F8 or F8m; A240, Type 304, or Type 316; or A376, Type 304 or Type 316 solution heat treated stainless steel, depending upon the mating pipe material selected by the Buyer. Nozzle ends for carbon steel pipe shall be ASTM A105, Grade II, forgings except phosphorous content shall be 0.035% Max. and sulphur 0.040% Max; ASTM A508 Class I; or ASTM A516 Grade 70. Proportions shall be as shown on Drawing 107C5305.
- 8.12.2 Standard flanges for flanged nozzles and separate mating flanges shall be ASTM A182, Grade F304, stainless steel.
- 8.12.3 Studs for standard flanges shall be SA193, Grade B7. Nuts for standard flanges shall be SA194, Grade 2H.
- 8.13 Pipes and tubes shall be ASTM A213, A249, A312, A376, solution heat treated, Grade TP304 or TP316; or A240, Type 304 plate welded and radiographed in accordance with ASME Code, Section III, Paragraph N624.
- 8.14 Miscellaneous bolting material shall be subject to the Buyer's approval.

8.15 Weld Electrodes and Rods

- 8.15.1 Material for weld electrodes and rods shall be selected from ASTM A233, A298, A316, A371 or equivalent for other processes and reported to the Buyer for approval.
- 8.15.2 All austenitic stainless steel welds and weld cladding shall contain controlled amounts of ferrite, confirmed by quantitative tests. The procedures for control of, and testing for the ferrite content of welds and weld cladding shall be submitted to the Buyer for approval. The acceptance standard for quantitative tests shall be either % Cr = 1.9 x % Ni, or 5% ferrite minimum.

ISSUED:		
MAR	-5	1969
1.1700	v	1000

GENERAL 🌆 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 18 CONT ON SHEET 19

mar – 5 1969

8.16 Alternate Materials

The Seller shall be free to suggest alternate materials during preparation of detailed drawings and shall bring such alternates to the attention of the Buyer, but shall not make substitutions without approval of the Buyer. Request shall include:

- 8.16.1 Reason for substitution.
- 8.16.2 Identification of the component or parts involved.
- 8.16.3 Either the complete material specification similar to ASTM for each type and form of proposed material, or the information as follows:
 - a) Type of Service (Structural, High/Low Pressure, Temperature, Weldable)
 - b) Manufactured Form (Pipe, Plate, Tube, Bar, Bolting)
 - c) Size, Thickness Limits
 - Alloy Grades (C-Steel, Alloy Steel, Stainless Steel Designations)
 - e) Steel-Making Process (Open Hearth, Basic Electric)
 - f) Forming Process (Hot Forged, Hot/Cold Rolled, Drawn, Seamless Welded, Cast)
 - g) Heat Treatment, Stress Relief Parameters
 - h) Type, Location and Number of Mechanical Tests (Tensile, Bend Homogeniety, Hydrostatic)
 - 1) Mechanical Property Acceptance Limits
 - i) Chemical Composition Acceptance Limits
 - k) Inspection Requirements such as: Radiography, Liquid Penetrant, Magnetic particle, Ultrasonic Including Acceptance Limits.
 - 1) Surface Finish Acceptance Limits
- 8.16.4 Allowable Stresses (If not an ASME Material)
- 8.16.5 For major pressure parts, additional information will be required regarding details of previous applications of the material, impact strength, NDT temperature, micro-structure variations, creep, stress rupture, hardness, radiation damage, welding, forming, corrosion and temperature effects as applicable for engineering evaluation of the application and as required for code purposes.

GENERAL 🛞 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 19 CONT ON SMEET 20

9.0 FABRICATION

- 9.1 Procedures
- 9.1.1 The Seller shall submit for the Buyer's approval, all of the following procedures and procedure specifications:
- 9.1.1.1 Heat treatment procedures for all thermal processes exceeding 800°F after the mill rolling or forging or foundry casting operation.
- 9.1.1.2 Forming and bending procedures for all forming during fabrication subsequent to mill forging or rolling or foundry forming and cladding.
- 9.1.1.3 Welding and weld repair procedures including temporary welds as required in accordance with the ASME Code, Section IX, Paragraphs Q-10 and 11, and QN-10 and 11, Section III, Paragraph N-540.
- 9.1.1.4 Method of qualifying welding procedures and performance, if other than ASME Code, Section IX and III.
- 9.1.1.5 Repair procedures for major and minor defects as defined in Paragraph 9.4.
- 9.1.1.6 Drawings showing location and preparation of test specimens, including specimens required in Attachment B.
- 9.1.1.7 Fabrication schedule including the detailed sequence to be followed in fabrication of the vessel.
- 9.1.1.8 All cleaning procedures, preserving procedures and a list of cleaning agents and preservatives together with their chemical content which shall be used during fabrication and in preparation for shipment. In lieu of a complete chemical analysis, the Buyer shall accept a report which states the chlorides, fluorides and sulfur content. Other harmful elements should also be reported.
- 9.1.2 All work by the Seller or his sub-suppliers shall be performed in accordance with Buyer approved drawing, and fabrication and test procedures.

9.2 <u>Material Cutting</u>

9.2.1 Stainless steel and carbon steel shall be cut to size or shaped by machining, shearing or thermal cutting.

أعتنص



ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 20 CONT ON SHEET 21

9.2.2 Thermal cutting of stainless steel shall be followed by the removal of approximately 1/32" depth from the cut surface. Thermal cutting of carbon steel shall be followed by the removal of oxides.

9.3 Welding

- 9.3.1 The reactor vessel base material pre-heat and interpass temperature shall be as specified in the welding procedures, but in no case less than 300°F, except weld overlay pre-heat which shall be no less than 200°F. Pre-heat temperature shall be maintained after welding until start of post-weld heat treatment. Pre-heating techniques shall be such as to ensure that the full thickness of the weld joint preparation and adjacent base material is at the specified temperature for the distance of "T" or two inches, whichever is greater, where "T" is the material thickness.
- 9.3.2 When stainless steel or nickel-chromium-iron alloy is welded to itself or to each other, no pre-heat is required, except when the heat-affected zone reaches ferritic base material as in the cases of welding to buttered nozzle ends or cladding. When the buttering or cladding is less than 1/4 inch thick, pre-heat to at least 200°F is required, followed by post-weld heat treatment except that subsequent welding to cladding greater than 1/8 inch thick may be done without preheat if the specific welding procedure is qualified to show that the heat affected zone does not reach the base metal.
- 9.3.3 All surfaces (to be welded) shall be free of cavities or protrusions which may interfere with the welding procedure.
- 9.3.4 Pre-heat, welding and post-weld treatment shall be planned and conducted to minimize undue distortion or warping of the parts and preclude cracking.
- 9.3.5 Machined surfaces and threads shall be protected against weld splatter.
- 9.3.6 Stainless steel welds shall be cleaned with stainless steel wool or stainless steel brushes before adding the next bead and following the final bead to facilitate inspection. The light oxide discoloration which forms on the weld surface need not be removed.
- 9.3.7 Welds shall be cleaned of slag and flux between passes and following the final deposit.

GENERAL 🌚 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

SPEC. NO.	21A1112	2	RE	٧.	NO.	6
SH NO.	21	CONT	ON	SH	EET	22

- 9.3.8 Any cracks, blow holes, or other defects which appear on the surface of weld beads shall be removed by machining, chipping, grinding, or arc gouging. Austenitic weld repairs, if arc gouged shall be followed by grinding. Austenitic welds shall not be peened; ferritic welds may be peened under controlled conditions after approval by the Buyer.
- 9.3.9 Wide welds to overcome poor fit are not permissible. Poor fits shall be remedied by suitable means such as regrooving, and approved by the Buyer. Except for small cavities, the Seller shall not correct a plate edge deficiency unless approved by the Buyer. The Buyer may require radiography or other methods of examination of welds used to correct plate edge deficiencies.
- 9.3.10 Post-weld heat treatment temperature shall be 1150°F +25°F -50°F. Interstage post-weld heat treatment holding time shall be 15 minutes minimum. Final post-weld heat treatment holding time shall be one hour per inch of thickness, minimum.

9.4 Repair of Defects

Repair procedures shall be prepared for the repair of all defects. Major defects shall require prior approval by the Buyer and may require witnessing by the Buyer's representative. Major repair is defined as (1) a repair to material other than weld metal which requires an excavation greater than 3/8 inch deep or 10 percent of the wall thickness, whichever is less; (2) the repair of any cracks, other than crater cracks, in any material or weld metal; and (3) the repair of any defect which is indicative of either a fundamental material problem or a process out of control. A minor repair is defined as all other repairs.

9.5 <u>Cleaning</u>

9.5.1 Interior Surfaces

After the Seller has completed all other work, the interior surfaces of the reactor vessel shall be thoroughly cleaned to be visibly free of lubricants, weld splatter, chips, embedded iron particles and other foreign materials. A preferred method for cleaning and rinsing is use of high pressure water blasting equipment for these operations given in Paragraph 10.8. To maintain cleanliness of the interior of the vessel and head during drying and sealing, the personnel required to enter the vessel or head should wear clean cloth shoe covers and clean clothes. The vessel shall be sealed to prevent entry of dirt or foreign materials. Seals used on nozzle ends and flange faces shall not alter weld preparations or sealing surfaces.

9.5.2 <u>Exterior Surfaces</u>

Exterior carbon steel surfaces shall be cleaned of oil and grease after which mill scale, rust scale, and other foreign matter shall be thoroughly removed by such means as sandblasting as specified by the Buyer. All surfaces shall be brushed or air cleaned to remove all traces of sand or grit.

1-24

GENERAL 🌑 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 22 CONT ON SHEET 23

10.0 INSPECTION AND TEST

10.1 General

The Seller shall submit for the Buyer's approval, the following inspection and test procedures:

10.1.1 Ultrasonic Examination Procedure for the following:

- 10.1.1.1 1. Forgings
 - 2. Plate
 - 3. Welds
 - 4. Weld build-ups
 - 5. Cladding
 - 6. Tubular Products

10.1.2 Magnetic Particle Examination Procedures for the Following:

10.1.2.1 Carbon steel 6 low alloy steel forgings

10.1.2.2 Carbon steel & low alloy steel welds

10.1.2.3 Weld build-ups

10.1.2.4 Bolting

10.1.2.5 Carbon steel and low alloy steel tubular products

10.1.2.6 Carbon steel and low alloy steel castings

10.1.2.7 Edge preparations of carbon steel and low alloy steel materials.

10.1.3 Liquid Penetrant Examination Procedures for the Following:

10.1.3.1 Austenitic Forgings

10.1.3.2 Austenitic welds

10.1.3.3 Austenitic weld buildup

10.1.3.4 Cladding

10.1.3.5 Austenitic tubular products

10.1.3.6 Austenitic castings

10.1.3.7 Edge preparations of austenitic materials

10.1.4 Radiographic examination procedures for welds, castings, for each type of radiographic source above and below 2 Mev.

10.1.5 Hydrostatic Examination Procedures

10.1.6 Leak Check Procedures

GENERAL 🌍 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 23. CONT ON SHEET 24

10.1.7 Methods, processes and equipment to be used in establishing "as-built" dimensions and alignment check, which are not generally used in a typical industrial shop.

10.2 Definitions

10.2.1 "As-Fabricated" Specimens

"As-fabricated" specimens are mechanical test specimens taken from carbon and low alloy steel forgings and plates used in the vessel fabrication from each heat and heat treatment lot and from welds between base material made by each welding procedure used and in a thickness equal to or greater than the thickest weld made with each procedure. Coupons for "as-fabricated" specimens shall be taken from the forgings or plates following all hot working or forming and all heat treatment except post-weld heat treatment. These coupons shall then be subjected to a post-weld heat treatment equivalent to the treatments which the parts it represents will receive in the completed vessel. This shall consist of holding the coupon at the post-weld heat treatment temperature for a time equal to or greater than the longest accumulated time any part it represents shall be at the post-weld heat treatment temperature.

10.2.2 "1/4T x T" Location

The " $1/4T \ge T$ " location of specimens is defined as a location within the material no closer than "1/4T" from one quenched surface, and no closer than "T" from any other quenched edge, where "T" is the nominal thickness of the material.

10.2.3 NIL-Ductility Transition (NDT) Temperature

The nil-ductility transition (NDT) temperature is defined as the temperature at which a specimen is broken in a series of tests in which duplicate no-break performance occurs at a temperature 10°F higher, when tested in accordance with ASTM E208.

10.2.4 Impact-Transition Curve

A curve representing breaking energy vs. temperature from at least twelve Type A Charpy-V specimens, tested in accordance with ASTM A370, except each specimen tested at a different temperature. The temperature range of testing shall establish the upper plateau, the transition region, and the lower plateau. Each plateau shall be determined by at least one, but not more than two points. The remain ng specimens shall be used to develop the transition region. The lower plateau need not be developed if it occurs below -80°F.

10.2.5 A "lot of material" consists of all material from one heat (one melt) in a heat treatment furnace.

GENERAL DELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 24 'ONT ON SHEET 25

10.3 <u>Material Mechanical Tests</u>

10.3.1 <u>Mechanical Properties</u>

- 10.3.1.1 Impact properties of all carbon and low alloy steel used in the main closure flanges and the shell and head materials connecting to these flanges shall meet the requirements of the ASME Code, Section III, Paragraph N-330 at a temperature no higher than 10°F. In addition, this material shall have an NDT temperature no higher than 10°F as determined per ASTM E208.
- 10.3.1.2 Impact properties of all other "as-fabricated" carbon and low alloy steel pressure containing material and the vessel support skirt material shall meet the requirements of the ASME Code, Section III, N-330 at a temperature no higher than 40°F. In addition, this material shall have an NDT temperature no higher than 40°F as determined per ASTM E208. The actual NDT temperature of all material opposite the center of the active fuel of the core as indicated on Drawing 886D482 shall be determined.
- 10.3.1.3 Tensile test properties of all materials shall be inspected and tested to meet the requirement of the applicable ASME Code or ASTM specification.
- 10.3.1.4 Test data shall be reported to the Buyer.
- 10.3.2 Required Number and Specimen Location

The number and location of tensile and impact test specimens required shall be per ASME Code, Section III, N-313.2 and the following depending on the form of the material. The following tests may be integrated with the tests required by the ASME Code and ASTM Specification wherever possible.

10.3.2.1 Vessel Flange and Head Flange Forgings

Tangential specimens, as-fabricated, shall be taken from locations per ASME Code, Section III, N-313.2 (d) (2). A total of at least 2 tensile, 6 Charpy-V impact and 4 drop weight specimens shall be tested for each flange from which 1 tensile, 3 Charpy-V impact and 4 drop weight specimens shall be located approximately 180° from the other specimens. The materia³ shall meet the requirements of Paragraph 10.3.1.

GENERAL 🐨 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SM NO. 25 CONT ON SHEET 26

10.3.2.2 Low-Alloy Steel Nozzle Forgings

Specimens, as fabricated, shall be taken from locations per ASME Code, Section III, N-313.2 (d) for forged nozzles. At least 2 tensile, 3 Charpy-V and 2 drop weight specimens shall be tested for each heat and heat treatment charge, except that nozzles with wall thickness of less than 4 inches and outside diameter less than 12 inches shall not require drop weight testing. The material shall meet the requirements of Paragraph 10.3.1.

10.3.2.3 In addition to the tests required by the ASME Boiler and Pressure Vessel Code, longitudinal specimens (parallel to the primary rolling direction), as-fabricated, shall be taken from the 1/4T x T location. At least 2 drop weight specimens shall be tested from the top end (top as determined by ingot pouring) or each mill rolled plate and each heat treatment charge. The material shall meet the requirements of Paragraph 10.3.1. Additional drop weight specimens shall be required for NDT temperature determination per Paragraph 10.3.1.2 for plates located opposite the center of the core.

10.3.2.4 Castings

Tangential specimens, as-fabricated, shall be taken from locations per ASME Code, Section III, N-313.2 (d). Castings 1000 lb. weight and under shall have a total of 1 tensile specimen, 1 metallographic specimen, and 3 Charpy-V and 2 drop weight specimens, tested for each heat and heat treatment charge. Castings over 1000 lb. weight shall have a total of 2 tensile specimens, 2 metallographic specimens, 6 Charpy-V and 4 drop weight specimens tested from which 1 tensile specimen, 1 metallographic specimen, 3 Charpy-V and 2 drop weight specimens shall be taken 180° apart and/or diagonally opposite. The metallographic specimens shall be for reference only. Additional drop weight specimens shall be required for NDT temperature determination in accordance with paragraph 10.3.1.2 if the casting is located in the core area. The material shall meet the requirements of paragraph 10.3.1.

GENERAL 🌆 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 26 CONT ON SHEET 27

10.3.2.5 Studs, Nuts, Bushings and Washers for Main Vessel Closure

Hardness tests shall be made on all main vessel closure bolting to demonstrate that heat treatment has been performed. Studs, nuts and bushings shall be hardness tested individually. One sample from each lot of washers shall be hardness tested. Impact tests required by ASME Code, Section III, paragraph N-330 shall meet the Code requirements at a temperature no higher than 10°F. In addition to the magnetic particle or liquid penetrant acceptance standards specified in ASME Code, Section III, paragraph N-325, axial defects of less than thread depth shall be investigated to determine their nature. Any cracks or sharply defined linear indications are unacceptable.

10.4 Welded Base Material - Mechanical Tests

10.4.1 ASME Code Weld Test Plates

The Seller shall prepare and test weld coupons of Category A and B joints in accordance with ASME Code, Section III, N-713. The impact test temperatures shall be determined in accordance with paragraph 10.3.1 of this specification. In addition to the tests required by the Code, 6 drop weight specimens shall be taken from the 1/4T x T location from these plates and, if different welding procedures are used, from plates for base material to base material welds of Category D joints as defined in ASME Code, Section III, N-461. Two each of the drop weight specimens shall represent the the base metal, heat affected zone and weld metal. The specimens shall meet the requirements of paragraph 10.3.1.2. Additional drop weight specimens shall be required in accordance with paragraph 10.3.1.2 if the welding procedure is to be applied in the area opposite the core.

- 10.4.2 One of the test plates of Category A or B required in 10.4.1 above shall be selected by the Buyer for the fabrication tests required in Attachment B, Paragraph 2. The Seller shall perform all required tests and reports. These tests are for information only, but time is of the essence and the tests should be performed and results reported as early as practical.
- 10.4.3 The Seller shall prepare and ship, but not test, Surveillance Test Program material and specimens in accordance with Attachment B, Paragraph 3.
- 10.4.4 Flange Forging Weld Test Plate

In the event the vessel and head flanges are made by welding two or more forged segments, the Seller shall prepare a weld test plate from the forging material. Impact and tensile specimens

GENERAL 🌚 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO.	21A11	12	REV. NO.	6
5H NO.	27	CONT	ON SHEET	28

shall be prepared and tested. The specimens shall be prepared from material in the weld-heat-affected zone and from the weld metal. Test results shall meet the requirements of paragraph 10.3.1.

10.5 <u>Ultrasonic Inspection</u>

- 10.5.1 Ultrasonic inspection of plate and forged material shall be performed in accordance with ASME Code, Section III, except that ASME Case Interpretation 1338-2, Alternate 2 shall not be acceptable, and the plate material testing shall be a 100 percent volumetric inspection and shall be performed after forming and heat treatment. The following acceptance criteria shall apply in addition to Code requirements. A defect which causes any echo indication that exceeds 50 per cent of the indication from the calibration standard and that is continuous during movement of the transducer more than 3 inches in any direction shall be unacceptable. A chart shall be maintained of defects with 50 per cent or greater loss of back reflection.
- 10.5.2 Prior to connecting any attachment, support or bracket, except insulation and thermocouple brackets, to the interior or exterior of plate portions of the vessel by means other than groove welds below the plate, the plate shall be ultrasonically inspected. The plate shall be inspected to a depth at least equal to the thickness of the part being joined, and over the entire area of the subsequent connection plus a band all around this area of width equal to half the thickness of the part being joined. The inspection shall be in accordance with ASME Code, Section III, Paragraph N-321, using longitudinal wave technique. The surface shall be 100 per cent inspected with the transverse interval being no greater than 90 per cent of the crystal diameter.

10.5.2.1 Reference Standard

The Seller shall prepare a reference standard which consists of a flat bottom hole having a diameter equal to one-quarter of the thickness of the part being joined or 1/4 inch diameter whichever is greater. The bottom of the hole shall be one thickness of the part being joined below the plate surface. This reference standard shall be used for calibration purposes.

10.5.2.2 Acceptance Standards

Any defect which produces a trace line pattern equal to or in excess of the appropriate reference standard shall be unacceptable.

GENERAL 🐲 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

FURCHASE SPECIFICATION

1		214111	12		6
1	SPEC. NO.		L 40	REV. NO.	-
	SH NO.	28	CONT	ON SHEET	29

ISSUED

MAR - 5 1969

10.5.3 The main closure stud, nut, bushing and washer material shall be ultrasonically tested following heat treatment and rough machining to 125 rms or better finish using both longitudinal and shear wave techniques. Longitudinal wave examination shall be performed on 100% of the cylindrical surface, and in addition on stud material from both ends of each stud. The longitudinal wave transducer shall have a maximum diameter of 1/2 inch. Shear wave examination shall be performed on 100% of the outer cylindrical surface in both axial and circumferential directions.

10.5.3.1 Reference Standards

The Seller shall prepare a reference standard of the same material, thickness and curvature as the part being examined. The reference standard shall contain calibration features as follows:

- 1) Longitudinal Wave-Radial Scan: 1/2 inch diameter flat-bottom hole having a depth equal to 10% of the material thickness.
- Longitudinal Wave-End Scan: Flat-bottom hole with area equal to 1% of stud cross-section or 1/4 inch diameter, whichever is smaller, having a depth of 1/2 inch.
- 3) Shear Wave: Square bottomed notches 1 inch long and 3% of the part thickness in depth, both axial and circumferential.

10.5.3.2 Acceptance Standards

Any defect which produces a trace line pattern (echo indication) greater than the indication from the applicable calibration feature shall be unacceptable. A distance-amplitude curve may be used for the longitudinal wave examination. The curve may be a line established by plugging the hole and examining it from both sides of the material. For end examination of studs the curve may be established for half the stud length and applied to an examination from each end to the center.



GENERAL DE ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 29 CONT ON SHEET 30

10.6 <u>Claddin</u>

10.6.1 Ultrasonic Inspection - Cladding General

10.6.1.1 The cladding bond shall be tested with the transducer on the clad side using a suitable couplant. The entire clad surface shall be inspected at intervals 1.4 times the base material thickness, but not greater than 12 inches, transverse to the direction of welding.

10.6.1.2 Reference Standard

The Seller shall prepare a reference standard which consists of a flat bottom groove in typical clad plate. The groove shall be 0.35 inch maximum width by at least one crystal diameter long, parallel to the direction of welding. The groove shall be formed by machining the base metal within 1/32" of the cladding interface and etched with nitric acid to remove excess ferritic material from the interface. This reference standard shall be used for calibration purposes.

10.6.1.3 Acceptance Standards

Cladding which produces a trace line pattern equal to or in excess of the appropriate Reference Standard shall be unacceptable if a continuous pattern occurs during movement of the transducer more than three inches in any direction or if one or more patterns occur during movement of the transducer less than one inch in any direction from the boundary of any one pattern.

- 10.6.2 Liquid Penetrant Inspection Cladding General
- 10.6.2.1 All clad areas and clad repairs shall be liquid penetrant inspected per ASME Code, Section III, N-627. The following indications shall constitute unacceptable defects and shall be repaired.
- 10.6.2.2 Any crack-like indications or incomplete fusion.
- 10.6.2.3 Linearly-disposed spot indications of 4 or more spots spaced 1/4 inch or less from edge to edge of the indication.
- 10.6.2.4 Spot indications which are indicative of defects greater than 1/32 inch deep as revealed by bleed-out.

GENERAL 🌚 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 30 CONT ON SHEET 31

10.6.3 Ultrasonic Inspection - Cladding Special Areas

- 10.6.3.1 The flange seal surfaces shall be inspected for bond to the flanges as per 10.6.1 except that the inspection shall be over 100 per cent of the area. Prior to final machining the volume 1/8 inch above and below the surfaces on which the double seals will seat shall be 100 percent inspected for defect using longitudinal wave technique. The acceptance criteria shall be that any defect which produces a trace line pattern equal to or in excess of a 1/16 inch flat bottom hole may be unacceptable.
- 10.6.3.2 The final machined surfaces on which the double seals seat shall be inspected by surface wave technique. Any defect producing a signal greater than the signal produced by the 0.002 inch deep by 1/8 inch long spark machined groove in a reference standard which the Seller shall furnish may be cause for rejection.

10.6.4 Liquid Penetrant Inspection - Cladding Special Areas

- 10.6.4.1 The area of the flange seal surfaces on which the double seals seat shall be liquid penetrant inspected per ASME Code, Section III, N-627, except that any indication of any type shall be unacceptable.
- 10.6.5 Magnetic Particle Inspection Plate Material
- 10.6.5.1 Both internal and external surfaces of all low alloy steel plate material shall be magnetic particle inspected per ASME Code, Section III, Paragraph N-626 following forming and heat treatment. The acceptance standard of ASME Code, Section III, Paragraph N-625.5 shall apply.
- 10.6.6 Openings in Pressure Parts
- 10.6.6.1 The entire surface of all openings for partial penetration nozzles, regardless of size, except for the seal leak detection connection, shall be examined in accordance with ASME Code, Section III, N-513.
- 10.6.6.2 The entire surface of the finished stud holes in the head flange and the holes in the vessel flange prior to tapping shall be examined by the methods of ASME Code, Section III, N-513. Any indication of cracks or linear indications shall be reported to the Buyer for information. Any crack or linear indication may be subject to removal and repair if required.
- 10.7 Welds
- 10.7.1 Radiographs
- 10.7.1.1 Gamma rays shall not be used unless approved by the Buyer.
- 10.7.1.2 Films shall be suitably marked to identify the weld. Film identification markings shall coincide with the detail drawing markings for each weld.

GENERAL 🌚 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SM NO. 31 CONT ON SHEET 32

10.8 Hydrostatic Tests

10.8.1 Code Test

Immediately prior to hydrostatic testing, all interior surfaces of the vessel and head that will contact water during hydrostatic testing shall be thoroughly cleaned. Cleaning and degreasing shall be by the use of high pressure (greater than 5000 psi) deionized water containing 500 ppm by weight of TSP for water blasting all internal surfaces. These surfaces shall be subsequently water blasted with deionized water (no additives). The vessel shall be filled with deionized water for hydrostatic testing. The method of heating the vessel is subject to approval by the Seller.

Definitions:

Deionized water Conductivity 2 micro-mho/cm Solids 10 ppm max Chlorides 1 ppm max Fluorides 1 ppm max Sulfides 1 ppm max TSP - Reagent grade per American Chemical Society Specification for tri-sodiumphosphate

CAUTION: Special care shall be taken to thoroughly water blast rinse with deionized water crevice areas such as between the bottom head and stub tubes and behind welded-in thermal sleeves directly following cleaning with TSP solutions until effluent conductivity is less than 5 micro-mho/cm.

> After completion of fabrication but prior to shipment, while the vessel is supported on its normal supports, the reactor vessel shall be pressuretested in accordance with the ASME Boiler and Pressure Vessel Code, Section III, Paragraph N-714. Reactor vessel material temperature shall be at least 100°F. In no case, however, shall the water temperature be higher than 200°F. Suitable gasket material instead of metal "0" rings may be used for this test.

10.8.2 Second Hydrostatic Test

Following the Code test, the vessel shall be hydrostatically tested at design pressure with new metal "0" rings. This test shall demonstrate that the head seal meets the sealing requirements. Relative displacement and rotation of the head closure flanges during this test shall be measured in at least four places and reported to the Buyer. The measurements shall be made prior to stud tightening and at 250 psi intervals from zero psi to the design pressure.

- 10.9 The placing of the head, tightening the studes to operating bolt-up loads, unbolting and removal of the head over the stude shall be demonstrated. The elapsed times for each step shall be recorded.
- 10.10 Final inspection after hydrostatic test per ASME Code, Section III, N-618 shall include seal surfaces and the nozzle weld preparation.

ISSUED:		
MAR	 1969	

1-33

GENERAL 🌆 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

spec. NO. 21А1112 REV. NO: 6 зн NO. 32 сонт он sheet 33

ISSUED:

MAR - 5 1969

11.0 SHIPMENT

11.1 Small Parts

Small, loose pieces, including bolting, tools, gaskets, etc., shall be adequately crated or boxed for protection during shipment. Parts subject to rusting shall be suitably protected. All pieces shall be marked with the equipment piece number or mark specified by the Buyer.

11.2 Shipping Weights and Dimensions

Estimated shipping weights and overall clearance dimensions of all major pieces to be shipped to the erection site shall be shown on the drawings when submitted to the Buyer for approval.

11.3 Shipping Skids

Shipping skids for components shall be designed to support the components adequately and securely during shipment to the erection site and to account for the means of movement lifting, and positioning to be provided by the Seller at the erection site.

12.0 SUBMITTALS

12.1 Tabulation (For Information Only)

Fabrication, qualification and inspection procedures, reports processes, and calculations are tabulated below (all of which require submittal to the Buyer in quantities as shown on Attachment A). This tabulation shall in no way be construed as being complete or limiting the documents necessary to meet the requirements of this specification.

Heat treatment procedure Forming and bending procedure Welding and weld repair procedure specification Repair procedures Cleaning and preserving procedures Ferrite content or Ni/Cr ratio control procedure Ultrasonic examination procedure Magnetic particle examination procedure Liquid penetrant examination procedure Radiographic examination procedure Hydrostatic examination procedure Leak Check Procedure Measurement reports "As-built" dimensions and alignment checks procedures.

GENERAL 🍘 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 6 SH NO. 33 NT ON SHEET J4

12.1 (Continued)

Design analysis calculations Material purchase specifications Material selections Thread Lubricant Specifications The following shall be submitted in accordance with Attachment A:

12.2.1 Drawings

12.2

- 12.2.1.1 Outline Drawings A drawing depicting the outline of the reactor vessel indicating over-all dimensions, location and size of nozzles, location of supports, shipping and operating weights.
- 12.2.1.2 Assembly Drawings A section drawing depicting the arrangement of the functional parts, parts list and material designation.
- 12.2.1.3 Detail Drawings Drawings for details of construction such as weld preparations, surface finishes, finished dimensions, nozzles lifting attachments, insulation attachments, thermocouple pads, flanges and supports.
- 12.2.1.4 Drawings for Approval Outline, assembly and detail drawings shall be submitted for approval. The detail drawings submitted shall be for design details enumerated in 12.2.1.3 which are required for coordination with piping and structure and design details which are at variance with the code or the requirements of this specification.

12.2.1.5 Controlling Location Arrangement Drawings

One or more drawings shall be devoted exclusively to outline dimensions such that mating components designed and supplied by others such as piping, anchor bolts, instruments, etc.. may be procured for an exact fit with the reactor vessel assembly. These drawings shall show reference to the controlling detail drawings and show over-all dimensions and locations on reactor vessel.

12.2.1.6 Drawings to be Certified - Outline, Assembly and Detail drawings for design coordination shall, upon completion of the design, be certified to be correct with no further changes required. No alterations may be made to the design after certification without the approval of the Buyer.

GENERAL 🍪 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO 21A1112 REV. NO 6 SH NO. 35 CONT ON SHEET F

- 12.2.2.5 Instructions and parts list shall be clearly legible and prepared on good quality paper; carbon copies and tissue copies or other flimsy material are not acceptable. Multiple page instructions shall be securely bound.
- 12.2.2.6 If a standard manual is furnished covering more than the specific equipment purchased, the applicable model (or other identification) parts and other information for the specific equipment purchased shall be clearly identified.

12.2.3 Photographs

The Seller shall provide the Buyer with sets of progress photographs of the vessel at each significant stage of fabrication. One set shall consist of one negative and three glossy $8'' \ge 10''$ prints.

- 12.2.4 Engineering Schedule
- 12.2.5 Fabrication Schedule
- 12.3 Records

The Seller shall maintain records of all material qualifications, all weld and weldor qualifications and all process qualifications required by this specification and the material specifications. In addition, the Seller shall maintain records of all tests and inspections (e.g. - ultrasonic, radiography and hydrostatic). A list of the records shall be submitted to the Buyer on completion of the job. The Buyer shall be able to obtain certified copies of such records for a five-year period. Where the Seller considers the actual test records to be proprietary, he shall submit certified reports containing all pertinent test data excerpted from the actual test reports. These certified test reports shall also be available for a five year period.

·- * ,

ATTACHMENT A 1 INSTRUCTION MANUAL, DRAWING & DATA REQUIREMENTS

Review or approval of drawings, procedures, data, or succifications by the buyer with regard to general design and controlling dimensions does not constitute acceptance of any designs, materials, or equipment which will not fulfill the functional or performance requirements established by this specification and the purchase contract. Documents and drawings submitted shall be black line and of a quality which will produce readable prints when microfilmed (35 mm) and blown back on a conventional 18 x 24 printer viewer such as Filmac 200 or litec. Send all documents and drawings to L.L. Kleinhesselink, GE, APED, (with copy of transmittal to APED Buyer, as indicated on the Purchase Order. All documents and drawings shall be identified with the appropriate Parts List Number(s).

DOCUMENT DESCRIPTION		No. REQUIRED & TYPE OF COPY	DUE	
UTLINE DIMENSIONS	Approval Certified	3_PRINTS + 1_REPRO 	•	
SSEMBLY AND CROSS SECTION RAWINGS WITH PARTS LIST WITH ATERIAL DESIGNATIONS	Approval Certified	3 PRINTS + 1 REPRO 3 REPRODUCIBLE	•	
ETAIL DRAWINGS	Approval Certified	3 PRINTS + 1 REPRO 3 REPRODUCIBLE	•	
ONTROLLING LOCATION-ARRANGEMENT	Approval Certified	3 PRINTS + 1 REPRO 3 REPRODUCIBLE	•	
NGINEERING SCHEDULE TO INCLUDE DATES OR START AND FINISH FOR DESIGN CALCU- ATIONS, DATA, MATERIAL SELECTIONS, PPROVAL DRAWINGS AND DOCUMENTS.	Approval	1REPRODUCIBLE	Within <u>20</u> days after award of order.	
ABRICATION SCHEDULE WHICH DETAILS HE SEQUENCE OF FABRICATION, AND INDI- ATES START AND FINISH OF EACH PHASE.	Approval	REPRODUCIBLE	Wirhin <u>30</u> days after award of order	
	Approval	<u> </u>	As completed but m later than 2 weeks prior to fabrica- tion	
ALL PROCEDURES & MAT'L PURCHASE SPEC. (EXCEPTION-SEE ITEM 12 BELOW)	Approval (Required Be- fore Used)	6 COPIES	30 days prior to anticipated use	
NSTRUCTION MANUALS	Approval	(Later) MANUALS 30	0 days before ship. days before sched- ed shipping date	
CODE CERTIFICATES		6 ORIGINAL COPIES	5 days after shipment	
PHOTOGRAPH	Certified	<u>3</u> PRINTS <u>1</u> NEGATIVE	At 2 month inter- vals	
FABRICATION QUALIFICATION PROCEDURES		<u>6</u> PRINTS	2 weeks prior to qualification test	
ADDITIONAL CALCULATION AND SUMMARY REPORT		<u> 6 </u> COPIES, EA.	Upon completion of final design	
ULTRASONIC, RADIOGRAPHIC & HYDRO- STATIC INSPECTION & TEST REPORTS	Certified	8_COPIES	5 days after test	
ithin <u>30</u> days after receipt of approval drawing	s or within	days of		
ECT:	DATE	AR - 5 1969 s	H 1 CONT ON FINAL	
	UTLIME DIMENSIONS SSEMBLY AND CROSS SECTION RAWINGS WITH PARTS LIST WITH ATERIAL DESIGNATIONS ETAIL DRAWINGS ONTROILING LOCATION-ARRANGEMENT ND DRAWINGS NGINEERING SCHEDULE TO INCLUDE DATES OR STAPT AND FINISH FOR DESIGN CALCU- ATIONS, DATA, MATERIAL SELECTIONS, PPROVAL DRAWINGS AND DOCUMENTS. ABRICATION SCHEDULE WHICH DETAILS HE SEQUENCE OF FABRICATION, AND INDI- ATES START AND FINISH OF EACH PHASE. ESIGN CALCULATIONS SULL PROCEDURES & MAT'L PURCHASE SPEC. (EXCEPTION-SEE ITEM 12 BELOW) NSTRUCTION MANUALS CODE CERTIFICATES PHOTOGRAPH FABRICATION QUALIFICATION PROCEDURES ADDITIONAL CALCULATION AND SUMMARY REPORT ULTRASONIC, RADIOGRAPHIC & HYDRO- STATIC INSPECTION & TEST REPORTS Thin <u>90</u> days after award of purchase contract thin <u>90</u> days after receipt of approval drawing receipt of purchase contract if approve	UTLINE DIMENSIONS Approval Certified SSEMBLY AND CROSS SECTION RAWINGS WITH PARTS LIST WITH ATERIAL DESIGNATIONS Approval Certified ETAIL DRAWINGS Approval Certified ONTROILING LOCATION-ARRANGEMENT ND DRAWINGS SCHEDULE TO INCLUDE DATES ON STAPT AND FINISH FOR DESIGN CALCU- ATIONS, DATA, MATERIAL SELECTIONS, PPROVAL DRAWINGS AND DOCUMENTS. Approval Approval ABRICATION SCHEDULE WHICH DETAILS HE SEQUENCE OF FABRICATION, AND INDI- ATES START AND FINISH OF EACH PHASE. Approval ESIGN CALCULATIONS Approval STRUCTION MANUALS Approval NSTRUCTION MANUALS Approval CODE CERTIFICATES Certified PHOTOGRAPH Certified CODE CERTIFICATES Certified PHOTOGRAPH Certified SUMMARY REPORT Certified STATIC INSPECTION & TEST REPORTS Certified	Type of Copy Type of Copy Type of Copy Constant of copy SEMBLY AND CROSS SECTION ARWINGS WITH PARTS LIST WITH ATERIAL DESIGNATIONS Approval Certified 3 PRINTS + 1 REPRO 3 PRINTS + 1 REPRO Certified Constant of copy of Certified Approval Certified 3 PRINTS + 1 REPRO 3 REPRODUCIBLE Constant of copy of Certified 3 PRINTS + 1 REPRO 3 REPRODUCIBLE ONTROLLING LOCATION-ARRANGEMENT ND DRAWINGS Approval Certified 3 REPRODUCIBLE NOTRENTING SCHEDULE TO INCLUDE DATES NOTRECHAINES MORE DOCUMENTS. Approval Approval APPROVAL DRAWINGS AND FINISH OF DESIGN CALCU- ATIONS, DATA, MATERIAL SELECTIONS, PPROVAL CALCULATION SCHEDULE WHICH DETAILS HE SEQUENCE OF FABRICATION, AND INDI- ATES START AND FINISH OF EACH PHASE. Approval APProval 1 REPRODUCIBLE APPROVE OF FABRICATION, AND INDI- ATES START AND FINISH OF EACH PHASE. Approval Approval LI PROCEDURES & MAT'L PURCHASE PFEC. (EXCEPTION-SEE ITEM 12 BELOW) Approval (Later) MANUALS 1 REPRODUCIBLE STRUCTION MANUALS 10 (Later) MANUALS 10 (Cater) MANUALS 10 (Cater) MANUALS <td co<="" td=""></td>	

.

GENERAL 🍪 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. ND.3 SH NO. 1 CONT ON SHEE 2

ATTACHMENT B - MATERIAL TESTS AND TEST SPECIMENS

1.0 SCOPE

The Seller shall retain selected portions of the material used to fabricate the reactor vessel of this contract. He shall process some of this material into finished mechanical specimens which shall be in metallurgical conditions representative of the following as-fabricated reactor vessel material: Base-Plate, Welds and Heat-Affected Zone. The Seller shall test some of these specimens for "Fabrication Tests" to determine the effect of thickness on the mechanical properties of the material. The remainder of the specimens and the remainder of the selected test material shall be prepared for shipment. These latter specimens will be used for "Surveillance Tests" to monitor the effect of neutron irradiation on the mechanical properties of the reactor vessel steel.

2.0 FABRICATION TEST PROGRAM

2.1 <u>Material</u>

- 2.1.1 The fabrication test material shall be representative of the formed, heat-treated, and fully-fabricated reactor vessel, and shall be removed from one of the heats of plate material used in the reactor vessel construction, but need not necessarily be from a plate which becomes a part of the reactor vessel.
- 2.1.2 The fabrication test material shall be documented as to chemistry, thermal history, degree of hot and/or cold work, and welding.

2.2 Description

- 2.2.1 The Seller shall perform fabrication tests of base metal and welded joint. The results of the fabrication tests shall be reported during the early stages of reactor vessel construction. All of the fabrication test specimens shall be removed from the same plate.
- 2.2.2 The Seller shall make and test .505 inch diameter tensile specimens with the gage length in the tangential direction of the shell plate material. Tensile specimens shall be prepared from the O.D., 1/4T, 1/2T, and 3/4T thickness levels of the plate material. Each thickness level shall, be tested at room temperature, 550°F, and 650°F per most recent ASTM Specifications E8 and E21. Three specimens shall be tested at each temperature for each thickness level. The tensile strength, yield strength, elongation, and reduction of area shall be reported.

GENERAL 🛞 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO 3 SH NO. 2" CONT ON SHEET 3.

ATTACHMENT B (CONT'D)

- 2.2.3 The Seller shall make and test, per most recent ASTM Specification E8, six tensile specimens whose gage diameter is iterated by the sector vessel wall thickness.
- 2.2.3.1 The gage length to gage diameter ratio of the specimens shall be no less than 3 to 1. Tests shall be conducted at room temperature. Stress-strain curves, tensile strength, yield strength, elongation, reduction of area and macrophotographs of the breaks shall be reported for each specimen tested.
- 2.2.3.2 Where the reactor vessel wall courses are made from rolled plate with a longitudinal weld, three specimens shall be made from a base metal test plate with their gage lengths oriented to a vessel wall tangential direction and three specimens shall be made from a test plate simulating a vessel longitudinal weld with their gage lengths across the weld.
- 2.2.3.3 Where the reactor vessel wall courses are made of forged rings, three specimens shall be made from a base metal test plate with their gage lengths oriented to a vessel wall longitudinal direction and three specimens shall be made from a test plate simulating a vessel girth weld with their gage lengths across the weld.
- 2.2.4 The Seller shall make and test Charpy V-Notch impact specimens (ASTM E23, Type A) entirely from base material to establish <u>curves</u> for determining the 30 ft.-lb. transition temperature at the O.D., 1/4T, 1/2T, and 3/4T thickness levels of the plate material. The energy data, fracture appearance data and lateral expansion data for each individual specimen shall be reported. The data from each individual specimen shall be reported. There shall be at least six points reported within the 20 to 40 ft.-lb. range, and at least three testing temperatures represented within the range. In addition to the above the Impact Transition curves shall conform to Paragraph 10.2.4.
- 3.0 SURVEILLANCE TEST PROGRAM
 - 3.1 Base Metal Figure 1
 - 3.1.1 The Seller shall furnish two plates, as shown in Figure 1, from the plate used to make the reactor vessel in the reactor core region, or from a similar plate from the same heat.
 - 3.1.2 The Seller shall heat treat these plates with the reactor vessel, or in similar fashion, to insure that they represent the metallurgical condition of the vessel steel, in the core region of the completed reactor vessel including all post-weld heat treat cycles seen by that region.

1-39

GENERAL 🍘 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 3 SH NO. 3 CONT ON SHEET 4

ATTACHMENT B (CONT'D)

- 3.1.3 The Seller shall furnish documents to the Buyer showing the location of the test plates and detailing all metallurgical data concerning the test plates.
- 3.1.4 The Seller shall make mechanical test specimens, as outlined below, from one of these plates and send the other to the Buyer.
- 3.2 <u>Welded Place Figure 2</u>
- 3.2.1 The Seller shall furnish a welded plate representative of a reactor vessel longitudinal weld, in the case of reactor vessels formed from plate or representative of a reactor vessel girth weld in the case of reactor vessels formed from forged rings, as shown in Figure 2, from the plate used to make the reactor vessel in the reactor core region, or from a similar plate from the same heat.
- 3.2.2 The Seller shall heat treat the plate with the reactor vessel, or in similar fashion, to insure that it and the weld represent the metallurgical condition of a vessel weld, in the core region of the completed reactor vessel including all post weld heat treatment cycles seen by that weld.
- 3.2.3 The Seller shall furnish documents to the Buyer showing the location of the test plates, detailing all metallurgical data and demonstrating that the weld was made in a manner similar to a reactor vessel weld. X-rays of the weld shall be furnished.
- 3.2.4 The Seller shall make mechanical test specimens, as outlined below, from half of the plate and shall supply the other half to the Buyer.
- 3.3 Surveillance Specimen Fabrication
- 3.3.1 The Seller shall provide a detailed plan of specimen preparation for the Buyer's approval prior to the start of any work required by this attachment. The Buyer can furnish a plan which the Seller may use as a guide. He shall be specific in indicating how the notch location of the Heat-Affected Zone Charpy specimens will be determined.
- 3.3.2 All specimen cutting shall be done by machining.
- 3.3.3 Specimen marking and mark orientation are of upmost importance. Each specimen shall be marked serially with the FAB Code series provided.

1-40

GENERAL 🎲 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 3 SH NO. 4 CONT ON SHEET 5

ATTACHMENT B (CONT'D)

- 3.3.4 The Seller shall apply rust preventative to all specimens, shall arrange them in serial groups of like materials, and shall wrap them to prevent mechanical damage.
- 3.3.5 The Seller shall provide drawings showing all specimen locations with respect to the plate.
- 3.4 Preparation of Base Metal Charpy Test Specimens

(Refer to Figure 3 and Drawing 117B1549)

The Seller shall prepare 53 standard Charpy V-Notch impact specimens (ASTM E23, Type A, G.E. Drawing 117B1549) from the base plate material described in previous paragraphs. The specimens shall be taken from 1/4 thickness positions in the plate and at least 1T from any asquenched edge. The long axes of the specimens shall be parallel to the plate rolling direction, or principal forging direction. The specimen notches shall be perpendicular to the original plate surface and shall be controlled by the orientation of the end marking on the specimen blanks.

3.5 Preparation of Base Metal Tensile Specimens

(Refer to Figure 3 and G.E. Drawing 117B1550)

The Seller shall prepare 14 1/4 inch gage diameter tensile specimens as per G.E. Drawing 117B1550, from the base plate material previously described. The specimens shall be taken from 1/4 thickness positions in the plate and at least 1T from any as-quenched edge. The long axes of the specimens shall be parallel to the plate rolling direction or principal forging direction.

3.6 Preparation of Weld Charpy Specimens

(Refer to Figure 4 and G.E. Drawing 117B1549)

The Seller shall prepare 53 Charpy impact specimens, per G.E. Drawing 117B1549 and Figure 4, from the weld deposit material of the furnished plate. The long axes of the specimens shall be perpendicular to the weld direction and parallel to the plate surface, with the middle of the specimen at the mid-plane of the weld, as shown in Figure 4. The specimen location in the stock material shall be recorded, approximately, by the numbering system. The notch shall be parallel to the plate surface and its orientation shall be controlled by the orientation of the marking sysmbols.

GENERAL 🍘 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SPEC. NO. 21A1112 REV. NO. 3 SH NO. 5 CONT ON SHEET 6

ATTACHMENT B (CONT'D)

3.7 Preparation of Weld Tensile Specimens

(Refer to Figure 5 and G.E. Drawing 117B1550)

The Seller shall prepare 13 tensile specimens, per G.E. Drawing 117B1550 from the weld deposit material of the furnished plate. The long axes of the specimens shall be parallel to the length of the weld and parallel to the top surface of the plate (See Figure 5). The gage length of the specimens shall be of weld-deposit metal only. The treaded ends of the specimens may include Heat-Affected Zone or base metal. The approximate location of the specimens in the stock material shall be recorded by the marking system.

3.8 Preparation of Heat-Affected Zone Tensile Specimens

(Refer to Figure 6 and G.E. Drawing 117B1550)

The Seller shall prepare 13 tensile specimens, per G.E. Drawing 117B1550, from the welded material of the furnished plate. The long axes of the specimens shall be perpendicular to the length of the weld and parallel to the top surface of the plate (See Figure 6). The center of the specimen shall be in the Heat-Affected Zone adjacent to the edge of the weld metal. The approximate location of the specimens in the stock material shall be recorded by the marking system.

3.9 Preparation of Heat-Affected Zone Charpy Specimens

(Refer to Figure 7 and G.E. Drawing 117B1549)


The Seller shall prepare 53 Charpy specimens, per G.E. Drawing 117B1549, from the welded material of the furnished plate. The long axes of the specimens shall be perpendicular to the length of the weld and parallel to the top surface of the plate (See Figure 7). The radius of the notch of the specimen shall be at one outer edge of the weld. The axis of the notch shall be perpendicular to the original plate surface. The notch orientation shall be controlled by the marking orientation. The location of the specimen in the stock material shall be recorded, approximately, by the marking system.

GENERAL 🎊 ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

í



DESIGN ANALYSIS SCHEDULE FOR REACTOR PRESSURE VESSEL FOR MONTICELLO POWER STATION

BOLTING AND CLOBURE FLANCES

DULITING AND CLOBURE FLAMES			
Taoko	ASHE Section III Stress Category	Responsible Party	A S O N D J F M A M J J A 8
(Total Task Time) Sizing, ASME Code Calculations	P _H ,P _L ,Q	CB&I	
Dravings and Dimensions		CB&I	
Loads - Pressure, T empe rature			
Therwal Analysis Stealy State Transient		30 26	C
Stress and Flange Rotation Analysis	alysis		
Analytical Model & Methods	E poi	CBGI	•
Hydro & Design P	P _M , P _L , P _B , Q	CBSI	2 S
Solt Preload	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	CB&I	1A11 h 1
Transfent Heatup and Shutdown	ď	10	12, Re Cont
G Fatigue Analysis	F	GE	v. 0 'd On
keview and Approval		20	2

1-44

î. Z

	DESI REACTOR PRESSURE		GN ANALYSIS "AEDULE FOR VESSEL FOR MONTICELLO POWER STATION	
BOTTOM HEAD AND SUPPORT SKIRT			SCHRDUT.	
Taska	ASHE Section III Stress Category	Responsible Party	1966 1967 A S O N D J F M A H J J A S	
(Total Task Time)				
Sizing, ASME Code Calculations	ь " ^г " ^н а	CB&I		
Drawings and Dimensions		CB&I	ATT	
Loads - Pressure, Temperature Seismic Weight Jet Forces		GE	ACHMENT C	
Analytical Model		CBGI	(CONT	
Seismic Analysis 🧄		CB&I	<u>'D)</u>	
Thermal Analysis its		GE	f	
Stress Analysis	P _N , P _B , P _L , Q	39	214 Sh	
ratigue Analysis	P	GE	1112, 2	
Revi cu and Approval		IJ	Rev. Cont. (
мти -2 от			0 1-45 Dn 3	

DLESTON ANALYSIS SCHEDULE FOR REACTOR PRESSURE VESSEL FOR MONTICELLO POWER STATION

RD PENETRATION

NOTT WIT THE I NOT			SCHEDULE	
	ASHE Section III Stress	Responsible Party	<u>1966</u> <u>1967</u>	
Casks	Category		A S O N D J F M A M J J A S	
(Total Task Time))rawings and Dimensions		CBCI		
itzing, ASME Calculation		CB&I		ATTA
Loade - Seismic, Scram Weights, Pressure Flow Rates and Temperatures		85		CHMENT C (C
Thermal Analysis - Steady State Transient		23	Ť	CONT'D)
Stress Analysis - Erimary	P _M , P _L , P _B	CB61		
Primary and Secondary	P _N , P _L , P _B , Q	23	1	21A1112 Sh 3
Fatigue Analysie	ᆲ°᠔ᠳ ^ឰ ᆲᠳᡀᡨᡀ	аS	4	, Rev. Cont.
Review and Approval		8		0 On 4

1-46

MAR -- 5 1969

. .

.

DRSICH ARALYSI (HEDULK FOR REACTOR PRESSURE VESSEL FOR MONTICELLO PONER STATION

:

*S312200			SCHEDULE	
Tasks	ASAE Section III Stress Category	Responsible Party	1966 1967 A S O N D J F M A M J J A S	
(Total Task Time)				
Drawings and Dimensions		CB&I		
Sizing, ASME Calculations		CB&I		AT
Loads - Pipe Reactions - Seismic - Pressures - Flow Rates and Temperatures		AD		IACHMENT C (C
Thermal Analysis - - Steady State - Transient		ЗD		ONT'D)
Stress Analysis - Primary	Pu, PL, P	CB&I		
-Primary and Secondary	P _M , P _L , P _B , Q	GE		21. Sh
Fatigue Analysis	PM.PL.PB.Q.F	GE	Ŧ	All12, R 4 Co
Review and Approval		a S		ev. () nt. On
* Mote breakdown of norries to be analyzed par		this schedule on page 5.		5

this schedule on page b. Note breakdown of norries to be analyzed par MAR - 5 1969

1-47

DESIGN ANALYSIS SCHEDULE FOR Reactor Pressure Vessel For Monticello Pourr Station

			SCHRNIT P	
	ASME Section	Responsible	1966	
.aske	III Stress Category	Party	A S O N D J F M A M J J A S	
(Total Task Time)				
HROUD SUPPORT Statue ASME Code Calculations		CB&I		
Drawings and Dimensions		CB&I		
Loads - Pressure, Temperature, Seismic, Weights and Forces		30	<u>TACHMENT</u>	
Stress Analysis	PH, PL, PB	CB&I	• <u>c</u> (
Review and Approval		CE	CONT'E	^
(Total Task Time)			<u>)</u>	
REFUELING BELLOWS SUPPORT SKIRT				
Sizing		CB&I		
Drawings and Dimensions		СВАІ	Sh	
Loads - Weight, Temperature		CE	5 →	1112,
Thermal Analysis		CB&I	Cont	
Stress Analysis	PH.P.F.Q	CB&I	τ. οτ	
Patigue Analysis	•	CBAI	n 6	0
Review and Approval		23	•	-
MAR - 5 1969				

1-48

}

DESIGN ANALYSA CHEDULE FOR REACTOR PRESSURE VESSEL FOR MONTICELLO POWER STATION	ASME Section Responsible 1966 SCHEDULE III Stress Party A 8 0 M D J F	AMLYTICAL REMORK Claim at APED for an estimated three trips GE	CB&I	 * The norrie schedule on page 4 is for the following norries: (1) Core spray and flooding (2) Feedwater (3) Control Rod Hydraulic Return (4) Core differential pressure and liquid control (5) Recirc Inlet (6) Recirc Outlet (7) Steam Outlet 	<pre>is responsible for the complete analysis of (1) All norrestee not specified above (2) Stabilizer brackets (3) Inaulation brackets (4) Head lifting lugs (5) Shroud head and dryer guide support (6) Feedwater sparger support (7) Any other internal vessel attachments</pre>	Map
	<u>1967</u> Н А М Ј Ј А	-			1A1112, Rev. 0 Sh 6 Cont. on F	

 $\left(\cdot \right)$

1-49

TEMPERATURE TRAI. ENTS

Vessel Part	No. of Cycles	Fluid Temp. Rate	Fluid Start Temp.	Fluid End Temp.	State of Fluid	Fluid Velocity	Vessel Pressure	Notes
Recirc. Outlet	200	100 F/hr	100	546	Water	25 ft/sec	Saturated	
	200	1000 F/hr 100 F/hr	546 370	370 100	Water	25 ft/sec	Saturated	Followed by
	s	Step	546 (Step to 130)	546 (Step from 130)	Water	5 ft/sec (reverse flow)	1000 ps1g	26 seconds duration at 130°F
Recirc. Inlet	200	100 F/hr	100	546	Water	32 ft/sec	Saturated	
Nozzle	200	00	546 90	546 90	Water Water	32 ft/sec 10 ft/sec	170 psig	Followed by
Steam Outlet Nózzle	532	100 F/hr	100	546	Steam	5 ft/sec	Saturated	Condensing Steam in nozzle
-	531	100 F/hr	546	346	Steam	5 ft/sec	Saturated	Followed by
		1000 F/hr 100 F/hr	346 296	296 100	Water Water	14 ft/sec 0	Saturated Saturated	Followed by
	1	1000 F/hr	546	370	Steam	25 ft/sec	Saturated	Followed by
		100 F/hr	370	100	Steam - Water	0	Saturated	
Feedwater Nozzle		0	376	376	Water	10 ft/sec	1100 psig	Steady State 546° Water in Vessel
	16.00	100 F/hr	100	546	Water	0	1100 psig	Followed by Step To
	¢	0 250 F/hr	100 260	100 376	Water Water	5 ft/sec 5* ft/sec	1100 paig 1100 paig	by Step
Core Spray	250	100 F/hr	100	546	Water	0	Saturated	
9TZZON	250	0	546 80 **	80	Water Water	0 20 ft/sec	1000 psig 0 psig	Followed by (Steam in Thermal Sleeve Annulus)
<pre>* Velocity changes linearly 5 ft/sec to 20 ft/ ** Water reaches this temperature in 15 seconds</pre>	nges line s this te	Velocity changes linearly 5 ft/sec to 20 Water reaches this temperature in 15 sec	to 20 ft/sec 15 seconds	ATTACIIMENT D				c

MAR - 5 1969

1-50

7

Sht. $\frac{1}{2}$ Cont. on $\frac{2}{2}$

ATTACHMENT D

;

1



ENTS TEMPERATURE TRA

Let Pump Late Pump Nextles 200 1000 F/hr 370 Vater 0 Saturated Saturated Followed by Mater Reburk Nexzles 100 F/hr 370 45° 45° Water 15 ft/sec 1000 psig Steady State 54° Repuils 200 0 45° 45° Water 15 ft/sec 1000 psig Nater in vessel Core Diff. 6 10 0 80 Water 15 ft/sec 1000 psig Nater in vessel Core Diff. 6 10 0 80 Water 0 Saturated Pollowed by Liquid Control 100 F/hr 370 Water 0 Saturated Followed by Nozzie 200 100 F/hr 370 Water 0 Saturated Followed by Nozzie 200 100 F/hr 370 Water 0 Saturated Followed by Nozzie 200 100 F/hr 370 Water 5 ft/sec* Saturated Followed by Strutuent 200	of Cycles	riuid Temp. Rate	Start Temp.	End Temp.	of Fluid	Fluid Velocity	Vessel Pressure	Notes
200 0 45° 45° 45° 45° 45° 45° 45° 45° 45° 45° 45° 45° 45° 45° 100 93 8	200	1000 F/hr 100 F/hr	546** 370	370 100	Water	00	Saturated Saturated	Followed by
6 10 0 80 Nate: 15 ft/sec 1000 psig Nozzie at stat:	200	0	45°	45°	Water	15 ft/sec	1000 psig	y State In vess
200 1000 F/hr 546** 370 Water 0 Saturated Followed by 200 100 F/hr 370 100 Water 0 Saturated Followed by 200 100 F/hr 330 100 Water 0 Saturated Followed by 200 100 F/hr 330 100 Water 5 Saturated Followed by 200 100 F/hr 370 Water 5 Saturated Followed by 200 100 F/hr 370 Water 5 Ft/sec* Saturated Followed by 199 100 F/hr 346 Water 5 Ft/sec* Saturated Followed by 1 100 F/hr 346 Water 5 Ft/sec* Saturated Followed by 1 100 F/hr 346 Water 5 Ft/sec* Saturated Followed by 1 100 F/hr 346 Water 5 Ft/sec* Saturated Followed by <td>· · · · · · · · · · · · · · · · · · ·</td> <td>0</td> <td>80 ***</td> <td>80 ***</td> <td>Water</td> <td>15 ft/sec ***</td> <td>1000 psig</td> <td>at mal</td>	· · · · · · · · · · · · · · · · · · ·	0	80 ***	80 ***	Water	15 ft/sec ***	1000 psig	at mal
200 100 F/hr 330 100 Water 0 Saturated Nozzle at 2 rt 200 1000 F/hr 546** 370 Water 0 Saturated Followed by rt 200 100 F/hr 370 Uater 5 ft/sec* Saturated Followed by rt 200 100 F/hr 100 546 Water 5 ft/sec* Saturated Followed by 199 100 F/hr 346 Water 5 ft/sec* Saturated Followed by 199 100 F/hr 296 Water 5 ft/sec* Saturated Followed by 1 100 F/hr 296 Water 5 ft/sec* Saturated Followed by 1 100 F/hr 346 Water 5 ft/sec* Saturated Followed by 1 100 F/hr 340 Water 5 ft/sec* Saturated Followed by 1 100 F/hr 340 Water 5 ft/sec* Saturated Followed by	200	1000 F/hr 100 F/hr	546** 370	370 100	Water Water	0 0	Saturated Saturated	Followed by
200 1000 F/hr 546** 370 Water 0 Saturated Followed by ort 100 F/hr 370 100 Mater 5 ft/sec* Saturated Followed by ort 200 100 F/hr 546 Water 5 ft/sec* Saturated Followed by 199 100 F/hr 346 Water 5 ft/sec* Saturated Followed by 199 100 F/hr 346 Water 5 ft/sec* Saturated Followed by 1 100 F/hr 296 Water 5 ft/sec* Saturated Followed by 1 100 F/hr 296 Water 5 ft/sec* Saturated Followed by 1 100 F/hr 346 370 Water 5 ft/sec* Saturated Followed by 1 100 F/hr 346 Mater 5 ft/sec* Saturated Followed 1 100 F/hr 346 Water 5 ft/sec* Saturated Followed Water Is on all sides of Core<	200	100 F/hг	330	100	Water	0	Saturated	Nozzle at 546° Igo- thermal at Start
ort 200 100 F/hr 100 546 Water 5 ft/sec* Saturated Followed by 199 100 F/hr 346 346 Water 5 ft/sec* Saturated Followed by 199 1000 F/hr 346 296 Water 5 ft/sec* Saturated Followed by 1000 F/hr 346 370 Water 5 ft/sec* Saturated Followed by 1 1000 F/hr 346 370 Water 5 ft/sec* Saturated Followed by 1 1000 F/hr 370 Water 5 ft/sec* Saturated Followed by 1 1000 F/hr 370 Water 5 ft/sec* Saturated Followed by Water is on all sides of Core Support structure and on inside surface of Reactor Vessel for Vessel for both the above transients. 546 Water See Recirc 1000 psig 26 seconds 5 Step to 130 Step from 130 0utlet 0utlet 0utlos 56 seconds	200	1000 F/hr 100 F/hr	546** 370	370 100	Water	0 0	Saturated Saturated	
199100 F/hr546346Water5 ft/sec*SaturatedFollowed by1000 F/hr346296Water5 ft/sec*SaturatedFollowed by100 F/hr296100Water5 ft/sec*SaturatedFollowed by1100 F/hr370Water5 ft/sec*SaturatedFollowed by1100 F/hr370100Water5 ft/sec*SaturatedFollowed byWater is on all sides of Core370100Mater5 ft/sec*SaturatedFollowed byWater is on all sides of CoreSupport structure and on inside surfaceof Reactor Vessel forboth the above transients.546546WaterSee Recirc1000 psig26 seconds5Step to 130Step from 130Outlet001 let001 letof 130°F	200	100 F/hr	100	546	Water		Saturated	
1000 F/hr346296Water5 ft/sec*SaturatedFollowed by100 F/hr296100Water5 ft/sec*SaturatedFollowed by1000 F/hr370Water5 ft/sec*SaturatedFollowed by100 F/hr370100Water5 ft/sec*SaturatedFollowed byWater is on all sides of Core Support structure and on inside surface of Reactor Vessel forVessel forVessel forboth the above transients.Step to 130Step from 130Outlet26 secondsStep to 130Step from 130OutletOutletof 130°F	199	100 F/hr	546	346	Water	1	Saturated	
1000 F/hr546370Water5 ft/sec*SaturatedFollowed by100 F/hr370100Water 1s on all sides of Core Support structure and on Inside surface of Reactor Vessel for both the above transients.VaterSee Recirc 1000 psig26 secondsStep546WaterSee Recirc 1000 psig26 secondsStep to 130Step from 130Outletof 130°F		1000 F/hr 100 F/hr	346 [.] 296	296 100	Water Water		Saturated Saturated	
Water is on all sides of Core Support structure and on inside surface of Reactor Vessel for both the above transients. Step 546 Water See Recirc 1000 psig 26 seconds Step to 130 Step from 130 Outlet of 130°F	1	1000 F/hr 100 F/hr	546 370	370 100	Water		Saturated	Followed by
Step 546 546 Water See Recirc 1000 psig 26 seconds Step to 130 Step from 130 0utlet of 130°F	Water both	is on all the above	ore		and on		of	
	5		to	546 Step	130	See Recirc Outlet	1000	seconds 130°F
r velocit ort plate irected a		Cycles Cycles 200 200 200 200 200 200 200 200 19 1 1 1 1 1 1 200 200 200 200 200 200 200	sel Part of Temp. cycles Rate cycles Rate cycles Rate 200 1000 F/hr strument 221e 200 0 sturh Nozzle 200 100 F/hr 100 F/hr 200 100 F/hr 200 100 F/hr 200 100 F/hr 100 F/hr 200 100 F/hr 199 100 F/hr 100 F/hr 100 F/hr 100 F/hr 100 F/hr 100 F/hr 200 100 F/hr 200 F/hr 200 100 F/hr 200 F/hr	of Temp. St Cycles Rate Te 200 100 F/hr 37 200 0 Y 200 0 45 200 0 45 200 0 45 200 0 80 10 F/hr 37 200 100 F/hr 37 199 100 F/hr 37 5	of Temp. St Cycles Rate Te 200 100 F/hr 37 200 0 45 200 0 45 200 0 45 200 0 45 200 0 80 10 F/hr 37 200 100 F/hr 37 199 100 F/hr 37 100 F/hr 37 <t< td=""><td>of Cycles Temp. Start Temp. End Tolo of Fluid 200 100 F/hr 546** 370 Water 200 100 F/hr 546** 370 Water 200 0 45° 45° Water 200 0 45° 45° Water 200 100 F/hr 546** 370 Water 200 100 F/hr 370 100 Water 200 100 F/hr 376** 370 Water 200 100 F/hr 376 Water Water 200 100 F/hr 376** 370 Water 200 100 F/hr 376 Water Water 199 100 F/hr 376 Water Water 199 100 F/hr 346 Water Water 199 100 F/hr 346 Water Water 190 100 F/hr 346 Water Water 190 100 F/hr<!--</td--><td>of Temp. Start End of Fluid Veloc 200 1000 F/hr 546** 370 Water 0 200 100 F/hr 546** 370 Water 15 ft 200 100 F/hr 546** 370 Water 15 ft 200 0 45° 45° Water 0 0 200 0 45° 45° Water 0 0 200 1000 F/hr 546** 370 Water 0 0 200 100 F/hr 370 Water 0 0 0 0 200 100 F/hr 370 Water 5</td><td>off Temp. Start End off Fluid Velocity Pres 200 100 F/hr 346** 370 Water 15 ft/sec 100 200 0 45° 45° 45° Water 15 ft/sec 100 200 0 45° 45° 45° Water 15 ft/sec 100 200 0 45° 45° 45° Water 15 ft/sec 100 200 0 80 80 46 47° 44</td></td></t<>	of Cycles Temp. Start Temp. End Tolo of Fluid 200 100 F/hr 546** 370 Water 200 100 F/hr 546** 370 Water 200 0 45° 45° Water 200 0 45° 45° Water 200 100 F/hr 546** 370 Water 200 100 F/hr 370 100 Water 200 100 F/hr 376** 370 Water 200 100 F/hr 376 Water Water 200 100 F/hr 376** 370 Water 200 100 F/hr 376 Water Water 199 100 F/hr 376 Water Water 199 100 F/hr 346 Water Water 199 100 F/hr 346 Water Water 190 100 F/hr 346 Water Water 190 100 F/hr </td <td>of Temp. Start End of Fluid Veloc 200 1000 F/hr 546** 370 Water 0 200 100 F/hr 546** 370 Water 15 ft 200 100 F/hr 546** 370 Water 15 ft 200 0 45° 45° Water 0 0 200 0 45° 45° Water 0 0 200 1000 F/hr 546** 370 Water 0 0 200 100 F/hr 370 Water 0 0 0 0 200 100 F/hr 370 Water 5</td> <td>off Temp. Start End off Fluid Velocity Pres 200 100 F/hr 346** 370 Water 15 ft/sec 100 200 0 45° 45° 45° Water 15 ft/sec 100 200 0 45° 45° 45° Water 15 ft/sec 100 200 0 45° 45° 45° Water 15 ft/sec 100 200 0 80 80 46 47° 44</td>	of Temp. Start End of Fluid Veloc 200 1000 F/hr 546** 370 Water 0 200 100 F/hr 546** 370 Water 15 ft 200 100 F/hr 546** 370 Water 15 ft 200 0 45° 45° Water 0 0 200 0 45° 45° Water 0 0 200 1000 F/hr 546** 370 Water 0 0 200 100 F/hr 370 Water 0 0 0 0 200 100 F/hr 370 Water 5	off Temp. Start End off Fluid Velocity Pres 200 100 F/hr 346** 370 Water 15 ft/sec 100 200 0 45° 45° 45° Water 15 ft/sec 100 200 0 45° 45° 45° Water 15 ft/sec 100 200 0 45° 45° 45° Water 15 ft/sec 100 200 0 80 80 46 47° 44

** Water reaches this temperature at a fluid temperature rate of 100F/hr.

*** See 886D482, Sht. 3 for location of liquid control flow.

21A1112, Rev.

1-51

Sht. 2 Cont. on <u>.</u>

ATTACHMENT D

		Steam fer			4.			an As- 546°		
	Notes	Condensing St Heat Transfer	Followed by Followed by	Followed by		Followed by Followed by	Followed by	Penetration sembly at 54 at Start	from Detailed Stress following values may back to	1
	Vessel Pressure	Saturated	Saturated Saturated	Saturated Saturated	Saturated	Saturated Saturated Saturated	Saturated Saturated	1000 ps1g		normal opera-
	Fluid Velocity	0	free Conv.	Free Conv.	5 ft/sec	5 ft/sec 5 ft/sec 5 ft/sec	5 ft/sec 5 ft/sec	* 10 ft/sec outside assembly	applicable except ode Section III, berating pressure	full range) during normal
TENTS	State of Fluid	Steam	Steam Water	Steam Steam	Water	Water Water Water	Water Water	Water a thermal tube tube	le vessel applicat he ASME Code Sect ure to operating	0 pst full r
TEMPERATURE TRAN	Fluid End Temp.	546	350 r at 330°F 150	375 100	546	375 330 100	370 100	50° ictents through a the nousing are: ft ² °F above stub tube ft ² °F at stub tube ft ² °F below stub tube	r parts of the ve nd N-451 of the A spheric pressure	fluctuations (200 ps1
TEMPI	Fluid Start Temp.	100	546 ng with water 300	546 375	100	546 375 330	546 370	0 50° 50° Wat *Heat transfer coefficients through a thermal sleeve within the housing are: (a) h = 75 Btu/hr ft ² °F above stub tube (b) h = 193 Btu/hr ft ² °F at stub tube (c) h = 40 Btu/hr ft ² °F below stub tube		pressure flu
	Fluid Temp. Rate	100 F/hr	100 F/hr Flooding 100 F/hr	1000 F/hr 100 F/hr	100 F/hr	100 F/hr 300 F/hr 100 F/hr	1000 F/hr 100 F/hr	0 *Heat trans sleeve wit (a) h = 7 (b) h = 1 (c) h = 4	the purposes of demonstrating for ysis according to Paragraphs N-415 sed. Total design pressure cycles from atmospheric pressure is 200 cycles	of significant pressure).
	No. of Cycles		199	1	200	199	1	370	urposes c according design p pheric pr	
	Vessel Part	Closure Flanges & Adjacent Shell	and Refueling Bellows Support Skirt		Bottom Head &		-	Control Rod Drive Penetra- tion Peripheral Location and Central Loca- tion	NOTE: For the pu Analysis a be used. (a) Total atmosp	(b) The number tion is 280

21A1112, Rev. 1

1-52

Cont. on Final

ſ

Sht

ATTACHMENT D

`.

MAR - 5 1969

(c) The number of major temperature fluctuations is 400

GÉNERAL ELECTRIC

ATOMIC POWER EQUIPMENT DEPARTMENT

PURCHASE SPECIFICATION

SFECIAL PROJECT MONTICELLO spec. No.21A1112 Rev. No.1 sh No. 1 CONT ON SHEET F

TITLE

REACTOR PRESSURE VESSEL

ađ

BRANCH Mechanical NO. 13540

ATTACHMENT E

CERTIFICATION OF DESIGN SPECIFICATION AS TO COMPLIANCE WITH THE REQUIREMENT OF THE ASME BOILER AND PRESSURE VESSEL CODE SECTION III NUCLEAR VESSELS

This Specification 21A1112, Rev. 6, lists for the Monticello Nuclear Power Station the purchase specification, specification control drawings, and supplementary specifications which comprise the Design Specifications required by Paragraph N-141 of the ASME Boiler and Pressure Vessel Code, Section III, Nuclear Vessels.

This certification is issued in order that design and fabrication of the reactor pressure vessels identified by General Electric Company Purchase Order 205-55582-I may proceed in accordance with the requirements of Section III.

Pursuant to Paragraph N-140 of Section III, this certification is solely for the purpose of complying with the requirements of ASME Boiler and Pressure Vessel Code, Section III, and is not to be construed as involving, modifying or changing contractual relations or legal liabilities.

CERTIFIED BY			Gall	DATE March 4, 1769
	Registered	l Prof	essional Engineer	

STATE <u>California</u>

REFERENCE DRAWINGS AND DOCUMENTS

	DESCRIPTION
NUMBER	Reactor Vessel Specification Control
886D482, Rev. **	
885D911, Rev. 2	Vessel Flange Bolting
107C5305, Rev. 2	Nozzle End Preparation
21A9821, Rev. 0	Stud Tensioners
117B1549, Rev. 2	Charpy Impact Specimen
117B1550, Rev. 2	1/4" Tensile Test Specimen
21A1050, Rev. 0	Reactor Servicing Tools
Attachment B, Rev. 3	Note of a mark mark Sandaran (NO. O. R. (N.)
	Temperature Transients
Attachment D, Rev. 1	Vessel As-Built Dimensions
- /JI20/0, JACK -,	
731E678, Sht. 2, Rev. 0	Vessel As-Built Dimensions
	THE OWNER WITH
** Sht. # Rev. # Sht. #	Rev. #
1 5 5	3
	ž 📥
$\begin{array}{cccc} 2 & 10 & 6 \\ 3 & 2 & 7 \end{array}$	
3 2 7	9 •
4 7 👗 8	3
7	1069
	MAR - 1 Inus

BY:	ISSUED:
DR HEISING	JA MAST

.

EXHIBIT 2

MANUFACTURER'S DATA REPORT AND VESSEL CERTIFICATION

.

REV 4 12/85

PRESSURE VESSEL REPORT

MANUFACTURER'S DATA REPORT AND VESSEL CERTIFICATION

MONTICELLO GENERAL ELECTRIC CO. APED - SAN JOSE VPF# 1811-355-1 EP# 2-1-1

PRESSURE VESSEL RECORD

MANUFACTURER'S DATA REPORT AND CERTIFICATIONS

BOILING WATER NUCLEAR REACTOR VESSEL 17.167' x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. G.E. CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

TABLE OF CONTENTS

- 1. Manufacturer's Data Report
- 2. Hydrostatic Testing Certification
- 3. Radiographic Testing Certification
- 4. Ultrasonic Testing Certification
- 5. Liquid Penetrant Testing Certification
- 6. Magnetic Particle Testing Certification
- 7. Final Cleaning Certification
- 8. Welding Certification
- 9. Weld Repair Certification
- 10. Heat Treatment Certification
- 11. Weld Rod and Wire Certification
- 12. Cladding Carbon Content Certification
- 13. Welder Qualifications Certification
- 14. Parkerizing Certification
- 15. Material Certification
- 16. Material Identification

17. Nameplate Photograph

: .

- 18. Fabrication Test Program Certification
- 19. Results of Tensile Tests per Par. 2.2.2 Attachment B
- 20. Results of Charpy V-Notch Impact Tests per Par. 2.2.4 Attachment B

								TJA	
						NUCLEAR V		10/2/6	
	As required	by the Prov	inions of t	the ASME	Code Rules	CB&I Co	ontract	No. 9-	624
1. Manufactured by	<u>Chicago</u>	<u>Bridge</u>	A Iron	Compa	ny <u>, Bir</u> i	mingham.	Alabam	L	
2. Manufactured for-	General	Electr	ic Co.	ForN	orthern	States	Pwr. Co.	Hont	cell
3. Type Y.R.T.L.	NUCI	ear kea	CTOT	(Name and a	ddress of Purc	heser)	Ne	Yr. Built	169 M
(Hons. or Vert.)	(Tank Jacket	eddiest Ez.)	(Mfre.	. Senai No.)	(State & State	No.)	. RO	If, Sa tilesond	
Items 4-8 incl. to be con	pleted for sing	le wall vessel	a, packets of	I jacketed ve	sseis, or shell	s erbest exches			
See	Sl belg			plow	Corrosion	outs 	.)ins.	hd/ins.	,hd.
									. if.
5. Seams: LongD.b.	1. Butt			**		omplete omplete	Efficiency	<u>100</u>	
Girth					A. K		No. of Cou		
*6. Heads: (a) Material	See S1							80.00)
Location (Top, bottom, wada)	Thickness	Radius.	Rediver	Netto	Apex Angle .	- Bomisphericai ; Radius.	Diamotes	Şide to Pr ⊈Gaşves ar Co	cave)
(a). <u>Bottom</u>	5.063.	938.		below)	·····	<u> </u>		Conca	/.e
(b). <u>1.9.0</u>	Studs 1	Nuts:	ASTR	<u>BP.10x)</u> A540 G	8 - 823	to C.C.	1335-2		15 00
Top Hd If removable, solta :	0866	(Material, Sm		Size Mu					26.64
7. Janias Giamore. H	ain Clos	sure flo	i: Ast	M A508	CLII W	ith .725	Min_I	<u>bk., S.S</u>	oye
	• • •						Fie	ld	
8. Constructed for	1000	•	5757-	Charpy Imped	410		Tant .		at
 Constructed for operating press.² 	1.MMUpsi	at Max. temp		et temp. of			Pressu	re].56.3	
Items \$ and 10 to be con	aptered for tase	e sections.				·			V
9. Tube Sheets: Statio	mary, Material.		Diam.		in. Thic	kaess	in. Attaches	et	******
								EA MONE' TRANSA	
Floe									
Floe					is. Thic	haess			
10. Tobes: Material	ting. Material.	(Kind & Spec.	Dism. No.)_ 1	 	in. Thic	haess 1 - 5 - 7	. in. Attachm	nt	
10. Tobes: Material	ting. Material.	(Kind & Spec.	Dism. No.)_ 1	 	in. Thic	haess 1 - 5 - 7	. in. Attachm	mt	
10. Tabes: Material (Kind Items 11 to 14 incl. to 1	ting. Material. 	(Kind & Spec.	Diam. No.) a. Thickness	s ed vessels, c	in. Thic 	Number.	. in. Attachm	nt	
10. Tobes: Material	ting Material.	(Kind & Spec. D.D.,	Dism. No.) 1 a. Thickness rm of jackets Nomin Thick	s	in The inches or tage	Number.	. in. Attachm Typ	e(Streight /	or U)
10. Tobes: Material	ting Material.	(Kind & Spec. D.D. r inner chambe . T.S. (Min. of ren	Dism. No.) 1 a. Thickness rm of jackets Nomin Thick age specified	ed vessels, o nel nessil	in The inchas inchas or the treas of channels of Corrosion a. Allowance	Number 	. in. Attachm. Typ	e(Streight -	or (J)
10. Tobes: Material	ting Material.	(Kind & Spec. D.D. r inner chambe . T.S. (Min. of ren	Dism. No.) 1 a. Thickness rm of jackets Nomin Thick age specified	ed vessels, o nel nessil	in The inchas inchas or the treas of channels of Corrosion a. Allowance	Number 	. in. Attachm. Typ	e(Streight -	or (J)
10. Tubes: Material (Kind Items 11 to 14 incl. to) 11. Shell: Material (Kind 12. Seams: Long	ting Material.	(Kind & Spec. D_De r inner chambe . T.S	No.) 1 n. Thickness rm of jackets Nomin Thick nge specified (Ye	ed vessels, o nai nessii))	in. Thicks inches or channels of Corrosion Allowance	Number 	. in. Attacim Typ Typ 		in.
10. Tubes: Material	ting. Material. (a Spec. No.) be completed fo 2 Spec. No.) Welded, Dbi., Si	(Kind & Spec. D_De r inner chambe - T.S (Min. of ren (Min. of ren 	Mo.) 1 m. Thickness is of jackets Nomin Thick nge specified (Ye T.1.	ed vessels, (nel ness	in. Thick inches or tage channels of Correston Allowance X.R.	Number.	. in. Attachan Typ 	Congth ft.	in. B) 7
10. Tubes: Material (Kind Items 11 to 14 incl. to) 11. Shell: Material (Kind 12. Seams: Long	ting. Material. (a Spec. No.) be completed fo 2 Spec. No.) Welded, Dbi., Si	(Kind & Spec. D_De	Mo.) 1 n. Thickness rs of jackets Nomin Thick Thick (Ye C.1	ed vessels, (nel ness	in. Thick inches or tage channels of Correston Allowance X.R.	Number.	. in. Attachan Typ 	Congth ft.	in.
10. Tubes: Material (Kived Items 11 to 14 incl. to 1 11. Shell: Material (Kind 12. Seems: Long	tung. Material. A Spec. No.) be completed for the spec. No.) weided, Dbi., Su Thickness	(Kind & Spec. D.D., r inner chambe . T.S. (Min. of ren (Min. of ren 	Mo.) 1 n. Thickness rs of jackets Nomin Thick Thick (Ye C.1	ed vessels, o ad messii)) ve or Noj risi 	in. Thic inches or there of channels of Corresion Allowance X.R.	Number.	. in. Attachan Typ 	Carraight (Straight Length ft. y	in.
10. Tubes: Material	tung. Material. A Spec. No.) be completed for the spec. No.) weided, Dbi., Su Thickness	(Kind & Spec. D.D., r inner chambe . T.S. (Min. of ren (Min. of ren 	Mo.) 1 a. Thickness frin of jackets Nomin Thick ge specified (Ye 	ed vessels, o ad messii)) ve or Noj risi 	in. Thick inchas or tage - in channels of Corrosion 3. Allowance X.R T.S Conscal	heres	. in. Attachan Typ Typ 	Carraight (Straight Length ft. y	in.
10. Tubes: Material (Kived Items 11 to 14 incl. to 1 11. Shell: Material (Kind 12. Seems: Long	tung. Material. A Spec. No.) be completed for the spec. No.) weided, Dbi., Su Thickness	(Kind & Spec. D.D., r inner chambe . T.S. (Min. of ren (Min. of ren 	Mo.) 1 a. Thickness frin of jackets Nomin Thick ge specified (Ye 	ed vessels, o ad messii)) ve or Noj risi 	in. Thick inchas or tage - in channels of Corrosion Allowance X.R. X.R. T.S. Conscal	heres	. in. Attachan Typ Typ 	Carraight (Straight Length ft. y	in.
 Tubes: Material	ting Material. A Spec. No.) be completed for the spec. No.) Feided, Dbi., Su Thickness S	(Kind & Spec. D_De	Mo.) 1 Mo.) 1 n. Thickness ris of jackets Nomin Thickness Nomin Thickness (Yo r. 1	ed vessels, d ad nessii) e or No) tiliptical Ratio	in. The DC inches or channels of Corrosion Allowance X.R. X.R. T.S. Conical Apex Angle	Number.	. in. Attachan Typ 	Length ft. y	
 Tubes: Material	ting Material. A Spec. No.) be completed for the spec. No.) Feided, Dbi., Su Thickness S	(Kind & Spec. D_De	Mo.) 1 Mo.) 1 n. Thickness ris of jackets Nomin Thickness Nomin Thickness (Yo r. 1	ed vessels, d ad nessii) e or No) tiliptical Ratio	in. The DC inches or channels of Corrosion Allowance X.R. X.R. T.S. Conical Apex Angle	Number.	. in. Attachan Typ 	Length ft. y	
 Tubes: Material	ting. Material. () & Spec. No.) be completed for a Spec. No.) feided, Dbi., Si Thickness is 	(Kind & Spec. D_De	Mo.) 1 Mo.) 1 n. Thickness ris of jackets Nomin Thickness Nomin Thickness (Yo r. 1	ed veisels, (ad messii)) rial Litiptical Ratio	in. Theoremain of the second s	In the set of the set	. in. Attachan Typ Typ 	Length ft. y	
 Tubes: Material	ting. Material. (a Spec. No.) be completed for the spec. No.) weided. Dbi., Si Thickness the Thickness the the the spec. the spec. th	(Kind & Spec. D_De T.S		ed veisels, d nel neesii i) rial lliptical Ratio Cherpy Impi	in. The UC inclusion or channels of Corrosion Allowance X.R. T.S. Conical Apex Angle (c)	Number. Number. in. Diem (c) Materi Hemispherical Radius	. in. Attachan 	A	
 Tubes: Material	ting. Material. (a Spec. No.) be completed for the spec. No.) Felded. Dbl., Su Thickness Thickness taged (a)	(Kind & Spec. D_De r inner chambe . T.S (Min. of rem 	Dism. No.) 1 a. Thickness rs of jackets Nomin Thick sge specified (Ye r. 1	ed veisels, d nel neesii i) rial lliptical Ratio Cherpy Impi	in. The UC inclusion or channels of Corrosion Allowance X.R. T.S. Conical Apex Angle (c)	Number. Number. in. Diem (c) Materi Hemispherical Radius	. in. Attachan 	A	
 Tubes: Material	ting. Material. (a Spec. No.) be completed for the Spec. No.) Feided, Dbi., Su Thickness I Thickness I Thickness I Thickness I Thickness I Thickness I Thickness I I I I I I I I I I I I I	(Kind & Spec. D_De r inner chambe . T.S (Min. of rem 	Mo.) 1 a. Thickness rm of jackets Nomin Thick nge specified (Ye r. 1	d veisels, d ad veisels, d nessii iii co or No) filiptical Ratio Cherpy Impe at temp, of	in. The UC inchase or channels of Corrosion Allowance X.R X.R Conical Apex Angle (c)	Interest Exchangers Interest	. in. Attachan 	A	
 Tubes: Material	ting. Material. (a Spec. No.) be completed for the Spec. No.) Feided, Dbi., Su Thickness I Thickness I Thickness I Thickness I Thickness I Thickness I Thickness I I I I I I I I I I I I I	(Kind & Spec. D_De r inner chambe . T.S (Min. of rem 	Mo.) 1 a. Thickness rm of jackets Nomin Thick nge specified (Ye r. 1	d veisels, d ad veisels, d nessii iii co or No) filiptical Ratio Cherpy Impe at temp, of	in. The UC inchase or channels of Corrosion Allowance X.R X.R Conical Apex Angle (c)	Number. Number. in. Diem (c) Materi Hemispherical Radius	. in. Attachan 	A	
 Tubes: Material	ting. Material. (a Spec. No.) be completed for the completed for t	(Kind & Spec. D_D_e	Mo.) 1 Mo.) 1 a. Thickness Nomin Thickness Nomin Thickness Nomin (Your Control of the second (Your Control of the second (Your Control of the second (Your Control of the second (Your Control of the second Control of	cherpy imper at temp, of 1 n f o r i	in. Thick DC imples or there of Corrosion Allowance X.R. T.S. Conical Apex Angle (c) (c) (c) Allowance Allowance (c) (c) (c) (c) (c) (c) (c) (c)	Number. Number. Kest exchangers i. in. Diam (c) Materi Hemispherical Reduus 	. in. Attachan 	A	
 Tubes: Material	ting. Material. () a Spec. No.) be completed for a Spec. No.) weided, Dbi., Si Thickness be Thickness be confided 1 If Postwold 2 List other Shell a	(Kind & Spec. D.D. r inner chambe T.S. (Min. of rem (Min. of rem . T.S. . T.S. Crown X Radius I . T.S. Crown X Radius I 	Dism. No.) 1 a. Thickness Nomin Thickness Nomin Thickness Nomin (You	cherpy impl at temp, of information in the second interval in the second interval in the second interval in the second in the se	in. The UC inclusion or channels of Corrosion Allowance X.R. T.S. Control Corrosion Allowance X.R. (c) (c) (c) (c) (c) (c) (c) (c)	Number. Number. in. Diem 	. in. Attachan 	A	
 Tubes: Material	ting. Material. (a Spec. No.) be completed for a Spec. No.) weided, Dbi., Si Thickness be Thickness be timed (a) used (a) timed (a) for the spec. scified 1 if Postwold 2 List other Shell a Firebox	(Kind & Spec. D_D_e	Mo.) _ 1] a. Thickness arm of jackets Nomin Thickness Nomin Thickness (Yo C	cherpy imper at temp. of int int coin it in for i 125 i	in. The UC inclusion or the set of Corrosion Allowance X.R. T.S. Control Corrosion Allowance X.R. (c) (c) (c) (c) (c) (c) (c) (c)	Number. Number. in. Diam 	. in. Attachan 	A	
 Tubes: Material	ting. Material. (a Spec. No.) be completed for a Spec. No.) weided. Dbi., Si Thickness a Thickness a Thickness a the control (a) a scified 1 If Postwell 2 List other Shell a Firebox Thickne	(Kind & Spec. D_D_t	Dism. No.) 1 a. Thickness Nomin Thickness Nomin Thickness Nomin (Ye C.1	cherpy imperiation of the second seco	in. The UC inclass or tage or channels of Corrosion Allowance X.R. T.S. Conical Apex Angle (c) (c) citient tempor nation the base me	Number. Number. in. Diem 	in. Attachan Typ Typ f. f. f. Efficience No. of Co al. Plat Diameter Char fastoning (Door tic or) Preside cable. 4 and (Cl.], stl. We	A	

1

••

FORM N-1 (back)

. Selety Velve Ormets: Number	Location Unknown
. Wearibe: A . Shop Installed	b) Field Installed Reinforcement How
-Outlet, Drain) Number Diam. or Size Type	Naturial Thickness Hatertal Attached
↓. ﻜઙૢૻ૾ઽ ₩₩Q.a [<u>1</u> .j	5/8 to 7-1/A Integral Welded
) <u>}</u>	
	Top Head Removable
- Threaded, No	
Supports: Skirt. Y.R.S. X. discontinue	Weided-Bottom Hea
Remarka A Service - Nuclear Reactor	Vessel
) Fabrication information: (1)	All plates formed and overlaid at Birr
ham Plant (2) Bottom head sul	baseablier formed and welded ad
Birzinghan and sent to Greenvil	le.for.additional.fabrication
Form Ne2-Attached [3] All nozz	1.00
. girth seems, in the cylindrical	portion, incl. overlay, to be made in
1. (5) Field to machine main close	ure flas. & bottom head
CERTIFICATI	UN OF DESIGN
	ron Co., Birmingham, Alabama
Stress asalysis report on file at LL.C.A.G.A.T.I.d.B.L.L.	con Col
Design apecifications certified by	Prof. Eng
	Prof. Esg. J.es
rtificate of Authorization Expires	Co. By: W. Wagner ships
CERTIFICATE OF	SHOP INSPECTION
	SHOP INSPECTION
VESSEL MADE BY	SHOP INSPECTION Company at Birmingham, Alabama al Bourd Boiler and Pressure Vessel Inspectors and/he the State
	SHOP INSPECTION Company at Birmingham, Alabama al Bourd Boiler and Pressure Vessel Inspectors and/he the State
VESSEL NADE BY Chicago Bridge & Iron i I, the undersigned, holding a valid commission issued by the Nation of	SHOP INSPECTION Company et Birmingham, Alabama al Bould of Boiler and Pressure Vessel Inspectors and/ha the State of Company (1967, and date report on (1967, and
VESSEL NADE BY Chicago Bridge L Iron I, the undersigned, bolding a valid commission issued by the Nation of and employed by S have imposted the pressure vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer	SHOP INSPECTION Company et Birmingham, Alabama al Bould of Boiler and Pressure Vessel Inspectors and/ha the State of Company (1967, and date report on (1967, and
VESSEL MADE BY <u>Chicago</u> Bridge Liron i I, the undersigned, holding a valid commission issued by the Nation of <u>Share inspected the pressure vessel</u> described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels.	SHOP INSPECTION Company et Birmingham, Alabama al Pourd of Boiler and Pressure Vessel Inspectors and the State of Company 1967, and has constructed this pressure vessel in accordance with the ASHE
VESSEL MADE BY <u>Chicago</u> <u>Bridge</u> <u>Liron</u> . I, the undersigned, holding a valid commission issued by the Nation of <u>Browned</u> and employed by <u>MSB</u> have innecessed the pressure vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate neither the Inspector nor his employer r vessel described in this manufacturer's data report. Furthermore, n	SHOP INSPECTION Company et Birmingham, Alabama al Board of Boiler and Pressure Vessel Inspectors and the State of June 1947, and has constructed this pressure vessel in accordance with the ASME makes any warranty, expressed or implied, concerning the pressure either the Inspector nor his amployer shall be liable in any manner
VESSEL MADE BY Chicago Bridge Liron in I, the undersigned, holding a valid commission issued by the Nation of state of the pressure vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate seither the inspector nor his employer r vessel described in this manufacturer's data report. Furthermore, n for any personal infiry or property damage or a loss of any kind aris	SHOP INSPECTION Company et Birmingham, Alabama al Board of Boiler and Pressure Vessel Inspectors and the State of June 1947, and has constructed this pressure vessel in accordance with the ASME makes any warranty, expressed or implied, concerning the pressure either the Inspector nor his amployer shall be liable in any manner
VESSEL MADE BY <u>Chicaco</u> <u>Bridge</u> <u>Liron</u> . I, the undersigned, holding a valid commission issued by the Nation of <u>state that to the best of my knowledge and belief</u> , the manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate seither the inspector nor his employer r vessel described in this manufacturer's data report. Furthermore, n for any personal ignry or property damage or a loss of any kind aris Date <u>19</u>	SHOP INSPECTION Company et Birmingham, Alabama al Board of Boiler and Pressure Vessel Inspectors and the State of June 1947, and has constructed this pressure vessel in accordance with the ASME makes any warranty, expressed or implied, concerning the pressure either the Inspector nor his amployer shall be liable in any manner
VESSEL MADE BY Chicaco Bridde Liron i I, the undersigned, holding a valid commission issued by the Nation of	SHOP INSPECTION Company at Btrmingham, Alabama al Doard of Boiler and Pressure Vessel Inspectors and the State of Boiler and Pressure Vessel In accordance with the ASME thas constructed this pressure vessel in accordance with the ASME makes any verranty, expressed or implied, concerning the pressure either the Inspector nor his employer shall be liable in any manner ing from or connected with this inspection. Commissions MC 2//
VESSEL MADE BY <u>Chicaco</u> Bridge Liron. I, the undersigned, holding a valid commission issued by the Nation of <u>States</u> and employed by <u>SS</u> have innected the pressere vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate seither the inspector nor his employer r vessel described in this manufacturer's data report. Furthermore, n for any personal ignry or property damage or a loss of any kind aris Data	SHOP INSPECTION COMPANY at B2.721.13 ham, Alabama al Board of Boiler and Pressure Vessel Inspectors and/he the State of Company 196.7, and has constructed this pressure vessel in accordance with the ASME makes any warranty, expressed or implied, concerning the pressure either the Inspector nor his amployer shall be liable in any manner ing from or connected with this inspection.
VESSEL MADE BY Chicago Bridge L Iron in I, the undersigned, holding a valid commission issued by the Nation of and employed by S have innected the pressere vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate seither the inspector nor his employer r vessel described in this manufacturer's data report. Furthermore, n for any personal injury or property damage or a loss of any kind aris Data	SHOP INSPECTION Company at Btrmingham, Alabama al Doard of Boiler and Pressure Vessel Inspectors and the State of Boiler and Pressure Vessel In accordance with the ASME thas constructed this pressure vessel in accordance with the ASME makes any verranty, expressed or implied, concerning the pressure either the Inspector nor his employer shall be liable in any manner ing from or connected with this inspection. Commissions MC 2//
VESSEL MADE BY Chicago Bridge L Iron in I, the undersigned, holding a valid commission issued by the Nation of and employed by have inspected the pressure vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate seither the inspector nor his employer r vessel described in this manufacturer's data report. Furthermore, n for my personal injury or property damage or a loss of any kind aris Data	SHOP INSPECTION COMPARY at B2.mi.ngham, Alabama al Board of Boiler and Pressure Vessel Inspectors and/he the State of Control of
VESSEL MADE BY Chicago Bridge L Iron in I, the undersigned, holding a valid commission issued by the Nation of	SHOP INSPECTION COMPANY at B27m1 righam, Alabama al Board of Boiler and Pressure Vessel Inspectors and the State of 19 m.7. and has constructed this pressure vessel in accordance with the ASME makes any warranty, expressed or implied, concerning the pressure either the Inspector nor his amployer shall be liable in any manner ing from or connected with this inspection. Commissions <u>MC</u> National Board or State and No. ASSEMBLY INSPECTION happagrafe Beilar and Pyeasure Veyfel Inspectory and/or the State
VESSEL MADE BYChicago Bridge L Iron f 1, the undersigned, holding a valid commission issued by the Nation of and employed by have immediated the presence vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate seither the impector nor his employer r vessel described in this manufacturer's data report. Furthermore, n for any personal injury or property damage or a loss of any kind aris Date	SHOP INSPECTION COMPANY at B2: mind ngham, Alabama al Board of Boiler and Pressure Vessel Inspectors and the State of 1947, and has constructed this pressure vessel in accordance with the ASME makes any warranty, expressed or implied, concerning the pressure either the Inspector nor his amployer shall be liable in any manner ing from or connected with this inspection. Commissions
VESSEL MADE BYChicago Bridge L Iron f 1, the undersigned, holding a valid commission issued by the Nation of and employed by have immediated the presence vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate seither the impector nor his employer r vessel described in this manufacturer's data report. Furthermore, n for any personal injury or property damage or a loss of any kind aris Date	SHOP INSPECTION COMPANY at BERMIRIGHAM, Alabama al Board of Boiler and Pressure Vessel Inspectors and/the biaste of 1967, and has constructed this pressure vessel in accordance with the ASME makes any warranty, expressed or implied, concerning the pressure either the Inspector nor his amployer shall be liable in any manner ing from or connected with this inspection. Commissions
VESSEL MADE BY Chicago Bridge L Iron in I, the undersigned, holding a valid commission issued by the Nation of and employed by have inspected the pressure vessel described in this manufacturer's state that to the heat of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate seither the inspector nor his employer r vessel described in this manufacturer's data report. Furthermore, n for any personal injury or property damage or a loss of any kind aris Data	SHOP INSPECTION COMPANY at B27m1 rightm, Alabama al Board of Boiler and Pressure Vessel Inspectors and/he the State of 1967, and has constructed this pressure vessel in accordance with the ASME makes any warranty, expressed or implied, concerning the pressure either the Inspector nor his amployer shall be liable in any manner ing from or connected with this inspection. Commissions <u>MC</u> National Board or State and No. ASSEMBLY INSPECTION al Board of Beiler and Pressure Veryel Inspectors and/or the State Mathematical Board of the former of the state Solar State and Pressure Veryel Inspectors and/or the State Mathematical Board of the state of the state Mathematical Board of the state of the state and the described pressure vessel and state that parts referred to as many manufacture that constructed and assertioned this arguer
VESSEL MADE BY Chicago Bridge L Iron I, the undersigned, holding a valid commission issued by the Nation of	SHOP INSPECTION COMPANY at B27m1 rightm, Alabama al Board of Boiler and Pressure Vessel Inspectors and/he the State of 1967, and has constructed this pressure vessel in accordance with the ASME makes any warranty, expressed or implied, concerning the pressure either the Inspector nor his amployer shall be liable in any manner ing from or connected with this inspection. Commissions <u>MC</u> National Board or State and No. ASSEMBLY INSPECTION al Board of Beiler and Pressure Veryel Inspectors and/or the State Mathematical Board of the former of the state Solar State and Pressure Veryel Inspectors and/or the State Mathematical Board of the state of the state Mathematical Board of the state of the state and the described pressure vessel and state that parts referred to as many manufacture that constructed and assertioned this arguer
VESSEL MADE BYChicago Bridge L Iron in I, the undersigned, holding a valid commission issued by the Nation of and employed by have imported the pressure vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessele. By signing this certificate seither the import of the employer of vessel described in this manufacturer's data report. Furthermore, a for any personal injery or property damage or a loss of any kind aris Date	SHOP INSPECTION COMPARY at B27m1.r.gham, Alabama al Board of Boiler and Pressure Vessel Inspectors and/he the State of 1967, and has constructed this pressure vessel in accordance with the ASME makes any verranty, expressed or implied, concerning the pressure wither the Inspector nor his employer shall be liable in any manner ing from or connected with this inspection. Commissions Market Based or State and No. Commissions Market Based or State and No. ASSEMBLY INSPECTION a Based of Basiler and Pressure Verfel Inspector and/or the State Matter de Constructed and side that parts referred to as the described pressure vessel and side that parts referred to as we included in the certificate of shop inspection have be manufacturer has constructed and assessible the pressure by The described vessel was inspected and subjected to a hy-
VESSEL MADE BYChicago Bridge Liron f 1, the undersigned, holding a valid commission issued by the Nation of and employed by have isagested the presence vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate meither the isagector nor his employer r vessel described in this manufacturer's data report. Furthermore, n for any personal inity or property damage or a loss of any kind aris Date	SHOP INSPECTION COMPANY at B27m1 rightm, Alabama al Board of Boiler and Pressure Vessel Inspectors and/he the State of 19 for 7, and has constructed this pressure vessel in accordance with the ASME makes any warranty, expressed or implied, concerning the pressure either the Inspector nor his amployer shall be liable in any manner ing from or connected with this inspection. Commissions <u>MC</u> Netional Board or State and No. ASSEMBLY INSPECTION be Baard of Beiler and Pleasure Veryel Inspectors and/or the State Metional Board of State and No. Assembly inspection have which the described pressure vessel and side that parts referred to as metiof the manufacturer has constructed and assembled this pressure by described vessel was inspected and assigned this pressure which the described vessel was inspected and assigned the pressure which any active the inspected and assembled this pressure by the described vessel was inspected and assigned to a by-
VESSEL MADE BYChicago Bridge L Iron in I, the undersigned, holding a valid commission issued by the Nation of and employed by have imported the preasers vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate seither the import of the manufacturer described in this manufacturer's data report. Furthermore, a for any personal intry or property damage or a loss of any kind aris Date	SHOP INSPECTION COMPANY at B2.7ml.r.gham. Alabama al Board of Boiler and Pressure Vessel Isopectors and/the biate data report on 19 m
VESSEL MADE BYChilcaco. Bridge & Iron.i I, the undersigned, holding a valid commission issued by the Nation of and employed by have inappeted the presence vessel described in this manufacturer's state that to the best of my knowledge and belief, the manufacturer Code for Nuclear Vessels. By signing this certificate seither the inspector nor his employer r vessel described in this manufacturer's data report. Furthermore, a for any personal injury or property damage or a less of any kind aris Date	SHOP INSPECTION COMPANY at B2.7ml.r.gham. Alabama al Board of Boiler and Pressure Vessel Isopectors and/the biate data report on 19 m

2-5b

j

:

	40.0"
--	-------

2-6

FORM N-2 MANUFACTURERS' PARTIAL DATA REPORT A Part of a Nuclear Vennel Fabricated by One Manufacturer for Another Manufacturer An required by the Provinions of the ASME Code Rules 9/3/4
(a) Manufactured byCHICAGO_BRIDGE & IRON_COGREENVILLEPENNSYLVANIA(Name and address of manufactures of part)
(b) Hans/actored for CHICAGO BRIDGE & IRON CO., BIRMINGHA, ABAMA (SEE 3C)
Identification-Hassisterurers Seriel No. of Pert. Reactor Vessel Serial No B4697
(a) Constructed According to Drawing No. 32. & 33
() Description of Portising of Bottom head side place assembly and dollar place () Description of the second side of items 34, 3 & Conly. Remark A) Bottom head hemispherical segment: Machining of edges and select
overlay areas.
B) Dollar plate: Prebore 121 CRD penetrations and 40 incore penetration
C) Assemblies will be shipped from Greenville, Pa, directly to the
field site at Monticello, Minnesota.
this preserve vessed conterns to the ABLE Code for Nuclear Vessels Date <u>ID - 2 19 & R super Chicago Bridge & Iron On Typerand L. Quitel</u> (and a figure of Authorizotion Expires Dec. 31, 1970
CERTIFICATION OF DESIGN
Design infernation on file at Chicago Bridge & Iron Co., Birmingham, Alabama
Bross analysis report on file at Chicago Bridge & Iron Co., Birmingham, Alabama
Design specifications continue by R. L. Call Prof. Eng Yes State Cal aver. No. 1354
Stress malyais report certified by R. F. Reedy Prof. Eng Yes suscill. Roy. No. 62-220
CERTIFICATE OF SHOP INSPECTION
I, the andersigned, holding a valid commission issued by the National Board of Bellyr and Pressure Vegaci Issuestors and/or the State
el
By signing this certificate, asither the inspector nor his employer makes any warranty, expressed or implied, concerning the part de- scribed in this manufacturer's partial data report. Furthermore, asither the inspector nor his employer shall be liable in any masher for any personal injury or property damage or a loss of any kind arising from or consocted with this inspection.
Date 19-63 <u>Or WW uksaw</u> Commissions <u>BA 1762</u> Lasperture Signature National Board or State and Pro.


60 181

						Nominal		orrosion			
Seil:	Materia	.		- T.S	Range 194	Thickness)is, Ä	110 we ce	ta. Di 📾 l	1is. Lee	gthft
-			¥•.)					-			_
30 000 6:	Leng.		*****	E.T. '		A	. R,	·····	ficiency (If Class	¥>	*
	Girda.	2	A N-	1.T.'	<u>۱</u>	X.		N	of Courses	•••••••••••••••	••••••
leads;	(a) X	eteri el X.: Lecelios			T.S	S	(b) Mai	Conical	Homisphorical		Side to Pres
	(Tee.	bottom.	nada) T	hicksess.	Radius	Radius	Ratio	ADex Angle	Radies	Diameter	(Conv. or Con

	•••										
	Lí rem	eveble, I	Dits as of	(Materia	I, Spec. N	o., T.S., Si	se, Number)	Other faster	ing	cribe er stla	aketch)
jacket	Clean	10 :							·····		****
•				Describe	aa egee ai	nd wetd, ba	r, etc. If ber	give dimension	na, if boited, des		• •
-					•		_		Charpy Impact		
					-		t max. temp.		at temps of .		
				be section					<u> </u>		
Tube 1	Deets:	Stations	ry. Nate	rial	h Bac M	Diem	ect to pressu	Dicksess	is. Attackme	at	
		Flack	na Mata	-	•		-	•	is. Attachme		
			-					• • •	in the second		
Tubes:	: Note	rieL)	is.	Thickness	(n gaga. Number.	T	(Br. er U)
											(2011 0 0)
11-14	4 Leci.	te be cas	pleted 10	t imer chi	Bers el)	acteled ve	SBALS, OF CRA	theis of lest	ICA A Cers.		
									•		
.		-1				Neminal		orreside			
Stoll:	Hotos					. Thickness	L 10. A	10	in. Diam f	t _i annia n, Le	Ch R
Sonns:	: Lmc				T 1	-					-
					A	X.	R		Ticiency		7
	-	** ** ********			A	X .1	R,	Ľ	Beioney(If Cie	66 S)	*
	Girth.	•• • •••• ••			T. 1	X.I	R	Ľ	If Cierces	66 8 }	*
	Girth.			 H .'	ד. י	X .1	R		. of Courses		•••••••••
	Girth.			 H .'	ד. י	X .1	R		(If Cle of Courses		•••••••••
Reads	Girth. (a) Ii			H.'	T. '	X. 1 8 uchie El	R (b) 11a Liptical C		of Courses	T.\$ Mat 8	ide to Prosess
Xooda L	Girth. (a) B				T. '	X. 1 8 uchie El	R (b) 11a Liptical C		of Courses	T.S Mat 8	ide to Prosess
Xooda L	Girth. (a) B				T. ¹ T. : 1998 Ea Miss Re	X. : S uchie <u>Si</u> uchie <u>I</u>	R (b) 11a Liptical C		of Courses	Mat S Mat Co	ide to Presser avez or Concev
Heads L (a) 1	Girth. (a) B	isteriaj E Licen, ende			T. ¹ T. : 1998 Ea Miss Re	X. : S uchie <u>Si</u> uchie <u>I</u>	R(b) Ma liptical C Ratio Ap		of Courses Biogherical I Radius Dia	Mat S Mat Co	ide to Presser avez or Concev
Heads L (a) 1 (b) (Girth. (a) B Loostie Pap, hei Chanaol	a teriad a Licen, ende l	Thick		T. '	X.i S uchie E1 adus [R(b) He liptical C Ratio Ap	nical Ia nical Ia nical Ia	of Courses	T.S Mat S motor (Co	ide te Preser avez er Cescav
Heads L (a) 1 (b) (Girth. (a) B Loostie Pap, hei Chanaol	a teriad a Licen, ende l	Thick	II	T. '	X.i S uchie E1 adus [R(b) He liptical C Ratio Ap	nical Ia nical Ia nical Ia	of Courses Biogherical I Radius Dia	T.S Plet Comotor (Co	ide te Presser avez er Cesca
Ecode L (a) 1 (b) (Girth. (a) B Loostie Pap, hei Chanaol	a teriad a Licen, ende l	Thick	II	T. '	X.i S uchie E1 adus [R(b) He liptical C Ratio Ap	nical Ia nical Ia nical Ia	of Courses	T.S Plet Comotor (Co	ide te Presser avez er Ceacev
E-asts [(a) 1 (b) (If res	Girth. (a) Il Loostio Pap, boi Channol movable	istorial n Item, ende i e, bades a	Τπικά 		T. '	X. : S uckie EL odius :	R(b) Her liptical C Ratio Ap-	netical la mical la is Angle	of Courses Mogherical 1 Radius Die . Other fastesing. Impact	T.S Met Co motor (Co 	ide to Prosser avez or Concev r sttach skotch
E	Girth. (a) Il Loostio Pap, boi Channol movable	istorial n Item, ende i e, bades a	Τπικά 		T. '	X. : S uckie EL odius :	R(b) Her liptical C Ratio Ap-	netical la mical la is Angle	of Courses Mogherical 1 Radius Die . Other fastesing. Impact	T.S Met Co motor (Co 	ide to Prosser avez or Concev r sttach skotch
Loods (a) 1 (b) (If res Consti openation	Girth. (a) 18 Loostio Pap, bo Channel movable movable	istorial n Licen, ende i e, balts a for specifies	Thick 	B. Co Beess Ra 	T. ¹	X.: S sockie EL odius I 	R(b) Her liptical C Ratio Ap-	netical la mical la is Angle	of Courses mispherical fi Radius Dia 	T.S Met Co motor (Co 	ide to Prosser avez or Concev r sttach skotch
Loods (a) 1 (b) (If res Consti openation	Girth. (a) 18 Loostio Pap, bo Channel movable movable	istorial n Licen, ende i e, balts a for specifies	Thick 		T. ¹	X.: S sockie EL odius I 	R(b) Her liptical C Ratio Ap-	netical la mical la is Angle	of Courses Mogherical 1 Radius Die . Other fastesing. Impact	T.S Met Co motor (Co 	ide to Proser avez or Concev r sttach skateh
Loods (a) 1 (b) (If res Constitution operation	Girth. (a) 3 Loostla Channel C	atorial a them, and i a, baits a for specif acure 4 caugici	Traine 		T. '	10mp	R	intial	of Courses Meghanical fi Radius Die Other fastening. Impact		ide to Preser avez or Coacev r stisch skotch
Economic (a) 1 (b) (c) If res Conomic operation	Girth. (a) 3 Loostla Channel C	atorial a them, and i a, baits a for specif acure 4 caugici	Traine 		T. '	10mp	R	intial	of Courses Mogherical 1 Radius Die . Other fastesing. Impact		ide to Preser avez or Coacev r stisch skotch
Economic (a) 1 (b) (c) If res Connection operation	Girth. (a) 30 Loostin Pap, hol Chained Maryabic Maryabic Maryabic Maryabic Valve	atorial a them, and i a, baits a for specif acure 4 caugici	Traine 		T. '	10mp	R	intial	of Courses Meghanical fi Radius Die Other fastening. Impact		ide to Preser avez or Coacev r stisch skotch
Economic (a) 1 (b) (c) 1f res Consett openation Safety Nession	Girth. (a) 30 Loostin Pap, hol Chained Maryabic Maryabic Maryabic Maryabic Valve	aterial a theo, and i e, baits a for specif eaure 7 <u>complete</u> Qutiens:	Traine 		T. '	10mp	R	intial	of Courses Meghanical fi Radius Die Other fastening. Impact		ide to Preser avez or Coacev r stisch skotch
Leads (a) 1 (b) (If ref Constitution operation Sefety Maggie Parpes	Girth. (a) 30 Loostin Pap, hol Channel movable moted f ting pro u to be Valve po:	aterial a then, and t e, builts a for specifies auro f Cettoto: t,	Traine 		T. '	10mp	R	intial	of Courses Diophonical I Radius Dio . Other fastening. . Other fastening. . Of . of	T.S Plet 8 motor (Co (Doscribe c	ide to Proser avez or Concev r attach skotch
Loads (a) 1 (b) (If ref Constitution operation selecty Nangio Parpos	Girth. (a) 3 Loontin Cap, bei Chancel Marchiel Marchiel Valve Valve St. Lo (Jalet	aterial a then, and t e, builts a for specifies auro f Cettplois Cutione:	Thick Thick and (a) had Man ber -		T. '	tomp.	R	Necial In enical In is Angle Charpy 07 at tang	of Courses		ide to Proper avez or Coacav r attach skotch bib How Attached
Londo (a) 1 (b) (If res Constit operation operation Safety Nangie Parport Contiet,	Girth. (a) 3 Loontin Cap, bei Chancel Marchiel Marchiel Valve Valve St. Lo (Jalet	atorial a them, and b a, balts a for specif asure 4 Complete Contiene: t, p	Thick Thick and (a) had Man ber -		T. '	tomp.	R	Charpy OF at tens	of Courses		ide to Proper avez or Concav Frattach agoten h-1b How Attached
Economic (a) 1 (b) (c) 1f res Constitution operation solution Parpert Cation,	Girth. (a) 3 Loostle Channel Channel Channel Ing pro Wing pro Waive Sec (In in , Drawn)	aterial a them, and b a, balts t for specif asure 4 <u>cettiplet</u> Qutlets:	Thick Thick and (a) had Man ber -		T. '	tomp.	R	Charpy OF at tens	of Courses		ide to Proper Avez or Concev
Londo (a) 1 (b) (c) If res Consets openal is belief Parper Contiet, 	Girth. (a) 31 Location Pap, boi Channel Marriel Marriel Valve Daile (2010) (2010)	atorial a them, and b a the space of a the space of a the space of a the space of the a the space of the space of the space of the a the space of the space of the space of the a the space of the space of the space of the space of the a the space of the space of the space of the space of the a the space of the space of the space of the space of the a the space of the space of the space of the space of the a the space of the a the space of the a the space of the space	Thick Thick (a) ited (a)	Dian. e	T. '	X.1 SX.1 S	R	Charpy OP at tang Thickness	of Courses		ide te Presser avez er Coacav r attach skotch h-1b How Attached
Lager	Girth. (a) 3 Loostle Channel Channel Ing pro Waive Se (Ja Jo Dank) 	interial interial	Thick Thick and (a) had d far at! Namber 	Dian. e	T. '	X.1	R	Charpy of at tang	of Courses		ide te Preser avez er Ceacav r sttach skotzh hib How Attached
Economic (a) 1 (b) (lf res Constitution operation Safety Nannie Parpor Outlon, 	Girth. (a) 3 Loostle Channel Channel Ing pro Waive Se (Ja Jo Dank) 	interial interial inters, and inters, and int	Thick Thick I	Dian. e	T. '	X.1	R	Charpy OP of temp	of Courses		ide te Presser Avez er Ceacev Frattoch skotch hib How Attached
Londo (a) 1 (b) (c) If res Consets openal is belief Parper Contiet, 	Girth. (a) 3 Loostle Channel Channel Ing pro Waive Se (Ja Jo Dank) 	interial interial inters, and inters, and int	Thick Thick I	Dian. e	T. '	X.1	R	Charpy OP of temp	of Courses		ide te Presser avez er Concav Frattach akotek blb
Langee Constitution If res Constitution Deliver Safety Heaging Parper Outlet, 	Girth. (a) 3 Loostin Pap, hol Chained meted f ting pro to be ting pro Valve pe: pe (30 let , Draus) clean gp:	aterial a theo, and a e, builts a for specif esure 4 Conjection Conje	Thick Thick and (a) had id for all Manber Manber a, No a, No d, No	Dian. e	T. '	X.1 S	R	Charpy Charpy P et tang	of Courses	T.S Plet 9 motor (Co (Describe d 	How Attached
Londa (a) 1 (b) (lf res Consti operation Safety Nazzie Parper Outiet, 	Girth. (a) 31 Lossite Pop, hol Channel movable moted 1 ing pro w to be Valve ps: 	interial interial inters, and inters, and int	Thick Thick and (a) had id far all Number 	Dian. e	T. '	tomp.	R	Charpy Charpy P et tang	of Courses		How Attached
Lange Consti operation Safety Maggie Darper Cutiet, Consti safety Maggie Cutiet, Cutiet, Cutiet, Consti Saper	Girth. (a) 31 Lossite Pop, hol Channel movable moted 1 ing pro w to be Valve ps: 	atorial a them, and b a, bolts a for specif actor 4 complete comple	Thick Thick and (a) had id far all Number 	Dian. e	T. '	tomp.	R	Charpy OP at tens Thickness	of Courses		How Attached

FORM N-2 (.back)

.



SUBJECT - ASME Code, Section III Hydrostatic Test PROJECT - Monticello Nuclear Reactor 9-5624 Type of Vessel - Boiling Water Nuclear Reactor Vessel Material - A533 Class I Grade Firebox Quality Vessel Height - 46'-0" + 1 1/2" T.L. Vessel Diameter - 17'-2 3/8" Base Metal I.D. Shell Thickness - 5 1/16" Min. Design Pressure - 1250 psig at bottom of vessel Design Temperature - 575°F Hydrostatic Test Pressure - 1563 psig at bottom of vessel Design Code - ASME Code, Section III, 1965 edition including Summer 1966 addenda, and the following additions or exceptions: A.--Details governed by analysis only. 1. Main closure flange configuration. 2. Configuration of the skirt attachment knuckle. B.--Application of Code Revisions not covered by the Summer 1966 addenda. 1. ASME SA533 plate material Summer 1967 addenda. 2. Inconel material per Summer 1967 addenda Main closure flange material per code case 1332-3. 3. Studs and nuts material for main closure flanges 4. per code case 1335-2. Main closure flange stud shank transition radius 5. per code case 1366. Bearing stresses for stabilizer brackets per 6. Winter 1967 addenda. Coefficients of Thermal Expansion per Winter 1967 7. addenda. 8. Magnetic particle and liquid penetrant examination per Winter 1966 addenda. Design Specifications -Certified G.E. Specification No. 21A1112, **Rev.** 5 Vessel Manufactured by - Chicago Bridge & Iron Company Vessel Manufactured for - General Electric Company The above vessel was hydrostatically tested according to the rules of ASME Code, Section III, Paragraph N-712. No detectable defects were found. The vessel was built and inspected according to the rules of ASME Code Section III (see above), and complies with the manufacturer's drawings. The vessel is completed except for the certification of the stress report and completion of the final ASME Code, Section III inspections. Signed Hartford Inspector

1-19-69 DATE

2-10

PROJECT Monticello Nuclear Reactor 9-5624

SUBJECT - LEAKAGE TEST

The leakage test of the gaskets in the vessel head closure flanges was performed as specified in procedure DHT-1, Rev.3%. The test was performed in conjuction with the hydrostatic test at design pressure per customer's specification, 21A112, Rev. % Paragraph 10.8.2.

No significant leakage was found in the inner or outer gaskets of the vessel closure flanges.

Signed

Quality Control Inspector

Chilling 1/30/69 for G.E.

DATE

CHICAGO BRIDGE & IRON COMPANY

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: MARCH 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' ID x 63.167 INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. GENERAL ELECTRIC CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: HYDROSTATIC TESTING CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that the above referenced vessel was hydrostatically tested in accordance with the ASME Code, Section III, 1965 Edition, with addenda through Summer 1966 and General Electric Co. Specification 21All12, Rev. 5, Paragraph 10.8 and also approved CB&I procedures CHT-1 Revision I and DHT I Revision 3. (included in Monticello Project Manual Volume II). Furthermore, no significant leakage was detected in the inner or outer gaskets of the vessel and closure head flanges. See attachments.

CHICAGO BRIDGE & IRON COMPANY

arnum

E.E. VARNUM NUCLEAR QUALITY ASSURANCE MANAGER

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. GE CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: RADIOGRAPHIC TESTING CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that radiographic examinations for the above referenced vessel were performed in accordance with the ASME Code, Section III, 1965 Edition, with Addenda through Summer 1966 and General Electric Co. Specification 21All12, Revision 5, Paragraph 10.7 and also approved CB&I Co. and/or suppliers Procedures RTP-1 Rev.2, and advanced products radiographic procedure of finished welds, Rev. 2 (above procedures included in Monticello Project Manual Volume II).

CHICAGO BRIDGE & IRON COMPANY

arnum

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: MARCH 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO,MINNESOTA G.E. Co. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: ULTRASONIC TESTING CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that ultrasonic examinations for the above referenced vessel were performed in accordance with the ASME Code, Section III, 1965 Edition, with Addenda through Summer 1966, and General Electric Co. Specification 21All12 Rev. 5, Paragraphs 10.5 and 10.6, and also approved CB&I Co. and/or suppliers procedures HT-101 Rev. 2, LE-2 Rev. 0, QCP-89 w/addendum Rev.0, TT-2 Rev.1, UTP-1 Rev.3, UTP-2 Rev.1 (same as 9Q-63 Rev.1), UTP-3 Rev.0, UTP-4 Rev.0, UTP-5 Rev.1, UTP-6 Rev.1, UTP-7 Rev.1, UTP-8 Rev.0, UTP-10 Rev.0 and UT-718777 Rev. 0 (above procedures included in Monticello Project Manual Volume II).

CHICAGO BRIDGE & IRON COMPANY

al num

E.E. VARNUM NUCLEAR QUALITY ASSURANCE MANAGER

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' x 63.167' INS.HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINNESOTA GE CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: LIQUID PENETRANT TESTING CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that liquid penetrant examinations for the above referenced vessel were performed in accordance with the ASME Code, Section III, 1965 Edition, with Addenda through Summer 1966, and General Electric Co. Specification 21All12 Rev. 5, Paragraph 10.6, and also approved CB&I Co. and/or suppliers procedures LE-4 Rev.0, PTP-1 Rev.3, PT-71877 Rev.0, advanced products liquid penetrant procedure Rev.1 and TT-4 Rev.1 (above procedures included in Monticello Project Manual Volume II).

CHICAGO BRIDGE & IRON COMPANY

4Marnum

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. G.E. CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: MAGNETIC PARTICLE CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that magnetic particle examinations for the above referenced vessel were performed in accordance with the ASME Code, Section III, 1965 Edition, with Addenda through Summer 1966, and General Electric Co. Specification 21A1112 Rev. 5, Paragraph 10.6 and also approved CB&I Co. and/or supplier's procedures LE-3 Rev. 0, MTP-1 Rev. 4, MTP-2 Rev. 1 (also known as Ladish 143-M), NDT-M-1 Rev. 0 and TT-3 Rev. 1 (above procedures included in Monticello Project Manual Volume II).

CHICAGO BRIDGE & IRON COMPANY

arnum

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. G.E. CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: FINAL CLEANING CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that the final cleaning of the above referenced vessel was performed in accordance with the ASME Code, Section III, 1965 Edition, with Addenda through Summer 1966, and General Electric Co. Specification 21All12 Rev.5 Paragraph 10.8 and also approved CB&I Co. Procedure CP-4 Rev.1 (above procedure included in Monticello Project Manual Volume II).

1. 1. **3**. 1. 1.

CHICAGO BRIDGE & IRON COMPANY

arnum E. VARNUM

NUCLEAR QUALITY ASSURANCE MANAGER

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. G.E. CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: WELDING CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that welding of the above referenced vessel was performed in accordance with the ASME Code, Section III, 1965 Edition, with Addenda through Summer 1966, and General Electric Co. Specification 21All12 Rev. 5, Paragraph 9.3 and also approved CB&I Co. procedures

WPS-1	Rev. 2	WPS-18	Rev. 4	WPS-35	Rev. 1
WPS-2	Rev. 2	WPS-19	Rev. 3	WPS-36	Rev. O
WPS-3	Rev. 0	WPS-20	Rev. O	WPS-37	Rev. l
WPS-4	Rev. 2	WPS-21	Rev. l	WPS-38	Rev. 1
WPS-5	Rev. 0	WPS-22	Rev. l	WPS-39	Rev. 0
WPS-6	Rev. 2	WPS-23	Rev. l	WPS-40	Rev. 1
WPS-7	Rev. 2	WPS-24	Rev. 4	WPS-41	Rev. û
WPS-8	Rev. 0	WPS-25	Rev. 0	WPS-42	Rev. 1
WPS-9	Rev. 0	WPS-26	Rev. 0	WPS-43	Rev. 0
WPS-10	Rev. 0	WPS-27	Rev. 2	WPS-44	Rev. 3
WPS-11	Rev. O	WPS-28	Rev. 5	WPS-45	Rev. 0
WPS-12	Rev. 2	WPS-29	Rev. 1	WPS-46	Rev. 0
WPS-13	Rev. 3	WPS-30	Rev. 2	WPS-47	P v. 0
WPS-14	Rev. 2	WPS-31	Rev. 1	WPS-48	Rev. 0
WPS-15	Rev. O	WPS-32	Rev. 1	WPS-49	Rev. 2
WPS-16	Rev. 2	WPS-33	Rev. 0	WPS-50	Rev. 2
WPS-17	Rev. l	WPS-34	Rev. 1	WPS-51	Rev. 0



		-2-
SUBJECT:	WELDING	CERTIFICATION

WPS-52	Rev. l	WPS-64	Rev. O
WPS-53	Rev. 0	WPS-66	Rev. 0
WPS-55	Rev. 0	WPS-68	Rev. 1
WPS-56	Rev. 0	WPS-69	Rev. 0
WPS-58	Rev. 0	WPS-73	Rev. l
WPS-59	Rev. 0	WPS-74	Rev. l
WPS-60	Rev. 0	WPS-75	Rev. 0
WPS-63	Rev. 0	WPS-77	Rev. 0

(above procedures included in Monticello Project Manual Volume II).

CHICAGO BRIDGE & IRON COMPANY

WW ainum

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. G.E. CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: WELD REPAIR CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that any weld repair done on the above referenced vessel was performed in accordance with the ASME Code, Section III, 1965 Edition, with Addenda through Summer 1966, and General Electric Co. Specification 21All12 Rev. 5, Paragraphs 9.3 and 9.4 and also approved CB&I Co. procedures GRP-1 Rev. 0, GRP-2 Rev. 1, GRP-3 Rev. 3, GRP-4 Rev. 0, GRP-5 Rev. 3, GRP-6 Rev. 0 and GRP-7 Rev. 0 (above procedures included in Monticello Project Manual Volume II).

CHICAGO BRIDGE & IRON COMPANY

Elillarnum_

E. E. VARNUM NUCLEAR QUALITY ASSURANCE MANAGER

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. G.E. CO. P. O. 205-55582-1 4 CB&I CONTRACT 9-5624

SUBJECT: HEAT TREATMENT CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that the heat treatment performed on the above referenced vessel was done in accordance with the ASME Code, Section III, 1965 Edition, with Addenda through Summer, 1966, General Electric Company Specification 21A1112 Revision 5, Paragraphs 8.0 and 9.0 and approved CB&I Company Procedures HTP-1 Revision 1, HTP-2 Revision 1, HTP-3 Revision 1, HTP-4 Revision 1 and HTP-5 Revision 0. Performance of heat treatment of material by suppliers is certified in the mill test reports. This work was performed in accordance with one or more of the following procedures: HLA-1 Revision 1, HT-718777 Revision 0, LE-1 Addendum 1 Revision 0, LE-5 Revision 3, LE-6 Revision 0, LE-7 Revision 1, LE-8 Revision 1, LE-9 Revision 1, LE-12 Revision 0, LS-1 Revision 2, LS-2 Revision 0, TS-1 Revision 0, TS-2 Revision 0, TS-3 Revision 0, TT-1 Revision 1, TT-5 Revision 1, TT-6 Revision 1, CA-1 Revision 1 and CA-2 Revision 1 (all of above CB&I Company and suppliers procedures included in Monticello Project Manual Volume II).

CHICAGO BRIDGE & IRON COMPANY

ruim

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' ID x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. E-4697 MONTICELLO PROJECT, MONTICELLO, MINN. GENERAL ELECTRIC CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: WELD ROD AND WIRE CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that all weld rod and wire used in the fabrication of the above referenced vessel was within the acceptable limits of the ASME Code, Section III, 1965 Edition, with Addenda through Summer 1966, and General Electric Co. Specification 21All15 Rev. 5, Paragraph 8.15 and also approved Chicago Bridge & Iron Company procedures which are included in Monticello Project Manual Volume II.

The types of weld rod and wire used in this contract were as follows:

SA316-E-8018 G SA233-E-7018 SA298-E-308-15 SA371-ER-309ELC SA298-E-309-15 SA371-ER-308L SA298-E-308L-15 SA298-E-308L

SA298-E-308

.

CHICAGO BRIDGE & IRON COMPANY

-2-

SUBJECT: WELD ROD AND WIRE CERTIFICATION

SA298-E-309 SB295-Inco 182 SB304-Inco 82 SB304-ERNiCr-3 SB295-ENiCrFe-3 Linde 40 w/l% Ni or equal.

CHICAGO BRIDGE & IRON COMPANY

arrilin

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: MARCH 11, 1969

REFERENCE: BOILING WATER NUĆLEAR REACTOR VESSEL 17.167' ID x 63.167" INS. HDS. MANUFACTURER'S SERIAL NG. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. GENERAL ELECTRIC CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: CLADDING CARBON CONTENT CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that the cladding has been accepted by General Electric Company as meeting the intent of Specification 21A1112 Revision 5, Paragraph 8.10, and of the contract. Furthermore, the carbon content of the cladding does not exceed 0.08% as specified in the above General Electric Company Specification.

CHICAGO BRIDGE & IRON COMPANY

num. E. E. VARNUM

NUCLEAR QUALITY ASSURANCE MANAGER

2-25

CHICAGO BRIDGE & IRON COMPANY

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' ID x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. GENERAL ELECTRIC CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: WELDER QUALIFICATION CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that all welder qualifications for both shop and field fabrication of the above referenced vessel were performed in accordance with the ASME Code, Sections III and IX, 1965 Edition, with Addenda through Summer 1966, and General Electric Specification 21All12 Rev. 5, Paragraph 9.0. Copies of these qualification records are on file with Chicago Bridge & Iron Company and will be furnished to General Electric Co. upon written request.

CHICAGO BRIDGE & IRON COMPANY

Warnum E. E. VARNUM NUCLEAR QUALITY ASSURANCE MANAGER

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' ID x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. GENERAL ELECTRIC CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: PARKERIZING CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that the Parkerizing performed on equipment supplied with the above referenced vessel was done in accordance with Federal Specification TT-C-490 dated March 30, 1961, titled: "Cleaning Methods and Pretreatment of Ferrous Surfaces for Organic Coatings", this procedure was approved by General Electric Co. for use on this contract, November 28, 1967. Process was performed for Chicago Bridge & Iron Co. by Hayes Aircraft Corporation, Birmingham, Alabama.

CHICAGO BRIDGE & IRON COMPANY

denclon

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' ID x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. GENERAL ELECTRIC CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: MATERIAL CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that the material in the above referenced vessel is in accordance with the ASME Code, Section III, 1965 Edition, with Addenda through Summer 1966, and General Electric Co. Specification 21A1112 Rev. 5, Paragraph 8.0 and also approved Chicago Bridge & Iron Company procedures MS-1 Rev. 0, MS-2 Rev. 1, MS-3 Rev. 3, MS-4 Rev. 3, MS-5 Rev. 1, MS-6 Rev. 1. MS-7 Rev. 2, MS-8 Rev. 0, MS-9 Rev. 0, MS-10 Rev. 0, MS-11 Rev. 2, MS-12 Rev. 0, MS-13 Rev. 2, MS-14 Rev. 0, MS-15 Rev. 2, MS-16 Rev. 1, MS-17 Rev. 1 and MS-MISC.-1 Rev. 1 (above procedures included in Monticello Project Manual Volume I).

CHICAGO BRIDGE & IRON COMPANY

avrillon

LIT NOTZ~MS-Z ASOB CLIT LONG WELD NECK~MS-D SAUSE GR FLOA ū HAND FLANGE - HS-D SAIBS GRF 304 THE WE-MS-I SARSS CLI GRB FOR . TOPHD PLATES-MS-I AS39 CLI GRB-HO4 SHELL FLANGE ~ MS 2 4348 CLI NUT--111 -DENTE HOLD ſ NUT STUD, VASHERS 6 BISHING AMEHI A 340 68.823 - 824 AND CC. (325-2 STUB~ A 516 6270 To 4300 GUER TOD 1007~54 340 TP 30 STUE BELLOWS SECT-ASIG SETO ------METAL P-4516 68 66 Π PUSHING STUM DINTE ~ SA 240 TP 304 STEAM DITLET NOZZ - MS-2 A508 CL II OVERLAT ON MELL C'S INSTRUMETATION NOZZ-M5-13 58 46 -STAB. BRAKT-MS-I SASSS CLI GRB FBX CORE BPRAY BRAKT FEDWATER REDNATE NOZZ-MS-2 ASOB CIT CORE SPRAY-MS-2 ASOB CLI -SAFE END - MS-16 INCONEL THERMAL SLEEVE- A312 TP 304 COM START NOZZ-M3-2 SA 508 CLI SAFE END ~ M5-6 M356 CLF8 THERMAL SLEEVE- SA 312 TP 304 INS SUP BRAKT- SAZ40 TP 304 & SA36 -SHELL PLATE (TYP)-MS-I A533 CLI GRB INSTRUMENTATION NOZZ, MS-13 SB 1667 JET PUMP RISER SUPPORT PAD WELD BUILD-OPS PER WES-27 306% NS. SUR BRAKT- SA 240 TP 304 & SA36 THERMAL SLIEVE SA 312 TP 304 REAL METNOZZ-MS-Z A508 CLI SAFE END - MS-6 SASS CLIB SAFE END-MS-6 SA386 CLE RECIRC OUTLET - MS-2 ASOB CLE SAFE 1 SHROUD SUPPOR M5-17 38 168 TO CC 1336 INCONE BOTTOM HD PLATES -MS-I A533 CLI CORE DIFF PRESS. CURUID CONTROL FORGING~45-2 ASOB CLI SAFE END M3-6 54336 CLP6 SAURT ATTACHMENT - MO-3 A533 CLI GEB VESSEL O -----SKIRT EXTENSION - SA SIG GR TO FOR CRD TUBES- MS-7 INC. NED . DRAIN NOZZ- ASOB CLT a jela la stat

P. O. BOX 13308, MEMPHIS, TENNESSEE 38113

901 947-3111

DATE: March 11, 1969

REFERENCE: BOILING WATER NUCLEAR REACTOR VESSEL 17.167' ID x 63.167' INS. HDS. MANUFACTURER'S SERIAL NO. B-4697 MONTICELLO PROJECT, MONTICELLO, MINN. GENERAL ELECTRIC CO. P.O. 205-55582-I CB&I CONTRACT 9-5624

SUBJECT: FABRICATION TEST PROGRAM CERTIFICATION

TO WHOM IT MAY CONCERN:

This is to certify that the fabrication test program was performed for the above referenced vessel in accordance with Attachment "B" Rev. 3 of General Electric Co. Specification 21All12 Rev. 5, Paragraph 2.0 titled: "Fabrication Test Program" and using specimens cut from plate of same heat as plate used in the vessel. These specimens were cold formed to CFP-1 Rev. 0 which corresponded to the cold forming performed on the plates of the Reactor Vessel.

Paragraph 2.2.3 of Attachment "B" was complied with by submitting "For Information Only" the test reports for 80% T tensile test on Chicago Bridge & Iron Company letter BBE-198 dated 8/9/68. The above test reports were compiled by the University of Illinois. Chicago Bridge & Iron Company took exception to Paragraph 2.2.3.2 of Attachment "B" and subsequently, agreement was reached with General Electric Co. during the meetings held in San Jose, California, August 22 through August 25, 1966, in the following manner:

Page 10 Item G-1

"The 80% T dia. test specimens from as formed plate may come from rolled plate with girth (category B) seam so that separate welded on grips are not necessary. This interprets differently the plate as regards Paragraph 2.2.3.2 of the GE Specification, but Paul Herbert and Bud Vancott (both were in the meeting when this was discussed) agreed that this was acceptable."

-2-


SUBJECT: FABRICATION TEST PROGRAM CERTIFICATION

Attachments:


- 1. CB&I Drawing T-4 Rev. 4, Results of Charpy V-notch impact tests as per Paragraph 2.2.4 of Attachment B.
- 2. CB&I Drawing T-5 Rev. 3, Results of tensile tests as per Paragraph 2.2.2 of Attachment B.

CHICAGO BRIDGE & IRON COMPANY

Marmun







MONTICELLO

EXHIBIT 3

.

TENSILE TESTS SPECIMENS OF 80 PERCENT PLATE THICKNESS

REV 4 12/85

F//-353-

Tensile Tests

Specimens of 80 Percent Plate Thickness

Nuclear Reactor Vessel

GE/APED for Northern States Power Company

Monticello, Minnesota

for

CHICAGO BRIDGE AND IRON COMPANY

Contract 9 - 5624

MONTICELLO AFT - FAN OSE Fr 18:1-353-1

TI

Richard N. Wright, IN Professional Engineer New York License 035399

Department of Civil Engineering University of Illinois Urbana, Illinois January 1968

I. Introduction

Test procedures and results are described for tests conducted for Chicago Bridge and Iron Company of six 80 percent thickness tension specimens for Nuclear Reactor Vessel GE/APED for Northern States Power Company, Monticello, Minnesota. The tests were conducted at the same time as similar tests for Nuclear Reactor Vessel GE/APED for Central Vermont Power Company, Vernon Dam, Vermont. Facilities of the Department of Civil Engineering, University of Illinois, Urbana, Illinois were used in accord with a Memorandum Agreement for Commercial Tests between the Department and the Chicago Bridge and Iron Company. R. N. Wright, Associate Professor of Civil Engineering, supervised the testing. G. K. Sinnamon, Professor of Civil Engineering, and V. J. McDonald, Associate Professor of Civil Engineering and Principal Research Engineer, participated in planning and conduct of the tests.

Instrumentation and test procedures are described in the following section. Test results are described in the last section.

2. Instrumentation and Test Procedures

Test specimens were prepared by Chicago Bridge and Iron Company. Dimensions are given in their drawing T6 Rev I for Contract No. 9-5624 which is reproduced here as Fig. 1. Gage diameter was 4-5/16 in. and gage length 13 in. Specimens were delivered to the Department of Civil Engineering on September 11, 1967 and stored in Talbot Laboratory adjacent to the testing machine until tested during the week of January 8, 1968. Test procedures conformed with ASTM E8 66. Test temperatures ranged from 70 to 75 degrees Fahrenheit.

The testing machine used was the University of Illinois 3,000,000 lb. capacity universal testing machine. Loads were recorded from the load indicator of the machine. Ames dial indicators with .0001 in. divisions were used in measuring elongations from zero load to approximately 1 percent strain; and Ames dial indicators with .001 in. divisions were used from zero load to maximum load. Initial gage lengths and elongations after rupture were measured using a steel scale with .01 in. divisions. Initial gage diameters and diameters after rupture were measured using micrometers with .001 in. divisions.

Figure 2 shows a specimen in place in the testing machine with the dial indicators supported by a split ring and angle device. Diametrically opposed, spring loaded, gage points fit holes 1/16 in. diameter by 1/8 in. deep drilled into the specimens to support the rings. A third gage point between the diametrical ones prevents rocking of the ring. The angles attached to the rings hold the two .001 in. division Ames dials at 4 1/4 in. from the axis of the specimen and the two .0001 in. division Ames dials at 6 1/4 in. from the tached to a similar split ring and angle device. Figure 3 shows indicators in place during loading and the television cameras used to read elongations. Figure 4 shows recording of load from the load measuring system of the testing machine and recording of elongations from closed circuit television receivers.

During the first two of the six tests, SR-4 electrical resistance strain gages were used to measure strain prior to yield in order to check upon the accuracy of the dial indicator system. SR-4 gages showed slightly greater strain during the first loading increment (50 to 100 kips) than the dial indicators; thence to yield essentially identical changes in strain were

recorded by the two procedures. The discrepancy in the initial increments is attributable to reseating of the gage points supporting the dial indicators following the reversal ~f strain direction during the preliminary steps of loading described below. Only strains obtained from elongation measurements with the dial indicators are reported here.

Preliminary steps of the testing consisted of centering the specimen in the upper head of the machine, recording initial elongations at zero load, fastening the lower head of the specimen and loading to 100 kips to set the grips, reducing load to 50 kips and reading elongations which were used as base values in reducing stress-strain data. Elastic range loading began with increase of load to 100 kips and reading of elongation, followed by increase of load and elongation reading in 100 kip increments. Upon noticeable yielding, a slow deformation rate was maintained, load and elongation were recorded at intervals of approximately .01 in. elongation until pronounced strain hardening at an elongation of about .1 in. Then load was reduced and the .0001 in. dial indicators were removed. Continuous deformation was resumed; load and elongation were recorded at intervals of about .05 in. elongation until maximum load was observed. Dial indicators were then removed from the specimen and it was deformed to rupture. In the first two tests somewhat fewer readings were made in the postyield range. In the inelastic range to maximum load, strain rate did not exceed .01 in./in./minute. In the elastic range stress rate did not exceed 10,000 psi/minute.

In the first test the lower ring came loose twice during the postyield range of testing. The deformed gage length was measured to 0.01 in. accuracy after the dial indicators were removed at maximum load. This measurement provided a basis for computing strains from dial readings for the majority of the postyield region; a small region of uncertainty is shown by dotted lines in Fig. 5. The cause of the loosing of the lower ring was improper spring

loading of the gage points. One more loosening of the lower ring occurred in the process of obtaining proper adjustment. It was in the second test, Fig. 6, at a stress of 81.9 ksi. It was determined that dial readings were not substantially affected by the loosening and replacement.

3. Test Results

Test results are summarized in Table 1. Shown for each specimen are: stress-strain curves, Fig. 5 through 10; photographs of the two fracture surfaces, Fig. 11 through 16; and photographs of the broken specimens with fracture surfaces fitted together, Fig. 17 through 22. Specimens are identified by the numbers provided by Chicago Bridge and Iron Company and an "OT No." assigned by the writer to facilitate identification of individual tests and specimens.


Table 1 shows that test results meet tensile requirements of ASTM A 533, Grade B, Class 1 steel. The elongation in 13 in. is not directly comparable to the standard elongation in 2 in. for a 1/2 in. diameter specimen. Larger elongation is observed because the gage length is only three times the diameter for these specimens. If, however, an additional 4-5/16 in. of gage length were considered to be present and to elongate by the 10 percent uniform strain typical of Fig. 5 through 10, the elongation in 17-1/4 in. would in every instance exceed 20 percent.

Welded specimens, denoted by T3-2X, showed substantially the same properties as the unwelded. It is apparent in Fig. 20 through 22 that fracture of the welded specimens was ductile and occurred in the base metal well away from the weld. A clear indication of weld yielding at a stress of 67 ksi appears in Fig. 10. Possible weld yielding at 64 ksi is suggested by the stressstrain curve shown in Fig. 9; for the stress-strain curve of Fig. 8, yielding of base metal and weld appears to have occurred simultaneously.

TABLE 1. SUMMARY OF TEST RESULTS

Specimens 5624 A 0998 2	Yield Strength ^a ksi	Tensile Strength ksi	Elongation in 13 inches percent	Reduction in Area percent
<u>T3-2</u>				
0T I	63.0	84.4	28.3	61.2
OT 2	62.0	84.2	25.8	61.1
OT 11	61.3	83.1	23.7	62.4
<u>T3-2X</u>				
OT 5 .	65.8	85.6	25.9	61.0
от 8	63.7	83.6	26.7	60.9
OT 9	64.8	84.5	25.8	58.9

^aYield strength at 0.2 percent offset.



3-8

)




FIGURE 2. Specimen with Elongation Instrumentation






FIGURE 3. Television Camera for Reading Elongation













FIG. 5 SPECIMEN 5624 T3-2 A0998 2 0T I





3-12












3-15

•



Stress, isx




FIGURE 11. Fracture Surfaces, 5624 T3-2 A0998 2, OT 1






FIGURE 12. Fracture Surfaces, 5624 T3-2 A0998 2, 0T 2








FIGURE 14. Fracture Surfaces, 5624 T3-2X A0998 2, 0T 5





FIGURE 15. Fracture Surfaces, 5624 T3-2X A0998 2, 0T 8






FIGURE 17. Fractured Specimen, 5624 T3-2 A0998 2, OT 1




FIGURE 18. Fractured Specimen, 5624 T3-2 A0998 2, 07 2




FIGURE 19. Fractured Specimen, 5624 T3-2 A0998 2, 0T 11




FIGURE 20. Fractured Specimen, 5624 T3-2X A0998 2, 0T 5




FIGURE 21. Fractured Specimen, 5624 T3-2X A0998 2, 0T 8




FIGURE 22. Fractured Specimen, 5624 T3-2X A0998 2, OT 9

PURCHASER 10. Chicag Bit. G.	r1đ Put	Revised Bridge & Ir Putman, P.A	sed Copy	Revised Copy 12-20-b6 Revised Copy 1-9-67 Revised LUKENS STEEL COMPANY Ge & Iron Co. TEST CERTIFICATE Man.P.A.	-bú Re	vised LUKE	Copy NS STE cont TEST CU	Copy 1-9-67 Re VS STEEL COMP COMPANIE, A. TEST CERTIFICATE	Revis MPAN ATE	Y Cooy 2	CCOL 2-1-UT ICVIECD COPY 3-3-57 ATTI: DATE 11-26-66 FILE NO 1 CONSIGNEE	scil Cop	У 3-3-57 File No.]	۲ 154 3
P.O. Box 27 Birmingham,	lox 277 Igham	Ala.	35202	· ·	HIL ORDER 140. 43211-1	1-1	εŋ Γ	сиsтомки r .o. 5624 ^{- 4}	ц С Щ	MB 112166 EM	M Boyles,	es, Ala,	-	
SPECIFICATIONS: A-533-	ATIONS: A-533-65 Gr.B	1	Class 1 Mod.by		C.B.&]	I. Spe	sc. MS	-1 DTD	8/25/1	Spec. MS-1 DTD 8/25/66 Fbx. 8	80000 Co	cont.# 9-5624	-5624	
BEND TEST	0.K.	HOMOG	HOMOGENITY TEST	0.K.										
					U	<u>CHEMICAL</u>	ICAL	ANAL	ANALYSIS					
MEIT NO.	52. 55.	ми 1.35	• 010	5 015	3	23. s	ź.o	5	Mo 47	11	V.I.P.Stee	6	5	1ze 8
8660W	50	1.27		110		18	18		6		=		T#7 B#8	8
. 		•												
. .									• .					
					- H d	HYSIC	CALP	PROPERTIE	RTIES					
MELT NO.	SIAB NG:	AFED 7510	TENSILE PSI R100	E PONG	XIX	NHe	V-Note	V-Notch +10°F.	F.			DESCRIPTION	110 N	
c1946	: :	4L3	914 848	26			56	55	52 ·		x 061-1	86 x 6-1/4"	1/4"	
A0998	N	626	873 864	27			51	37	45		1-300 x 120 x 6-1/4"	120 x 6	"#/[-	
Two Surface		Drop Weight	test	a sat	1sfactory	y at	+10•F							
Plates heated 1625-1675 F., held 1 400 F. by holding in water for at 1 then tempered 1200-1250 F., held 1	ted 16 holdin red 12	55-167 11 we	ter f	held l br at l held l	hr. east hr.	r 1/2	чач	per per	Jater quenc inch of th itr copled.	guenched t of thickne. pled.	b unde Allirmed and subscribed before me bs. 1967 19 this day oMAR 3 1967 19	ted and si day old AR	ubscribed 1 1 3 1967	before me
64°F per hr. to 1125-1176 rate of to 80°F, per hr.	Reto	per hr	T75 F	held beld	50 hre	- - - - - - - - - - - - - - - - - - -	- F 4	leating to e c		uthin a rate	E	17 191	Coma	hillip A. Bomanding P.
not longer	than]	hr. p	er 1nch	of	hickness				apa neug		MP Commissi	MF Commission Expires Azı 1 1961	Not:	Notary Public
Mill inspection	·	by Chicago		Bridge &	Iron									ok Huw
We here by certify the above figures are correct as contained in the records of the company.	fy the abo	ve figure:	s are cori	ect as cor	tained in	the rec	ords of th	ne compa	۲۰	SUFERV	SUFENISOE FESTING	04.0	X len	ne.
														(

)






NOU-DESTRUCTIVE TESTICO REPORT


CORRECTED COPY	INSPECTION DEPART	INSPECTION DEPARIMENT CORRECTED COPY	2
CUSTOMER	MILL OKDER NO.	TYPE 1651	DATÉ
CHICAGO BEIDGELTEON CO.	1-11227-2751	国についるというとの	1-2-1-60
P.0. Bax 277	QUALITY SUG. 1-0LY	SPECIFICATION	
	0,000	195ME SEC. 3 CODE CASE 1335-2 ALT2	SE 1335-2 ALT2
	CUSTOMER NO.	EQUIPMENT USED	
	5624 34664 2	SPEERY UNTEL REFLECTOSCOPE	「日にようちにのや日」
CONSIGNED TO	SEARCH UNIT		CCUPLANT
CHICHEO CHIDER + TEAN CO.	1		J YORD +WATED
	TRANSDUCER	GAID KEF.	TYPE OF SURACE
SOULES HIRA.	こ アカトロの戸 ぞれが出	S. S. P. C. H.	3LASTED
-	INSPECTORS NAME & QUALIFICATIONS	SIZE	
	二 1, 1, 0, 4, 5,	1-300 × 120× 674	J
	WITNESSED BY	MELT & SLAB	MARK
•		1-0000-5	

	TOP	En	Ø					
				Ŷ		<u> </u>	2 Ke Head	
						1. 3. 0. 4	ca l	
-			,		- 62 - 62	24 N	To%	Ci.
				-63.1	23-			C. F. Q. D.
								CC: INVICE
				1655 L 30			····>	
 -								1
			· 			· · ·		
								IHE BEST
								IS CORRECT TO TH
								THE ABO
 						- <u>-</u>	~~~>	CERTEY THAT THE AEO MOWLEDGE AND BELIEF
						- 13 X 		
				6	<u><u> </u></u>		*	I HEREEY OF MY I


.

.





•




, ,


.

.

••



/ 、



MONTICELLO

•

;

EXHIBIT 4

SUMMARY STRESS REPORT

REV 4 12/85

Summary Report

Monticello--NSP Reactor Vessel

CB&I Contract 9-5624

MONTICELLO 1 - 339·/ 2-1-1 Ì .

General Electric P. O. No. 205-55582-I Reactor

SUMMARY REPORT INDEX

MONTICELLO NUCLEAR REACTOR

Page 2

2	Introduction
3	Main Closure Flange (S-1*)
3 7	Main Closure Flange (T-1*)
7	Skirt Junction (S-2)
7	Skirt Junction (T-2)
8 8	Shroud Support (S-3)
8	Shroud Support (T-3)
12	Feedwater Nozzle (S-4)
12	Feedwater Nozzle (T-4)
14	Control Rod Drive Penetration in Bottom Diameter Dollar Plate(S-5)
14	Control Rod Drive Penetration in Bottom Diameter Dollar Plate(T-5)
16	3" Ø Control Rod Drive Hyd. Return Nozzle (S-6)
16	3" Ø Control Rod Drive Hyd. Return Nozzle (T-6)
18	Core Spray and Flooding Nozzle $(8" \phi)$ (S-7)
18	Core spray and Flooding Nozzle $(8" \phi)$ (T-7)
20	Recirculation Inlet Nozzle $(12" \phi)$ (S-8)
20	Recirculation Inlet Nozzle $(12" \phi)$ $(T-8)$
22	Recirculation Outlet Nozzle (36×28) $(S-9)$
22	Recirculation Outlet Nozzle (36 x 28) (T-9)
24	18" Ø Steam Outlet Nozzle (S-10)
24	18" ø Steam Outlet Nozzle (T-10)
26	Core Differential Pressure and Liquid Control (S-11)
26	Core Differential Pressure and Liquid Control (T-11)
26	Instrumentation Nozzle (6" Ø) (S-12)
26	Vent (4" ø) (S-13)
27	Instrumentation Nozzles (4" ø) (S-14)
27	Jet Pump Instrumentation Nozzles (4" ø) (S-15)
28	Refueling Bellows (S-16)
28	Refueling Bellows (T-16)
30	Stabilizer Brackets (S-17)
32	Brackets (S-18)
33	Main Shell Stress Analysis (S-19)
34	Miscellaneous Stress Analysis (S-20)

"Sl" indicates a stress analysis and "Tl" indicates a thermal analysis.

Monticello Project - Reactor _______ Cont. 9-5624 Dot 3-7-69 DGJ Subject_ GO 64 OB Checked by____Date____Rev.No.____Date____Rev.No.____Date_____Date_____Date_____

4-3

34

Rev.No._

Dute

OAK BROOK ENGINEERING

CHICAGO BRIDGE & IRON COMPANY

Subject

SUMMARY REPORT--INTRODUCTION SUMMARY OF THE MONTICELLO STRESS REPORT

The stress analysis for the Monticello Reactor Vessel has been performed in accordance with the General Electric Purchase Specification 21All12, Rev. 5 and Section III of the ASME Code. The stress report has been certified by a registered professional engineer who is experienced in pressure vessel design.

The following paragraphs summarize the stress results for the various components of the Monticello Reactor Vessel. For each component, the calculated stress intensities for each stress category, primary membrane stress intensity, local membrane plus bending stress intensity and primary plus secondary stress intensity range, are compared with the appropriate Section III, ASME Code allowables. The specified fatigue cycles and Code allowable cycles are given wherever appropriate. This Summary Report is being submitted as required in Paragraph 6.8 of the General Electric Purchase Specification mentioned above.

By All

_ Rev.No._

Cont. 9-5624 Date___

Rev No. ____ Date____

SUMMARY OF STRESS ANALYSIS FOR MAIN CLOSURE FLANGES

The stress analysis for the main closure flanges and the studs was conducted in accordance with requirements of GE Design Specification No. 21Alll2, Rev. 5, dated 9-30-68. Temperature distributions used in this analysis are presented in Section Tl of the stress report.

The minimum required stud cross-sectional area, per ASME Code, Section III, Article I-12, was found to be 1177.14 square inches (page I-S1-7). This was based on an allowable stress $S_m = 36,325$ psi at 575°F. The actual crosssectional area, provided by 64 studs with 5-1/16 inch shank diameter and 7/16" extensiometer hole, is 1278.61 square inches. The average and maximum stud service stresses (per ASME III - N-416.1) were found to be critical during startup at 270 minutes into the transient, with their respective magnitudes being 47,929 psi and 89,824 psi (page I-S1-84). The average stud temperature at this time is 340°F. Allowable stresses at this temperature are 2 $S_m = 79,280$ psi for the average stress and 3 $S_m = 118,920$ psi for the maximum stress.

The stud fatigue anlaysis was performed in accordance with Par. N-416.2 of ASME Code, Section III. The peak stress intensity ranges were computed at the root of the thread using a fatigue strength reduction factor of 4. The cumulative usage factor was found to be 0.5637 which is well within the allowable of 1.0 (page I-S1-100).

0....

0 ... NA

MONTICELLO REACTOR VESSEL

B M ...

Subject_

. . .

____ Cont. <u>9-5624</u> Date_____By_<u>AEE</u>_Stat_<u>3</u> of <u>34</u>

Rev.No. Date

D-+=

The basic stress intensities in the main closure flanges and the adjacent top head and cylindrical shell per ASME it, Section III, N-414, are as follows: the maximum primary membrane stress intensity in the top hemispherical head is due to preload plus pressure loading at 1250 psi and occurs 4.379 inches above the flange transition section. Its magnitude is 28,620 psi (page I-S1-64). Due to the influence of the head to flange discontinuity it is classified as a local primary membrane stress intensity. It is seen to be less than 1.1 S_m = 29,370 psi.

The maximum primary plus secondary stress intensity range occurs during the startup transient at the hemispherical head to top flange junction, and has a magnitude of 55,320 psi. The allowable stress intensity range in this case is $3 S_m = 80,100 psi$.

The maximum primary membrane stress intensity in the cylindrical shell below the shell flange is 29,560 psi (page I-S1-65). This stress intensity is due to the preload plus pressure loading at 1250 psi, and is located 15 inches below the cylinder to shell flange junction. As the width of the band in which 1.1 $S_m = 29,370$ psi is exceeded is 8.2 inches, and the allowable width is $.5\sqrt{Rt} =$ 11.746 inches, this stress intensity is classified as local. For the location of the above stress intensity band see the attached sketch. The allowable stress intensity for local primary membrane stress intensity is 1.5 $S_m =$ 40,050 psi.

The maximum primary plus secondary stress intensity range in the shell flange is 47,110 psi (page I-S1-67). It

_ Cont. <u>9-5624</u> Date_____

Date

By<u>AEE___Sht_4__of__</u>


_ Rev.No._

CHICAGO BRIDGE & IRON COMPANY

occurs during the startup transient and is located on the outside of the shell flange to cylindrical shell junction. The allowable stress intensity range in this case is 3 $S_m = 80,100$ psi.

It was found that all the requirements of the ASME Code, Section III, Par. N-415.1 could be satisfied for the main closure flanges, and therefore no fatigue analysis of the same is required.

Subject_	MONTICELLO	REACTOR VI	ESSEL	Cont. <u>9-5(</u>	524 Date	<u>ву АЕЕ</u>	sh: <u>3</u> <u>34</u>
	-	–	• ••	0 N.	Data	Rev.No.	Octe



<u>KM shr 7 at 34</u>

4-9

SUMMARY OF STRESS ANALYSIS FOR SUPPORT SKIRT AND ITS JUNCTION TO BOTTOM HEAD

Using the data contained in the contract specifications and temperatures calculated in Section T2, the stress analysis has been done in Section S2.

The maximum value of seismic stress along the support skirt is 2623 psi. The maximum local membrane and bending primary stress intensity occurs at the inside point of the skirt-tobottom head junction and has a value of 10,625 psi. The Code allowable at design temperature for the sum of all primary stresses is 1.5 $S_m = 40,000$ psi.

The value of the maximum range of primary plus secondary stress intensities, which also occurs at inside point of the junction, is 55,580 psi. The Code limits this range to 3 $S_m = 80,000$ psi.

The same point is also most critical from a fatigue standpoint. The conservatively calculated value of the fatigue usage factor at this point is 0.40.

MONTICELLO REACTOR VESSE

SUMMARY OF RESULTS - STRESS ANALYSIS OF SHROUD SUPPORT

The static analysis of Subsection C of Section S3 indicates that all cous requirements for the secondary membrane plus bending combined with local membrane, local and general primary membrane and also primary bending stress intensities, have been met. The maximum secondary membrane plus bending combined with local membrane stress intensities of 23,970 psi occurs at point 5 of the main shell (see page S3-57), and 26,099 psi occurs at point 17 of the shroud. Both of these stresses are below allowables of 3 $S_m = 80,000$ psi and 3 $S_m = 70,000$ psi respectively (see Figure 1).

Local membrane stress intensities of 15,555 psi at Section 7-8 and 15,575 psi at Section 17-18 are also within the allowable limits of 1.5 $S_m = 40,000$ psi and 1.5 $S_m =$ 34,950 psi. Primary bending plus membrane and general primary membrane stress intensities are 26,740 psi at point b and 26,585 psi at Section a-b on the main shell which are below the allowable of 1.5 $S_m = 40,000$ psi and $S_{m} = 26,700$ psi. This also holds for internals with maximum primary membrane stress = 7,910 psi at point c and primary general membrane stress = 7,750 psi at Section c-d for Inconel material for which allowables are 34,950 psi and 23,300 psi respectively (see Figure 1).

Subsection C of Section S3 also shows that the stilts which support the shroud will not buckle under the most critical compressive load.

Day No

Charlend by

n-••

Rou Na.

Cont. 9-5624 Date___ ____ Rev.No.____

Date

_ Date

Rev.No.

CHICAGO BRIDGE & IRON COMPANY

Checked by

Date_

Stress intensity calculations of Subsection E of Section S3 show that maximum range of secondary membrane plus bending stress intensity for carbon steel is 62,100 psi at point 13, which is less than the allowable of 3 $S_m = 80,000$ psi, and Inconel material for the internals is 58,924 psi at point 30, also within the allowable of 3 $S_m = 70,000$ psi (see Figure 2).


Stress analysis of the jet pump baffle plate was performed at the junctions to the main shell and shroud support. Results are listed under Subsection F for static loading and transients considered. The results in the static analysis show that local membrane stress intensity is 17,327 psi at Section 3-4 and secondary membrane plus bending combined with local membrane stress intensity is 19,229 psi at point 3 within the allowables of 1.5 S_m = 34,950 psi and 3 S_m = 70,000 psi respectively. Results of loading plus transients stress analysis show maximum range of stress intensity of 63,656 psi at point 3 which is also below the allowable of 3 S_m = 70,000 psi (see Figure 2).


Fatigue analysis performed under Subsection G shows a permissible number of 4000 cycles and the usage factor of .064 for point 7 based on stress results of Subsection E and 20,000 cycles and the usage factor of .012 for point 3 based on Subsection F (see Figure 2).

ubject___MONTICELLO_REACTOR_VESSEL_____Cont. <u>9-5624</u> Date_____By_JT___Shr_9

Date







Rev No. Date

OAK BROOK ENGINEERING

SUMMARY OF STRESS ANALYSIS FOR FEEDWATER NOZZLE

Using the loadings contained in the contract specification and temperatures calculated in Section T4, the stress analysis has been performed in accordance with Article 4 of Section III of the ASME Code.

The area replacement requirements of Article 4 have been satisfied. The calculated maximum general membrane stress intensity for the safe end is 18,200 psi (page S4-10) compared to the allowable, at 575°F, of 18,200 psi. For the nozzle forging, the calculated maximum general primary membrane stress intensity is 14,218 psi compared to the allowable of 26,700 psi.

The maximum local membrane and bending stress intensity due to design pressure plus nozzle loads is 22,580 psi (page S4-10) at section AA on the attached sketch. The allowable stress intensity is 1.5 $S_m = 27,300$ psi.

The maximum ranges of primary plus secondary stress intensity are 26,540 psi on the inside of section DD and 59,600 psi on the inside of section CC for the safe end and nozzle forging respectively. (See pages S4-35 and S4-33.) The Code allowable ranges are 56,040 for the safe end material and 80,100 psi for the forging.

The allowable number of fatigue stress cycles is 1760 versus a specified number of 1500.

<u>, By_JH</u>


Pau Na

Subject.

GO 64 0B

Checked by

OAK BROOK ENGINEERING



By MSM

Cont. 9-5624 Date

MONTICELLO REACTOR

Subject_


"bookod b.

SUMMARY OF STRESS ANALYSIS CRD PENETRATIONS

The maximum primary plus secondary stress intensity in the stainless steel housing is 38,408 psi compared to an allowable of 3 S_m (= 52,800 psi), at point 1. The maximum value for the Inconel stub tube is 58,351 psi at point 2 against an allowable of 3 S_m (= 60,000 psi).

The maximum alternating stress intensity occurs at point 3. This value is 79,634 psi. The allowable number of cycles from the applicable design fatigue curve is 2900 against 370 specified cycles.

The points referred to above are shown in the sketch on the following page. The sketch shows an outermost penetration which is found to be more critical than the center penetration.



OAK BROOK ENGINEERING

GO 64 OB Checked by_____Date____Rev.No.____Date____Rev.No.____

_____By___MSM___Sh, 16 ;; 34

__ Date

____ Rev.No. _____

Cont. 9-5624 Date___

Date

Pau Na

SUMMARY OF STRESS ANALYSIS 3" CRDHSR_NOZZLE

In the safe end area, the maximum primary plus secondary stress intensity of 44,320 psi occurs at point 3, against an allowable of 48,000 psi at design temperature.


In the nozzle forging, the nozzle vessel junction (point 19) is the highest stressed point. Based on the stress index method, the maximum pressure stress intensity is 88,100 psi. To this is added the thermal stress intensity at steady state, which is 38,841 psi, giving a peak stress intensity range of 126,951 psi and an alternating stress amplitude of 63,475 psi, which gives an allowable number of cycles of 2000 against an expected 782 cycles, based on the applicable design fatigue curve.

The points referred to above are shown in the sketch on the following page.

MONTICELLO REACTOR VESSEL

Subject_

OAK BROOK ENGINEERING



4-19

Subject MONTICELLO REACTOR VESSEL O 64 OB Checked by___

Rev.No.

Date____

_____Date_

Doto 3/5/69 By MSM shr 17 of 34 . Cont.

_ Rev. No. _____ Date ___ __ Rev.No._ Date .

OAK BROOK ENGINEERING

SUMMARY OF STRESS ANALYSIS for CORE SPRAY NOZZLE

Using the data contained in the contract specifications and temperatures calculated in Section T7, the stress analysis has been done in Section S7.

The calculated maximum general membrane primary stress intensity, for the safe end, is 14,050 psi (page S7-7) compared to the allowable, at 575°F design temprature, of 23,300 psi. For the nozzle, the calculated maximum general membrane primary stress intensity is 12,550 psi (page S7-8) and the allowable at design temperature is 26,700 psi.


The maximum local membrane and bending primary stress intensities are 24,783 psi, 2,656 psi, and 11,123 psi for the safe end, sleeve and nozzle respectively, (page S7-86). The allowables for corresponding materials in the same order are 35,000 psi, 23,700 psi and 40,000 psi.

The maximum range of primary plus secondary stress intensities are 28,262 psi, 29,445 psi and 8,157 psi at points 8, 22 and 31 respectively, (page S7-92). These points are located on the safe end, sleeve, and nozzle, in that order; with respective allowables of 70,000 psi, 47,400 psi and 80,000 psi.

The most critical point from the fatigue standpoint is point 11. The conservatively calculated value of the fatigue usage factor at this point is 0.52.

(Points referred to above are shown on the sketch of the following page.)

20010609	ELLO	REACTOR	VESSEL	c56	24 Date 3/	/3/69 KM	_Shr_18 of 34	-
 Charled hu	Date:	Dav Na	Data	D N.	n -+-	Dav Na	D-+-	



CORE SPRAY NOZZLE

Subject MONTICELLO REACTOR VESSELCont. 9-5624 Date 3/3/69 By KM Shr 19 of 34

OAK BROOK ENGINEERING

Date ...

SUMMARY OF STRESS ANALYSIS for RECIRCULATION INLET NOZZLE

Using the data contained in the contract specifications and temperatures calculated in Section T8, the stress analysis has been done in Section S8.

The calculated maximum general membrane primary stress intensity, for the safe end, is 12,900 psi (page S8-4) compared to the allowable, at 575°F design temperature, of 15,800 psi. For the nozzle, the calculated maximum general membrane primary stress intensity is 16,600 psi (page S8-5) and the allowable at design temperature is 26,700 psi.

The maximum local membrane and bending primary stress intensities are 17,107 psi (page 58-9) and 23,488 psi (page 58-11 for the safe end and nozzle respectively. The allowables for corresponding materials in the same order are 23,700 psi and 40,000 psi.

The maximum range of primary plus secondary stress intensities are 33,670 psi (page S8-30), 47,830 psi (page S8-33) and 43,550 psi (page S8-31) at points 4, 9 and 6 respectively. These points are located on the safe end, sleeve and nozzle, in that order; with respective allowables of 47,900 psi, 47,900 psi and 80,000 psi.


The most critical point from the fatigue standpoint is point 8. The calculated value of the fatigue usage factor at this point is approximately .003.

(Points referred to above are shown on the sketch of the following page.)

	MONTI Subject	CELLO R	EACTOR	VESSEL	 Cont. 9-56	24 Date	в <u>у_КМ</u> si	h, <u>20_</u> s/ <u>3</u>	; <u> </u>
64 OR	Chacked hv	Data	Rav. No.	Date	 Rev.No.	Date	Rev.No.	Date	

OAK BROOK ENGINEERING

CHICAGO BRIDGE & IRON COMPANY



OAK BROOK ENGINEERING

SUMMARY OF STRESS ANALYSIS FOR RECIRCULATION OUTLET

Using the loadings contained in the contract specification and temperatures calculated in Section T9, the stress analysis has been performed in accordance with Article 4 of Section III of the ASME Code.

The area replacement requirements of Article 4 have been satisfied. The calculated maximum general membrane stress intensity for the safe end is 13,806 psi (page S9-36) compared to the allowable, at 575°F, of 15,800 psi. For the nozzle forging, the calculated maximum general primary membrane stress intensity is 12,261 psi compared to the allowable of 26,700 psi.


The maximum local membrane and bending stress intensity due to design pressure plus nozzle loads is 14,777 psi at section AA on the attached sketch (page S9-37). The allowable stress intensity is $1.5 S_m = 23,700 psi$.

The maximum ranges of primary plus secondary stress intensity are 26,540 psi on the inside of section BB and 36,700 psi on the inside of the same section at the safe endnozzle forging junction. See page S9-19 of the report. The Code allowable ranges are 47,400 for the safe end material and 80,100 psi for the forging.

The Code allowable number of fatigue stress cycles for the maximum stress amplitude is 41,720 compared with the 400 cycles specified.

64 08

OAK BROOK ENGINEERING



OAK BROOK ENGINEERING

CHICAGO BRIDGE & IRON COMPANY

MONTICELLO

Subject____

REACTOR

SUMMARY OF STRESS ANALYSIS 18" STEAM OUTLET NOZZLE

The maximum primary plus secondary stress intensity in the safe end is 11,924 psi at point 1 against an allowable of 57,450 psi (3 S_m at design temperature).

In the nozzle forging, the nozzle-vessel junction is the highest stressed point (point 13). Based on the stress index method, the maximum pressure stress intensity is 88,100 psi. To this is added the maximum thermal stress intensity of 19,592 psi and the additional stress intensity due to the pipe reactions at the point which is 10,919 psi, giving a total peak stress intensity of 118,621 psi and an alternating stress amplitude S_{alt} of 59,310 psi. This gives an allowable number of cycles of 2500 which is more than the expected 532 cycles.

The points referred to above are shown in the sketch on the following page.

Cont. 9-5624 Date

Ç.

Date.

GO 64 OB Checked by_


2

Rev.No.

Date.

OAK BROOK ENGINEERING

18"\$ STEAM OUTLET NOZZLE



Subject MONTICELLO REACTOR VESSEL Cont.

Rev.No.

Date_

Date 3/5/63 MSM sh, 25 of 34 Date Rev.No.

OAK BROOK ENGINEERING

4-28

SUMMARY OF STRESS ANALYSES for CORE DIFFERENTIAL PRESSURE AND LIGUED CONTROL NOZZLE, HEAD COOLING SPRAY AND INSTRUMENTATION NOZZLES, VENT NOZZLE, INSTRUMENTATION NOZZLES, JET PUMP INSTRUMENTATION NOZZLES, DRAIN NOZZLE, HIGH PRESSURE SEAL LEAK DETECTOR NOZZLE and LOW PRESSURE SEAL LEAK DETECTOR NOZZLE

The maximum primary membrane stress intensity for the core differential pressure and liquid control nozzle is 6076 psi (page S11-6), compared to the allowable, 15,800 psi. This nozzle has been exempted from fatigue analysis in accordance with the rules of Par. N-415.1 of Section III, ASME Code.

The maximum primary membrane stress intensity for the head cooling spray and instrumentation nozzles is 2849 psi (page S12-7), compared to the allowable, 15,800 psi. This nozzle has been exempted from fatigue analysis in accordance with the rules of Par. N-415.1 of Section III, ASME Code.

The maximum primary membrane stress intensity for the vent nozzle is 2501 psi (page S13-6), compared to the allowable, 15,800 psi. This nozzle has been exempted from fatigue analysis in accordance with the rules of Par. N-415.1 of Section III, ASME Code.

_ Cont. <u>9-5624</u> Date_

Data

Day Ma

_____By___<u>JH</u>

Pau Na

of 34

sh, 26

OAK BROOK ENGINEERING

CHICAGO BRIDGE & IRON COMPANY

The maximum primary membrane stress intensity for the jet pump instrumentation nozzles is 10,489 psi (page S15-6), compared to the allowable, 15,800 psi. This nozzle has been exempted from fatigue analysis in accordance with the rules of Par. N-415.1 of Section III, ASME Code.

The maximum primary membrane stress intensity for the instrumentation nozzles is 5796 psi (page S14-6), compared to the allowable, 15,800 psi. This nozzle has been exempted from fatigue analysis in accordance with the rules of Par. N-415.1 of Section III, ASME Code.

Subject <u>MON</u>	TICELLO F		VESSEL	Cont. 9-5	6 <u>24</u> Date_	By <u>JH</u> s	intaf_	34
 Charlend hu	Date	Ray No.	Date	Rev No	Date	Rev.No.	Date	

OAK BROOK ENGINEERING

SUMMARY OF STRESS ANALYSIS FOR REFUELING BELLOWS

Using the data contained in the contract specifications and the temperatures calculated in Section T16, following is a summary of the stress analysis which is found in Section S16.

The calculated maximum general membrane primary stress intensity for the refueling bellow skirt is 3547 psi occuring during refueling at a point midway on piece #3. This is compared to the allowable at 70°F of 23,300 psi. (See Page I-S16-A18 of the Stress Report.)

The maximum local membrane and bending stress intensity is 10,310 psi occuring at the inside face of part #2 at the junction to part #1. This occurs during refueling. This is compared to the allowable stress intensity of 34,950 psi at 70°F. (See Table 1, Page I-S16-1 of Section S16.) The maximum range of primary plus secondary stress intensity is 51,734 psi and occurs in the cooldownsteady state cycle at the inside face of the junction of part #3 and part #2. The maximum allowable stress intensity at 545°F is 59,070 psi. (See Pages I-S16-1 and I-S16-10.)


The most critical point from a fatigue standpoint is at the junction of part #2 and #3 during the cooldown-steady state cycle. The fatigue usage factor at this point is .67. (See Page I-S16-2 of Section S16.)

(Points referred to above are shown on the sketch on the following page.)

Cont. 9-5624 Date 3/4/69 By W/ Snr. 25 of 34

1 64 SSD

OAK BROOK ENGINEERING SPECIAL STRUCTURES DESIGN



OAK BROOK ENGINEERING

SUMMARY OF STRESS ANALYSIS FOR STABILIZER BRACKETS

The stabilizer brackets were analyzed for two loading conditions per GE Specification Drawing 886D482, Sheet 8. For loading condition #1 the bracket stresses were limited to allowable stresses per ASME Code, Section III. For loading condition #2 the bracket stresses were limited to the yield strength of the material.

The bracket design stresses and the corresponding allowable stresses are as follows:

LOADING CASE 1

Actual Maximum Stresses

Pure Shear Stress at Pin Hole = 15,238 psi
Bearing Stress at Pin Hole = 21,642 psi
Maximum Stress Intensity
At Face of Shell

Allowable Stresses

Pure Shear Stress	=	16,020	psi
Bearing Stress	=	42,300	psi
Maximum Stress Intensity	, =	26,700	psi

Subject	MONTICELLO	REACTOR V	ESSEL	Cont. <u>9-56</u>	524 Date	By_ <u>AEEShr_30_of_34</u>
.	•	• ••	P	Day Na	Date	Rev. No Date

4 - 33

LOADING CASE 2

Actual Maximum Stresses

Pure Shear Stress at Pin Hole = 19,551 psi Bearing Stress at Pin Hole = 27,767 psi Maximum Stress Intensity) = 26,854 psi At Face of Shell

Allowable Stresses

Pure Shear Stress	=	21,150	psi
Bearing Stress	=	42,300	psi
Maximum Stress Intensity	=	42,300	psi

OAK BROOK ENGINEERING

ļ	SubjectMC	NTICELLO	REACTOR V	ESSEL	Cont. <u>9-5</u>	<u>624</u> Date_	
50 44 0B	Chacked hu	Date	Dav Na	P	Date Ma	D	

AEE Shr 31 of 34 0 ... M.

n....

SUMMARY OF STRESS ANALYSIS

FOR BRACKETS

Brackets were analyzed for loadings specified on GE Drawing 886D482, Sheet 7, Rev. 5. All brackets, except stabilizer brackets and steam dryer supports*, are included in this section.

The brackets are subject to primary membrane and bending stresses for which the allowable stress intensity is 1.5 S_{m} in accordance with Fig. N-414, Section III of the ASME Code.

The maximum stress intensities for the various brackets are as follows:

BRACKET	STRESS INTENSITY
Core Spray	10,007 psi
Guide Rod	18,982 psi
Feedwater Sparger	314 psi
Dryer Hold Down	9,052 psi
Shell Insulation Support	2,500 psi
Head Insulation Support	1,590 psi
Upper Surveillance Bracket	8,350 psi
Lower Surveillance Bracket	5,078 psi

The allowable stress intensity for all brackets, except the guide rod brackets and the head insulation supports is 24,060 psi at 545°F. The allowable stress intensity for the guide rod brackets is 30,000 psi at 120°F and the head insulation supports 28,725 psi at 575°F.

* The steam dryer supports have been reanalyzed for the replacement steam dryer. (Reference EC 14214)

Subject	Monticello Reactor	Vessel	Con	t. <u>9-5624_</u> Date	By <u>AEE</u>	Sht <u>32</u> of	<u>34</u>
GO 640B Checked by	Date	Rev. No.	Date	Rev. No.	Date	Rev.No	Date

OAK BROOK ENGINEERING

4-35

CHICAGO BRIDGE & IRON COMPANY

SUMMARY OF STRESS ANALYSIS FOR TOP_HEAD AND CYLINDRICAL SHELL

In this section the maximum stress intensities in the top head and cylindrical shell due to combined loadings were computed. The loadings considered were: stud preload, internal pressure, dead weight of vessel and contents, insulation weight, horizontal and vertical seismic forces, horizontal jet reactions, stabilizer rod reactions, local bracket and nozzle reactions, refueling bellows support loads, and the thermal loads.

The maximum stress intensities and their locations were found to be as follows: the maximum general primary membrane stress intensity occurs in that portion of the cylindrical shell which is removed from gross structural discontinuities. Its magnitude is 26,375 psi which is within the allowable value of 1 S_m = 26,700 psi. The maximum local membrane stress intensity of 29,610 psi occurs at 15 inches below the bottom of the shell flange hub. This stress intensity was found to be local in extent and is less than the allowable value of 1.5 S_m = 40,050 psi.

The maximum range of stress intensity for primary plus secondary stresses has a magnitude of 55,320 psi which is well within the allowable of 3 $S_m = 80,100$ psi. The location of this stress intensity is at the top of the hub of the head flange.

	Subject MONTICELLO REACTO	<u>R VESSEL</u>	<u>،</u> C،	nt. <u>9-562</u>	4_ DateE	ly_AEE_Shr	33 4
3 64 08	Checked byDate Rev.	No. Do		/ Nin 🔰	••• •	0 N	

OAK BROOK ENGINEERING

SUMMARY OF STRESS ANALYSIS FOR DRAIN NOZZLE

The Code area replacement requirements for the drain nozzle have been satisfied.

The maximum primary membrane stress intensity is 6716 psi versus the Code allowable of 18,200 psi.

30 64 08 Checked by_____Date____Rev.No.____Date____Rev.No.____Date_____Rev.No.____Date_____

MONTICELLO

EXHIBIT 5

•

.

VESSEL FABRICATION AND ASSEMBLY REPORT

.

REV 4 12/85

MONTICELLO

VPF# 18/1-356-1 IV. VESSEL FABRICATION AND ASSEMBLY

4.1 DIVISION OF WORK

A significant portion of the vessel fabrication was performed in the shop, just as would be done for a shop fabricated vessel. This work was in accordance with the ASME Code and G.E. fabrication and quality control requirements. The balance of the fabrication and assembly at the site was performed, utilizing proven techniques and equipment, without any compromise in the design, quality, or functional requirements of the vessel.

A typical site assembly area is shown in Figure IV-1 and an artist's rendering of the completed composite reactor and containment vessels is shown in Figure IV-2.

4.2 SHOP FABRICATION AND SUBASSEMBLY WORK

As much fabrication and subassembly work as possible was performed at CB&I's Birmingham, Alabama, and Greenville, Pennsylvania, manufacturing plants. The overall job economics favored this approach because of the convenience of overhead handling equipment, utilization of the existing shop labor pool and facilities for machining, heat treatment, etc. Restriction on shipping dimensions (not weight) was the determining factor in considering how much of the vessel assembly work could be performed prior to shipment.

5 - 2

An effort was made to clear completed shell rings 18 feet diameter by 10 feet 11-1/2 inches long and weighing 140,000 pounds. Although these rings could be barged to Minneapolis, the interconnecting railroad (Minneapolis, Northfield and Southern Railway) could not move the shipment from Port Cargill to the Great Northern Cedar Lake yard interchange. The Great Northern services the Monticello area. Overland truck handling clearance checks were also unsuccessful in finding an open route to the Great Northern Railroad; therefore, half ring sections were shipped from the shop. Figure IV-3 shows the shop assembled pieces for the Monticello reactor vessel.

A 17-foot diameter support skirt extension with leveling devices attached was shipped in one piece to the site. It joined the stub skirt on the vessel bottom head to the long skirt constructed with the drywell. as shown in Figure IV-2.

A cold forming procedure was utilized to press the bottom head, shell, and top head plates. All plate material was detailed to the maximum length and width dimensions that could be delivered from eastern mills and properly handled by the fabricating facility. The shell plates were purchased in the quenched and tempered condition and cold formed utilizing approved procedures.

Before starting fabrication, all plates were inspected for size, thickness, surface condition and the mill stamps properly dentified. Ultrasonic testing of material was done by trained

and qualified personnel in accordance with Code specifications. Certified mill test reports and all quality control measures were reviewed by CB&I engineers to assure compliance with material specifications.

After the plates were marked and flame cut to approximate size, they were pressed to shape on a 6,000-ton hydraulic press, designed by CB&I. Any minor deviation from curvature tolerances found in checking with box templates and sweeps were corrected by sizing the plates on the press. Each plate was then marked and cut to size and edges beveled with semi-automatic cutting torches. To insure proper dimensions and alignment, shop assembled weldments were fit-up and match-marked prior to shipment to the jobsite for assembly and welding together.

The bottom head was shipped in two sections consisting of (1) the knuckle course of plates with the stub skirt attached and (2) the dollar plate assembly. The dollar plate assembly was predrilled in the shop to accommodate the 121 control rod drive sleeves. The initial holes were drilled to approximately 5 inches in diameter. These holes are large enough to accommodate a boring bar cutting assembly that was used in place for the final boring of the sleeves at the site. Because of the availability of machining equipment, this assembly and predrilling work was performed at CB&I's Greenville, Pennsylvania, plant. The final drilling of the holes was performed in place at the site.

The bottom head knuckle course shop weldment was positioned and two overlay weld metal build-ups were applied (see Figure IV-4) in the two areas where the shroud support was welded to the bottom head. These weld build-ups were shop machined to the contours shown in Figure IV-4.

The Monticello vessel shell was made up of four rings, approximately 11 feet wide. Each ring was made from two formed plates. The half ring sections were temporarily welded together and placed on a roller bed. The ring was preheated and the overlay weld metal deposited with automatic equipment similar to that shown in Figure IV-5. All shell fittings were shop installed. Postweld heat treatment was performed and inspection of the overlay weld deposit and insert seams was made after cool-down.

The shell and head flanges were shipped directly to the site as rough machined, non-drilled, seamless forged rings from the Ladish Company plant in Cudahy, Wisconsin. The weld ends were prepared at the forge works (Ladish) for fit-up and welding to the adjacent No. 4 shell ring and top head weldment. This top head assembly was shipped in one piece. It was welded together from six knuckle plates and a one-piece dollar plate assembly, as shown in Figure IV-6.

The internal shroud support was completely shop fabricated, including preliminary machining, at Greenville and shipped as an integral ring assembly to the site where it was welded in place to the bottom head. The final machining was completed after welding.

The stud bolts, washers, and gaskets were shipped directly from General Electric qualified manufacturers to the jobsite storeroom.

4.3 SITE SUBASSEMBLY AND ERECTION

Site subassembly of the reactor vessel started about three months after work began on the containment vessel. Erection of the reactor bottom head followed the completion of the leak rate test of the drywell. The bottom head and stub skirt was welded to the reactor support skirt which was attached to the drywell prior to the leak rate test.

Unlike the case for determining the maximum size of subassemblies at the shop, weight of the lifts or derrick capacity dictated the subassemblies that could be made at the site. The closure seams between subassembled sections were made in place.

The postweld heat treatment zones were established by the location of penetrations with respect to circumferential weld joints and the adherence to safe thermal gradients through adjacent vessel materials.

Methods of achieving the machined surface requirements, drilling and tapping and boring operations were developed by CB&I engineers using commercial equipment, where available, and designing and building custom-made devices, where necessary.

Suitable weather protection devices were provided to shelter the vessel weldments during ground assembly, welding, and postweld heat treatment.

The postweld heat treatment furnaces were also used for environmental housings for the welding and radiographic work. Figure IV-7 shows typical postweld heat treatment of the longitudinal ring welds. Figures IV-8 and IV-9 similarly show postweld heat treatment of the bottom head and stub skirt assembly and the top head and flange assembly.

Temperatures from thermocouples were permanently recorded on a multiple point potentiometer instrument. Adequate thermocouples were used to obtain representative readings from all parts of the section being heated.

The various parameters for heat treating, such as heating and cooling rate, variation of temperature during the holding period, etc., were in accordance with Section III of the ASME Boiler and Pressure Vessel Code and other requirements of the General Electric specifications.

4.3.1 Site Subassembly

The basic assembly yard fabrication process was performed as follows on the head and shell components: (a) shell halves joined into rings, bottom head to skirt extension, top head to flange on level work tables; (b) preheat to 300° F to 400° F and weld sections

together; i.e., four shell rings, one bottom head with skirt and one top head with flange; (c) magnetic particle check weld periodically during deposition of metal as preliminary inspection step and replace any unsound material found therein; (d) hot ultrasonic test welds before postweld heat treatment; (e) post weld heat treat at $1150^{\circ}F$; (f) cool and radiograph welds; (g) ultrasonic welds again; (h) manual overlay welds; (i) postweld heat treat; (j) cool and ultrasonic overlay; (k) dye check overlay.

4.3.2 Assembly and Machining

The bottom head and stub support skirt assembly was set in place, leveled, and welded on a 17-foot diameter tubular support skirt furnished in the drywell base of the containment structure.

The vessel centerline was established as a vertical line of sight using a precise jig transit instrument located below the bottom head and sighting on a target in the geometric center of the center control rod drive penetration.

The leveling and plumbing procedure was repeated after placement of each of the four shell rings. The centerline for the bottom head and skirt assembly was located as shown in Figure IV-10. The No. 1 shell ring, assembled and we ded in the assembly yard, was placed as an integral ring in position atop the bottom head. The girth seam was fit, preheated and hand welded. The No. 2 ring was then placed, fit and welded. The preheat was maintained on

the bottom head to No. 1 ring girth seam until the No. 1 to No. 2 girth seam was ready for postweld heat treatment. At that time, the two rings were postweld heat treated simultaneously in the temporary furnace. Steps (b) through (k) used for site subassembly (Paragraph 4.3.1) were used for assembly in place.

Non-destructive testing methods in the field were the same as those performed in the shop. Radiography was performed utilizing a 75 to 100 Curie Gamma source with appropriate shielding. Usage of the source was in accordance with the applicable Federal and State regulations.

Concurrent with erection of the vessel shell, the vessel top head weldment was fit and welded to the cover flange in the assembly yard area. After completion of all the welding, postweld heat treatment and examination steps, the top head was positioned for drilling the 5-1/4-inch diameter hold-down bolt holes, as shown in Figure IV-11. With the cover in this same position, the grooves for the two 1/2-inch diameter stainless "O" ring gaskets were machined with the portable CB&I equipment as depicted in Figure IV-12.

After the No. 1 and No. 2 girth seams were postweld heat treated, the temporary furnace was converted into an air-conditioned and ventilated work room around the bottom head and No. 1 shell ring. A temporary cover was installed above this work area so that the balance of the vessel could be erected without interfering with

the bottom head work. The holes and sleeves for the 121 6-inch diameter control rod drive thimbles and the 40 2-inch diameter holes for the in-core flux sensors were machined utilizing precision-bored guide templates, optically aligned in a temperature controlled housing to guide a verticle boring bar and cutter head, as shown in Figure IV-13. These methods not only assured that the holes were on accurate centers but that they were plumb.

The vessel closure flange was drilled and tapped in the assembly yard after it was welded to the No. 4 shell ring.

The gasket sealing face on the vessel flange was machined in the assembly yard using the same equipment that was used for machining the top head flange.

Drilling of the control rod drive sleeve holes, welding the sleeves and boring them to the final precision dimension was performed in parallel with the work on the vessel as described above.

4.3.3 Cleaning and Hydrostatic Test

Upon completion of the machining work on the control rod drive sleeves, the reactor head was attached to the vessel in preparation for cleaning. The cleaning of the interior surfaces of the vessel was done using high pressure (approximately 8000 PSI) deionized water containing 500-ppm by weight of TSP. Special care was taken to thoroughly water-blast rinse all areas and crevices to

insure complete removal of the TSP solution. The rinsing continued until the effluent conductivity was 5 micro-mho/cm.

Upon completion of the initial cleaning, the vessel was filled with heated deionized water and tested per the requirements of the ASME Code. Upon completion of the overload pressure test, the vessel head was removed and service gaskets installed. The vessel head was then replaced and a leakage rate test was performed between the double "O" ring seals at the design pressure.

Upon completion of the hydrostatic test at design pressure, the test caps were removed from the vessel and replaced with temporary covers. The vessel was once again high pressure blasted with deionized water. After drying the interior surfaces of the vessel, the vessel was sealed to prevent entry of dirt or other foreign materials.

4.4 REACTOR VESSEL QUALITY CONTROL

4.4.1 Objective

The quality control for the Monticello nuclear reactor was directed by a Quality Control Manager with the assistance of Quality Control Coordinators. The primary objective of this group was to coordinate CB&I's many quality connected functions into a system which assured that the reactor vessel produced would meet the quality requirements and to document the fact that these quality requirements were met.

4.4.2 Project Quality Control Organization

Authority lines for project management and project quality control were separated by having both managers report directly to the Regional Operations Manager, who, in turn, reported to the Vice President and Manager of Operations. Company standards and policies for quality control -- or more aptly, quality assurance -- were set by the Quality Control Administrator, who also reported to the Vice President and Manager of Operations. The latter was on the same level as the Vice President and Manager of Welding and Inspection. The Q.C. Coordinator for manufacturing was concerned with only nuclear reactors. The Q.C. Coordinator for engineering, purchasing, and construction was concerned with only this vessel from the date of contract until vessel completion.

4.4.3 <u>Compliance with Specifications</u>

By using check-off type records, spot checking operations as the work progressed, and by auditing all inspections, the plant and site Q.C. Coordinators were able to assure that:

- 1. Approved procedures were used;
- 2. The approved procedures were being followed;
- 3. Required inspections were properly performed;
- 4. Inspections were witnessed by the customer's Q.C. representative; and
- 5. The material or part met the required level of quality before it was further processed.

Each item or piece of material received at the shop or at the site was covered by a Work Order and Traveler Card which listed, in sequence, all of the operations and inspections which that particular item or piece underwent. Each operation or inspection was given a unique reference number so that it could be referenced to the report of record. Each operation was referenced to the applicable approved procedure with special notations for witness points or points beyond which further progress was halted until clearance was obtained. Provision was made for sign-off by the supervisor after the operation was completed, by the inspector after the inspection was performed, and by the Q.C. Coordinator as well as the customer's Q.C.

4.4.4 Documents and Records

In addition to the usual records required for pressure vessels built to Section III of the ASME Code, a complete thermal history of all parts and a quality control spread sheet of this vessel will be maintained for the specified time period. Written non-destructive test reports were prepared for each radiographic, ultrasonic, magnetic particle and liquid penetrant inspection. Also, welders' performance qualification certificates and test results are available for review.

The same record, report, inspection or process procedure was used for similar operations regardless of whether performed in the shop or at the site. Traveler Cards, Thermal History, and Spread

Sheets were initiated in the shop and were carried through to the completion of the job.

160 SANSOME STREET, SAN FRANCISCO, CALIFORNIA 94104

April 1, 1969

In Quintuplicate

General Electric Company Atomic Power Equipment Department Nuclear Energy Division 175 Curtner Avenue San Jose, California 95125

Attention: Mr. B. K. Lloyd, Buyer Mail Code 522 Monticello Project P.O. 205-55582-I Reactor Vessel Contract 9-5624 Seq. No. SFC-259

Area Code: 415 981-7530

Re: Vessel Fabrication and Assembly Report

Gentlemen:

Following our discussions in your office on March 25, 1969, we have once again reviewed Section IV of the Report prepared for the AEC and issued in November 1966 under the title "Monticello Nuclear Generating Plant - Design, Fabrication and Erection of the Reactor Vessel." Accordingly, we have marked the appropriate technical changes to indicate the revisions made during fabrication and erection of the vessel.

Our attached sheets, marked Attachment A, dated April 1, 1969, describe the technical changes made in Section IV. This Attachment could be modified and issued as an Erratum to the original Report.

As for the submittal of different photographs, we assume that you can review the photographs that have been furnished you in accordance with our terms of the contract and choose those pictures that best depict the actual work done at the jobsite.

With this transmittal, we assume the Vessel Fabrication and Assembly Report is complete as far as Chicago Bridge & Iron Company is concerned.

Very truly yours,

CHICAGO BRIDGE & IRON COMPANY

Robert C. Baker Contracting Engineer

RCB:aer Enclosure 9-5624

MONTICELLO REACTOR VESSEL

.

April 1, 1969

ATTACHMENT A

.

SECTION	PAGE	COMMENT
4.2	IV-3	First Paragraph: Revise to reflect that all shell fittings were shop installed.
4.3	IV-3	First Paragraph: Site subassembly began about three months after work started on the containment. Erection of the reactor bottom head followed the completion of the leak rate test of the containment vessel.
4.3.1	IV-4	First Paragraph: Revise Item (f) to read "cool and ultrasonic welds" and Item (g) to read "radiograph welds."
4.3.2	IV-5	First Paragraph, Ninth Line: Delete reference to the shroud support skirt.
4.3.2	IV-5	Second Paragraph: Revise to indicate that the radiography work was done with a 75 to 100 Curie Gamma source.
4.3.2	IV-5	Last Paragraph: Revise to indicate that the vessel closure flange was drilled and tapped in the assembly yard after being welded to the No. 4 shell ring.
4.3.2	IV-6	First Paragraph: Revise to read that the gasket sealing face on the vessel flange was machined in the assembly yard using the same equipment as was used for machining the top head.
4.3.2	IV-6	Second Paragraph: Delete this paragraph.
4.3.3	IV-6	First Paragraph: Revise the Section to indicate that, after completion of work and placement of the reactor head on the vessel, the interior surfaces of the vessel were-cleaned using high-pressure

5-17

CHICAGO BRIDGE & IRON COMPANY

ATTACHMENT A (Cont'd)

Page 2 April 1, 1969

SECTION PAGE

COMMENT

deionized water containing 500 parts per million by weight of TSP. Special care was taken to thoroughly waterblast rinse all areas and crevices to insure complete removal of the TSP solution. The rinsing continued until the conductivity of the effluent was measured at 5 micro-mho/cm.

Following the Code hydrotest, the vessel was once again high-pressure blasted with deionized water.

4.4.1 IV-6

-6 First Paragraph:

Add the comment that, in addition to the control rod penetrations, the instrument nozzles in the third and fourth ring were partial penetration weld connections. These partial penetration welds used details per Figure N-462.4(d) in Section III of the 1965 ASME Code.

- 4.4.2 IV-7 Second Paragraph: Delete the note in the parenthesis. All nozzles were installed in the shop.
- 4.5.8 IV-20 First Paragraph: In the second line, delete "CB&I Quality Control. Coordinators will maintain a Daily Progress Recond."
- 4.5.8 IV-21 First Paragraph: Delete this paragraph.
- 4.5.8 IV-21 Fourth Paragraph: Delete the first two sentences.

EXHIBIT 6

INDEPENDENT STRESS ANALYSIS REPORT

.

REV 4 12/85

INDEPENDENT REVIEW OF STRESS ANALYSIS REPORT

In accordance with a suggestion by the USAEC Advisory Committee on Reactor Safety (Monticello ACRS Letter, April 13, 1967, AEC Docket #50-263), the Reactor Pressure Vessel Stress Analysis Report was reviewed by independent experts. This study has been performed by Teledyne Materials Research Division of the Teledyne Company, Waltham, Massachusetts.

Teledyne's summary letter concerning their review is included herewith as Exhibit 6 of this report.



TELEDYNE MATERIALS RESEARCH

103 BEAR MILL ROAD WALFHAM MANSACHI SETTS 02154 617: 899-1350

A TELEDYNE COMPANY

September 15, 1969 Project E-1113

General Electric Company Nuclear Energy Division 175 Curtner Avenue San Jose, California 95125

Subject: GE PO #205-F0144 Audit of Monticello Vessel Design Analysis

Attention: Mr. D. K. Heising

Gentlemen:

Teledyne Materials Research has completed the audit of the stress analysis report of the Monticello - NSP Reactor Vessel. On the basis of our review of the final report, we are of the opinion that:

- The analytical methods employed by General Electric Co. and Chicago Bridge and Iron Co. are consistent with the state-of-the-art as generally practiced in the industry.
- 2) The ASME code interpretations employed with respect to the analytical results are proper.

Very truly yours, TELEDYNE MATERIALS RESEARCH

W. E Gorpen

William E. Cooper Vice President

WEC/mef

MONTICELLO

7-1

EXHIBIT 7

REACTOR VESSEL DESIGN SPECIFICATION (REPAIRS)

REV 5 12/86

GENERAL CEECTRIC	REVISION STATUS SHEET		22A5541 CONT ON SHEET 2 SH NO. 1
DOCUMENT TITLE REACTOR VESS	EL		
SPECIFICATION ODRAWING OTHER	R T	PE	ESIGN SPECIFICATION (REPAIR)
_	5	MF	/A
LEGENO OR DESCRIPTION OF GROUPS	MPL	NaN	/A

7-2

REVISIONS IDENTIFIED WITH A SPADE (A)

		REVIS	10% \$				C
0	DHD-2139 A,R,C.						
1	THE GARBER	A.S. 8.5					
	NE92594						
2	DA POWELL JAN 1 7 1978	45. E.S					
	NE92646						
	CHKD BY: A LONG						
			390	150	1252		·
			937	518			
ļ			519	PR			
			1320	229	L		
			200	<u>746</u>			
			458	354			
			602	312			
	1 . li. l		1		PRINTS TO		
i	SOLOI JULY 29, 1977 J.E.CHAR	960	Lande	- OE	NED	SAN JOS	E
CHA		11.ET	y Une	<u>1977</u>	HED	L SAN UUS	
5	L. SILVA AUG 2-77 E. SAXO	N Z		2 1977 00	NT ON SHEET	2 SH NO.	-1 -

GENERAL DELECTRIC

·	22A5541	SH. NO.	2
REV.	2		•

1. SCOPE

1.1 This specification gives the functional and engineering requirements for feedwater nozzle and safe end repair. The repair consists of removing cladding from the nozzle blend radius and bore, machining the safe end to accept a feedwater sparger interference fit thermal sleeve with a piston ring seal, and removal of any remaining linear liquid penetrant indications.

1.2 This specification replaces the original Reactor Pressure Vessel Design Specification for the Reactor Pressure Vessel Feedwater Nozzles and Safe Ends.

2. APPLICABLE DOCUMENTS

2.1 <u>General Electric Documents</u>. The following documents form a part of this specification to the extent specified herein.

2.1.1 Supporting Documents

- - -

The multiple steeve	112D1696
Feedwater Nozzle Inside Machining Drawing	7672204
Cleaning and Cleanliness Control for Assembly of Reactor Components	21A2045
Reactor Vessel Modification	769E367
Vessel Feedwater Nozzle Blend Radii Crack Removal Tooling	22A4705
Thermal Sleeve End	112D1693
	Feedwater Nozzle Inside Machining Drawing Cleaning and Cleanliness Control for Assembly of Reactor Components Reactor Vessel Modification Vessel Feedwater Nozzle Blend Radii Crack Removal Tooling

2.1.2 Supplementary Documents. None

GENERAL C ELECTRIC

REV. 2

2.2 <u>Codes and Standards</u>. The following codes and standards form a part of this specification to the extent specified hereing

a. American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code

- (1) Section XI, Inservice Inspection of Nuclear Reactor Cooling Systems, 1974 Edition with Addenda to and including the Summer 1975 Addenda.
- (2) Section III, Nuclear Power Plant Components, 1974 Edition with Addenda to and including the Summer 1976 Addenda.
 - (3) Code Case 1804.

3. DESCRIPTION

3.1 The repair will minimize damage to the feadwater nozzle due to thermal cycling. This repair will be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code.

4. REQUIREMENTS

Articles IWA-4000 and IWB-4000 of Section XI of the ASME Code.

4.2 Functional

4.2.1 The machined safe end shall be compatible with interfacing thermal sleeve shown on Drawings 112D1693 and 112D1696.

4.2.2 Clad removal and the safe end machining shall be compatible with the generic feedwater nozzle inside machining specified on Drawing 767E204 and with Drawing 769E367, and shall be performed in accordance with Specification 22A4705.

4.2.3 All work shall be performed in accordance with Specification 21A2045.

4.2.4 <u>Repair of Linear Indications</u>. If any linear indications are detected after machining is completed, they shall be removed in the following manner.

4.2.4.1 Remove all unacceptable indications by grinding.

4.2.4.2 After the unacceptable indications have been removed, the sides of the cavity shall be ground to merge s nothly with adjacent surfaces. In the hoop direction, the sides shall be merged with a minimum blend slope of 4:1 (width to depth). In the axial direction, the sides shall be merged with a minimum blend slope of 2:1 (width to depth). The cavity shall be round bottomed with a minimum radius of two times the depth of the material removed from the final machined surfaces.

	22A5541	SH. NO.	4	
REV.	2			

4.3 Design

GENERAL

NUCLEAR ENERGY DIVISION

4.3.1 <u>Thermal Sleeve Reactions</u>. The Inconel thermal sleeve shown on Drawing 112D1693 will be installed with a cold nominal interference of 0.010 inch across the diameter. The effects of the thermal sleeve on the safe end and nozzle shall be considered in the design analysis. The geometry is shown in Figure 2 and on Drawing 769E367.

4.3.2 Design pressure is 1250 psig. Normal operating pressure is 1111 psig.

4.3.3 Design temperature is 575°F. Normal operating temperature is 546°F.

ELECTRIC

4.3.4 Normal operating condition pipe reaction loads are shown in Figure 1. There are no upset, emergency, or fault pipe loads specified for this design.

F _C	3.0 kips
FL	5.7 kips
FZ	3.2 kips
Mc	156.0 inkips
M,	336.0 inkips
Mz	348.0 inkips

Loads can be in either direction for all values shown.





Figure 1

4.3.5 Seismic loads are included in the pipe reactions.

4.3.6 <u>Corrosion Allowance</u>. All exposed exterior ferritic steel surfaces of pressure containing parts shall have a corrosion allowance of 0.032 inch in 40 years. All ferritic steel surfaces exposed to reactor coolant shall have a corrosion allowance of 0.063 inch in 40 years.

4.3.7 <u>Design Life</u>. The design life of this repair shall be not less than 24 months. If design life is extended beyond 24 months, then additional analysis, according to this specification, is required.

7-5



4.4 Operational Environment

4.4.1 Neutron fluence is negligible at the feedwater nozzle.

4.4.2 It shall be assumed that the interior of the nozzle and safe end interior of the nozzle and safe end are exposed to saturated strum and demineralized water under operating conditions.

4.4.3 <u>Insulation</u>. Exterior surfaces of the nozzle and safe end are insulated. The average heat transfer rate under operating conditions is 80 Btu/hr-ft².

4.4.4 <u>Heat Transfer Coefficients</u>. The heat transfer coefficients defined below are from emperical data for this design and are to be used in the analyses required in Section 5. Heat transfer coefficients for other locations shall be calculated by conventional methods.

4.4.4.1 The heat transfer coefficient for the nozzle inside surface (areas A thru D in Figure 3) for all leakage flow rates is:

h =
$$\frac{Z @ Annulus fluid temperature}{Z @ 500°F} \times \left(\frac{0}{n_{E}}\right)^{8} \times 9000 \frac{Btu}{hr-ft^2-F}$$

The minimum value of n shall be invo bru/nr-rt -r.

4.4.4.2 The heat transfer coefficient for the inside of the safe end and thermal sleeve that is exposed to the feedwater flow is:


$$h = \frac{Z @ Feedwater temperature}{Z @ 100°F} x \frac{Q}{960} x 2600 \frac{Btu}{hr-ft^2-°F}$$

4.4.4.3 Nomenclature

$$Z = \frac{K P_{r}^{1/3}}{v^{*8}}$$

K = Thermal conductivity of the fluid

- P_ = Prandtl Number
- v = Kinematic viscosity
- Q = Feedwater flow per nozzle (gpm)
- QR = Feedwater flow per nozzle at 100% rated power (gpm) as defined in Paragraph 4.5.1.3.





2245541	SH. NO. 8
rev. 2	

4.4.4.4 The heat transfer coefficient for the inside of the vessel shell outside of areas A through D shall be 1000 Btu/hr-ft²-°F for all conditions.

4.4.5 Annulus Fluid Temperature

$$T = T_{FW} + (C_1) \times (C_2) \times (T_A - T_{FW})$$

where

T = annulus fluid temperature

 T_{FW} = feedwater fluid temperature

 T_A = Region A fluid temperature = 546°F

C₁ = Coefficient from Table 1

 C_2 = Coefficient from Figure 4


Table 1 Ccefficient C1

Location (see Flow Figure 3	A	B	С	D
100% rated feedwater flow	0.44	0.59	0.72	0.88
20% rated feedwater flow	0.66	0.88	0.96	0.96
0% rated feedwater flow	1.0	1.0	1.0	1.0

Interpolate linearly between defined points A, B, C, and D and between flow rates given.









▲ 4.5 <u>Cyclic Conditions</u>. There are three sources of normal operation thermal cycles, system cycling, unstable flow cycling, and rapid mixing cycling. There are no upset, emergency, or fault thermal cycles specified for this design.

4.5.1 <u>System Cycling</u>. This type cycling results from changes in the flow and temperature of the feedwater and/or of the reactor water.

4.5.1.1 Seventy-five cycles of the following transient represent the equivalent of 24 months of this type of cycling.

4.5.1.2 The temperature transient consists of:

ELECTRIC

GENERAL (

NUCLEAR ENERGY DIVISION

4.5.1.2.1 <u>Initial Condition</u>. The nozzle, safe end, thermal sleeve and all contained water is isothermal at 100°F and is at 0.0 psig.

4.5.1.2.2 The nozzle, safe end, and thermal sleeve are heated by the contained water. The water is heated from 100°F to 545°F at a rate of 100°F/hr. The pressure is increased to 1111 psig.


4.5.1.2.3 The hot feedwater is displaced by 100°F feedwater with a velocity of 5 ft/sec. This condition exists until steady state is achieved.

4.5.1.2.4 The feedmater temperature then steps to 200°F.

4.5.1.2.5 The feedwater temperature then is increased to $376^{\circ}F$ at $250^{\circ}F/hr$. Simultaneously the feedwater flow velocity is increased from 5 ft/sec to 20 ft/sec. The end points, $376^{\circ}F$ and 20 ft/sec are reached simultaneously. This condition exists until steady state is achieved.

4.5.1.3 Feedwater flow rate shall be obtained from feedwater velocity by using an area of 64.5 square inches. The velocity that corresponds to 100% rated feedwater flow is 20 ft/sec at a temperature of 376° F.





4.5.1.4 The temperature transient is shown in tabular form below:

Fluid Temp. Rate	Fluid Start Temp.	Fluid End Temp.	State of Fluid	Fluid Velocity	Vessel Pressure	Notes
10C F/hr C 250 F/hr	100 100 260	546 100 376	Water Water Water	0 5 ft/sec 5* ît/sec	1111 psig 1111 psig 1111 psig 1111 psig	Followed by Step To Followed by Step To

TEMPERATURE TRANSIENT

Velocity changes linearly 5 ft/sec to 20 ft/sec

GENERAL 🌍 ELECTRIC

NUCLEAR ENERGY DIVISION

4.5.2 <u>Unstable Flow Cycling</u>. During reactor startup under low power conditions temperatures in the top half of the feedwater nozzle safe end and thermal sleeve shall be assumed to fluctuate over a 250°F temperature range from (100°F to 350°F) as shown on Figure 5, for 1% of the operating time, i.e., 88 hours per year. This cycling is in addition to the temperature cycling in the nozzle defined in Paragraph 4.5.1. This cycling is due to unstable flow when the icedwater flow rate is too low to keep the hot region A fluid swept out of the sparger, chernic store, one safe the form and bottom for both cold flushing and nozzle remain at 100°F during this cycling. The heat transfer coefficient, calculated according to the procedure given in Paragraph 4.4.4.2 at 25% rated feedwater flow, is to be used for the top and bottom for both cold flushing and hot back flow. The transient stresses may be calculated by assuming an axisymmetric model with boundary conditions for the top half of the nozzle. The stresses due to the top-to-bottom temperature may be upper bounded by assuming that the vessel shell, nozzle forging, and attached piping are rigid and using an equation of the form

 $\sigma_{\chi} = \frac{E \alpha (T_{Top} - T_{Bottom})}{2}$ for the safe end.

where

- σ_{χ} = axial membrane stress in safe end, use upper sign for top, lower sign for bottom
- E = Youngs Modulus
- a = coefficient of thermal expansion
- Trop mean temperature of top half of safe end
- TBottom⁼ mean temperature of bottom half of safe end

GENERAL DE ELECTRIC

22A5541 3H. NG. 12 REV. 2




FIGURE 5

Å

÷.,

SH. NO. 13

REV. 2

22A5541

4.5.3 Rapid Cycling

GENERAL 🤅

NUCLEAR ENERGY DIVISION

4.5.2.1 Rapid temperature cycling (on the order of 0.1 Hz to 1.0 Hz) occurs as a result of cold feedwater being injected into a hot reactor. The most dominant cause of this cycling in the nozzle bore and on the blend radius is turbulent mixing of leakage flow with region A fluid. Rapid cycling is caused in the absence of leakage flow by turbulent region A fluid causing the thermal boundary layer around the cold thermal sleeve to be broken up and swept against the nozzle. Incompletely mixed sparger discharge flow and region A fluid that is carried back to the nozzle also causes some rapid cycling.

4.5.3.2 The metal surface temperature ranges are given by the following emperical equation:

$$\Delta T_{p-p} = \pi \times C_3 \times C_4 \times (T_A - T_{FW})$$

where:

 ΔT_{n-n} = metal surface peak to peak temperature range

ELECTRIC

A = amplitude coefficient for a given frequency of cycling, from Table 2

C₂ = coefficient from Table 3

 T_{FW} and T_A are defined in Table 4.

4.5.3.3 The amplitudes and cycles given in Table 2 and the flow/temperature/time data from Table 4 are to be used in the fatigue evaluation. (The design life is given in Paragraph 4.3.7.)

Table 2 Amplitud	e/Frequency Data	for Rapid Cycling
------------------	------------------	-------------------

Index I	Amplitude A	Frequency Cycles/hr
1 2 3 4 5 6 7 8 9 10 11	1.00 0.95 0.96 0.85 0.77 0.66 0.56 0.46 0.36 0.26 0.15	15 30 30 75 120 150 180 225 375 375 375 1125

GENERAL DELECTRIC


Table 3 Coefficient C3

Pt.	100% Rated	20% Rated	0% Rated
	Feedwater Flow	Feedwater Flow	Feedwater Flow
A	0.20	0.12	0.12
	0.20	0.12	0.12
Ċ	0.30	0.18	0.18
D	0.10	0.06	0.06

Interpolate linearly between defined points A, B, C, and D and between given flow rates.

Index J	Feedwater Flow % Rated	TFW Feedwater Temperature °F	TA Region A Temperature °F	Time	Hours Per Year
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23	100 84 57 37 10 20 10 2 84 100 100 100 0 0 0 1 2 2 84 100 100 0 0 0 1 2 2 84 100 100 2 2 84 100 100 2 2 84 100 20 10 20 30 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	367 358 330 195 101 101 131 70 278 315 278 315 278 200 300 400 300 300 350 190 125 70 190 200 70	546 546 546 546 546 546 546 546 546 546	51.33 14.00 7.47 3.73 3.73 0.47 0.93 0.47 0.99 0.93 0.00 0.067 0.15 0.24 0.999 0.003 0.020 0.016 0.003 0.018 0.004 5.14	5373 1226 654 327 327 41 81 41 7.9 16 81 0.0 5.88 13.38 20.88 87.5 0.25 1.78 1.38 0.25 1.60 0.38 450

Table 4 Flow, Temperature, and Time Data for Rapid Cycling



RAPID CYCLING MULTIPLIER CA

GENERAL DELECTRIC

	22A5541	sh. NO. 16	
REV.	2		

4.5.3.4 The alternating stress produced by the rapid cycling shall be calculated using:

$$\sigma_{alt} = \frac{E - \Delta T_{p-p}}{2(1-V)}$$

where:

E (Youngs Modulus) and α (instantaneous coefficient of thermal expansion) are evaluated at a temperature of

$$T = T_{\underline{r}} - 0.5 \times C_3 \times C_4 \times (T_4 - T_{\underline{r}})$$

Y = Pcisson's Ratio

 ΔT_{p-p} , T_A , C_3 , C_4 , and T_{Fk} are defined in Paragraph 4.5.3.2

4.5.3.5 The fatigue usage factor due to rapid thermal cycling is given by:

$$U = \sum_{\substack{i=1\\j=1}}^{23} U_{ij} \times \text{Design Life}$$

where

- U = usage factor due to rapid cycling
- U_{ij} = usage factor due to ith amplitude and frequency for the jth flow, temperature, and time

4.5.4 Leakage flow rates are to be calculated for all conditions. The following assumptions are to be used:

- a. Neglect the pressure of any seal rings, springs, and ring grooves, i.e., assume the thermal sleeve looks like Figure 3.
- b. There is zero leakage flow when there is zero clearance between the thermal sleeve and nozzle.
- c. The pressure drop across the thermal sleeve is 10.9 psi at 100% rated feedwater flow.



4.5.4 (Continued)

- d. Yielding of the thermal sleeve and sufe end (and thus relaxing the initial interference fit) at this leckage gap shall be considered.
- e. Changes in the leakage gap due to differential expansions between the nozzle and thermal sleeve must be considered. See Figures 2 and 3 for dimensions and materials for determining leakage gap.
- f. The leakage gap (i.e., radial gap) increases at the rate of 0.0017 inch per year due to corrosion.
- g. The leakage flow velocity averaged over the annulus area at the discrete point of interest shall be used in determining C_2 and C_4 from Figures 4 and 6 except for zones C and D. Use the maximum average leakage velocity in zone C to determine C_2 and C_4 and use these values for all of zone C. Assume that the leakage velocity varies from the zone C value to zero at point D.
- 5. ANALYSIS

5.1 <u>Primary Stresses</u>. The final machined and ground nozzle and safe end thicknesses shall secure youkkary Stress requirements of IEE Code Section IEE, Article' NB-3000.

5.2 <u>Secondary and Peak Stresses</u>. The nozzle and safe end shall separately be shown to satisfy the secondary and peak stress requirements of ASME Code Section III, Article NB-3000. The fatigue curve shown on Figure 7 shall be used. The operating pressure and temperature identified in Paragraphs 4.3.2 and 4.3.3 shall be used.

6. DOCUMENTATION

6.1 The required analysis shall be documented in a manner suitable for submission to enforcement and regulatory agencies.

6.2 The required analysis shall be certified.




FIGURE 7

7-19

22A5541

SH. NO. 18

MONTICELLO

8-1

EXHIBIT 8

REACTOR VESSEL SYSTEM CYCLING (STRESS REPORT)

.

...

REV 5 12/86

	REVISION STATUS SHEET	8-2
í Es		22A7454
GENERAL 🍪 ELECTRIC		CONT ON SHEET 2 SH NO.
JCLEAR ENERGY BUSINESS GROUP		
DOCUMENT TITLE REACTOR VESSE	L (SYSTEM CYCLING)	
	TYPE	STRESS REPORT
EGEND OR DESCRIPTION OF GROUPS	FMF	MONTICELLO
	MPL ITEM NO.	(s) PRODUCT SUMMARY (SECT
- DENOTES CHANGE		
8		
IMPORTANT TO SAFETY - THIS ITEM IS OR CONT		
0 DMH-1172		
T, Ethnicge	AL	
1 D ETHRIDGE APR 09		
NH14523 GENERAL DOCUMENT	T CHANGE	
CHK BY: 2. amarel	.F. LOSKOT	
L AMARAL V		
	PS	
	PS	
	▶	•
	▶	
	▶	
	▶	
	775	PRINTS TO
MADE BY McComments A ME CORNWELL AND 16 1980	▶	PRINTS TO DEPT LOCATION NED SAN JOSE



SH NO. 2

CERTIFICATION OF STRESS REPORT

This certification for the Monticello Reactor Vessel (System Cycling) feedwater nozzle and safe end repair Stress Report and accompanying documents comprises the Stress Analysis required by Paragraph NCA-3550 of the ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, 1977 Edition with Addenda through Summer 1978. I certify that to the best of my knowledge and belief the Stress Analysis Report is correct and complete and in accordance with Design Specification 22A6996, Revision 0, and in compliance with the requirements of Article NB-3000 of the ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, 1977 Edition with Addenda through Summer 1978. I hereby certify that this report was prepared by me or under my direct supervision and that I am a duly Registered Professional Engineer under the laws of the State of Minnesota.

Type of Document	Title	Document Number	Revision <u>Number</u>
Stress Report	Reactor Vessel Rapid Cycling	22A7227	0
Design Spec	Reactor Vessel System Cycling	22A6996	0

.E. Number: 14372 Certified By CHARNLE E.

Date: 9 april 1982

NUCLEAR ENERGY BUSINESS GROUP 22A7454 Rev 1

SH NO. 3

TABLE OF CONTENTS

- 1. ABSTRACT
- 2. SUMMARY AND CONCLUSIONS
- 3. DESIGN REQUIREMENTS
- 4. ANALYSIS
 - 4.1 Thermal Transient Analysis

4.1.1 Thermal Model 4.1.2 Feedwater Nozzle Heat Transfer Coefficients

> 4.1.2.1 Cool-Down Transient 4.1.2.2 Heat-Up Transient 4.1.2.3 Normal Operation

4.1.3 Feedwater Nozzle Annulus Fluid Temperatures 4.1.4 Thermal Analysis Results

4.2 Stress Analysis

4.2.1 Selected Locations for Stress Evaluation 4.2.2 Thermal Stress Analysis

4.2.2.1 Selection of Times For Stress Evaluation 4.2.2.2 Thermal Stress Analysis Results

4.2.3 Mechanical Load Stress Analysis

4.2.3.1 Applied Mechanical Loading 4.2.3.2 Mechanical Load Range Calculations

4.2.4 Pressure Stress Analysis

4.2.4.1 Pressure Stress Analysis Results

4.2.5 Total Primary Plus Secondary Stress Range

4.2.5.1 Thermal Stress Ranges

4.2.5.2 Nozzle End and Thermal Sleeve Load Stress Ranges

4.2.5.3 Pressure Stress Ranges

4.2.5.4 Total P + Q Range

4.2.6 Interference Fit Stresses

NEBG-807A (6/80)

GENERAL 🔮	BELECTRIC
-----------	-----------

NUCLEAR ENERGY **BUSINESS GROUP**

22A7454 REV 1

TABLE OF CONTENTS (Continued)

4.3 Fatigue Analysis

4.3.1 Stress Concentration Factors

- 4.3.2 Alternating Stress Range

- 4.3.3 Usage Calculation 4.3.4 High Cycle Fatigue 4.3.5 Accumulated Fatigue Usage
- 4.3.6 Total Fatigue Usage

5. RESULTS

6. REFERENCES

APPENDIX 10 LISTING OF 'NONO'

APPENDIX 20 INTERGRANULAR STRESS CORROSION INDEX CALCULATIONS

APPENDIX 30 RECALCULATIONS REQUIRED DUE TO MANUFACTURING DEVIATIONS

SH NO. 4

22A7454 Rev 1

SH NO. 5

1. ABSTRACT

This report documents the stress analysis performed for the feedwater nozzle and safe end assembly. The analysis is concerned with Service Level A, B, and C events, and design conditions. A fatigue analysis was also performed.

This analysis of the feedwater nozzle and safe end assembly is required because of the complete redesign of the existing safe end and thermal sleeve assembly. As a consequence of this redesign, the component's geometries will change from the ones originally analyzed, thus necessitating this report. The nozzle and safe end assembly in this report are analyzed in accordance with the requirements of the ASME Code (Reference 6.2), and the General Electric design specification (Reference 6.1).

NUCLEAR ENERGY	GENERAL 🥵 ELECTRIC	22A7454	SH NO. 6
BUSINESS OPERATIONS		REV 1	

2. SUMMARY AND CONCLUSIONS

2.1 It is shown by analysis in this report that the feedwater nozzle and safe end assembly fully meet the stress francity limits for all design, Service Level A, B, and C conditions. Some of the significant results of this analysis are as follows:

NOTE: These results include the results of Appendix 30.

Maximum design primary stress intensity: (Table 3-2 and Table 30.3.1-1)

 $P_m = 14.05$ ksi ; P_m Allowable = 18.1 ksi $P_{M+B} = 24.38$ ksi ; P_{M+R} Allowable = 27.9 ksi

Maximum Level 'C' primary stress intensity: (Table 3-2 and Table 30.3.1-1)

 $P_m = 15.46$ ksi ; P_m Allowable = 27.1 ksi $P_{M+B} = 33.89$ ksi ; P_{M+B} Allowable = 41.7 ksi

Maximum range of primary plus secondary stress intensity, P + Q: (Paragraph 4.2.5.4 and Paragraph 30.3.3.4.4)

P + Q = 62.9 ksi

Maximum range of primary plus secondary stress intensity excluding thermal bending: (Paragraph 4.2.5.4 and Paragraph 30.3.3.4.4)

P + Q = 45.94 ksi ; P + Q Allowable = 55.8 ksi

Maximum total fatigue usage due to low and high cycle fatigue plus existing accumulated fatigue: (Paragraph 4.3.6 and Paragraph 30.3.4.2)

 $\overline{U}_{\text{max}} = 0.439$

NEO 807A (REV. 10/81)

NUCLEAR ENERGY BUSINESS GROUP

GENERAL 🍘 ELECTRIC

22A7454 Rev 1

SH NO. 7

3. DESIGN REQUIREMENTS

The safe end and thermal sleeve geometry is provided in References 6.8, 6.10, and 6.13. The nozzle geometry is provided in References 6.1 and 6.7. The operating thermal and mechanical loads are provided by Reference 6.1.

This section illustrates accceptance for the design and Service Level C conditions. Primary membrane and primary membrane and bending (sizing) calculations are performed.

In Sections G through J, moments due to thermal sleeve axial loads are assumed negligible.

NEBG-807A (6/80)




FIGURE 3.1 NOZZLE, SAFE END, AND THERMAL SLEEVE GEOMETRY

NEDG 807A

GENERAL 🍘 ELECTRIC

TABLE 3-1 SECT	ION PROPERTIES	FOR NOZZLE	(Corrosion	Included)
Section	Thickness (In.)	Area (In ²)	Section Modulus (In ³)	<u>Material</u>
A	0.531	19.03	51.98	SA-508 (CL.2)
B	0.531	19.03	51.98	
č	0.531	19.03	51.98	
D	0.531	19.03	51.98	
E ·	0.531	19.03	51.98	
F	0.4917	15.89	39.09	
Ğ	0.375	10.46	22.32	
H	0.375	10.46	22.32	-
Ĩ	0.494	13.78		SA-351 (CF3)
Ţ	0.494	13.78	29.07	
	operties used $1/4$ ($D_0^2 - D_1^2$)	here (conser		(Outside Diameter - Corrosion)
ALCA - A	v (bo i v		0	
Section = Modulus	$\frac{I}{C} = \frac{\pi/64}{D}$	$\frac{D_o^4 - D_i^4}{o^{/2}}$	D _i =	(Inside Diameter - Corrosion)
Corrosion Allow	ances (Refere	nce 6.1)		·
Exterior E	xposed Carbon	Steel -		1/32 inch
Interior E	xposed Carbon	Steel _		1/16 inch
Interior E	xposed Stainle	ss Steel		0.003 inch
Material Allows	<u>bles</u> (Referen	ce 6.2)		S(at 550°F)
	SA-508	CL.1		18.1 ksi
	SA-609	CL.2		26.7 ksi
<u>Carbon Ste</u>		LF2		18.6 ksi
		GD.6		18.1 ksi
	04 999	Jø.v .		2012
<u>Stainless</u> Ste	els SA-351	CF3		16.0 ksi

NEBG-807A (6/80)

8-10

SH NO. 9

22A7454

REV 1

NUCLEAR		G E	NERAL	ELE	CTRIC		2A7454 EV 1	8 sh no. 10
Load	ing							
No	zzle Safe	End Load	<u>s</u> (Refere	nce 6.1)			·	
							Forces in Moments i	
	<u>Condition</u>	F <u>x</u>	F 	F	<u>M</u>	M 	<u> </u>	R _(in)
Design	-	2.54	3.15	2.28	387.6	172.9	324.6	131.6
Nozzle 'A' Loads	Dead Wt. Seismic Thermal	- 0.11 <u>+</u> 0.29 0.02		0.15 <u>+</u> 2.23 - 0.21	11.6 <u>+</u> 9.3 - 12.0	- 14.1 <u>+</u> 158.9 - 12.1	9 <u>+</u> 313.4	131.6
Nozzle 'B' Loads	Dead Wt. Seismic Thermal	- 0.07 ± 2.44 0.82	<u>+</u> 1.97	- 0.04 ± 0.26 1.37	- 7.0 ± 376.0 267.2	- 2.: ± 106.: - 66.:	3 <u>+</u> 10.6	131.6
The	rmal Sleeve	Loads (1	Reference 6.	.1)		Fe	orces in kir	95
					·	M	oments in in	k ips
Con	dition	F <u>x</u>	F 	F_z	M <u>x</u>	M 	M 	R _(in)
Des	ign	2.5	0.6	5.7	2.4	2.0	0	103.0
Sci The	d Wt. smic <u>+</u> rmal raulic		$\begin{array}{c} \pm 0.3 \\ 0 \\ \end{array}$		- 1.2 <u>+</u> 1.2 0 0	0 + 2.0 0 0	0 0 0 0	103.0

8-11

NEBG-807A (6/80)



22A7454 ^{Rev} 1 8-12

Emergency condition (Service Level 'C') defined in Reference 6.1 as follows:

Normal operation plus two times Seismic Loads

To calculate the largest nozzle loads, use the following:

 $P = (F_{x}^{2} + F_{y}^{2})^{1/2}$ $M = (M_{x}^{2} + M_{y}^{2} + M_{z}^{2})^{1/2}$

Nozzle 'A' Loading (Service Level 'C')

- P = 5.70 kip
- M = 721.5 in-kip
- $F_z = 4.61 \text{ kip}$

Nozzle 'B' Loading (Service Level 'C')

P = 6.44 kip M = 789.3 in-kip F₂ = 0.56 kip

Therefore, the following loads are used for the design and Service Level 'C' conditions: (Note: No faulted condition exists)


Nozzle Loads

		Forces in kips Moments in in-kip			
<u>Condition</u>	<u>P</u> 4.05	<u>M</u> 534.4	<u>F</u> 2.28		
Design Service Level 'C'	6.44	789.3	4.61		

UCLEAR ENERGY	GENERAL 🍪 E	LECTRIC	22A7454 Rev 1	SH NO. 12
Thermal Sleeve Load	ς		 	
	-	Forces in Moments in		
<u>Condition</u>	<u>P</u>	X	F	
Design	2.57	3.124	5.7	
			6.0	

Design Pressure	=	1,250 psi
Service Level 'C' Pressure	æ	1,375 psi

Loading Sign Convention



Sign Convention applies to both safe end and thermal sleeve loadings.

NEBG-807A (6/80)

	GE	N	E	RA	L	36	E	LE	C	T	R	10	;
--	----	---	---	----	---	----	---	----	---	---	---	----	---

NUCLEAR ENERGY BUSINESS GROUP 22A7454 REV 1 8-14 sh no. 13

Section A

Design Pressure Stress:

 $\sigma_{\Theta} = \frac{P D_{i}}{2t} = \frac{1,250 (10,875)}{2 (0.531)} = 12,800 \text{ psi}$ $\sigma_{\Theta} = \frac{\sigma_{\Theta}}{2} = 6,400 \text{ psi}$ $\sigma_{r} = -1,250 \text{ psi}$

Stress Due To Nozzle Loads:

P = 4.05 kip M = 534.4 in-kip $F_{z} = 2.28 \text{ kip}$

m = 534.4 + 4.05 (12.83) + 2.28 (0.56) = 587.64 in-kip

 $\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{587.64}{51.98} = 11.31 \text{ ksi}$

 σ_{AX} = $\frac{F_z}{A}$ = $\frac{2.28}{19.03}$ = 0.12 ksi

NEBG-807A (6/80)

		0
GENERAL 🖓 ELECTRIC	22A7454	SH NO. 14
	REV 1	
mal Sleeve Loads:		
P = 2.57 kip		
-		
M = 3.124 in-kip		
$F_{\tau} = 5.7 \text{ kip}$		
-		
2.57 (15.76) + 5.7 (2.36) = 57.08	8 in-kip	
$=\frac{M}{Z}=\frac{57.08}{51.98}=1.1$ ksi		
2		
F ₇ 5.7		
$= \frac{1}{A} = \frac{1}{19.03} = 0.30$ ksi		
6,400 + 11,310 + 120 + 1,100 + 300		
	GENERAL () ELECTRIC Final Sieeve Loads: P = 2.57 kip M = 3.124 in-kip $F_z = 5.7 \text{ kip}$ 2.57 (15.76) + 5.7 (2.36) = 57.0 $= \frac{M}{Z} = \frac{57.08}{51.98} = 1.1 \text{ ksi}$ $= \frac{F_z}{A} = \frac{5.7}{19.03} = 0.30 \text{ ksi}$	$\frac{\text{REV 1}}{\text{rmal Sleeve Loads:}}$ $P = 2.57 \text{ kip}$ $M = 3.124 \text{ in-kip}$ $F_z = 5.7 \text{ kip}$ $2.57 (15.76) + 5.7 (2.36) = 57.08 \text{ in-kip}$ $= \frac{M}{Z} = \frac{57.08}{51.98} = 1.1 \text{ ksi}$

 $\sigma_{\Theta} = 12,800 \text{ psi}$

 $\sigma_r = -1,250 \text{ psi}$

NEBG-807A (6/80)

Ĺ

8-15

-..

			8-16
NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 REV 1	sh no. 15

Section A

Service Level 'C' Pressure Stress:

 $\sigma_{\Theta} = \frac{P D_{i}}{2t} = \frac{1.375 (10.875)}{2 (0.531)} = 14,081 \text{ psi}$ $\sigma_{\Phi} = \frac{\sigma_{\Theta}}{2} = 7,040 \text{ psi}$ $\sigma_{T} = -1,375 \text{ psi}$

Stress Due To Nozzle Loads:

P = 6.44 kipM = 789.3 in-kip $F_{z} = 4.61 \text{ kip}$

m = 789.3 + 6.44 (12.83) + 4.61 (0.56) = 874.51 in-kip

 $\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{874.51}{51.98} = 16.83 \text{ ksi}$

$$\sigma_{AX.} = \frac{F_z}{A} = \frac{4.61}{19.03} = 0.243$$
 ksi

NEBG-807A (6/80)

ar			8-17
	GENERAL 鎀 ELECTRIC	22A7454	SH NO. 16
USINESS GROUP		REV 1	
Stress Due to 1	Thermal Sleeve Loads:		
	P = 5.08 kip		
	M = 5.39 in-kip		
	$F_{-} = 6.0 \text{ kip}$		
	$F_z = 6.0 \text{ kip}$		
M = 5.39	+ 5.08 (15.76) + 6.0 (2.36) = 99.61	in-kip	
σ _{BEN}	$D_{1} = \frac{M}{Z} = \frac{99.61}{51.98} = 1.92$ ksi		
DEN			

$$\sigma_{AX.} = \frac{F_z}{A} = \frac{6.0}{19.03} = 0.316$$
 ksi

Total Stress

 $\sigma_{\phi} = 7,040 + 16,830 + 243 + 1,920 + 316 = 26,349 \text{ psi}$ $\sigma_{\Theta} = 14,081 \text{ psi}$ $\sigma_{r} = -1,375 \text{ psi}$

NEBG-807A (6/80)



NUCLEAR ENERGY **BUSINESS GROUP**

REV 1

22A7454

Section B

Design Pressure Stress:

 $\sigma_{\Theta} = \frac{P D_i}{2t} = \frac{1.250 (10.875)}{2 (0.531)} = 12,800 \text{ psi}$ $\sigma_{\theta} = \frac{\sigma_{\theta}}{2} = 6,400 \text{ psi}$ $\sigma_{r} = -1,250 \text{ psi}$

Stress Due To Nozzle Loads:

 $P = 4.05 \, kip$ M = 534.4 in-kip $F_{-} = 2.28 \, kip$

M = 534.4 + 4.05 (10.22) + 2.28 (0.56) = 577.07 in-kip

 $\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{577.07}{51.98} = 11.102 \text{ ksi}$

 σ_{AX} = $\frac{F_z}{A}$ = $\frac{2.28}{19.03}$ = 0.12 ksi

NEBG-807A (6/80)

8-18

SH NO. 17

	GENERAL 🛞 ELECTRIC	22A7454	8-19 SH NO. 18
UCLEAR ENERGY USINESS GROUP		REV 1	
		· · · · ·	· · · · · · · · · · · · · · · · · · ·
Stress Due to T	hermal Sleeve Loads:		
	P = 2.57 kips		
	M = 3.124 in-kips		
	$F_{\pm} = 5.7 \text{ kip}$		
	+ 2.57 (18.37) + 5.7 (2.36) = 63.79 = $\frac{M}{Z} = \frac{63.79}{51.98} = 1.23$ ksi	9 in-kip	
σAX.	$= \frac{F_z}{A} = \frac{5.7}{19.03} = 0.30 \text{ ksi}$		
<u>Total Stress</u>			
∞ ∳ =	6,400 + 11,102 + 120 + 1,230 + 300	= 19,152 psi	
రద ్	= 12,800 psi		

-1,250 psi

σ

٠

GENERAL 🍘 ELECTRIC

NUCLEAR ENERGY BUSINESS GROUP 8-20

Section B

Service Level 'C' Pressure Stress:

 $\sigma_{\Theta} = \frac{P D_{i}}{2t} = \frac{1.375 (10.875)}{2 (0.531)} = 14,080.2 \text{ psi}$ $\sigma_{\Phi} = \frac{\sigma_{\Theta}}{2} = 7,040 \text{ psi}$ $\sigma_{r} = -1.375 \text{ psi}$

Stress Due To Nozzle Loads:

P = 6.44 kip M = 789.3 in-kip F_z = 4.61 kip

M = 789.3 + 6.44 (10.22) + 4.61 (0.56) = 857.7 in-kip

 $\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{857.7}{51.98} = 16.501 \text{ ksi}$

$$\sigma_{AX}$$
 = $\frac{F_z}{A}$ = $\frac{4.61}{19.03}$ = 0.243 ksi

LEAR ENERGY	GENERAL 🍘 ELECTRIC	22A7454	SH NO. 20
INESS GROUP		REV 1	
			······
Stress Due to T	hermal Sleeve Loads:		. .
	P = 5.08 kips		
	M = 5.39 in-kips		
	$F_z = 6.0 \text{ kip}$		
	z		
M = 5.39	+ 5.08 (18.37) + 6.0 (2.36) = 112.87	in-kip	
BEND	$=\frac{M}{Z}=\frac{112.87}{51.98}=2.172$ ksi		
σ	$= \frac{F_z}{A} = \frac{6.0}{19.03} = 0.316 \text{ ksi}$		
AX.	A 19.03		
<u>Total Stress</u>			
° ♦ =	7,040 + 16,501 + 243 + 2,172 + 316	= 26,272 psi	
σ. =	= 14,080 psi		
· ·			
ح -	= -1,375 psi		

NEBG-807A (6/80)

	-		8-22
NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev <u>1</u>	SH NO. 21

Section C/D

Design Pressure Stress:

 $\sigma_{\Theta} = \frac{P D_{i}}{2t} = \frac{1.250 (10.875)}{2 (0.531)} = 12,800 \text{ psi}$ $\sigma_{\Phi} = \frac{\sigma_{\Theta}}{2} = 6,400 \text{ psi}$ $\sigma_{r} = -1,250 \text{ psi}$

Stress Due To Nozzle Loads:

P = 4.05 kipM = 534.4 in-kip F_z = 2.28 kip

M = 534.4 + 4.05 (7.47) + 2.28 (0.56) = 566.0 in-kip

$$\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{566.0}{51.98} = 10.89 \text{ ksi}$$

 σ_{AX} = $\frac{F_z}{A}$ = $\frac{2.28}{19.03}$ = 0.12 ksi

EAR ENERGY NESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	sh no. 22
Stress Due to 1	<u>Chermal Sleeve Loads:</u>		
	P = 2.57 kips		··· · _
	M = 3.124 in-kips		
	$F_z = 5.7 \text{ kip}$		
M = 3.12	4 + 2.57 (21.12) + 5.7 (2.36) = 70.8	6 in-kip	
σBEN	$= \frac{M}{Z} = \frac{70.86}{51.98} = 1.364 \text{ ksi}$		
°AX.	$= \frac{F_z}{A} = \frac{5.7}{19.03} = 0.30 \text{ ksi}$		
<u>Total Stress</u>			
۵	= 6,400 + 10,890 + 120 + 1,364 + 300	= 19,074 psi	
٩	= 12,800 psi		
σ_	= -1,250 psi		

SH NO. 23

Section C/D

Service Level 'C' Pressure Stress:

 $\sigma_{\Theta} = \frac{P D_{i}}{2t} = \frac{1.375 (10.875)}{2 (0.531)} = 14,080 \text{ psi}$ $\sigma_{\phi} = \frac{\sigma_{\Theta}}{2} = 7,040 \text{ psi}$ $\sigma_{r} = -1,375 \text{ psi}$

Stress Due To Nozzle Loads:

P = 6.44 kipM = 789.3 in-kip $F_z = 4.61 \text{ kip}$

M = 789.3 + 6.44 (7.47) + 4.61 (0.56) = 840 in-kip

$$\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{840}{51.98} = 16.16 \text{ ksi}$$

$$\sigma_{AX}$$
. = $\frac{1}{A}$ = $\frac{4.61}{19.03}$ = 0.243 ksi

NEBG-807A (6/80)

.

NUCLEAR ENERGY	GENERAL 🍘 ELECTRIC	22.47	454	SH NO.	24
BUSINESS GROUP		REV	1		

•.

Stress Due to Thermal Sleeve Loads:

$$P = 5.08 \text{ kips}$$

$$M = 5.39 \text{ in-kips}$$

$$F_z = 6.0 \text{ kip}$$

$$M = 5.39 + 5.08 (21.12) + 6.0 (2.36) = 126.84 \text{ in-kip}$$

$$\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{128.84}{51.98} = 2.44 \text{ ksi}$$

$$\sigma_{\text{AX.}} = \frac{F_z}{A} = \frac{6.0}{19.03} = 0.316 \text{ ksi}$$
Total Stress

$$\sigma_{\Theta} = 7,040 + 16,160 + 243 + 2,440 + 316 = 26,199 \text{ psi}$$

$$\sigma_{\Theta} = 14,080 \text{ psi}$$

			8-26
NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	SH NO. 25
- <u>, </u>			

Section E

Design Pressure Stress:

 $\sigma_{\Theta} = \frac{P D_{i}}{2t} = \frac{1,250 (10.875)}{2 (0.531)} = 12,800 \text{ psi}$ $\sigma_{\Phi} = \frac{\sigma_{\Theta}}{2} = 6,400 \text{ psi}$ $\sigma_{\tau} = -1,250 \text{ psi}$

Stress Due To Nozzle Loads:

P = 4.05 kip M = 534.4 in-kip $F_{z} = 2.28 \text{ kip}$

M = 534.4 + 4.05 (4.72) + 2.28 (0.56) = 554.8 in-kip

 $\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{554.8}{51.98} = 10.68 \text{ ksi}$

 σ_{AX} = $\frac{F_z}{A}$ = $\frac{2.28}{19.03}$ = 0.12 ksi

JCLEAR ENERGY JSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 REV 1	sh no. 26
<u>Stress Due to T</u>	hermal Sleeve Loads:	_	
	P = 2.57 kip		
	M = 3.124 in-kip		
	$F_z = 5.7 kip$		
M = 3.124	+ 2.57 (23.87) + 5.7 (2.36) = 77.93	i n- kip	
BEND	$=\frac{M}{Z}=\frac{77.93}{51.98}=1.5$ ksi		
^σ ΑΧ.	$= \frac{F_z}{A} = \frac{5.7}{19.03} = 0.30 \text{ ksi}$		·
σ _{AX} .	$=\frac{Z}{A} = \frac{5.7}{19.03} = 0.30$ ksi		

Total Stress

 $\sigma_{\dot{b}} = 6,400 + 10,680 + 120 + 1,500 + 300 = 19,000 \text{ psi}$ $\sigma_{\Theta} = 12,800 \text{ psi}$ $\sigma_{r} = -1,250 \text{ psi}$

NEBG-807A (6/80)



NUCLEAR ENERGY **BUSINESS GROUP**

SH NO. 27

8-28

Section E

Service Level 'C' Pressure Stress:

 $\sigma_{\Theta} = \frac{P D_i}{2t} = \frac{1.375 (10.875)}{2 (0.531)} = 14,080 \text{ psi}$ $\sigma_{i} = \frac{\sigma_{\Theta}}{2} = 7,040 \text{ psi}$ $\sigma_{r} = -1,375 \text{ psi}$ Stress Due To Nozzle Loads: P = 6.44 kipM = 789.3 in-kip F_ = 4.61 kip

M = 789.3 + 6.44 (4.72) + 4.61 (0.56) = 822.28 in-kip

 $\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{822.28}{51.98} = 15.82 \text{ ksi}$

$$\sigma_{AX}$$
 = $\frac{F_z}{A}$ = $\frac{4.61}{19.03}$ = 0.243 ksi

CLEAR ENERGY SINESS GROUP	GENERAL 🍪 ELECTRI	C 22A7454 Rev 1	SH NO. 28
<u>Stress Due to T</u>	hermal Sleeve Loads:		
	P = 5.08 kip		
	¥ = 5.39 in-kip		
	$F_z = 6.0 kip$		
σ _{BEND}	+ 5.08 (23.87) + 6.0 (2.36) = 1 . = $\frac{M}{Z}$ = $\frac{140.81}{51.98}$ = 2.71 ksi F		
σ _{AX} .	$= \frac{F_z}{A} = \frac{6.0}{19.03} = 0.316 \text{ ks}$	i	
<u>Total Stress</u>			· .
σφ =	- 7,040 + 15,820 + 243 + 2,710 +	316 = 26,129 psi	
σ _θ ≖	= 14,080 psi		
ర_ =	= -1,375 psi		

8-29

~

			8-30
NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	_{SH NO.} 29
Section F			•
<u>Section F</u> Design Pressur	o_Stress:		

 $\sigma_{\Theta} = \frac{P D_i}{2t} = \frac{1,250 (9,794)}{2 (0.4917)} = 12,450 \text{ psi}$ $\sigma_{\phi} = \frac{\sigma_{\theta}}{2} = 6,225 \text{ psi}$ $\sigma_r = -1,250 \text{ psi}$

Stress Due To Nozzle Loads:

		P = 4.05 kip
		M = 534.4 in-kip
		$F_z = 2.28 kip$
M	E	534.4 + 4.05 (1.62) = 541 in-kip
		$\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{541.0}{39.09} = 13.84 \text{ ksi}$
		σ_{AX} . = $\frac{F_z}{A}$ = $\frac{2.28}{15.89}$ = 0.144 ksi

UCLEAR ENERGY USINESS GROUPGENERAL GENERAL ConstraintsELECTRIC $22A7454$ RevSH RevStress Due to Thermal Sieeve Loads: $P = 2.57$ kip $M = 3.124$ in-kip $F_z = 5.7$ kip $M = 3.124$ in-kipM = 3.124 + 2.57 (26.97) + 5.7 (1.8) = 82.7 in-kip	NO. 30
$P = 2.57 \text{ kip}$ $M = 3.124 \text{ in-kip}$ $F_z = 5.7 \text{ kip}$	NU
$P = 2.57 \text{ kip}$ $M = 3.124 \text{ in-kip}$ $F_z = 5.7 \text{ kip}$	
$P = 2.57 \text{ kip}$ $M = 3.124 \text{ in-kip}$ $F_z = 5.7 \text{ kip}$	
$F_z = 5.7 \text{ kip}$	• ••
_	
M = 3.124 + 2.57 (26.97) + 5.7 (1.8) = 82.7 in-kip	
$\sigma_{\rm BEND.} = \frac{M}{Z} = \frac{82.7}{39.09} = 2.12$ ksi	
F57	
σ_{AX} = $\frac{F_z}{A}$ = $\frac{5.7}{15.89}$ = 0.36 ksi	
Total Stress	
· · · · · · · · · · · · · · · · · · ·	

 $\sigma_{\phi} = 6,225 + 13,840 + 144 + 2,120 + 360 = 22,689 \text{ psi}$ $\sigma_{\phi} = 12,450 \text{ psi}$ $\sigma_{r} = -1,250 \text{ psi}$

NEBG-807A (6/80)

G	E	N	E	R	A	L	¥6)	E	L	E	C	T	R	l	C	
---	---	---	---	---	---	---	-----	---	---	---	---	---	---	---	---	--

NUCLEAR ENERGY BUSINESS GROUP

Section F

Service Level 'C' Pressure Stress:

 $\sigma_{\Theta} = \frac{P D_{i}}{2t} = \frac{1.375 (9.794)}{2 (0.4917)} = 13,694 \text{ psi}$ $\sigma_{\Phi} = \frac{\sigma_{\Theta}}{2} = 6,847 \text{ psi}$ $\sigma_{r} = -1,375 \text{ psi}$ Stress Due To Nozzle Loads: P = 6.44 kip M = 789.3 in-kip $F_{z} = 4.61 \text{ kip}$ M = 789.3 + 6.44 (1.62) = 799.8 in-kip $\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{799.8}{39.09} = 20.46 \text{ ksi}$

 σ_{AX} . = $\frac{F_z}{A}$ = $\frac{4.61}{15.89}$ = 0.291 ksi

NEBG-807A (6/80)

8-32

SH NO. 31

LEAR ENERGY NESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	SH NO. 32
Stress Due to 1	hermal Sleeve Loads:		
	P = 5.08 kips		
	M = 5.39 in-kips		
	$F_z = 6.0 kip$		
M = 5.39	+ 5.08 (26.97) + 6.0 (1.8) = 153.2	in-kip	
σBEN	$D_{1} = \frac{M}{Z} = \frac{153.2}{39.09} = 3.92 \text{ ksi}$		
σAX.	$= \frac{F_z}{A} = \frac{6.0}{15.89} = 0.378 \text{ ksi}$		
<u>Total Stress</u>	•		
σ	= 6,847 + 20,460 + 291 + 3,920 + 378	= 31,896 psi	

 σ_{Θ} = 13,694 psi

 $\sigma_{r} = -1,375 \text{ psi}$

			8-34
NUCLEAR ENERGY	GENERAL 🥵 ELECTRIC	22A7454	SH NO. 33
BUSINESS GROUP		REV 1	

Thickness Requirement of Section F

Treating the safe end as a 'Nozzle', the safe end thickness adjacent to the attaching pipe shall not be thinner than the greater of the pipe thickness or the quantity t S_{mp}/S_{mn}).

 $t_{p} (S_{mp}/S_{mn}) = 0.526 in$

Where:

t = Pipe nominal thickness S = Pipe allowable (S) S = Safe End Allowable (S)

For our geometry:

mn

t_p = 0.5405 in. S_{mp} = 18.1 ksi S = 18.6 ksi

SAFE END = 0.5855 in. THICKNESS

.'. Criteria Met

LEAR ENERGY INESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	sн NO. 34
Section G			
Design Pressure	Stress:		
	$\sigma_{\Theta} = \frac{P^{*D}_{i}}{2t} = \frac{222^{*}(8.505)}{2(0.375)}$	= 2,518 psi	
	$\sigma_0 = \frac{\sigma_0}{2} = 1,259 \text{ psi}$		
	σ = -222 psi r		
Stress Due to]	hermal Sleeve Loads:		
	P = 2.57 kip		
	M = 3.124 in-kip		
	$F_z = 5.7 kip$		
M = 3.124	+ 2.57 (23.87) = 64.47 in-kip	·	
σBENI	$D_{1} = \frac{M}{Z} = \frac{64.47}{22.32} = 2.89 \text{ ksi}$		
	$=\frac{F_z}{A}=\frac{5.7}{10.46}=0.545$ ksi		·

* 222 psi pressure assumed, twice normal operation

NEBG+807A (6/80)

Stress Due To Nozzle Loads:

P = 4.05 kip M = 534.4 in-kip $F_z = 2.28 \text{ kip}$

The exact amount the safe end loads influence the thermal sleeve is unknown. However, from previous analysis it has been determined that a conservative approach is to ratio the safe end loads to correspond with the moments of inertia.

 $\frac{I_{Thermal Sleeve}}{I_{Nozzle}} = \frac{137.93}{362.33} = 0.381$

NOTE: Corrosion not included in calculation (more conservative)

M = 534.4 + 4.05 (4.72) + 2.28 (1.8) = 557.62 in-kip $\sigma_{\text{BEND.}} = 0.381 \frac{M}{Z} = (0.381) \frac{557.62}{22.32} = 9.52 \text{ ksi}$

 σ_{AX} = 0.381 $\frac{F_z}{A}$ = (0.381) $\frac{2.28}{10.46}$ = 0.083 ksi

Total Stress

 $\sigma_{\phi} = 1,259 + 2,890 + 545 + 9,520 + 83 = 14,297 \text{ psi}$ $\sigma_{\Theta} = 2,518 \text{ psi}$ $\sigma_{r} = -222 \text{ psi}$

NEBG-807A (6/80)

ENERGY GENERAL 🥵 ELECTRIC

22A7454 Rev 1 8-36

SH NO. 35

NUCLEAR ENERGY	GENERAL 🍘 ELECTRIC	2217454	SH NO. 36
BUSINESS GROUP		REV 1	

Section G

Ser 'ng Level C' Pressure Stress:

 $\sigma_{\Theta} = \frac{P^{\bullet}D_{i}}{2t} = \frac{333^{\bullet} (8,505)}{2 (0.375)} = 3,776 \text{ psi}$ $\sigma_{\Phi} = \frac{\sigma_{\Theta}}{2} = 1,888 \text{ psi}$ $\sigma_{T} = -333 \text{ psi}$

Stress Due to Thermal Sleeve Loads:

P = 5.08 kipM = 5.39 in-kip $F_z = 6.0 \text{ kip}$

M = 5.39 + 5.08 (23.87) = 126.65 in-kip

$$\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{126.65}{22.32} = 5.675 \text{ ksi}$$

$$\sigma_{AX}$$
 = $\frac{F_z}{A}$ = $\frac{6.0}{10.46}$ = 0.574 ksi

• 333 psi pressure assumed (conservative)

8-37

GENERAL 🍘 ELECTRIC

22A7454 REV 1

Stress Due To Nozzle Loads:

The exact amount the safe end loads influence the thermal sleeve is unknown. However, from previous analysis it has been determined that a conservative approach is to ratio the safe end loads to correspond with the moments of inertia.

 $\frac{I_{\text{Thermal Sleeve}}}{I_{\text{Nozzle}}} = \frac{137.93}{362.33} = 0.381$

NOTE: Corrosion not included in calculation (more conservative)

M = 789.3 + 6.44 (4.72) + 4.61 (1.8) = 828.0 in-kip

 $\sigma_{\text{BEND.}} = 0.381 \frac{M}{Z} = (0.381) \frac{828.0}{22.32} = 14.134 \text{ ksi}$

 σ_{AX} = 0.381 $\frac{F_z}{A}$ = (0.381) $\frac{4.61}{10.46}$ = 0.168 ksi

Total Stress

 σ_{ϕ} = 1,888 + 5,675 + 574 + 14,134 + 168 = 22,439 psi σ_{Θ} = 3,776 psi σ_{r} = -333 psi

NEBG-807A (6/80)

SH NO. 37

NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	SH NO. 38

<u>Section H</u>

Design Pressure Stress:

 $\sigma_{\Theta} = \frac{P^*D_i}{2t} = \frac{222^* (8.505)}{2 (0.375)} = 2,518 \text{ psi}$ $\sigma_{\Phi} = \frac{\sigma_{\Theta}}{2} = 1,259 \text{ psi}$ $\sigma_r = -222 \text{ psi}$ Stress Due to Thermal Sleeve Loads: P = 2.57 kip M = 3.124 in-kip $F_z = 5.7 \text{ kip}$

M = 3.124 + 2.57 (20.12) = 54.84 in-kip

$$\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{54.84}{22.32} = 2.46 \text{ ksi}$$

$$\sigma_{AX}$$
 = $\frac{F_z}{A}$ = $\frac{5.7}{10.46}$ = 0.545 ksi

* 222 psi pressure assumed (conservative)

NEBG-807A (6/80)

NUCLEAR	ENERGY
BUSINESS	GROUP

P = 4.05 kip M = 534.4 in-kip F₂ = 2.28 kip

The exact amount the safe end loads influence the thermal sleeve is unknown. However, from previous analysis it has been determined that a conservative approach is to ratio the safe end loads to correspond with the moments of inertia.

 $\frac{I_{\text{Thermal Sleeve}}}{I_{\text{Nozzle}}} = \frac{137.93}{362.33} = 0.381$

NOTE: Corrosion not included in calculation (more conservative)

M = 534.4 + 4.05 (8.47) + 2.28 (1.8) = 572.81 in-kip

 $\sigma_{\text{BEND.}} = 0.381 \frac{M}{Z} = (0.381) \frac{572.81}{22.32} = 9.78 \text{ ksi}$

 σ_{AX} = 0.381 $\frac{F_z}{A}$ = (0.381) $\frac{2.28}{10.46}$ = 0.083 ksi

Total Stress

 $\sigma_{0} = 1,259 + 2,460 + 545 + 9,780 + 83 = 14,127 \text{ psi}$ $\sigma_{\Theta} = 2,518 \text{ psi}$ $\sigma_{r} = -222 \text{ psi}$

NEBG-807A (6/80)

8-40

SH NO. 39

22A7454

REV 1

	_		8-41
LEAR ENERGY INESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	sh no. 40
······································		• • • • •	
Section H			
Service Level	'C' Pressure Stress:		
	$\sigma_{\Theta} = \frac{\frac{P * D_{i}}{2t}}{2t} = \frac{333 * (8.505)}{2 (0.375)}$) = 3,776 psi	
	$\sigma_{\phi} = \frac{\sigma_{\Theta}}{2} = 1,888 \text{ psi}$	÷	
	$\sigma = -333 \text{ psi}$		
Stress Due to	Thermal Sleeve Loads:		
	P = 5.08 kip		· -
	M = 5.39 in-kip		
	$F_z = 6.0 \text{ kip}$		•
M = 5.39	+ 5.08 (20.12) = 107.6 in-kip		
GBEN	$\frac{M}{Z} = \frac{M}{22.32} = 4.821 \text{ ksi}$		
σΑΣ.	$= \frac{F_z}{A} = \frac{6.0}{10.46} = 0.574 \text{ ksi}$		

- -

* 333 psi pressure assumed (conservative)

NEBG-807A (6/80)

.

22A7454 Rev 1

Stress Due To Nozzle Loads:

P = 6.44 kip M = 789.3 in-kip $F_z = 4.61 \text{ kip}$

The exact amount the safe end loads influence the thermal sleeve is unknown. However, from previous analysis it has been determined that a conservative approach is to ratio the safe end loads to correspond with the moments of inertia.

 $\frac{I_{\text{Thermal Sleeve}}}{I_{\text{Nozzle}}} = \frac{137.93}{362.33} = 0.381$

<u>NOTE:</u> Corrosion not included in calculation (more conservative)

M = 789.3 + 6.44 (8.47) + 4.61 (1.8) = 852.15 in-kip $\sigma_{\text{BEND.}} = 0.381 \frac{M}{Z} = (0.381) \frac{852.15}{22.32} = 14.55 \text{ ksi}$ $\sigma_{AX} = 0.381 \frac{F_z}{A} = (0.381) \frac{4.61}{10.46} = 0.168 \text{ ksi}$

Total Stress

 $\sigma_{\dot{0}} = 1,888 + 4,821 + 574 + 14,550 + 168 = 22,001 \text{ psi}$ $\sigma_{\Theta} = 3,776 \text{ psi}$ $\sigma_{r} = -333 \text{ psi}$

NEBG-807A (6/80)

SH NO. 41

UCLEAR ENERGY USINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 REV 1	sh no. 42
		· · · · · · · · · · · · · · · · · · ·	
Section I			
Design Pressure	Stress:		
	$\sigma_{\Theta} = \frac{\frac{P * D_{i}}{2t}}{2t} = \frac{222 * (8,386)}{2 (0.494)}$) = 1,884 psi	
	$\sigma_{\phi} = \frac{\sigma_{\Theta}}{2} = 942 \text{ psi}$		
	σ _r = -222 psi		
Stress Due to	Thermal Sleeve Loads:		
	P = 2.57 kip		
	M = 3.124 in-kip		
	$F_z = 5.7 kip$	•	
M = 3.12	4 + 2.57 (20.12) = 54.84 in-kip		
σ _{BEN}	D. $=\frac{M}{Z} = \frac{54.84}{29.07} = 1.887$ ksi		

* 222 psi pressure assumed (conservative)

NEBG-807A (6/80)

8-43

.



NUCLEAR ENERGY BUSINESS GROUP 22A7454 Rev <u>1</u> 8-44 sh no. **43**

Stress Due To Nozzle Loads:

P = 4.05 kip M = 534.4 in-kip F_z = 2.28 kip

The exact amount the safe end loads influence the thermal sleeve is unknown. However, from previous analysis it has been determined that a conservative approach is to ratio the safe end loads to correspond with the moments of inertia.

 $\frac{I_{\text{Thermal Sleeve}}}{I_{\text{Nozzle}}} = \frac{137.93}{362.33} = 0.381$

NOTE: Corrosion not included in calculation (more conservative)

M = 534.4 + 4.05 (8.47) + 2.28 (1.8) = 572.81 in-kip $\sigma_{\text{BEND.}} = 0.381 \frac{M}{Z} = (0.381) \frac{572.81}{29.07} = 7.51 \text{ ksi}$ $\sigma_{\text{AX.}} = 0.381 \frac{F_z}{A} = (0.381) \frac{2.28}{13.78} = 0.063 \text{ ksi}$

Total Stress

 $\sigma_{0} = 942 + 1,887 + 414 + 7,510 + 63 = 10,816 \text{ psi}$ $\sigma_{\Theta} = 1,884 \text{ psi}$ $\sigma_{r} = -222 \text{ psi}$

NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	SH NO. 44

Section I

Service Level 'C' Pressure Stress:

 $\sigma_{\Theta} = \frac{p \cdot p_{i}}{2t} = \frac{333 \cdot (8.386)}{2(0.494)} = 2,826 \text{ psi}$ $\sigma_{\Phi} = \frac{\sigma_{\Theta}}{2} = 1,413 \text{ psi}$ $\sigma_{r} = -333 \text{ psi}$

Stress Due to Thermal Sleeve Loads:

P = 5.08 kipM = 5.39 in-kip $F_z = 6.0 \text{ kip}$

M = 5.39 + 5.08 (20.12) = 107.6 in-kip

$$\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{107.6}{29.07} = 3.702 \text{ ksi}$$

$$\sigma_{AX}$$
 = $\frac{F_z}{A}$ = $\frac{6.0}{13.78}$ = 0.436 ksi

333 psi pressure assumed (conservative)

NEBG-807A (6/80)

GENERAL 🍪 ELECTRIC

22A7454 REV 1

Stress Due To Nozzle Loads:

P = 6.44 kipM = 789.3 in-kip $F_{-} = 4.61 \, kip$

The exact amount the safe end loads influence the thermal sleeve is unknown. However, from previous analysis it has been determined that a conservative approach is to ratio the safe end loads to correspond with the moments of inertia.

 $\frac{I_{\text{Thermal Sleeve}}}{I_{\text{Nozzle}}} = \frac{137.93}{362.33} = 0.381$

NOTE: Corrosion not included in calculation (more conservative)

M = 789.3 + 6.44 (8.47) + 4.61 (1.8) = 852.15 in-kip

 $\sigma_{\text{BEND}} = 0.381 \frac{M}{Z} = (0.381) \frac{852.15}{29.07} = 11.17 \text{ ksi}$

 σ_{AX} = 0.381 $\frac{F_z}{A}$ = (0.381) $\frac{4.61}{13.78}$ = 0.128 ksi

Total Stress

 σ_{h} = 1,413 + 3,702 + 436 + 11,170 + 128 = 16,849 psi $\sigma_{\Omega} = 2,826 \text{ psi}$ σ_ = −333 psi

NEBG-807A (6/80)

SH NO. 45

NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 REV 1	sh no. 46
Section J			

Design Pressure Stress:

 $\sigma_{\Theta} = \frac{P \cdot D_i}{2t} = \frac{222 \cdot (8.386)}{2(0.494)} = 1,884 \text{ psi}$ $\sigma_{\Phi} = \frac{\sigma_{\Theta}}{2} = 942 \text{ psi}$ $\sigma_{g} = -222 \text{ psi}$ <u>Stress Due to Thermal Sleeve Loads:</u>

P = 2.57 kipM = 3.124 in-kip F_z = 5.7 kip

M = 3.124 + 2.57 (19.33) = 52.81 in-kip

$$\sigma_{\text{BEND.}} = \frac{M}{Z} = \frac{52.81}{29.07} = 1.82 \text{ ksi}$$

$$\sigma_{AX}$$
 = $\frac{F_z}{A}$ = $\frac{5.7}{13.78}$ = 0.414 ksi

* 222 psi pressure assumed (conservative).

NEBG-807A (6/80)

SH NO. 47

Stress Due To Nozzle Loads:

P = 4.05 kip M = 534.4 in-kip F_z = 2.28 kip

The exact amount the safe end loads influence the thermal sleeve is unknown. However, from previous analysis it has been determined that a conservative approach is to ratio the safe end loads to correspond with the moments of inertia.

 $\frac{I_{\text{Thermal Sleeve}}}{I_{\text{Nozzle}}} = \frac{137.93}{362.33} = 0.381$

<u>NOTE:</u> Corrosion not included in calculation (more conservative)

M = 534.4 + 4.05 (9.26) + 2.28 (1.8) = 576.01 in-kip $\sigma_{\text{BEND.}} = 0.381 \frac{M}{Z} = (0.381) \frac{576.01}{29.07} = 7.55 \text{ ksi}$

 σ_{AX} = 0.381 $\frac{F_z}{A}$ = (0.381) $\frac{2.28}{13.78}$ = 0.063 ksi

Total Stress

 $\sigma_{\phi} = 942 + 1,820 + 414 + 7,550 + 63 = 10,789 \text{ psi}$ $\sigma_{\Theta} = 1,884 \text{ psi}$ $\sigma_{\tau} = -222 \text{ psi}$

JCLEAR ENERGY	GENERAL 🌮 ELECTRIC	2217454	SH NO.	48
JSINESS GROUP		REV 1		
Section J				
	C' Pressure Stress:			
Service Level	C ^r riessule <u>Sciess</u> .		-	
· · · · · ·	$\sigma_{\Theta} = \frac{P^*D_i}{2t} = \frac{333^* (8,386)}{2 (0.494)}$	= 2,826 psi		
	$\sigma_{\phi} = \frac{\sigma_{\Theta}}{2} = 1,413 \text{ psi}$			
	σ = -333 psi r			
Stress Due to T	hermal Sleeve Loads:			
	P = 5.08 kip			
	M = 5.39 in-kip			
• •	$F_z = 6.0 \text{ kip}$		•.	
¥ = 5.39	+ 5.08 (19.33) = 103.59 in-kip			
σ _{BEND}	$= \frac{M}{Z} = \frac{103.59}{29.07} = 3.564$ ksi			
٥.	$= \frac{F_z}{A} = \frac{6.0}{13.78} = 0.436 \text{ ksi}$			

• 333 psi pressure assumed (conservative).

Stress Due To Nozzle Loads:

P = 6.44 kipM = 789.3 in-kip $F_z = 4.61 \text{ kip}$

The exact amount the safe end loads influence the thermal sleeve is unknown. However, from previous analysis it has been determined that a conservative approach is to ratio the safe end loads to correspond with the moments of inertia.

 $\frac{I_{\text{Thermal Sleeve}}}{I_{\text{Nozzle}}} = \frac{137.93}{362.33} = 0.381$

<u>NOTE:</u> Corrosion not included in calculation (more conservative)

M = 789.3 + 6.44 (9.26) + 4.61 (1.8) = 857.24 in-kip

 $\sigma_{\text{BEND.}} = 0.381 \frac{M}{Z} = (0.381) \frac{857.24}{29.07} = 11.24 \text{ ksi}$

 σ_{AX} = 0.381 $\frac{F_z}{A}$ = (0.381) $\frac{4.61}{13.78}$ = 0.128 ksi

Total Stress

 σ_{ϕ} = 1,413 + 3,564 + 436 + 11,240 + 128 = 16,781 psi σ_{Θ} = 2,826 psi σ_{r} = -333 psi

NEBG-807A (6/80)

8-50

SH NO. 49

22A7454

REV 1

GENERAL 🍘 ELECTRIC

NUCLEAR ENERGY BUSINESS GROUP 22A7454 REV 1

TABLE 3-2 MAXIMUM PRIMARY STRESS INTENSITY

P_m - Primary Membrane P_m - Primary Bending

All Stresses in ksi

<u>Condition</u>	Section	P	P • MA11ow,	$P_{m} + P_{b}$	P + P ** A110w	<u>Naterial</u>
	A	14.05	26.7	20.48	40.05	SA-508 (CL.2)
	· B	14.05	18.1	20.41	27.15	SA-508 (CL.1)
	С	14.05	18.1	20.33	27.15	SA-508 (CL.1)
	D	14.05	18.6	20.33	27.90	SA-350 (LF2)
Design	Ε	14.05	18.6	20.25	27.90	SA-350 (LF2)
Event	F	13.70	18.6	23.94	27.90	SA-350 (LF2)
	G	2.74	18.6	14.52	27,90	SA-350"('LF2) "
_	H	2.74	18.6	14.35	27,90	SA-350 (LF2)
	H I	2.11	16.0	11.04	24.0	SA-351 (CF3)
	J	2.11	16.0	11.01	24.0	SA-351 (CF3)
	Å	15.46	42.60	27.73	63.90	SA-508 (CL.2)
	В	15.46	27.10	27.65	40.65	SA-508 (CL.1)
	С	15.46	27.10	27.58	40.65	SA-508 (CL.1)
Service	D	15.46	27.85	27.58	41.77	SA-350 (LF2)
Level	E	15.46	27.85	27.51	41.77	SA-350 (LF2)
'C'	F	15.07	27.85	33.28	41.77	SA-350 (LF2)
Event	G	4.11	27.85	22.77	41.77	SA-350 (LF2)
	H	4.11	27.85	22.33	41.77	SA-350 (LF2)
	I	3.16	19.2	17.18	28.80	SA-351 (CF3)
	J	3.16	19.2	17.11	28.80	SA-351 (CF3)

* P is S for Design and the larger of 1.2 S or S for Service Level C. Mallowable

** P + P is 1.5 S for Design and the larger of 1.8 S or 1.5 S for m BAllowable m Service Level C.

4. ANALYSIS

This section provides all the detailed thermal and stress analysis required to show an acceptable design for the operating transients imposed on the nozzle and safe end assembly.

NEBG-807A (6/80)

8-51

SH NO. 50


GENERAL 🍘 ELECTRIC

NUCLEAR ENERGY BUSINESS GROUP 22A7454 Rev 1 SH NO. 51


4.1 <u>Thermal Transient Analysis</u>. The only feedwater nozzle thermal transient for the vessel operating conditions (Service Levels A and B) is defined in the design specification (Reference 6.1). This transient is also illustrated in Figure 4.1-1 for convenience. In order to simplify the thermal analysis, the feedwater transient was idealized as two separate transients (a heatup and cooldown). These idealized transients are illustrated in Figure 4.1-2. Notice the step change in temperatures were simulated by steep ramps. This was done to facilitate numerical convergence and results in slightly nonconservative stresses. For more detailed information on the two idealized transients, see Reference 6.1.

4.1.1 <u>Thermal Model.</u> The axisymmetric finite element model of the feedwater nozzle is shown in Figure 4.1.1-1. The model is made up of 2-D axisymmetric isoparametric temperature elements (STIF 55, Reference 6.3). A portion of the vessel wall was modeled as a disc for convenience of analysis since the effect of this approximation on the temperature solutions in the regions of interest is insignificant. The model ends (RPV, thermal sleeve, and safe end) are considered constant for all temperatures. The thermal properties used are as follows. Thermal properties are those of approximately 360°F.

Carbon Steel	K	H	0.03972 BTU/min in°F
•	p	=	0.283 lb/in ³
	c _p	=	0.1226 BTU/1bm°F
	_		· · · · · · · · · · · · · · · · · · ·
<u>Stainless Steel</u>	K	=	0.01327 BTU/min in°F
	p	=	0.290 lb/in ³



NEBG 807A



GENERAL BELECTRIC

NUCLEAR ENERGY BUSINESS GROUP

REV 1____

4.1.2 <u>Feedwater Nozzle Heat Transfer Coefficients</u>. The heat transfer coefficients were evaluated as specified in Appendix 20 of the design specification (Reference 6.1) The nozzle metal surfaces having unique film heat transfer coefficients are i... tified in Figure 4.1.1-1. The calculated values for each of these surfaces follow. Table 4.1.2-1 contains the water properties used at the various temperatures analysed.

4.1.2.1 Cool-Down Transient

<u>Region 1</u> ID = 9.67 in. = 0.80575 ft.

No Flow Condition (Natural Convection)

For natural convection the film heat transfer equation is as follows (Reference 6.4):

$$h_{f} = 0.14 \frac{K}{L} (GR Pr)^{1/3}$$

= 0.14 K $\left(\frac{p^{2} \beta g}{\mu^{2}} (Pr)\right)^{1/3} \Delta T^{1/3}$

using water properties at 350°F, and assuming a film temperature differential (ΔT) of 10°F, obtain

 $h_f = 218.44 \text{ BTU/Hr Ft}^2 \circ F$

NEBG-807A (6/80)

8-55

SH NO. 54

SH NO. 55

TABLE 4.1.2-1 WATER PROPERTIES

				<u>T (°F)</u>			
	ater operty	<u>100</u>	200	<u>250</u>	<u>350</u>	<u>500</u>	<u>550</u>
ρ	<u>Ibm</u> Ft ³	62.0	60.1	58.8	55.6	49.0	45.9
С _р	BIU 1bm °F	0.998	1.00	1.01	1.05	1.19	1.31
μ	<u>Ibm</u> Ft Sec	0.46×10^{-3}	0.205×10^{-3}	0.158×10^{-3}	0.105×10^{-3}	0.71 ± 10^{-4}	$0.64 \ge 10^{-4}$
K	<u>BIU</u> Hr Ft °F	0.364	0.394	0.396	0.391	0.349	0.325
	Pr	4.52	1.88	1.45	1.02	0.87	0.93
β	<u>1</u> •F	2×10^{-4}	4×10^{-4}	4.8 x 10 ⁻⁴ .	$6.9 \ge 10^{-4}$	1 x 10 ⁻³	1.1×10^{-3}
μ	<u>Ibm</u> Ft Hr	1.649	0.738	0.569			
	Where:				(Values t	aken from Refe	rence 6.4)
	P	= Density					
	с _р	= Specific	Heat				
	μ	= Viscosit	У				

- K = Conductivity
- R_{ρ} = Reynolds No. = (DV ρ/μ)
- V = Fluid Velocity
- $P_{T} = Prandt1$ No.

AND

 $1 \text{ gal} = 0.1337 \text{ Ft}^3$

NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	SH NO. 56

Forced Convection

For turbulent flow, the film heat transfer coefficient equation is as follows: (Reference 6.4):

$$h_{f} = 0.023 \frac{K}{D} R_{e} \frac{0.8}{r} P_{r}$$

And for 25% flow (100% flow = 3,720 Gal/min) (Reference 6.1)

$$\nabla = \frac{Q}{A} = \frac{0.25(3.720)(0.1337)(4)(60)}{\pi (0.80575)^2} = 14,631 \text{ Ft/Hr}$$

At T =
$$550^{\circ}F$$

 $\frac{DV_{\rho}}{\mu} = 2.35 \times 10^6$; $R_e^{0.8} = 1.25 \times 10^5$ R $P_r = 0.93$; $P_r^{0.4} = 0.9708$ 2 F

$$\underline{At T} = 500^{\circ}F$$

$$R_{e} = \frac{DV\rho}{\mu} = 2.26 \times 10^{6} ; R_{e}^{0.8} = 1.211 \times 10^{5}$$

$$P_{r} = 0.87 ; Pr^{0.4} = 0.9465$$

$$\therefore h_{e} = 1142.23 \text{ BTU/Hr Ft}^{2} \text{ oF}$$

At T =
$$350^{\circ}F$$

$$R_{e} = \frac{DV_{p}}{\mu} = 1.734 \times 10^{6} ; R_{e}^{0.8} = 9.80 \times 10^{4}$$
$$P_{r} = 1.015 ; Pr^{0.4} = 1.006$$
$$\therefore h_{f} = 1100.4 \text{ BTU/Hr Ft}^{2} \text{ oF}$$

JCLEAR ENERGY JSINESS GROUP	GENERAL 🍪 ELECTRIC	8-58 22A7454 SH NO. 57 REV 1
<u>At T = 200°F</u>		
I	$e = \frac{DV\rho}{\mu} = 9.6 \times 10^5$; R	$e^{0.8} = 6.107 \times 10^4$
	P = 1.88 ; P	$r^{0.4} = 1.2853$
	$h_{f} = 882.84 B$	TU/Hr Ft ² °F
<u>At T = 100°F</u>	DVo 5	0.8
1	$e = \frac{DV\rho}{\mu} = 4.433 \times 10^5$; E	
	$P_{r} = 4.52$; F	$r^{0.4} = 1.828$
	$h_{f} = 625.27 H$	STU/Hr Ft ² °F
	·	•

USINESS GROUP REV 1 Region 2 D = 8.38 in. = 0.69833 ft. No Flow Condition (Natural Convection) For natural convection, the film heat transfer equation is identic: that of Region 1. Again using water properties at 350°F and a ΔT of 10 obtain \therefore h _f = 218.44 BTU/Hr Ft ² °F Forced Convection For turbulent flow, the film heat transfer equation is as follows: (Reference 6.4): h _f = 0.023 $\frac{K}{D}$ R _e ^{0.8} P _r ^{0.4} And for 25% flow (100% flow = 3,720 Gal/min) (Reference 6.1) $V = \frac{Q}{A} = \frac{0.25(3,720)(0.1337)(4)(60)}{\pi (0.69833)^2} = 19,478.3 Ft/$ At T = 550°F R _e = 2.7098 x 10 ⁶ ; R _e ^{0.8} = 1.4007 x 10 ⁵ P _r ^{0.4} = 0.9708	a1 to
No Flow Condition (Natural Convection) For natural convection, the film heat transfer equation is identical that of Region 1. Again using water properties at 350°F and a ΔT of 10 obtain $\therefore h_f = 218.44 \text{ BTU/Hr Ft}^2 \text{ oF}$ Forced Convection For turbulent flow, the film heat transfer equation is as follows: (Reference 6.4): $h_f = 0.023 \frac{\text{K}}{\text{D}} \text{ R}_e \frac{0.8}{\text{P}_x} \frac{0.4}{\text{A}}$ And for 25% flow (100% flow = 3,720 Gal/min) (Reference 6.1) $V = \frac{Q}{A} = \frac{0.25(3,720)(0.1337)(4)(60)}{\pi (0.69833)^2} = 19,478.3 \text{ Ft/}$ At T = 550°F $R_e = 2.7098 \times 10^6$; $R_e^{0.8} = 1.4007 \times 10^5$	al to
For natural convection, the film heat transfer equation is identic; that of Region 1. Again using water properties at 350°F and a ΔT of 10 obtain $\therefore h_f = 218.44 \text{ BTU/Hr Ft}^2 \text{ eF}$ Forced Convection For turbulent flow, the film heat transfer equation is as follows: (Reference 6.4): $h_f = 0.023 \frac{\text{K}}{\text{D}} \text{ R}_e = 0.8 \text{ P}_r = 0.4$ And for 25% flow (100% flow = 3,720 Gal/min) (Reference 6.1) $V = \frac{Q}{A} = \frac{0.25(3,720)(0.1337)(4)(60)}{\pi (0.69833)^2} = 19,478.3 \text{ Ft/}$ At T = 550°F $R_e = 2.7098 \times 10^6$; $R_e^{0.8} = 1.4007 \times 10^5$	al to
that of Region 1. Again using water properties at 350°F and a ΔT of 10 obtain $\therefore h_f = 218.44 \text{ BTU/Hr Ft}^2 \text{ °F}$ Forced Convection For turbulent flow, the film heat transfer equation is as follows: (Reference 6.4): $h_f = 0.023 \frac{\text{K}}{\text{D}} \text{ R}_e \stackrel{0.8}{\text{P}_r} \stackrel{0.4}{\text{M}}$ And for 25% flow (100% flow = 3,720 Gal/min) (Reference 6.1) $V = \frac{Q}{A} = \frac{0.25(3.720)(0.1337)(4)(60)}{\pi (0.69833)^2} = 19,478.3 \text{ Ft/}$ At T = 550°F $R_e = 2.7098 \times 10^6$; $R_e^{0.8} = 1.4007 \times 10^5$	al to
$\frac{\text{Forced Convection}}{\text{For turbulent flow, the film heat transfer equation is as follows:} (Reference 6.4): h_f = 0.023 \frac{\text{K}}{\text{D}} R_e^{0.8} P_r^{0.4} And for 25% flow (100% flow = 3,720 Gal/min) (Reference 6.1) V = \frac{Q}{A} = \frac{0.25(3.720)(0.1337)(4)(60)}{\pi (0.69833)^2} = 19,478.3 \text{ Ft/} \frac{\text{At T} = 550^{\circ}\text{F}}{R_e} = 2.7098 \times 10^6 ; R_e^{0.8} = 1.4007 \times 10^5$	
For turbulent flow, the film heat transfer equation is as follows: (Reference 6.4): $h_{f} = 0.023 \frac{K}{D} R_{e}^{0.8} P_{r}^{0.4}$ And for 25% flow (100% flow = 3,720 Ga1/min) (Reference 6.1) $V = \frac{Q}{A} = \frac{0.25(3.720)(0.1337)(4)(60)}{\pi (0.69833)^{2}} = 19,478.3 \text{ Ft/}$ $\frac{At T = 550^{\circ}F}{R_{e}} = 2.7098 \times 10^{6} ; R_{e}^{0.8} = 1.4007 \times 10^{5}$	
(Reference 6.4): $h_{f} = 0.023 \frac{K}{D} R_{e} ^{0.8} P_{r} ^{0.4}$ And for 25% flow (100% flow = 3,720 Gal/min) (Reference 6.1) $V = \frac{Q}{A} = \frac{0.25(3.720)(0.1337)(4)(60)}{\pi (0.69833)^{2}} = 19,478.3 Ft/$ At T = 550°F $R_{e} = 2.7098 \times 10^{6} ; R_{e} ^{0.8} = 1.4007 \times 10^{5}$	
And for 25% flow (100% flow = 3,720 Gal/min) (Reference 6.1) $V = \frac{Q}{A} = \frac{0.25(3.720)(0.1337)(4)(60)}{\pi (0.69833)^2} = 19,478.3 \text{ Ft/}$ At T = 550°F R _e = 2.7098 x 10 ⁶ ; R _e ^{0.8} = 1.4007 x 10 ⁵	
(Reference 6.1) $V = \frac{Q}{A} = \frac{0.25(3,720)(0.1337)(4)(60)}{\pi (0.69833)^2} = 19,478.3 \text{ Ft/}$ At T = 550°F $R_e = 2.7098 \times 10^6 ; R_e^{0.8} = 1.4007 \times 10^5$	
<u>At T = 550°F</u> $R_e = 2.7098 \times 10^6$; $R_e^{0.8} = 1.4007 \times 10^5$	
$R_e = 2.7098 \times 10^6$; $R_e^{0.8} = 1.4007 \times 10^5$	Hr
$P_r^{0.4} = 0.9708$	
$h_{f} = 1455.6 \text{ BTU/Hr Ft}^2 \text{ °F}$	
$At T = 500^{\circ}F$	
$R_e = 2.6076 \times 10^6$; $R_e^{0.8} = 1.358 \times 10^5$	
$P_r^{0.4} = 0.94648$	
$h_{f} = 1477.75 \text{ BTU/Hr Ft}^2 \text{ °F}$	

8-59

			0-00
LEAR ENERGY	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	sh no. 59
	· · · · · · · · · · · · · · · · · · ·	,	
$\underline{At T} = 350^{\circ}$	$\frac{F}{R_e} = 2.0007 \times 10^6 ; R_e^{0.8} = 1.09$	89 x 10 ⁵	
	$P_r^{0.4} = 1.006$		
	$h_{f} = 1423.6 \text{ BTU/Hz}$	Ft ² °F	
<u>At T = 2009</u>	$\frac{PF}{R_e} = 1.1077 \times 10^6$; $R_e^{0.8} = 6.84$	477 x 10 ⁴	
	$P_r^{0.4} = 1.2853$		
	$h_{f} = 1142.12 \text{ BTU/}$	Hr Ft ² °F	
<u>At T = 100</u>	$\frac{P_{e}}{R_{e}} = 5.115 \times 10^{5}$; $R_{e}^{0.8} = 3.6$	903 x 10 ⁴ .	
	$P_r^{0.4} = 1.828$		
	$h_{f} = 808.92 \text{ BTU/H}$	r Ft ² °F	

8–60

GENERAL 🍪 ELECTRIC	22A7454
	REV 1

No Flow Condition (Natural Convection)

For natural convection, the film heat transfer equation is identical to that of Region 1. Again using water properties at 350°F and a AT of 10°F, obtain

".
$$h_f = 218.44 \text{ BTU/Hr Ft}^2 \text{ °F}$$

Forced Convection

For turbulent flow, the film heat transfer equation is as follows: (Reference 6.4):

$$h_{f} = 0.023 \left(\frac{K}{D}\right) \left(R_{e}\right)^{0.8} \left(P_{r}\right)^{0.4}$$

And for 25% flow (100% flow = 3,720 Gal/min) (Reference 6.1)

$$V = \frac{Q}{A} = \frac{0.25(3,720)(0.1337)(4)(60)}{\pi (0.51333)^2} = 36,047.6 \text{ Ft/Hr}$$

At $T = 550^{\circ}F$

$$R_{e} = 3.686 \times 10^{6} ; R_{e}^{0.8} = 1.792 \times 10^{5}$$

$$P_{r}^{0.4} = 0.9708$$

$$h_{f} = 2533.05 \text{ BTU/Hr Ft}^{2} \text{ °F}$$

At T = 500°F

$$R_e = 3.5474 \times 10^6$$
; $R_e^{0.8} = 1.7375 \times 10^5$
 $P_r^{0.4} = 0.9465$
 $\therefore h_f = 2571.5 \text{ BTU/Hr Ft}^2 \text{ oF}$

NEBG-807A (6/80)

SH NO. 60

LEAR ENERGY NESS GROUP	GENERAL 🍘 ELECTRIC	22A7454 REV 1	SH NO. 61
<u>At T = 350°F</u>			
	$R_e = 2.7218 \times 10^6$; $R_e^{0.8} = 1.405$	7 x 10 ⁵	
	$P_{r}^{0.4} = 1.006$		
·	$h_{f} = 2477.4 \text{ BTU/Hr}$	Ft ² °F	
<u>At T = 200°F</u>			
	$R_e = 1.5069 \times 10^6$; $R_e^{0.8} = 8.759$	4 x 10 ⁴	
	$P_{x}^{0.4} = 1.285$		
	h _f = 1987.5 BTU/Hr	Ft ² °F	
<u>At T = 100°F</u>			
	$R_e = 6.958 \times 10^5$; $R_e^{0.8} = 4.720$	6 x 10 ⁴	
	$P_r^{0.4} = 1.828$		
	$h_{f} = 1407.67 \text{ BTU/Hr}$	Ft ² °F	

REV 1

22A7454

Region 4

As given in the design specification (Reference 6.1), the exterior surfaces are to be insulated with material having a conduction rat of 0.2 BIU/Hr Ft² °F. The ambient air outside the insulation is to be at least 100°F during normal operation. Therefore, for all feedwater flow and no flow conditions, use

$$h_{f} = 0.2 \frac{BTU}{H_{T} E_{t}^{2} e_{E}}$$

Region 5

As given in Appendix 20 of the design specification (Reference 6.1), the heat transfer coefficient against the vessel wall is constant for all feedwater flow conditions.

$$h_f = 500 \frac{BTU}{Hr Ft^2 \circ F}$$

For no feedwater flow, natural convection is the medium of heat transfer. The film heat transfer equation for natural convection is identical to that of Region 1. Using water properties of 350°F and a AT of 10°F, obtain


$$h_f = 218.44 \qquad \frac{BTU}{Hr Ft^2 \circ F}$$

Region 6

Region 6 is broken up into five separate sections. This is illustrated in Figure 4.1.2-1. In addition to this, the film heat transfer coefficient on the lower surface must be adjusted to compensate for the secondary thermal sleeve which is present there. Since the temperature of the water in the annulus is given in Appendix 20 of the design specification (Reference 6.1), an equivalent heat transfer coefficient for the lower surface will be used which includes the secondary sleeve. This is illustrated in Figure 4.1.2-2.

SH NO. 62

			8-64
NUCLEAR ENERGY	GENERAL 🕵 ELECTRIC	22A7454	SH NO. 63
BUSINESS GROUP		REV 1	





Ì

NE36 807A




FIGURE 4.1.2-2 EQUIVALENT HEAT TRANSFER COEFFICIENT

NEBG 807A



SH NO. 65

8-66

Upper Surface

For all feedwater flows, the film heat transfer coefficient for the upper surface is given in Appendix 20 of the design specification (Reference 6.1). The coefficients given are as follows (h_f in BTU/Ft Hr² °F);

Section	h _f at Left End	h at Right End	Variation
A - B*	400	750	Linear
B - C*	750	750	Constant
C - D	7 5 0	1500	Linear
D – E	1500	1500	Constant
E – F	1500	500	Linear

Lower Surface

Since the thermal model does not include the secondary thermal sleeve; the equivalent film heat transfer coefficient for the outer surface of the primary sleeve must be found. The equivalent heat transfer analysis for the primary sleeve is made up of the following:

- a. h_f of outer surface secondary sleeve (h_1)
- b. h_f of inner surface secondary sleeve (h_2)
- c. h_f of outer surface primary sleeve (h_3)

The conduction through the secondary sleeve will be neglected along with any conduction through the water. The three modes of heat transfer are illustrated in Figure 4.1.2-2.

NOTE: This is different from the design specification. However, the slight difference yields higher heat transfer coefficients for these sections and thus is conservative.

GENERAL 🍘 ELECTRIC NUCLEAR ENERGY **BUSINESS GROUP** REV 1 Natural convection will be assumed for the annulus between the two sleeves. Therefore, from Reference 6.4, for natural convection, $h_f = 0.14 \left(\frac{K}{L}\right) (Gr Pr)^{1/3}$ = 0.14 K $\left(\frac{p^2 \beta g}{\mu^2}$ (Pr.) $1/3 \Delta T^{1/3}$ using properties at $T = 350^{\circ}F$, obtain $h_{f} = 101.39 \text{ AT}^{1/3} \frac{BTU}{Hr Ft^2 \circ F}$ Assuming the AT from the water to the thermal sleeve surface is the same for both primary and secondary sleeves, obtain $q = h_{eq_T} \land (\Delta T_T)$ where: A = surface area $\frac{1}{h_{eq_{rr}}} = \frac{1}{h_{1}} + \frac{1}{h_{2}} + \frac{1}{h_{3}}$ $\Delta T_{T} = T_{Annulus} - T_{Feedwater}$ And $q = h_{eq_1}, A(\Delta T_1)$ where: A = surface area $\frac{1}{h_{eq}} = \frac{1}{h_{1}} + \frac{1}{h_{2}}$

 $\Delta T_1 = 2\Delta T$

And

 $q = h_1 A \Delta T$ where:

> = surface area A

NEBG-807A (6/80)

8-67

SH NO. 66

22.47454

SH NO. 67

8-68

Using the fact that the heat flow is constant through the heat transfer path, obtain q = constant

Therefore,

 h_{eq_T} (ΔT_T) = $h_1 \Delta T$

Recalling that for natural convection,

$$h_f = h_1 = h_2 = 101.4 \ \Delta T^{1/3}$$

obtain

$$\left(\frac{1}{\frac{1}{h_3} + \frac{2}{101.4 \ \Delta T^{1/3}}}\right) \qquad \left(T_{\text{Annulus}} - T_{\text{Feedwater}}\right) = 101.4 \ \Delta T^{1/3} \ (\Delta T)$$

This reduces to yield the following,

$$\frac{101.4 \Delta T^{4/3}}{h_3} + 2 \Delta T = (T_{Annulus} - T_{Feedwater})$$

This was solved by trial and error. The following is a summary of the solutions.

Feedwater Temperature	$h_3 = 750 \frac{BTU}{Ft^2 Hr \circ F}$	$h_3 = 1500 \frac{BTU}{Hr Ft^2 \circ F}$
500°F	$\Delta T = 18.74^{\circ}F$	$\Delta T = 19.25^{\circ}F$
350°F	ΔT = 73.35°F	$\Delta T = 82.1^{\circ}F$
200°F	$\Delta T = 124.2^{\circ}F$	$\Delta T = 141.25^{\circ}F$
100°F	$\Delta T = 156.9^{\circ}F$	$\Delta T = 179.8^{\circ}F$

Recalling the equation for the equivalent heat transfer coefficient, obtain

$$\frac{1}{h_{oq}} = \frac{1}{h_3} + \frac{2}{101.39 (\Delta T)^{1/3}}$$

GENERAL 🍘 ELECTRIC

22A7454 REV 1

The following is a summary of these equivalent heat transfer coefficient calculations.

	All h's i	$\frac{BTU}{Hr Ft^2 \circ F}$
Feedwater	<u> </u>	
Temperature	$h_3 = 750$	$h_3 = 1500$
500°F	114.6	124.58
350°F	165.41	192.12
200°F	189.15	224.5
100°F	200.37	240.3

Due to a calculation error in the trial and error process explained earlier, the following equivalent heat transfer coefficients were used instead of the correctly calculated values shown above.

-	h	a
Feedwater Temperature	$h_3 = 750$	$\frac{h_3}{3} = 1500$
500°F	111.57	124.58
350°F	158.03	185.65
200°F	178.84	215.03
100°F	188.5	228.95

To assess this five percent difference in the coefficients, the Biot number for each pair of coefficients was compared. The comparison showed that the change in the Biot number was very small. This coupled with the fact that the portion of the thermal sleeve affected by this five percent difference is relatively far away from any highly stressed regions. Thus yielding the conclusion that the effect of this five percent difference in coefficients on the highly stressed areas, is negligible. The Biot numbers are contained in DRF (Reference 6.5).

NEBG-807A (6/80)

8-69

SH NO. 68

SH NO. 69

GENERAL 🛞 ELECTRIC

NUCLEAR ENERGY BUSINESS GROUP 22A7454 REV 1

4.1.2.2 Heat-Up Transient

Region 1

Forced Convection

For turbulent flow, the film heat transfer equation is as follows: (Reference 6.4):

$$\mathbf{h}_{\mathbf{f}} = 0.023 \left(\frac{\mathbf{K}}{\mathbf{D}}\right) \left(\mathbf{R}_{\mathbf{e}} \quad 0.8\right) \left(\mathbf{P}_{\mathbf{r}} \quad 0.4\right)$$

For 25 percent flow, from previous section (Paragraph 4.1.2.1),

 $V = 14,631 \, Ft/Hr$

and for 100 percent flow

 $V = 58,524.1 \, Ft/Hr$

At $T = 100^{\circ}F$ (Flow = 25 percent)

The heat transfer coefficient is identical to that calculated for the Cool-Down transient (Paragraph 4.1.2.1)

$$h_{f} = 625.27 \frac{BTU}{Hr Ft^{2} \circ F}$$

At $T = 180^{\circ}F$ (Flow = 25 percent)

Will assume the heat transfer coefficient to be identical to that calculated at 200°F in the Cool-down section.

...
$$h_f = 882.84 \frac{BTU}{T-Ft^2 \circ F}$$

•			8-7
UCLEAR ENERGY SUSINESS GROUP	GENERAL 🍘 ELECTRIC	22A7454 REV 1	sh no. 70
			•
$At T = 260^{\circ}F$	(Flow = 25 percent)	4	
	$R_e = 1.2187 \times 10^6$; $R_e^{0.8} =$	7.3912 x 10	
	$P_r^{0.4} = 1.1605$		
	-	97T	
	$h_{f} = 969.55 - H_{f}$	Ft ² °F	
$\underline{At T} = 376^{\circ}\underline{F}$	(Flow = 100 percent) 6 - 0.8	10 ⁵	
	$R_e = 6.936 \times 10^6$; $R_e^{0.8} = 2$		
	$P_{r}^{0.4} = 1.006$		
	· · _ 2225 8	BTU	
•.	$h_{f} = 3335.8 - H_{f}$	Ft ² °F	
		• •	
•			
		•	

٩

NEBG-807A (6/80)

.

.

<u>Region 2</u> ID = 8.38 in. = 0.69833 Ft.

Forced Convection

For turbulent flow, the film heat transfer equation is as follows: (Reference 6.4):

$$\mathbf{h}_{\mathbf{f}} = 0.023 \left(\frac{\mathbf{K}}{\mathbf{D}}\right) \left(\mathbf{R}_{\mathbf{e}}^{0.8}\right) \left(\mathbf{P}_{\mathbf{r}}^{0.4}\right)$$

For 25 percent flow, from previous section (Paragraph 4.1.2.1),

 $V = 19,478.3 \, Ft/Hr$

and for 100 percent flow

 $V = 77,913.8 \, Ft/Hr$

At $T = 100^{\circ}F$ (Flow = 25 percent)

The heat transfer coefficient is identical to that calculated for the Cool-Down transient (Paragraph 4.1.2.1)

$$h_{f} = 808.92 \frac{BTU}{Hr Ft^2 \circ F}$$

At $T = 180^{\circ}F$ (Flow = 25 percent)

Will assume the heat transfer coefficient to be identical to that calculated at 200°F in the Cool-down section. (Paragraph 4.1.2.1)

$$h_{f} = 1142.12 \frac{BTU}{Hr Ft^{2} \circ F}$$

SH NO. 71



	GENERAL 🍪 E	LECTRIC	22A7454	<u> </u>
BUSINESS GROUP			REV 1	
				·
At T = 260°F	(Flow = 25 percent)			
	$R_{e} = 1.406 \times 10^{6}$;	$\mathbb{R}_{e}^{0.8} = 8.$.2875 x 10 ⁴	
	$P_r^{0.4} = 1.160$)5		
	.'. ^h f ⁻	= 1254.4 <u>BT</u> Hr Ft ²	0 °F	
$\underline{At T} = 376^{\circ}F$	(Flow = 100 percent))		
	$R_e = 8.0 \times 10^6$;	$R_e^{0.8} = 3.33$	3 x 10 ⁵	
	$P_r^{0.4} = 1.000$	5		
	•••• h _f	$= 4315.7 \frac{BT}{Hr Ft}$	02 •F	
			• •	•
			•	
			•	•

• •

8-74

<u>Region 3</u> ID = 6.16 in. = 0.51333 Ft.

Forced Convection

For turbulent flow, the film heat transfer equation is as follows: (Reference 6.4):

$$\mathbf{h}_{f} = 0.023 \left(\frac{K}{D}\right) \left(\mathbf{R}_{e}^{0.8}\right) \left(\mathbf{P}_{r}^{0.4}\right)$$

For 25 percent flow, from previous section (Paragraph 4.1.2.1),

 $V = 36,047.7 \, Ft/Hr$

and for 100 percent flow

 $V = 144,190.7 \, Ft/Hr$

At T = $100^{\circ}F$ (Flow = 25 percent)

The heat transfer coefficient is identical to that calculated for the Cool-Down transient (Paragraph 4.1.2.1)

$$h_{f} = 1407.67 \frac{BTU}{Hr Ft^2 \circ F}$$

At $T = 180^{\circ}F$ (Flow = 25 percent)

Will assume the heat transfer coefficient to be identical to that calculated at 200°F in the Cool-down section (Paragraph 4.1.2.1).

$$h_{f} = 1987.5 \frac{BTU}{Hr Ft^2 \circ F}$$

NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	sh _{NO} . 74
	(Flow = 25 percent) $R_e = 1.913 \times 10^6$; $R_e^{0.8} = 1.913$.06 x 10 ⁵	
	$P_r^{0.4} = 1.1605$	· .	
	$h_{f} = 2182.85 \frac{BT}{Hr}$	0 2 •F	
$\underline{At T} = 376^{\circ}F$	(Flow = 100 percent)		
	$R_e = 1.0887 \times 10^6$; $R_e^{0.8} = 4.2$	61 x 10 ⁵	
	$P_{r}^{0.4} = 1.006$		
	$h_{f} = 7509.98 \frac{BT}{Hr Ft}$	U 2 •F	

8-75

22A7454 REV 1 SH NO. 75

Region 4

As given in the design specification (Reference 6.1), the exterior surfaces are to be insulated with material having a conduction rate of $0.2 \frac{BTU}{2}$

Hr Ft² °F

$$h_f = 0.2 \frac{BTU}{Hr Ft^2 \circ F}$$

Region 5

As given in the design specification (Reference 6.1), the heat transfer coefficient against the vessel wall is constant for all feedwater flow conditions.

$$h_{f} = 500 \frac{BTU}{Hr Ft^{2} \circ F}$$

Region 6

The analysis of Region 6 here follows the same procedure of the analysis of Region 6 during the cool down transient (Paragraph 4.1.2.1). Refer to Paragraph 4.1.2.1 for greater details.

Upper Surface

For all feedwater flows, the film heat transfer coefficient for the upper surface is given in Appendix 20 of the design specification (Reference 6.1). They are listed in Paragraph 4.1.2.1.

Lower Surfaces

The procedure used is identical to that of Paragraph 4.1.2.1. For more details, refer to Paragraph 4.1.2.1.

The following equation must be solved by trial and error to obtain the ΔT across the thermal sleeve.

$$\frac{101.4 \Delta T^{4/3}}{h_3} + 2 \Delta T = (T_{Annulus} - T_{Feedwater})$$



			8–77
NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 Rev 1	SH NO. 76

The following is a summary of the solutions.

Feedwater Temperature	$h_3 = 750$	BTU Ft ² Hr °F	$h_3 = 1500$	BTU Hr Ft ² •F	 :
100°F	ΔT =	157°F	ΔT =	180°F	· .
180°F	ΔT =	131°F	ΔT =	149°F	
260°F		104°F	ΔT =	117.7°F	
376°F	ΔT =	58°F	_ΔT =	64.5°F	

Recalling the equation for the equivalent heat transfer coefficient, obtain

All h's in -

BLD

H- E+2 0E

$$\frac{1}{h_{eq}} = \frac{1}{h_3} + \frac{2}{101.39 (\Delta T)^{1/3}}$$

The following is a summary of these equivalent heat transfer coefficient calculations.

Feedwater Temperature	$\frac{h_{a}}{h_{3}} = 750$	$h_3 = 1500$	
100°F	200.4	240.4	
180°F	191.7	228.0	
260°F	180.9	213.14	
376°F	155.5	179.04	

4.1.2.3 <u>Normal Operation</u>. The heat transfer coefficients used for the normal operation run are the same as those given during the heat up transient (Paragraph 4.1.2.2) when $T = 376^{\circ}F$.

22A7454 Rev 1 SH NO. 77

8-78

4.1.3 <u>Feedwater Nozzle Annulus Fluid Temperature</u>. Appendix 20 of the design specification (Reference 6.1), defines the annulus fluid temperatures for all conditions. For completeness it is repeated below.

 $T = T_{FW} + C (T_A - T_{FW})$

Where:

- T = Annulus fluid temperature
- T_{FW} = Feedwater fluid temperature
- T_{A} = Region A fluid temperature = 546°F

C = Coefficient defined by table below

Feedmenter			<u>Points</u>		
Feedwater <u>Flow</u>	<u>a</u>	<u>b</u>	<u>c</u>	<u>d + e</u>	<u>f</u> .
2 5%	0.70	0.92	0.96	.0.96	0.96
1005	0.68	0.83	0.86	0.86	0.90

Use the above values of C for all cases with feedwater flow. Use C = 1.0 when no feedwater flow. Use C = 1.0 downstream of f for all feedwater flows. Interpolate linearly between defined points; see Figure 4.1.2-1 for point locations.

NEBG-807A (6/80)

ROUP

GENERAL 🍘 EL	.E	CT	Ř I	C
--------------	----	----	-----	---

22A7454 SH NO. 78

4.1.4 <u>Thermal Analysis Results.</u> By applying the boundary conditions (heat transfer coefficients and flow temperatures), a transient heat transfer analysis was performed using the finite element program ANSYS (Reference 6.3) for the thermal transients does t'bed earlier. During these transients, the isolated face of the disc in the finite element model was maintained at a constant vessel temperature of 546°F to simulate the vessel as a heat source. The temperature solutions obtained for the various times of the transients were saved on tape for later use in the thermal stress analysis. Some of the isotherm plots obtained for various times of the transients are shown in Figures 4.1.4-1 through 4.1.4-7.

NEBG-807A (6/80)

8-79

NUCLEAR	ENERGY
BUSINESS	GROUP

8-80 SH NO. 79




FIGURE 4.1.4-1 COOLDOWN TRANSIENT

NEBG-807A (6/80)

- - - .




FIGURE 4.1.4-2 COOLDOWN TRANSIENT

NEBG-807A (6/80)

8-81

			8-	-82
NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 SH NO		1
		REV 1		




FIGURE 4.1.4-3 COOLDOWN TRANSIENT





FIGURE 4.1.4-4

NEBG-807A (6/80)

8-83

NUCLEAR ENERGY	GENERAL 🐲 ELECTRIC	22A7454
BUSINESS CROUP	S	REV 1



8-84 SH NO. 83




FIGURE 4.1.4-5

NEBG-807A (6/80)

1

BUSINESS GROUP




FIGURE 4.1.4-6




FIGURE 4.1.4-7

NEBG-807A (6/80)

22Å7454 SH NO. 86 REV 1

4.2 <u>Stress Analysis</u>. The stress analysis is broken into three separate areas: thermal stresses, mechanical load stresses, and pressure stresses. The stress intensities for these three cases are then summed up to yield the total primary plus secondary stress intensity. A fatigue analysis is then performed to obtain the fatigue usage factor for the system.

4.2.1 <u>Selected Locations for Stress Evaluation</u>. The sections shown in Figure 4.2.1-1 are the locations selected for stress evaluation. Finite element stresses are integrated across each section to determine the equivalent membrane, bending, and peak stresses. This was done by averaging the stress across the section and linearizing the stress distribution through the section thickness as shown in Figure 4.2.1-2. These calculations were performed using an engineering aid computer program 'NONO'. A listing of this program is included in Appendix 10.

- 51

8-87

G	E	N	E	R	A	L	<i>9</i> 6	E	LE	CT	RI	C
---	---	---	---	---	---	---	------------	---	----	----	----	---




FIGURE 4.2.1-1 LOCATIONS FOR EVALUATING STRESSES

NEBG-807A (6/80)

8-88


٠,

SH NO. 87

22A7454

1

REV



LINEARIZATION OF STRESS DISTRIBUTION ACROSS A SECTION THICKNESS

FIGURE 4.2.1-2 LINEARIZATION OF STRESS DISTRIBUTION ACROSS A SECTION THICKNESS

NEBG-807A (6/80)

•



22A7454 REV 1 SH NO: 89

8-90

4.2.2 <u>Thermal Stress Analysis</u>. The thermal stresses were obtained using the finite element computer program ANSYS. The same finite element model used for the thermal transient analysis (Figure 4.1.1-1) was also used for the thermal stress analysis. However, instead of temperature elements being used, 2-D axisymmetric isoparametric stress elements (STIF-42, Reference 6.3) were used. The modeling of the portion of the vessel wall as a disc is a conservative assumption for the thermal stress solutions since the inplane radial stiffness of a disc is higher than that of a shell. The applied boundary condition at the isolated surfaces of the vessel, safe end, and thermal sleeve is the generalized plane strain condition. The elastic properties used were considered constant for all temperatures. These properties are:

 $\frac{\text{Carbon Steel}}{\text{Carbon Steel}} = 27.2 \times 10^{6} \text{ psi}$ $a = 7.33 \times 10^{-6} \text{ in./in.}$ = 0.3 $p = 0.283 \text{ lbf/in.}^{3}$ $\frac{\text{Stainless Steel}}{\text{Carbon Steel}} = 26.85 \times 10^{6} \text{ psi}$ $a = 9.87 \times 10^{-6} \text{ in./in.}$ = 0.3 $p = 0.29 \text{ lbf/in.}^{3}$ $\frac{\text{Vessel Steel}}{\text{Carbon Steel}} = 28.8 \times 10^{6} \text{ psi}$ $a = 7.33 \times 10^{-6} \text{ in./in.}$ = 0.3 $p = 0.283 \text{ lbf/in.}^{3}$

NEBG-807A (6/80)

NUCLEAR ENERGY BUSINESS GROUP



NUCLEAR ENERGY BUSINESS GROUP


NEBG-807A (6/80)

22A7454 Rev 1

SH NO. 90

4.2.2.1 <u>Selection of Times for Stress Evaluation</u>. The times in the transients considered important for subsequent thermal stress evaluation are determined by a review of temperature differences between selected nodes of the thermal model. This process is performed for the cool down transient. Figure 4.2.2.1-1 illustrates the selected nodal points and Table 4.2.2.1-1 contains the temperature information. Actual temperatures are in DRF B13-909 (Reference 6.5).

4.2.2.2 <u>Thermal Stress Analysis Results</u>. The thermal transient stresses were evaluated at the indicated times of the transients. The thermal membrane plus bending stresses for each of the previously noted transient times are tabulated in Tables 4.2-1 through 4.2-9. The thermal membrane plus bending plus peak stresses for each of the previously noted transient times are tabulated in Tables 4.2-10 through 4.2-18.



8-92

FIGURE 4.2.2.1-1 LOCATIONS USED FOR EVALUATING TEMPERATURE DIFFERENCE

GENERAL 🍘 ELECTRIC

22A7454 REV 1

TABLE 4.2.2.1-1 TEMPERATURE DIFFERENCES FOR COOL DOWN TRANSIENT

Load	Time			-		
Step	(Minutes)	$\frac{T_7 - T_6}{2}$	$T_7 - T_3$	ΔT ₇	ΔΤ ₃	$\frac{\Delta T_4}{4}$
6	0.10	59	99	205	129	30
7	0.1167	69	117	220	128	33
8	0.1333	78	130	232	125	34
9 -	0.150	84	141	250	122	36
10	0.1667	90	149	265	120	36
11	0.2083	102	163	274	115	36
12	0.250	111	169	281	111	36
13	0.333	128	172	269		36
14	0.50	147	156	235		32
15	0.750	158	122	204		24
16	1.00	156	94			
17	2.00	127				
18	3.00	112				

(All $\Delta T's$ in °F)

DRF B13-909 contains actual nodal temperature data (Reference 6.5)

Times Selected	Load Step	<u>Time (Minutes)</u>
	б	0.10
	12	0.25
	16	1.00
	23	Steady State

NEBG-807A (6/80)

SH NO. 92

GENERAL 🐲 ELECTRIC

22A7454 REV 1 SH NO. 93

4.2.3 <u>Mechanical Load Stress Analysis</u>. The mechanical load stresses were obtained by using the procedure followed in Paragraph 3 to obtain the design stresses. The only variation is in obtaining the applied loading (however, this will be investigated in the following Paragraph). For completeness, the calculations are presented in this report in Paragraph 4.2.3.2.

4.2.3.1 <u>Applied Mechanical Loading.</u> To obtain the largest load ranges, the loadings given in Section 3 are used. Note that in load range calculations, dead weight loads are not included. These loads simply cancel out.

2

Nozzle Loading

NUCLEAR ENERGY

BUSINESS GROUP

$$P = (F_x^2 + F_y^2)^{1/2}$$
$$M = (M_y^2 + M_y^2 + M_y^2)^{1/2}$$

 $\frac{'A' \text{ Nozzle Loading}}{P} = (0.02^2 + 0.16^2)^{1/2} = 0.161$ Static $M = (12.0^2 + 12.1^2 + 45.0^2)^{1/2} = 48.12$ $F_z = 0.21$ $P = (0.29^2 + 2.51^2)^{1/2} = 2.53$ Dynamic $M = (9.3^2 + 158.9^2 + 313.4^2)^{1/2} = 351.5$ $F_z = 2.23$

NEBG+807A (6/80)

NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 SH NO. 94 REV 1
<u>'B' Nozzle</u> Static	<u>Loading</u> (Service Level 'B') $P = (0.82^{2} + 4.34^{2})^{1/2} = 4.42$ $M = (267.2^{2} + 66.7^{2} + 1.4^{2})^{1/2}$	= 275.4
	$F_{z} = 1.37$	
Dynamic	$P = (2.44^{2} + 1.97^{2})^{1/2} = 3.136$ $M = (376^{2} + 106.3^{2} + 10.6^{2})^{1/2}$	= 390.2

 $F_{z} = 0.26$

NEBG-807A (6/80)

NUCLEAR ENERGY BUSINESS GROUP

22A7454 Rev 1 8-96

<u>Thermal Sleeve Loading</u> (Service Level 'B') $P = (F_x^2 + F_y^2)^{1/2}$ $M = (M_x^2 + M_y^2 + M_z^2)^{1/2}$ P = 0Static M = 0 $F_z = 3.7$ $P = (2.5^2 + 0.3^2)^{1/2} = 2.52$ Dynamic $M = (1.2^2 + 2.0^2)^{2-1/2} = 2.333$ $F_z = 1.5$

Therefore, the following will be used to calculate the largest mechanical load range. Note: the dynamic loads are due to seismic loadings only.

Nozzle Loads (Service Level 'B') P = 4.42 kip Static M = 275.4 in kip $F_z = 1.37$ kip $P = \pm 3.136$ kip Dynamic $M = \pm 390.9$ in kip $F_z = \pm 0.26$ kip

NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 REV 1	sh no. 96	

8-97

Thermal Sleeve Loads (Service Level 'B')

$$P = \pm 2.52 \text{ kip}$$
Dynamic
$$M = \pm 2.333 \text{ in kip}$$

$$F_z = \pm 1.5 \text{ kip}$$

Static $F_z = 3.7$ kip

4.2.3.2 <u>Mechanical Load Range Calculations</u>. The section properties used are found in Table 3-1 of Section 3. Note, these properties include effects of corrosion. A summary of the calculations is given in Table 4.2.3.2-1.

8-98

SH NO. 97

22A7454

REV 1

NUCLEAR ENERGY BUSINESS GROUP

Section A Nozzle Loads P = <u>+</u> 3.136 kip $P = 4.42 \, kip$ $M = \pm 390.9$ in kip M = 275.4 in kip $F_{-} = \pm 0.26 \, \text{kip}$ $F_{-} = 1.37 \text{ kip}$ M = 390.9 + 3.136 (12.83) + 0.26 (0.56)M = 275.4 + 4.42 (12.83) + 1.37 (0.56)= 431.3 in kip = 332.9 in kip $\sigma_{\phi_{\text{BEND}}} = \frac{M}{Z} = \frac{332.9}{51.98} = 6.41 \text{ ksi}$ $\sigma_{b_{BEND}} = \frac{M}{Z} = \frac{431.3}{51.98} = 8.3 \text{ ksi}$ $\sigma_{\phi} = \frac{F_z}{AX} = \frac{0.26}{19.03} = 0.014$ ksi $\sigma_{\phi_{AX}} = \frac{F_z}{A} = \frac{1.37}{19.03} = 0.072$ ksi Thermal Sleeve Loads $P = \pm 2.52 \, kip$ $F_{-} = 3.7 \, kip$ $M = \pm 2.333$ in kip $F_{=} \pm 1.5 \, kip$ M = 2.333 + 2.52 (15.76) + 1.5 (2.36)M = 3.7 (2.36) = 8.73 in kip = 45.59 in kip $\sigma_{b} = \frac{M}{Z} = \frac{45.59}{51.98} = 0.877$ ksi $\sigma_{\text{BEND}} = \frac{M}{Z} = \frac{8.73}{51.98} = 0.168 \text{ ksi}$ $\sigma_{\phi} = \frac{F_z}{AX} = \frac{1.5}{19.03} = 0.079 \text{ ksi}$ $\sigma_{\phi_{AX}} = \frac{F_z}{A} = \frac{3.7}{19.03} = 0.195 \text{ ksi}$ Total Stress σ BEND = 6,578 psi = <u>+</u> 9,177 psi = <u>+</u> 93 psi = 267 psi σφ_{AX}.

🗍 GENERAL 🥵 ELECTRIC

UCLEAR ENERGY GENERAL C ELI	CTRIC	22A7454 Rev 1	SH NO. 98
Section B			
Nozzle Loads	1		
P = 4.42 kip	$\mathbf{P} = \pm$	3.136 kip	
M = 275.4 in kip	M = ±	390.9 in kip	
$F_z = 1.37$ kip	$F_z = \pm$	0.26 kip	
M = 275.4 + 4.42 (10.22) + 1.37 (0.56)	M = 390.9	+ 3.136 (10.22	2) + 0.26 (0.5
= 321.34 in kip	= 423.1	in kip	
$\sigma_{\phi} = \frac{M}{Z} = \frac{321.34}{51.98} = 6.182 \text{ ksi}$	$\sigma_{\mathbf{b}_{\text{BEND}}} = \frac{\mathbf{M}}{\mathbf{Z}}$	$=\frac{423.1}{51.98}$	= 8.14 ksi
$\sigma_{\phi_{AX.}} = \frac{F_z}{A} = \frac{1.37}{19.03} = 0.072$ ksi		$\frac{z}{19.03} = \frac{0.26}{19.03}$	= 0.014 ksi
Thermal Sleeve Loads	P = +	2.52 kip	
$F_z = 3.7 \text{ kip}$	X = <u>+</u>	2.333 in kip	
2	$F_{\tau} = \pm$	1.5 kip	
M = 3.7 (2.36) = 8.73 in kip	-	+ 2.52 (18.37) + 1.5 (2.36)
	= 52.17	in kip	
$\sigma_{\phi} = \frac{M}{Z} = \frac{8.73}{51.98} = 0.168$ ksi	$\sigma_{0} = \frac{\mathbf{M}}{\mathbf{Z}}$	$= \frac{.52.17}{.51.98}$	= 1.004 ksi
$\sigma_{\phi} = \frac{F_z}{AX} = \frac{3.7}{19.03} = 0.195 \text{ ksi}$	σφ _{AI} . = -	$\frac{1.5}{19.03}$	= 0.079 ksi
Total Stress			
σ. = 6,350 psi BEND	= <u>+</u> 9,144	psi	
σ = 267 psi	= <u>+</u> 93 psi		

.

NEBG-807A (6/80)

					8-100
NUCLEAR ENERGY BUSINESS GROUP	GENERAL	ELE	CTRIC	22A7454 Rev 1	sh no. 99
Section_C/D					
Nozzle Loads					
P = 4.42 ki	P		P =	<u>+</u> 3.136 kip	
M = 275.4 i	n kip		M =	<u>+</u> 390.9 in kip	
$F_{z} = 1.37$ ki	P		$F_z =$	<u>+</u> 0.26 kip	
M = 275.4 + 4.4	2 (7.47) + 1.37	(0.56)	M = 390.	9 + 3.136 (7.47)	+ 0.26 (0.56)
= 309.19 in k	ip		= 414.	48 in kip	
$\sigma_{\phi_{BEND}} = \frac{M}{Z} = $	<u>309.19</u> = 5.952 51.98 =	ksi	°¢ _{BEND} =	$\frac{M}{Z} = \frac{414.48}{51.98} =$	= 7.974 ksi
$\sigma_{\phi_{AX}} = \frac{F_z}{A} = -\frac{1}{1}$	<u>1.37</u> = 0.072 9.03	2 ksi	^م ه =	$\frac{F}{Z} = \frac{0.26}{19.03}$	= 0.014 ksi
Thermal Sleeve Lo	ads		P =	<u>+</u> 2.52 kip	
$F_{\tau} = 3.7 ki$	P		M =	<u>+</u> 2.333 in kip	
Z			F_ =	<u>+</u> 1.5 kip	
M = 3.7 (2.36)	= 8.73 in kip		-	33 + 2.52 (21.12) + 1.5 (2.36)
			= 59.1	10 in kip	
	$\frac{8.73}{51.98} = 0.16$	1		$\frac{M}{Z} = \frac{59.10}{51.98}$	
$\sigma_{\phi_{AX}} = \frac{F_z}{A} = \frac{F_z}{A}$	<u>3.7</u> = 0.19 19.03	5 ksi	^σ φ _{AX} . =	$\frac{F_z}{A} = \frac{1.5}{19.03}$	= 0.079 ksi
<u>Total Stress</u>					
$\sigma_{\phi} = 6,118 $			= ± 9,11	1 psi	
$\sigma_{\phi} = 267 \text{ ps}$			= <u>+</u> 93 p	si	

JCLEAR ENERGY GENERAL CE EL	ECTRIC 22A7454 SH NO. 100 REV 1
Section E	
Nozzle Loads	.
P = 4.42 kip	$P = \pm 3.136 kip$
H = 275.4 in kip	$M = \pm 390.9$ in kip
$F_z = 1.37$ kip	$F_z = \pm 0.26 \text{ kip}$
M = 275.4 + 4.42 (4.72) + 1.37 (0.56)	M = 390.9 + 3.136 (4.72) + 0.26 (0.
= 297.03 in kip	= 405.85 in kip
$\sigma_{\phi_{\text{BEND}}} = \frac{M}{Z} = \frac{297.03}{51.98} = 5.715 \text{ ksi}$	$\sigma_{\phi_{\text{BEND}}} = \frac{M}{Z} = \frac{405.85}{51.98} = 7.808 \text{ ksi}$
$\sigma_{\phi} = \frac{F_z}{AX} = \frac{1.37}{19.03} = 0.072 \text{ ksi}$	$\sigma_{\phi} = \frac{F_z}{AX} = \frac{0.26}{19.03} = 0.014$ ksi
Thermal Sleeve Loads	$P = \pm 2.52 kip$
$F_z = 3.7 kip$	M = <u>+</u> 2.333 in kip
-	$F_z = \pm 1.5$ kip
M = 3.7 (2.36) = 8.73 in kip	M = 2.333 + 2.52 (23.87) + 1.5 (2.3)
	= 66.03 in kip
$\sigma_{\phi_{\text{BEND}}} = \frac{M}{Z} = \frac{8.73}{51.98} = 0.168 \text{ ksi}$	$\sigma_{b} = \frac{M}{Z} = \frac{.66.03}{.51.98} = 1.27 \text{ ksi}$
$\sigma_{\phi} = \frac{F_z}{AX} = \frac{3.7}{19.03} = 0.195 \text{ ksi}$	$\sigma_{\phi} = \frac{F_z}{AX} = \frac{1.5}{19.03} = 0.079 \text{ ks}$
Total Stress	
σφ ≕ 5,883 psi BEND	$= \pm 9,078 \text{ psi}$
σφ = 267 psi AX.	= <u>+</u> 93 psi

NEBG-807A (6/80)

CLEAR ENERGY SINESS GROUP	GENERAL 🍪 EL	ECTRIC	22A7454 SH NO. REV 1	8- 101
Section F				
Nozzle Loads		1		
P = 4.42 ki	l p	$P = \pm$	3.136 kip	
M = 275.4 ±	ln kip	M = <u>+</u>	390.9 in kip	
$F_{z} = 1.37 kz$	ip	$F_z = \frac{1}{2}$	0.26 kip	
M = 275.4 + 4.4	42 (1.62)	M = 390.9) + 3.136 (1.62)	
= 282.56 in 1	tip	= 395.9	98 in kip	
$\sigma_{\phi_{\text{BEND}}} = \frac{M}{Z} =$	$\frac{282.56}{39.09} = 7.23 \text{ ksi}$	σ¢ _{BEND} = 2	$\frac{4}{2} = \frac{395.98}{39.09} = 10.13$	ksi
$\sigma_{\mathbf{A}} = \frac{\mathbf{F}}{\mathbf{Z}} = \mathbf{F}$	<u>1.37</u> = 0.087 ksi 15.89	$\sigma_{\phi_{AX}} = \frac{1}{2}$	$\frac{3}{z} = \frac{0.26}{15.89} = 0.017$	ks i
Thermal Sleeve L	oads		<u>+</u> 2.52 kip	
$F_z = 3.7 k$	ip	M =	<u>+</u> 2.333 in kip	
*		$F_z = \frac{1}{2}$	<u>+</u> 1.5 kip	•
M = 3.7 (1.8)	= 6.66 in kip	M = 2.33	3 + 2.52 (26.97) + 1.5	(1.8)
		= 73.0	in kip	
$\sigma_{\phi_{BEND}} = \frac{M}{Z} =$	$\frac{6.66}{39.09} = 0.171 \text{ ksi}$	°¢ _{BEND} =	$\frac{M}{Z} = \frac{73}{39.09} = 1.868$	ksi
$\sigma_{\phi_{AX}} = \frac{F_z}{A} =$	$\frac{3.7}{15.89} = 0.233$ ksi	σ ₀ , =	$\frac{F_z}{A} = \frac{1.5}{15.89} = 0.095$	ksi
Total Stress				
$\sigma_{\phi_{\text{BEND}}} = 7,401$	psi	= <u>+</u> 11,99	8 psi	
$\sigma_{\phi} = 320 \text{ ps}$		= <u>+</u> 112 p	si	

. .

NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELI	ECTRIC	22A7454 Rev 1	SH NO. 102
<u>Section G</u> Nozzle Loads				
P = 4.42 ki	p .	$P = \pm$	- 3.136 kip	
M = 275.4 i		M = <u>+</u>	- 390.9 in kip	
$F_{1} = 1.37 ki_{1}$	p	F = +	<u>+</u> 0.26 kip	
2	2 (4.72) + 1.37 (1.8)	M = 390.9	9 + 3.136 (4.72) + 0.26 (1.8)
= 298.73 in k	ip	= 406.1	17 in kip	
$\sigma_{\phi_{\text{BEND}}} = (0.381) = \frac{M}{Z}$	= (0.381) $\frac{298.73}{22.32}$ = 5.1 ksi	$\sigma_{b_{BEND}} = 0.3$	$\frac{M}{Z} = (0.381)^{\frac{2}{3}}$	$\frac{106.17}{22.32} = 6.934$ ks
	$(0.381) \frac{1.37}{10.46} = 0.05 \text{ ksi}$	ر • • = 0.385	$\frac{F_z}{A} = (0.381)$	<u>0.26</u> = 0.01 ksi 10.46
Thermal Sleeve Lo	ads	P = :	<u>+</u> 2.52 kip	
$F_{z} = 3.7 ki$	P	M = :	<u>+</u> 2.333 in kip	
-		$F_z = z$	<u>+</u> 1.5 kip	
		M = 2.33	3 + 2.52 (23.8	7)
		= 62.4	9 in kip	
		°¢ _{BEND} =	$\frac{M}{Z} = \frac{62.49}{22.32}$	= 2.8 ksi
$\sigma_{\phi_{AX}} = \frac{F_z}{A} = \frac{F_z}{A}$	<u>3.7</u> = 0.354 ksi .0.46	σφ _{AX.} =	$\frac{F_z}{A} = \frac{1.5}{10.46}$	= 0.144 ksi
<u>Total Stress</u>				- <u></u>
$\sigma_{\phi} = 5,100 $	osi	= <u>+</u> 9,734	psi	
$\sigma_{\phi} = 404 \text{ ps}$		= <u>+</u> 154 p	si	

NEBG-807A (6/80)

8-104

NUCLEAR ENERGY BUSINESS GROUP

GENERAL 🍘 ELECTRIC

22A7454 Rev 1 SH NO. 103

• • • • •	
Section H	
Nozzle Loads	1
P = 4.42 kip	$P = \pm 3.136 kip$
M = 275.4 in kip	$M = \pm 390.9$ in kip
$F_z = 1.37$ kip	$F_z = \pm 0.26 \text{ kip}$
M = 275.4 + 4.42 (8.47) + 1.37 (1.8)	M = 390.9 + 3.136 (8.47) + 0.26 (1.8)
= 315.3 in kip	= 417.93 in kip
$\sigma_{\phi} = (0.381) = \frac{M}{Z} = (0.381) \frac{315.3}{22.32} = 5.383$ ksi	$\sigma_{\phi} = 0.381 \frac{M}{Z} = (0.381) \frac{417.93}{22.32} = 7.134 \text{ ksi}$
$\sigma_{hax} = 0.381 \frac{F_z}{A} = (0.381) \frac{1.37}{10.46} = 0.05 \text{ ksi}$	$\sigma_{\phi} = 0.381 \frac{F_z}{AX} = (0.381) \frac{0.26}{10.46} = 0.01 \text{ ksi}$
<u>Thermal Sleeve Loads</u>	$P = \pm 2.52 kip$
$F_z = 3.7 \text{ kip}$	$M = \pm 2.333$ in kip
	$F_z = \pm 1.5 \text{ kip}$
	M = 2.333 + 2.52 (20.12)
	= 53.04 in kip
	$\sigma_{b_{BEND}} = \frac{M}{Z} = \frac{53.04}{22.32} = 2.377 \text{ ksi}$
$\sigma_{\phi} = \frac{F_z}{AX} = \frac{3.7}{10.46} = 0.354 \text{ ksi}$	$\sigma_{\phi} = \frac{F_z}{AX} = \frac{1.5}{10.46} = 1.44$ ksi
Total Stress	·
∽ ∲ = 5,383 psi BEND	= <u>+</u> 9,511 psi
$\sigma_{\phi} = 404 \text{ psi}$	= <u>+</u> 154 psi

NUCLEAR ENERGY GEN BUSINESS GROUP	NERAL 🍪 ELECTRIC	22A7454 SH NO. 104 REV 1
<u>Section I</u>	• •	
Nozzle_Loads		· · · · · ·
P = 4.42 kip	P	= <u>+</u> 3.136 kip
M = 275.4 in kip	M	= <u>+</u> 390.9 in kip
$F_{\mu} = 1.37$ kip	Fz	= <u>+</u> 0.26 kip
M = 275.4 + 4.42 (8.47)) + 1.37 (1.8) $M = 3$	90.9 + 3.136 (8.47) + 0.26 (1.8)
= 315.3 in kip	= 4	17.93 in kip
$\sigma_{\phi} = (0.381) = \frac{M}{Z} = (0.38)$	(1) $\frac{315.3}{29.07} = 4.133$ ksi σ_{BEND}	= 0.381 $\frac{M}{Z}$ = (0.381) $\frac{417.93}{29.07}$ = 5.478 ksi
$\sigma_{\phi AX.} = 0.381 \frac{F_{Z}}{A} = (0.381)$	$\frac{1.37}{13.78} = 0.038$ ksi $\sigma_{0AX.} = 0$	$0.381 \frac{F_z}{A} = (0.381) \frac{0.26}{13.78} = 0.008 \text{ ks}$
Thermal Sleeve Loads	P	$= \pm 2.52 \text{ kip}$
$F_z = 3.7 kip$	1	$= \pm 2.333$ in kip
4	Fz	$= \pm 1.5 \text{kip}$
·	1	2.333 + 2.52 (20.12)
·	=	53.04 in kip
	°¢ _{beni}	$=\frac{M}{Z}=\frac{53.04}{29.07}=1.83$ ksi
$\sigma_{\phi} = \frac{F_z}{AX} = \frac{3.7}{13.78}$	= 0.269 ksi ^σ .	53.04 in kip $= \frac{M}{Z} = \frac{53.04}{29.07} = 1.83 \text{ ksi}$ $= \frac{F_z}{A} = \frac{1.5}{13.78} = 0.109 \text{ ksi}$
Total Stress		
σφ = 4,133 psi BEND	= ± '	7,308 psi
$\sigma_{\phi} = 307 \text{ psi}$	= <u>+</u> :	117 psi

NEBG-807A (6/80)

NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 REV 1	SH NO. 105	
·.				
Section J				

•	
Nozzle Loads	
P = 4.42 kip	$P = \pm 3.136 \text{kip}$
M = 275.4 in kip	M = <u>+</u> 390.9 in kip
$F_z = 1.37$ kip	$F_z = \pm 0.26 \text{ kip}$
M = 275.4 + 4.42 (9.26) + 1.37 (1.8)	M = 390.9 + 3.136 (9.26) + 0.26 (1.8)
= 318.8 in kip	= 420.4 in kip
$\sigma_{\mathbf{b}_{BEND}} = (0.381) = \frac{M}{Z} = (0.381) \frac{318.8}{29.07} = 4.179 \text{ ksi}$	$\sigma_{b} = 0.381 \frac{M}{Z} = (0.381) \frac{420.4}{29.07} = 5.51 \text{ ksi}$
$\sigma_{\phi} = 0.381 \frac{F_z}{A} = (0.381) \frac{1.37}{13.78} = 0.038 \text{ ksi}$	$\sigma_{\phi_{AX.}} = 0.381 \frac{F_z}{A} = (0.381) \frac{0.26}{13.78} = 0.008 \text{ ksi}$
Thermal Sleeve Loads	
	$P = \pm 2.52 \text{ kip}$
$F_z = 3.7 kip$	$M = \pm 2.333$ in kip
	$F_z = \pm 1.5 \text{ kip}$
· .	M = 2.333 + 2.52 (19.33)
	= 51.05 in kip
	$\sigma_{b} = \frac{M}{Z} = \frac{51.05}{29.07} = 1.756$ ksi
$\sigma_{\phi_{AX}} = \frac{F_z}{A} = \frac{3.7}{13.78} = 0.269$ ksi	$\sigma_{\phi_{AX}} = \frac{F_z}{A} = \frac{1.5}{13.78} = 0.109 \text{ ksi}$
Total Stress	1
♂ = 4,179 psi BEND	= <u>+</u> 7,266 psi
$\sigma_{\phi} = 307 \text{ psi}$	= <u>+</u> 117 psi

...

NUCLEAR ENERGY GENERAL C ELECTRIC

TABLE 4.2.3.2-1 MAXIMUM MECHANICAL LOAD STRESS INTENSITY (Service Level 'B')

Section	Static Stress	DIEL C Stress*
A	6,845	<u>+</u> 9,270
В	6,617	<u>+</u> 9,237
С	6,385	<u>+</u> 9,204
D	6,385	<u>+</u> 9,204
E	6,150	<u>+</u> 9,171
F	7,721	<u>+</u> 12,110
G	5,504	<u>+</u> 9,888
H	5,787	<u>+</u> 9,665
I	4,440	<u>+</u> 7,425
J	4,486	<u>+</u> 7383

(All stress in psi)

-. .

* Dynamic stresses are due to seismic only.

NEBG-807A (6/80)

GENERAL 🥵 ELECTRIC

NUCLEAR ENERGY BUSINESS GROUP SH NO. 107

8 - 108

4.2.4 <u>Pressure Stress Analysis</u>. The pressure stresses were obtained using the finite element computer program ANSYS. The same finite element model used for the thermal stress analysis (described in Paragraph 4.2.2 and Figure 4.1.1-1) was also used for the pressure stress analysis. The modeling of the portion of the vessel wall as a disc is a nonconservative assumption. It is recognized that the pressure stresses in the vessel wall regions obtained from using this model are not strictly valid. However, stresses in the safe end-thermal sleeve regions are valid since the effect of this modeling in these regions is insignificant. The applied boundary condition at the isolated surfaces of the safe end and thermal sleeve was the equivalent meridional stress caused by the pressure. The vessel boundary condition was the average of the hoop and meridional stresses.

4.2.4.1 <u>Pressure Stress Analysis Results.</u> The pressure stresses were evaluated for the specified pressures of 1,111 psig nozzle pressure and 1,000 psig vessel pressure. The pressure membrane plus bending stresses are tabulated in Table 4.2-9. The pressure membrane plus bending plus peak stresses are tabulated in Table 4.2-18. Figures 4.2.4-1 and 4.2.4-2 show an isostress plot and a deflection plot of the pressure case.




FIGURE 4.2.4-1 MONTICELLO FEEDWATER NOZZLE STRESS ANALYSIS - DISPLACEMENT PLOT (PRESSURE RUN)



NUCLEAR ENERGY BUSINESS GROUP




FIGURE 4.2.4-2 MONTICELLO FEEDWATER NOZZLE STRESS ANALYSIS - STRESS PLOT (PRESSURE RUN)

8-110

SH NO. 109

22A7454

REV 1



NUCLEAR ENERGY BUSINESS GROUP

REV 1 ----

SH NO. 110

8-111

4.2.5 Total Primary Plus Secondary Stress Ranges. This section of the report calculates the P+Q stress intensity ranges at the previously selected locations in order to validate the subsequent fatigue and sis. These stress ranges are calculated as the sum of three independent ranges; one for thermal stresses, a second for the maximum safe end and thermal sleeve load stresses. and a third for the pressure stresses.

4.2.5.1 Thermal Stress Ranges. The maximum thermal membrane plus bending stress ranges can be found by inspection using Tables 4.2-1 through 4.2-8. Table 4.2.5-1 will be used to identify the transient times used in the thermal analysis.

TABLE 4.2.5-1 TRANSIENTS USED IN THERMAL STRESS EVALUATION

- 1. Cool Down (t = 6.0 sec)
- 2. Cool Down (t = 15.0 sec)
- 3. Cool Down (t = 60.0 sec)
- 4. Cool Down (t = steady state)
- 5. Heat Up (t = 2.0 sec)
- 6. Heat Up (t = 3.0 sec)
- 7. Heat Up (t = 12.0 sec)
- 8. Normal Operation
- 9. Stress Free

The maximum thermal membrane plus bending stress ranges are found to be as follows:

•	Maximum Stress	
Location	<u>Range (psi)</u>	Cases
A	4,709	1-7
B	4,907	1-7
C	11,917	1-6
D	12,188	1-6
E	18,275	2-9
F	28,777	1-7
G	34,852	2-9
H	38,999	1-9
I	43,017	1-9
J	38,310	2-9

8-112

SH NO. 111

REV 1

4.2.5.2 <u>Nozzle End and Thermal Sleeve Load Stress Ranges</u>, The maximum nozzle end and thermal sleeve load stress ranges are found using Table 4.2.3.2-1. The maximum stress ranges are as follows:

	Maximum P+Q
Location	<u>(ksi)</u>
A	18.54
В	18.48
С	18.41
D	18.41
Ε	18.35
F	24.22
G	19.78
H	19.33
I	14.85
J	14.77

4.2.5.3 <u>Pressure Stress Ranges</u>. The pressure membrane plus bending stress ranges are found using Table 4.2-9. The P+Q pressure stress intensities are found to be as follows:

	S _n
Location	<u>(psi)</u>
A	5,963
В	9,437
C	8,941
D	8,873
Ε	6,524
F	8,678
G	7,654
H	4,567
I	4,670
J	6,229

GENERAL 🝘 ELECTRIC

REV 1

4.2.5.4 Total P+Q Range. The total primary plus secondary stress range for the selected locations is as follows:

	P+Q
Location	<u>(ksi)</u>
A	29.22
В	32.83
С	39.27
D	39.48
E	43.15
F	61.68
G	62.29
H	62.90
I	62.54
J	59.31

The limit for the primary plus secondary stress intensity is 3 S_. At 550°F, carbon steel (SA-350 LF2) has a S $_{\rm m}$ of 18.6 ksi, and stainless steel (SA-351 CF3) has a S_m of 16.0 ksi. In calculating 3 S_m , it is seen that Sections F through J are in excess of their limits, therefore, the simplified elasticplastic method will be used. For the simplified elastic-plastic fatigue analysis to be valid, the primary plus secondary minus thermal bending must be less than 3 S_m. So for Sections F through J, P+Q excluding thermal bending will be calculated.

The maximum thermal membrane stress ranges are found to be as follows: [Calculations included in DRF (Reference 6.5)]

	Thermal Membrane	
Location	Range (psi)	Cases
F	3,705	2-7
G	17,979	3-9
H	16,964	1-9
I	13,669 ·	8-9
J	3,117	8-9

Therefore, the total P+Q stress intensity ranges excluding thermal bending are found to be: 2 6

	P+Q	3 S m
Location	<u>(ksi)</u>	<u>(ksi)</u>
F	36.61	55.8
G	45.42	55.8
H	40.87	55.8
I	33.19	48.0
J	24.12	48.0

NEBG-807A (6/80)

8 - 113

SH NO. 112





SH NO. 113


8-114

4.2.6 <u>Interference Fit Stresses</u>. Since both male and female members are stainless steel, both member's respective moduli are equal

From Shigley - Page 78 (Reference 6.14)

$$P = \frac{E\delta}{b} \qquad \frac{(c^2 - b^2)(b^2 - a^2)}{2b^2(c^2 - a^2)}$$

Now the dimensions (from Reference 6.13, 6.9, and 6.8)



Also - yield highest stresses at room temperature

E = 28.3 x 10⁶ psi
P =
$$\frac{(28.3 x 10^{6})(0.0065)}{3.19}$$
 $\frac{(3.69^{2} - 3.19^{2})(3.19^{2} - 2.71^{2})}{2(3.19)^{2}(3.69^{2} - 2.71^{2})} = 4,401.$ psi

Hoop stresses for the inner and outer members are as follows:

$$\sigma_{\Theta \text{ inner}} = -P \frac{b^2 + a^2}{b^2 - a^2} = -27,228 \text{ psi}$$

$$\sigma_{\Theta \text{ outer}} = P \frac{c^2 + b^2}{c^2 - b^2} = 30,438 \text{ psi}$$

The total hoop stresses at this location includes a pressure effect.

$$\sigma_{\Theta} = \frac{PD}{2t} = \frac{111(6.16)}{2(0.5)} = 684 \text{ psi}$$

By inspection, the total P+Q stresses for this location are less than the allowed 3 S limit (3 S = 48 ksi). This section will not be examined again.

GENERAL 🍘 ELECTRIC

Section		Inside			Ontside	<u>.</u>
3001101	۵¢	σθ	σr	٩	σ _θ	σr
A	2,679	2,390	-	-2,442	-2,165	-
B	2,892	2,972		-2,620	-2,659	-
С	2,723	2,662	-	-2,413	-3,880	-
D	2,748	2,596	-	-2,437	-3,953	-
E	9,820	169	-	-9,251	-9,885	-
F	28,589	21,490	-	-26,331	-20,696	
G	16,087	29,153	-	-15,027	-7,305	-
H .	27,845	38,999	-	-26,414	-5,073	-
I	28,682	15,876	_	-23,569	-43,017	-
J	26,741	31,274	-	-22,590	-34,654	-

TABLE 4.2-1 THERMAL MEMBRANE PLUS BENDING STRESSES (CASE 1)

Cool Down (t = 6.0 seconds) All stresses in psi

Sections Illustrated in Figure 4.2.1-1.

8-116 sh ng. 115

TABLE 4.2-2 THERMAL MEMBRANE PLUS BENDING STRESSES (CASE 2)

Cool Down (t = 15.0 seconds) All stresses in psi

		Inside			Outside	
Section	σφ	αθ	٥r	٩٥	٥θ	σŗ
A	2,532	2,223	-	-2,345	-1,933	_
В	2,381	2,615	-	-2,180	-2,150	-
С	1,226	1,370	-	-1,034	-3,756	-
D	1,243	1,230	-	-1,050	-3,894	-
E	16,142	-3,012	-	-15,293	-18,275	-
F	28,685	19,599	-	-26,724	-17,769	-
G	3,827	34,852	-	-4,068	7,377	-
H	28,805	33,739	-	-27,954	-10,155	-
I	29,154	20,294	-	-25,852	-39,015	-
J	29,003	34,673	-	-26,491	-38,310	-

Sections Illustrated in Figure 4.2.1-1.

Cool Down (t = 60. seconds) All stresses in psi

22A7454 Rev 1

Section	Inside				Ontside	
5601101	۵	σθ	σΓ	٥þ	۵	σŗ
Å	328	863	-	-291	-8	_
В	554	1,109	-	-517	103	-
с	-3,992	-1,074	-	-3,866	202	-
D	-4,168	-1,298	-	4,036	93	-
E	9,787	-8,278	-	-9,304	-16,283	-
F	16,829	8,280	-	-15,898	-7,339	-
G	-4,453	26,808	-	3,696	9,150	-
H	28,236	29,932	-	-27,688	-12,507	-
I	28,528	21,439	-	-26,195	-36,052	-
J	30,698	35,913	-	-29,186	-37,833	

TABLE 4.2-3 THERMAL MEMBRANE PLUS BENDING STRESSES (CASE 3)

Sections Illustrated in Figure 4.2.1-1.

NEBG-807A (6/80)

SH NO. 116

GENERAL 🍘 ELECTRIC

NUCLEAR ENERGY BUSINESS GROUP 22A7454 Rev 1 8-118 SH NO. 117

TABLE 4.2-4 THERMAL MEMBRANE PLUS BENDING STRESSES (CASE 4)

Cool Down (t = steady state) All stresses in psi

	Inside			Inside Outside		
Section	۵¢	σθ	σr	٥	αθ	ď
A	-1,083	75	-	1,050	655	
В	-1,084	766	-	1,054	1,308	-
C .	-8,213	-3,595	-	7,884	1,686	-
D _.	-8,452	-3,914	-	8,114	1,579	-
E	6,431	-8,180	-	-6,247	-8,762	-
F	12,842	1,706	-	-12,215	-6,227	_
G	186	17,261	-	-545	99	-
H	27,722	30,407	-	-27,204	-11,813	· -
I	28,097	21,945	-	-25,794	-35,367	-
J	30,926	36,270	-	-29,414	-37,645	-

Sections Illustrated in Figure 4.2.1-1.

NUCLEAR ENERGY BUSINESS GROUP SH NO. 118

TABLE 4.2-5 THERMAL MEMBRANE PLUS BENDING STRESSES (CASE 5)

Section	Inside			Outside		
	σţ	۵	σΓ	٩	σ _θ	σΓ
A	-1,485	-235		-1,393	-1,009	
В	1,521	204	-	1,521	1,791	-
С	-8,885	-4,262	-	8,458	2,412	-
D	-9,129	-4,574		8,694	2,314	-
E	5,083	-8,486		-5,005	-7,446	-
F	5,694	-4,237	-	-5,899	-835	-
G	-5,412	10,737	-	4,408	3,684	-
H	22,221	25,867	-	-22,841	-7,180	-
I	22,531	14,531	-	-21,391	-30,069	Car
J	24,286	28,860	-	-24,354	-30,295	-

Heat Up (t = 2.0 seconds) All stresses in psi

Sections Illustrated in Figure 4.2.1-1.

8-120

TABLE 4.2-6 THERMAL MEMBRANE PLUS BENDING STRESSES (CASE 6)

Heat Up (t = 3.0 seconds) All stresses in psi

Section	Inside			Outside		
	۵.	αθ	σ	٩٣	σ _θ	σr
A	-1,828	-561		1,712	-1,308	-
В	-1,982	-156	-	1,854	2,126	, _
с	-9,194	-4,564	-	8,748	2,848	-
D	-9,440	-4,869	-	8,984	2,757	e .
E	4,102	-8,505	-	-4,073	-6,434	-
F	2,116	-6,930	-	-2,496	1,856	-
G	-7,342	7,633	·	6,342	4,635	-
H	20,041	24,289	-	-20,825	-4,890	-
I	20,459	11,332	-	-19,388	-27,807	-
J	21,565	26,078	-	-21,894	-26,953	-

Sections Illustrated in Figure 4.2.1-1.

GENERAL 🍘 ELECTRIC

NUCLEAR ENERGY BUSINESS GROUP

SH NO. 120

8-121

TABLE 4.2-7 THERMAL MEMBRANE PLUS BENDING STRESSES (CASE 7)

Heat Up (t = 12.0 seconds) All .c. esses in psi

Section	Inside			Outside		
	٥ţ	٩	٥r	٩	۵ ۵	ďr
A	-2,030	-738	-	1,927	1,439	-
В	-2,015	-244	-	1,906	2,155	-
с	-8,781	-4,249	-	8,375	3,056	-
D	-9,024	-4,522	-	8,608	2,993	-
E	1,166	-7,155	-	-1,263	-2,599	-
F	167	-7,287	-	-415	1,709	-
G	-2,698	4,763	• •	2,319	-1,662	-
Ħ	19,881	26,925	-	-20,309	-2,510	-
I	20,516	9,822	-	-18,572	-28,958	-
J	-19,335	24,115	-	-19,124	-24,777	-

Sections Illustrated in Figure 4.2.1-1.

GENERAL 🍘 ELECTRIC

SH NO. 121

TABLE 4.2-8 THERMAL MEMBRANE PLUS BENDING STRESSES (CASE 8)

(Normal Operation) All stresses in psi

Section	Inside			Outside		
	٩	σθ	σr	م٩	σθ	٥r
A	-3	-357	-	3	-302	-
В	-610	209	-	593	549	-
С	-3,615	-1,675	-	3,470	674	-
D	-3,711	-1,812	-	3,563	619	-
E	3,456	-3,492	-	-3,349	-4,116	-
F	4,754	285	-	-4,521	-2,520	· _
G	-432	7,902	-	218	289	-
H	12,072	25,112	-	-13,090	5,539	-
I	12,769	-1,322	-	-10,602	-26,016	-
J	7,786	10,666	-	-7,411	-16,899	-

Sections Illustrated in Figure 4.2.1-1.

NEBG-807A (6/80)

22A7454 Rev 1

TABLE 4.2-9 THERMAL MEMBRANE PLUS BENDING STRESSES

Pressure Case

All stresses in psi

Nozzle Pressure = 1,111 psi Vessel Pressure = 1,000 psi

Section	Inside			Outside		
	٩	σθ	σŗ	٩٥	αθ	٥r
A	1,127	4,963	-1,000	3,496	5,194	-
В	589	8,437	-1,000	4,276	8,618	-
С	1,037	7,941	-1,000	3,837	7,931	-
D	1,086	7,873	-1,000	3,790	7,846	-
E ·	5,524	5,476	-1,000	-1,961	2,522	- .
F	5,432	7,567	-1,111	4,393	6,492	-
G	-1,430	3,615	-1,111	6,654	5,531	-1,000
Ħ	3,189	-1,378	-1,111	2,294	-1,557	-1,000
I	3,289	-1,381	-1,111	2,194	-1,612	-1,000
J	4,962	-1,267	-1,111	658	-2,457	-1,000

Sections Illustrated in Figure 4.2.1-1.

NEBG-807A (6/80)

8-123 SH NO. 122 NUCLEAR ENERGY BUSINESS GROUP GENERAL 🛞 ELECTRIC

22A7454 Rev 1 SH NO. 123

8 - 124

4.3 <u>Fatigue Analysis</u>. This section provides all the detailed fatigue analysis required to show an acceptable design for the operating transients imposed on the nozzle and safe end assembly. (Service Level 'B' Events)

4.3.1 Stress Concentration Factors

Section A

The geometry of the outside surface of Section A is illustrated in Figure 4.3-1. To calculate the stress concentration factor, Reference 6.6 will be used.

 $\frac{\text{NOTE:}}{\text{t}} = \frac{3.88}{.65} = 5.97$

Using Paragraph A.7.2.6 (Reference 6.6),

D = 2T = 12.12 in

d = 2t = 1.3 in .

K is found from Figure A.7-1, since the scale stops at r/t = 3.6, that value is assumed.

 $K_0 = 1.24$

Using Paragraph A.7.2.4, for r < h

$$\frac{K' - 1}{K_0 - 1} = 1 - \left(\frac{\beta}{90}\right)^{1 + 2.4 \sqrt{r/h}}$$

Solving for K', obtain

$$\mathbf{K'} = \mathbf{1} + \mathbf{0.24} \quad \mathbf{1} - \left(\left(\frac{45}{90} \right)^{-1} + \mathbf{2.4} \sqrt{\frac{3.88}{5.41}} \right)$$

 $K_{t} = 1.21$

			8-125
NUCLEAR ENERGY	GENERAL 🍘 ELECTRIC	22A7454	SH NO. 124
BUSINESS GROUP		REV 1	

.

Section F

The geometry of Section F is illustrated in Figure 4.? To calculate the stress concentration factor, Reference 6.6 will be used. A concentration factor for both the inner and outer surface will be calculated, however, only the largest will be used.


Assume $r \approx 0$, hence $K_{0} = 4.0$.


Then using Paragraph A.7.2.4 (Reference 6),

 $\frac{(K'-1)}{(K_0-1)} = 1 - \frac{\beta}{90}$


Solving for K', using $\beta_{inner} = 72.3^{\circ}$ and $\beta_{outer} = 75.74^{\circ}$

K' = 1.59 K'_{outer} = 1.48 $K_{t} = 1.59$









	۰.			8-127
NUCLEAR ENERGY		GENERAL 🥵 ELECTRIC	22A7454	SH NO. 126
BUSINESS GROUP			REV 1	

Sections E and G

The generatory of Sections E and G are illustrated in Figure 4.3-3. Also in Figure 4.3-3, is the idealized geometry used to obtain the factor. To obtain the stress concentration factor, Reference 6.6 will be used. Using Figure A.7-1 of Reference 6.6, obtain

For Section E; $r/t = 0.30$	$K_t = 2.15$
and for Section G; $r/t = 0.50$	$K_{+} = 1.80$

Section J

The geometry of Section J is illustrated in Figure 4.3-4. ANSYS, which was used to obtain the stress levels of the nozzle and safe end accounts for global discontinuities only. Therefore, only the local discontinuity stress concentration factor must be found. Conservatively, use Paragraph A.7.2.4 (Reference 6.6).

Assume $r \sim 0$, and hence $K_0 = 4.0$.

Then using Paragraph A.7.2.4 (Reference 6.6), obtain

$$\frac{(\mathbf{K}'-1)}{(\mathbf{K}_0-1)} = 1 - \frac{\beta}{90}$$

Solving for K', using $\beta = 76.44^{\circ}$

$$K' = 1 + 3 \left(1 - \frac{76.44}{90} \right)$$

.°. $K_{t} = 1.452$




FIGURE 4.3-3 SECTION E AND G GEOMETRY




FIGURE 4.3-4 SECTION J GEOMETRY

8-128

		0010464	
NUCLEAR ENERGY	GENERAL 🍘 ELECTRIC	22A7454	SH NO. 128
BUSINESS GROUP		REV 1	

Sections B, C, D, H, and I

All of these sections are at locations of welds. A conservative stress concentration factor will be put on these locations. For pipe juined by butt welds, the thermal K_{\pm} is 1.8 (Reference 6.2). This will be assumed here.

 $K_{+} = 1.8$

4.3.2 <u>Alternating Stress Range</u>. To calculate the alternating stress range, the following equation is used.

$$S_{alt} = 1/2 K_e (K_t S_N + F_1)$$

where:

 K_{\perp} = stress concentration factor

K = simplified elastic-plastic factor

 $S_{y} = P+Q$ stress intensity

 F_1 = peak stress identified by 'NONO' program

The peak stress identified by the 'NONO' program is found using Tables 4.3-3 through 4.3-11. These tables contain the total surface stresses at each section. A conservative method of obtaining these peak stresses is to find the largest stress intensity range for the surface stresses and subtracting the P+Q stress intensity found earlier in Paragraph 4.2.5. This was followed and the results are given in Table 4.3-1. Also in Table 4.3-1 is the stress intensity range for the mechanical load case which does not include seismic loads. These are needed to calculate the P+Q range excluding seismic, hence the alternating stress range excluding seismic is given.

22A7454

REV 1

8-130 SH NO. 129

4.3.2 (Continued)

The total alternating stress range is calculated for both seismic loading included and seismic loading not included. The simplified elastic-plastic factor is defined by the following (Reference 6.2).

1.0 for $S_N < 3S_m$ $1 + \frac{(1 - n)}{n(m - 1)} \left(\frac{S_N}{3S_m} - 1\right) \text{ for } 3S_m < S_N < m3S_m$

 $1/n \text{ for } m3S_m < S_N$.

where:

for carbon steel n = 0.2m = 3for stainless steel

n = 0.3m = 1.7

 $S_{N} = P+Q$ stress intensity range

The results are tabulated in Table 4.3-2.

GE	N	E	R	A	L	E	E	L	E	C	T	R	l	C
----	---	---	---	---	---	----------	---	---	---	---	---	---	---	---

REV 1

2287454

TABLE 4.3-1 CALCULATION OF PEAK STRESS

All etresses in ksi

Thermal 'Skin' Stresses Included

Location	Mechanical Range (Seismic)	Mechanical Range (No Seismic)	Thermal Range	Cases*	Pressure Range	Maximum Surface Stress Range	S _N ** P+Q	(F ₁) Peak Stress
A	18.54	6.85	5.93	1-7	6.22	30.69	29.22	1.47
В	18.48	6.62	6.78	16	9.64	34.90	32.83	2.07
С	18.41	6.39	14.69	1-6	8.96	42.06	39.27	2.79
D	18.41	6.39	14.98	1-6	8.89	43.28	39.48	2.80
Е	18.35	6.15	26.20	2-9	9.53	54.08	43.15	10.93
F	24.22	7.73	40.55	1-6	8.83	73.6	61.68	11.92
G	19.78	5.51	38.81	2-9	10.15	68.74	62.29	6.45
H	19.33	5.79	44.73	19	4.76	68,82	62.90	5.92
I	14.85	4.44	50.94	1-9	4.91	70.7	62.54	8.16
J	14.77	4.49	55.52	1-9	7.79	78.08	. 59,31	18.77

• Cases shown in Table 4.2.5-1

** From Section 4.2.5.4

NEBG-807A (6/80)

8-131

SH NO. 130

8-132

SH NO. 131

GENERAL 🍘 ELECTRIC

NUCLEAR ENERGY **BUSINESS GROUP**

22A7454

REV 1

TABLE 4.3-2 CALCULATION OF ALTERNATING STRESS

All stresses in ksi

Location	s _{N1} *	s _{N2} +*	K _t	$\begin{pmatrix} F_1 \\ Peak \end{pmatrix}$ Stress	K. * *	^к е2	S _{alt} 1	S _{alt2}
Å	29.22	17.53	1.21	1.47	1.0	1.0	18.42	11.34
В	32.83	20.97	1.8	2.07	1.0	1.0	30.6	19.91
C ·	39.27	27.25	1.8	2.79	1.0	1.0	36.8	26.0
D	39.48	27.46	1.8	2.80	1.0	1.0	37.0	26.2
E	43.15	30.95	2.15	10.93	1.0	1.0	51.9	38.8
F	61.6 8 [.]	45.19	1.59	11.93	1.21	1.0	66.6	41.9
G	62.29	48.02	1.8	6.45	1.233	1.0	73.1	46.5
H	62.90	49.36	1.8	5.92	1.255	1.0	74.8	47.4
I	62.54	52.13	1.8	8.16	2.01	1.287	121.4	65.7
J	59.3 1	49.03	1.45	18.77	1.786	1.072	93.6	48.2

Subscript 1 for seismic; Subscript 2 for no seismic loads *

 S_{N_2} found using Section 4.2.5 and Table 4.2.3.2-1

GENERAL 🍘 ELECTRIC

TABLE 4.3-3 THERMAL 'SKIN' STRESSES (P + Q + F_1) (CASE 1)

Cool Down (t = 6.0 seconds) All stresses in psi

6		Inside			Outside			
Section	٥ţ	۵ ۵	σŗ	۵¢	σθ	σr		
A	3,623	3,419	-	-1,873	-1,494	-		
В	4,183	4,353	-	-1,797	-1,792	-		
С	4,340	4,422	-	-1,292	-2,749	-		
D	4,368	4,357		-1,317	-2,823	-		
E	16,358	3,038	-	-7,253	-8,440	-		
F	38,712	29,769	- .	-21,225	-15,334	-		
G	23,724	37,262	· _	-10,544	-1,992	-		
H	33,822	44,723	-	-27,107	-4,255	-		
I	50,935	38,423	-	-4,123	-24,635	-		
J	50,037	55,518	-	-5,889	-17,421	-		

Sections Illustrated in Figure 4.2.1-1.

SH NO. 133

TABLE 4.3-4 THERMAL 'SKIN' STRESSES $(P + Q + F_1)$ (CASE 2)

Cool Down (t = 15.0 seconds) All stresses in psi

		Inside			Outside			
Section	σ¢	σ _θ	σΓ	٩٥	αθ	σΓ		
A	3,113	2,877	-	-1,992	-1,470	-		
В	3,206	3,518	-	-1,602	-1,531	-		
с	2,230	2,558	-	-128	-2,882	-		
D	2,250	2,418	-	-140	-3,019	- ·		
E	26,195	5	-	-12,272	-16,508	-		
F	36,613	25,636	-	-23,420	-13,914	-		
G	7,629	38,809	-	-75	9,598	-		
H	29,686	35,301	-	-33,577	-13,094	-		
I	39,914	31,376	-	-17,613	-31,359	-		
J	40,400	46,428	-	-19,565	-31,097	-		

Sections Illustrated in Figure 4.2.1-1.

8-135

TABLE 4.3-5 THERMAL 'SKIN' STRESSES $(P + Q + F_1)$ (CASE 3)

Cool Down (t = 60, seconds) All stresses in psi

		Inside			Outside			
Section	۵¢	۵Ð	σr	σţ	٩	σ. r		
Ă	428	9 83	-	-189	75			
B	702	1,269	-	-419	219	-		
С	-4,004	-867	a	4,317	467	-		
D	-4,189	-1,119	-	4,505	360	-		
E	17,328	-6,934	-	-6,859	-15,349	-		
F	20,038	10,184	-	-15,449	-6,371	-		
G	-2,865	28,192	-	7,709	9,610	_		
H	26,786	29,469	-	-35,539	-17,295	-		
I	33,583	26,665	-	-23,875	-34,231	- '		
J	35,206	40,230	-	-29,417	-37,795	-		

Sections Illustrated in Figure 4.2.1-1.



NEBG-807A (6/80)

8-136

TABLE 4.3-6 THERMAL 'SKIN' STRESSES $(P + Q + F_1)$ (CASE 4)

Cool Down (t = steady state) All stresses in psi

		Inside			Outside			
Section	۵¢	αθ	σr	۵۵	۵ ⁶	٥r		
A	-1,123	42	-	1,160	649	-		
В	-1,158	722	-	1,112	1,321	-		
С	-8,705	-3,860	- '	8,344	1,738	-		
D	-8,961	-4,203	-	8,593	1,631	-		
E	11,513	-8,565	-	-5,060	-9,135	-		
F	14,726	2,289	-	-12,418	-6,132	-		
G	1,099	18,047	-	1,083	-166	-		
Ħ	26,237	29,924	-	-3'5,042	-16,606	-		
I	33,098	27,126	-	-23,496	-33,584	-		
J	35,424	40,531	· _	-29,711	-37,674			

Sections Illustrated in Figure 4.2.1-1.

GENERAL 🍘 ELECTRIC

NUCLEAR ENERGY **BUSINESS GROUP**

.

22A7454 REV 1

8-137 SH NO. 136

TABLE 4.3-7 THERMAL 'SKIN' STRESSES $(P + Q + F_1)$ (CASE 5)

Heat Up (t = 2.0 seconds) All str \sim s in psi

Section		Inside			Outside			
366 5101	σţ	σθ	σr	σ¢	٩	σŗ		
A	-1,875	-635	-	1,352	840	_		
В	-2,200	-356	-	1,341	1,560	-		
С	-10,008	-5,183	-	8,597	2,139	-		
D	-10,271	-5,520	-	8,851	2,041	-		
E	8,835	-9,759	-	-4,209	-8,158	-		
F	2,762	-7,988	-	-8,384	-3,018	-		
G	-8,872	7,052	-	3,722	816	-		
H	14,115	20,018	-	-34,578	-15,131	-		
I	20,488	11,739	-	-23,383	-32,975	. 		
J	17,903	22,761	-	-30,218	-35,591	—		

Sections Illustrated in Figure 4.2.1-1.

.....

1

8-138

TABLE 4.3-8 THERMAL 'SKIN' STRESSES (P + Q + F_1) (CASE 6)

Heat Up (t = 3.0 seconds) All stresses in psi

		Inside			Outside			
Section	٥ġ	αθ	σr	٩٥	σ _θ	ar		
A	-2,278	-1,029	-	1,591	1,048	-		
В	-2,592	-763	. 🕳	1,599	1,813	-		
С	-10,347	-5,531	-	8,800	2,485	-		
D	-10,611	-5,861	-	9,056	2,395	-		
E	7,369	-9,907	-	-3,462	-7,280	-		
F	-1,128	-10,780	-	-5,368	-752	-		
G	-10,334	4,345	-	5,903	1,739	-		
H	11,751	18,369	–	-33,126	-13,254	-		
I	18,842	8,825	-	-21,948	-31,365	-		
J	14,040	19,115	-	-29,368	-33,807	-		

Sections Illustrated in Figure 4.2.1-1.

REV 1

8-139 SH NO. 138

• •

TABLE 4.3-9 THERMAL 'SKIN' STRESSES (P + Q + F_1) (CASE 7)

Heat Up (t = 12.0 seconds) All stresses in psi

<u> </u>		Inside			Outside			
Section	٥¢	٩	σr	۵	σθ	σ		
A	-2,299	-1,029	-	1,893	1,251	-		
В	-2,409	-638		1,742	1,928	-		
C	-9,663	-4,970	-	8,496	2,778	-		
D	-9,924	-5,267	-	8,748	2,715	-		
E	2,900	-8,592	-	-1,084	-3,587	-		
F	-1,500	-9,444	-	-2,150	34	-		
G	-3,205	4,035	-	2,937	-2,753	- .		
H	14,616	23,468	-	-30,172	-9,000	-		
I	24,816	13,262	-	-16,209	-27,771	-		
J	18,352	23,870	-	-22,504	-27,294	-		

Sections Illustrated in Figure 4.2.1-1.

SH NO. 139

8-140

TABLE 4.3-10 THERMAL 'SKIN' STRESSES $(P + Q + F_1)$ (CASE 8)

(Normal Operation) All stresses in psi

		Inside			Outside				
Section	٩	σθ	σr	٩٥	٩	σ			
A	-11	-364		2	-303				
В	-648	187	-	625	556	-			
с	-3,833	-1,791	-	3,673	698	- .			
D	-3,936	-1,936	-	3,773	645	-			
E	5,932	-3,610	-	-2,775	-4,261	-			
F	5,453	483	—	-4,590	-2,492	-			
G	15	8,293	-	1,181	214	-			
H	5,573	20,891	-	-22,570	-758	-			
I	20,091	4,523	-	-4,088	-21,360	-			
J	8,568	12,150	-	-7,694	-16,972	-			

Sections Illustrated in Figure 4.2.1-1.

GENERAL 🍪 ELECTRIC

22A7454 SH NO. 140 REV 1

TABLE 4.3-11 MEMBRANE PLUS BENDING PLUS SKIN STRESSES (P + Q + F_1)

(Pressure Case) All stresses in psi

Section		Inside		Outside				
Section	٥	σθ	σr	٩٥	σθ	۵Ľ		
Å	1,052	4,978	-1,000	3,632	5,220			
В	436	8,436	-1,000	4,394	8,637	-		
С	931	7,954	-1,000	3,923	7,946	-		
D	981	7,886	-1,000	3,872	7,859	-		
E	8,103	5 ,982	-1,000	-1,426	2,662	-		
F	6,096	7,719	-1,111	4,690	6,545	-		
G	-969	3,700	-1,111	9,036	5,931	-1,000		
H	3,202	-1,367	-1,111	2,284	-1,551	-1,000		
I	3,290	-1,376	-1,111	2,152	-1,620	-1,000		
J	5,311	-1,231	-1,111	543	-2,479	-1,000		

. •

Sections Illustrated in Figure 4.2.1-1.

8-142	
-------	--

GENERAL 🍪 ELECTRIC

22A7454 REV 1

454 SH NO. 141

4.3.3 <u>Usage Calculations</u>. Using the total alternating stress levels found in Table 4.3-2, the fatigue usage factor can be solved. From the design specification (Reference 6.1), there are 1,500 thermal cycles and it is assumed there are 10 seismic cycles. Using Figures I-9.2 and I-9.1 from Reference 6.2, the fatigue usage factors are found. Table 4.3.3-1 contains these calculations. Notice, the stress ranges must be adjusted to the elastic modulus of the fatigue curves. The total usage factors are as follows.

Location	<u>Fatigue Usage</u>
A	0.0016
В	0.0257
С	0.0609
D	0.0609
E	0.233
F	0.2789
G	0.4065
Ħ	0.4074
I	0.2006
J	0.0556

NUCLEAR ENERGY

BUSINESS OPERATIONS

NUCLEAR ENERGY BUSINESS OPERATIONS GENERAL 🍘 ELECTRIC

22A7454 REV 1

TABLE 4.3.3-1 CALCULATION OF FATIGUE USAGE

Location	S _{alt} (ksi)	** Elastic Modulus Factor	S _A 1 (ksi)	Allow. Cycles		S _{alt2} (ksi)	Elastic Modulus Factor	S _{A2} (ksi)	Allow. Cycles	Usage Factor
A	18,42	1.042	19.2	10 ⁵	0.0001	11.34	1.042	11.9	10 ⁶	0.00149
В	30.6	1.103	33.8	13,000	0.0008	19.91	1.103	22.0	60,000	0.0249
С	36.8	1.103	40.6	8,000	0.0013	26.0	1.103	28.7	25,000	0.0596
D	37.0	1.103	40.9	8,000	0.0013	26.2	1.103	28.9	25,000	0.0596
E	51.9	1.103	57.3	2,750	0.0037	38.8	1.103	42.8	6,500	0.2293
F	66.6	1.103	73.5	1,250	0.0080	41.9	1.103	46.3	5,500	0.2709
G	73.1	1.103	80.7	1,100	0.0091	46.5	1,103	51.3	3,750	0.3974
H	74.8	1.103	82.6	1,000	0.0100	47.4	1.103	52.3	3,750	0.3974
I	121.4	0.968	119.7	700	0.0143	65.7	0.968	64.8	8,000	0.1863
J	93.6	0.968	92.3	1,700	0.0059	48.2	0.968	47.6	30,000	0.0491

* Subscript 1 for Seismic; Subscript 2 for no seismic loads.

** For carbon steel fatigue curve, $E = 30 \times 10^6$ psi; for stainless steel fatigue curve, $E = 26 \times 10^6$ psi

NEO \$07A (REV. 10/81)

8-143

142

SH NO.

22Å7454 REV 1 SH NO. 143

8-144

4.3.4 <u>High Cycle Fatigue</u>. The cumulative high cycle fatigue usages due to rapid cycling was determined to be as follows (Reference 6.12).

U = 0.000063

4.3.5 <u>Accumulated Fatigue Usage</u>. The extisting nozzle and remaining part of the safe end have accumulated a fatigue usage of 0.22 (Reference 6.1).

4.3.6 Total Fatigue Usage, The total fatigue usage is as follows.

Location	System <u>Fatigue</u>	High <u>Cycle</u>	Existing Fatigue	Total <u>Usage</u>
A	0.0016	0.0001	0.22	0.2217
В	0.0257	0.0001	0.22	0.2458
С	0.0609	0.0001	0.22	0.2810
D	0.0609	0.0001		0.0610
E	0.233	0.0001		0.2331
F	0.2789	0.0001	 .	0.2790
G	0.4085	0.0001	·	0.4086
H	0.4099	- 0.0001		0.4100
I	0.2006	0.0001		0.2007
J	0.0556	0.0001	-	0.0557

E	N	E	R	A	L	36	El	LE	C	T	R	I	C
---	---	---	---	---	---	----	----	----	---	---	---	---	---

22A7454 ^{Rev} 1

SH NO. 144

5. RESULTS

Detailed stress analysis of the feedwater nozzle and safe end assembly shows that the nozzle and assembly fully meet the ASME Code (Reference 6.2) stress intensity limits. Further, the nozzle and assembly are shown to satisfy the requirements for cyclic operation, with the maximum cumulative fatigue usage determined to be:

 $\overline{U}_{max} = 0.41$

G

6. REFERENCES

- 6.1 'Reactor Vessel System Cycling', Design Specification 22A6996, Rev. 0.
- 6.2 ASME Boiler and Pressure Vessel Code, Section III, Subsections NA and NB, 1977 Edition including Addenda through Summer 1978.
- 6.3 'ANSYS, Engineering Analysis System, User's Manual,' Swanson Analysis Systems, Inc.
- 6.4 Kreith, F., 'Principles of Heat Transfer', Third Edition, IEP Publisher, 1973.
- 6.5 DRF# B13-909, Monticello Feedwater Nozzle Stress Analysis Design Record File.
- 6.6 'Tentative Structural Design Basis for Reactor Pressure Vessels and Directly Associated Components', 1958.
- 6.7 GE Drawing No. 769E531, Rev. 0, As-Built Feedwater Nozzle.
- 6.8 GE Drawing No. 105D6009, Rev. 2, Thermal Sleeve
- 6.9 GE Drawing No. 137C7841, Rev. 1, Reducing Tee
- 6.10 GE Drawing No. PDS-3108, Layout.
- 6.11 GE Drawing No. 137C7843, Rev. 2, Safe End.
- 6.12 Reactor Vessel Rapid Cycling, GE Document No. 22A7227, Rev. 0.
- 6.13 GE Drawing No. 112D2892, Rev. 3, Safe End Assembly.
- 6.14 J.E. Shigley, <u>Mechanical Engineering Design</u>, McGraw-Hill, Second Edition, 1972.

GENERAL 🍘 ELECTRIC -

REV

2217454 1

8-146

145 SH NO.

APPENDIX 10 LISTING OF 'NONO'

10 REAL HENSTE 20 REAL NEWSIE 30 REAL NUAVGS 40 REAL NUDIS 50 REAL MONARH 60 REAL HOMENT 70 DINENSION NELH(25).CORDX(27).STRS(27).DISAVG(27).STAVG(27).TETR(27). 808 NEWSTR(27).NUAVGS(27).NUDIS(27).HOHARH(27).HOHENT(27).KOUNT(999) 90 PRINT:"" PRINT:"" 100 110 PRINT:"" 120 PRINT: "DO YOU NEED INSTRUCTIONS? (1=YES.0=NO)" 130 READ: NOYESO 140 IF(NOYESO.EQ.0) GOTO 10 1.50 PRINT:"" 160 PRINT:"" PRINT:"" 170 180 PRINT:"" 190 PRINT: "THIS PROGRAM LINEARIZES THE STRESSES THROUGH THE " 200 PRINT:"" 210 PRINT: "THICKNESS OF A SECTION." 220 PRINT:"" PRINT: "INFUT THE LOCATION OF THE POINTS WHERE STRESSES ARE" 230 240 PRINT:"" 250 PRINT: "ACTING, I.E. THE FIRST SURFACE. THE CENTROIDS AND" 260 FRINT:"" 270 PRINT: "THE SECOND SURFACE." 280 PRINT:"" 290 PRINT: "INFUT STRESSES AT THE FIRST SURFAFE. CENTROIDS AND " 300 PRINT:"" 310 PRINT: "THE SECOND SURFACE." 320 PRINT:"" PRINT:" IF N IS THE NUMBER OF ELEMENTS THEN TOTAL STRESS AND" 330 340 PRINT:"" 350 PRINT: "LOCATION ENTERIES REQUIRED ARE N+2. (I.E. 2 SURFACES" 360 PRINT:"" 370 PRINT: "AND N CENTROIDS.)" 380 PRINT:"" 390 FRINT: "THE PROGRAM THEN COMPUTES THE MEMBRANE STRESS BY" 400 PRINT:"" 410 PRINT: "THE EQUIVALENT AREA HETHOD." 420 PRINT:"" 430 PRINT: "THE BENDING STRESSES ARE COMPUTED BY LINEARIZING THE" 440 PRINT:"" 450 PRINT: "MOMENT ACROSS THE SECTION THICKNESS." 460 PRINT:"" 470 PRINT: "PEAK STRESSES ARE THE TOTAL STRESS MINUS THE" 480 PRINT:"" 490 PRINT: "NEMBRANE AND BENDING STRESSES AT THE SURFACES." PRINT:"" 500 501 PRINT:""



22A7454 REV 1

APPENDIX 10 (Continued)

.

502		PRINT:""
503		PRINTER
510		PRINT: "WHEN FINISHED INFUT NUMBER OF ELEMENTS = 0 TO EXIT"
520		PRINT:""
530		PRINT:""
540	10	PRINT:""
550		PRINT:""
560		PRINT: "WANT A LISTING OF THE INPUT STRS & COORDS., (1=YES.O=NO)"
570		READ: NOYES
580		DO 300 L=1,997
590		PRINT:" "
600		PRINT:" "
310		NSTRS=0
320		FRINT:" INFUT NO. OF ELEM ACROSS THCK "
630		READ: NEL
ó40		IF(NEL.LE.0)GOTO 301
550 -		LOCATE=NEL+2
660		KOUNT(L)=L
670		IF(KOUNT(L).EQ.1) GOTO 11
680		PRINT:""
670		PRINT:""
700		PRINT: "USE COORDS. FROM THE PREVIOUS RUN?? (YES=1.NO=0)"
710		READ: NOYES1
720		IF(NOYES1.ED.0) GOTO 11
730		GOTO 12
740	11	PRINT: " INPUT COORD. LOCATIONS X1, X2, ETC. "
. 750		READ: (CORDX(I),I=1,LOCATE)
760C		
770	12	2 PRINT:" INFUT CORRES STRESSES "
780		NSTRS=LOCATE
790		READ: (STRS(J).J=1,NSTRS)
800		TDTSTR=0.
510		TOTDIS=0.
820		100 K=1, (NSTRS-1)
830		STAVG(K) = (STRS(K) + STRS(K+1))/2.0
S40		BISAVG(K) = (CORDX(K+1) - CORDX(K))
850		TSTR(K)= STAVG(K) +DISAVG(K)
860		TOTSTR=TOTSTR+TSTR(K)
870		TOTDIS=TOTDIS+DISAVG(K)
880	10	O CONTINUE
890		MENSTR=TOTSTR/TOTDIS
900		TOTHOH=0.

NEBG-807A (6/80)

8-147

SH NO. 146

GENERAL 🍪 ELECTRIC

NUCLEAR ENERGY BUSINESS GROUP

REV 1

22.17454

147 SH NO.

8-148

APPENDIX 10 (Continued)

910	r	10 101 I=1.NSTRS
920		EVSTR(I)=STRS(I)-MENSTR
930		0 102 I=1.(NSTRS-1)
740		(UAVGS(I)=(NEUSTR(I)+NEUSTR(I+1))/2.0
950		(UDIS(I) = CORDX(I+1)-CORDX(I)
960		TOMARH(I)=(CORDX(I)-CORDX(1))+(CORDX(I+1)-CORDX(I))/2.
970		OHENT(I)=NUAVGS(I)*NUDIS(I)*HOMARH(I)
980		TOTHON= TOTHON+HONENT(I)
990		CONTINUE
1000		SBEND=(6*TOTNOH)/(TOTDIS*TOTDIS)
1010		SBENDI=ABS(SBEND)
1020		SBEND2=SBEND1*(-1.)
1020		SBEND=ABS(SBEND)
1030		IF(STRS(1).LT.STRS(NSTRS)) GO TO 400
1040		PEAKS1=STRS(1)-MEMSTR-SBEND1
:050		PEAKS2=STRS(NSTRS)-NEMSTR-SBEND2
1060		GO TO 401
1070	400	PEAKS1=STRS(1)-MEMSTR-SBEND2
1050		PEAKS2=STRS(NSTRS)-MEMSTR-SBENDI
1090	401	IF(NOYES.EQ.0) GOTO 20
1100		PRINT:" "
1110		PRINT:"INPUT STRESSES ARE:"
1120		PRINT:" "
1130		WRITE(06,202)(STRS(I),I=1,NSTRS)
1140		PRINT:""
1150		PRINT:""
1160		PRINT:"INPUT COORD. ARE:"
1170		PRINT:""
1180		WRITE(06.203)(CORDX(I),I=1,LOCATE)
1190		WRITE(06,200) MENSTR, SBEND. PEAKS1, PEAKS2
1200		CONTINUE
1210		URITE(06,204)
1220		FORMAT(//,4X,"HENBRANE STRESS = ",F10.1,4X.
1230		"BENDING STRESSES = (+ OR-) ",F10.1.//.4X.
1240		."PEAKS1 =".F10.1,4X."PEAKS2 =".F10.1.//)
1 250		PERMAT(4X.4F10.1./)
1260		; FORMAT(4X,4F10.3./) E FORMAT(7/." HAVE A NICE DAY !! "•///
1 27 0		
1 260		STOP
1 2 9 0		END



22A7454 Rev 1 SH NO. 148

8-149

APPENDIX 20 INTERGRANULAR STRESS CORROSION INDEX CALCULATION

The areas requiring an IGSCC stress rule index calculation are Sections C/D and H/I. These sections are at new weld locations.

20.1 Sections C and D

S.I. = $\frac{P_m + P_B}{S_y}$ + $\frac{Q + F + RESID}{S_y + 0.002E}$

Section C is SA-508 (Class 1) carbon steel and Section D is SA-350 (LF2) carbon steel.

20.1.1 <u>Mechanical Load Stress.</u> The mechanical load stresses are the result of dead weight, thermal, and hydraulic loads during normal operation. The loads are obtained from Reference 6.1, and are as follows.

Nozzle Loads

Dead Weight (Nozzle 'A' Loads used)

F₂ = -0.11 kip m₂ = +11.6 in-kip

 $F_{y} = -0.63$ kip $m_{y} = -14.1$ in-kip

 $F_{\tau} = +0.15$ kip $m_{\tau} = -11.1$ in-kip

Thermal (Nozzle 'B' Loads used)

 $F_{x} = +0.82 \text{ kip}$ $m_{x} = +267.2 \text{ in-kip}$

 $F_{y} = -4.34$ kip $m_{y} = +66.7$ in-kip

 $F_{=} = +1.37 \text{ kip}$ $m_{=} = +1.4 \text{ in-kip}$

8-150 SH NO. 149

20.1.1 (Continued)

Thermal Sleeve Loads

Dead Weight Plus Hydraulic

 $F_{\tau} = -0.3$ kip $F_z = -3.0$ kip $m_r = -1.2$ in-kip

Thermal

$$F_z = -1.2$$
 kip

The same procedure used in Section 3 will be used here. If more detail is required, refer to Section 3 for a reference.

$$P = (F_x^2 + F_y^2)^{1/2}$$
$$m = (m_x^2 + m_y^2 + m_z^2)^{1/2}$$

Nozzle Loads

Dead Weight

$$P = 0.64 \text{ kip}$$

m = 21.4 in-kip
 $F_z = 0.15 \text{ kip}$

Thermal.

 $P = 4.42 \, kip$ m = 275.41 in-kip F₇ = 1.37 kip

8-151 SH NO. 150

20.1.1 (Continued)

Thermal Sleeve Loads

Dead Weight plus Hydraulic

- P = 0.3 kip
- m = 1.2 in-kip
- $F_z = 3.0 kip$

Thermal

$$F_{-} = 1.2 \, kip$$

Section C and D

Nozzle Load Stresses

Dead Weight

m = 21.4 + 0.64(7.47) + 0.15 (0.56) = 26.27 in-kip

$$\sigma_{\text{BEND}} = \frac{m}{z} = \frac{26.27}{51.98} = 0.506 \text{ ksi}$$
$$\sigma_{\text{AX}} = \frac{F_z}{A} = \frac{0.15}{19.03} = 0.008 \text{ ksi}$$

Thermal.

m = 275.41 + 4.42(7.47) + 1.37(0.56) = 309.2 in-kip

$$\sigma_{\text{BEND}} = \frac{m}{z} = \frac{309.2}{51.98} = 5.95 \text{ ksi}$$
$$\sigma_{\text{AX}} = \frac{F_z}{A} = \frac{1.37}{19.03} = 0.72 \text{ ksi}$$

REV 1

22A7454 SH NO. 151

8-152

20.1.1 (Continued)

Thermal Sleeve Stresses

Dead Weight plus Hydraulic

m = 1.2 + 0.3(21.12) + 3.0(2.36) = 14.62 in-kip

 $\sigma_{\rm BEND} = \frac{m}{z} = \frac{14.62}{51.98} = 0.282$ ksi

$$\sigma_{AX.} = \frac{F_z}{A} = \frac{3}{19.03} = 0.158 \text{ ksi}$$

Thermal.

m = 1.2(2.36) = 2.84 in-kip

 $\sigma_{\text{BEND}} = \frac{m}{z} = 0.055 \text{ ksi}$ $\sigma_{AX} = \frac{F_z}{A} = 0.063 \text{ ksi}$

Total Stresses. Primary stresses are dead weight and hydraulic stresses, while secondary stresses are thermal load stresses.

Primary Stress

 $\sigma_{\dot{0}} = \sigma_{\rm BEND} + \sigma_{\rm AX} = 0.954 \ \rm ksi$

Secondary Stress

 $\sigma_{\dot{0}} = \sigma_{\rm BEND} + \sigma_{\rm AX} = 6.14$ ksi

· _			8-153
NUCLEAR ENERGY BUSINESS GROUP	GENERAL 🍪 ELECTRIC	22A7454 REV 1	SH NO. 152

20.1.2 Pressure Stress

Prim Pressure Stress

 $\sigma_{\Theta} = \frac{Pri}{t} = \frac{1,000(10,875)}{2(0.531)} = 10.24 \text{ ksi}$ $\sigma_{\Phi} = \frac{\sigma_{\Theta}}{2} = 5.12 \text{ ksi}$ $\sigma_{r} = -1,000 \text{ psi}$

<u>Secondary Pressure Stress</u>. The stresses in Table 4.2-9 are the P+Q pressure stresses corrosion not included. The primary stress (corrosion not included) is expected to be as follows.

 $\sigma_{\Omega} = 8,600 \text{ psi}$

 $\sigma_{h} = 4,300 \text{ psi}$

The actual stress from Table 4.2-9 is given as

 $\frac{\text{Section C}}{\sigma_{\Theta}} = 7,931 \text{ psi} \qquad \sigma_{\Theta} = 7,846 \text{ psi}$

 $\sigma_{b} = 3,837 \text{ psi}$ $\sigma_{b} = 3,790 \text{ psi}$

Therefore, the secondary pressure stresses are as follows.

<u>Section C</u>	Section D
σ _θ = -669 psi	σ _θ = -754 psi
σ, = -463 psi	σ ₀ = -510 psi

8-154

NUCLEAR ENERGY **BUSINESS GROUP**

GENERAL 🍘 ELECTRIC

2247454 REV 1

SH NO. 153

20.1.3 Thermal Stresses. The thermal stresses given in Table 4.2-8 for steady state normal operation are:

Section C	<u>Section D</u>		
σ _θ = 674 psi	σ _θ = 619 psi		
σ. = 3,470 psi	σ ₀ = 3,563 psi		

20.1.4 <u>Peak Stresses.</u> The peak stresses are obtained for both the pressure and thermal cases by comparing Tables 4.2-8 and 4.2-9 to 4.2-17 and 4.2-18, respectively. The total peak stress is the addition of these two values.

> Section C Section D $\sigma_{\Omega} = 203 + 86 = 289 \text{ psi}$ $\sigma_{\Omega} = 210 + 82 = 292 \text{ psi}$ $\sigma_{h} = 24 + 15 = 39 \text{ psi}$ $\sigma_{h} = 26 + 13 = 39 \text{ psi}$

The peak stresses due to mechanical loads are small and, therefore, are not included.

20.1.5 Index Calculation

Stress Summary:

* + refers to locations 180° apart

Primary Stresses

Loading	^σ θ ksi	" (ksi)	<u> </u>
Mechanical Load		<u>+</u> 0.954*	
Pressure	10.24	5.12	-1.0
TOTAL	10.24	6.074/4.166	-1.0

CLEAR ENERGY INESS GROUP	GENERAL 🍘	ELECTRIC	22A7454 Rev 1	е sh no. 15
			·····-	
20.1.5 (Continued)			
Secondary Stresses				
<u>Loading</u> Sections	$\frac{\sigma_{\Theta \text{ ksi}}}{(C)}$	(C) ↓ (D)	^σ r (lsi)	
Mechanical Load		<u>+</u> 6.14*		
Pressure	-0.671-0.76	-0.46 -0.51		
Thermal	0.671 0.62	3.47 3.57		
	<u>Section</u> C		Section D	
TOTAL	σ _θ =	σθ	= -0.14 ksi	
	$\sigma_{b} = 9.15/-3.13$	ksi oh	= 9.2/-3.08 ksi	

Peak Stresses

<u>Section C</u>	Section D	
σ _θ = 0.04 psi	σ _θ = 0.04 psi	
σ. = 0.29 psi	$\sigma_{\phi} = 0.29 \text{ psi}$	

For,

 $\frac{SA-350 (FL2) Carbon Steel}{S_y} = 27.85 \text{ ksi}$ $E = 26.0 \text{ x } 10^3 \text{ ksi}$ RESID = 37 ksi $\frac{SA-508 (Class 1) Carbon Steel}{S_y} = 27.1 \text{ ksi}$ $E = 26.0 \text{ x } 10^3 \text{ ksi}.$

RESID = 37 ksi

20.1.5 (Continued)

For Section C

Based on Stress Intensities

 $P_{m} + P_{R} = 11.24$ ksi

<u>Q+F:</u> The two possible stress intensities are based on the following stress components:

Comb	<u>σφ (ksi)</u>	^σ θ (ksi)	
1	0.04	9.44	(Q+F) _{max} = 9.44 ksi
2	0.04	-2.84	

Therefore,

S.I. =
$$\frac{11.24}{27.1} = \frac{9.44 + 37}{27.1 + 52}$$

= 0.4148 + 0.5871 = 1.0019

Now, since S.I. > 1.0, allowed, the S.I. is recalculated based on positive principle stresses.

Based on Positive Principle Stresses

 $P_{m} + P_{B} = 10.24$ ksi Q + F = 9.44 ksi S.I. = $\frac{10.24}{27.1} = \frac{9.44 + 37}{27.1 + 52}$

= 0.3779 + 0.5871 = 0.965 < 1.0 allowed

By inspection, the S.I. at Section C is higher than that at Section D.

SH NO. 156

20.2 <u>Sections H and I.</u> Section H is SA-350 (LF2) carbon steel and Section I is SA-351 (CF3) stainless steel.

20.2.1 Section H

20.2.1.1 <u>Mechanical Load Stress.</u> The mechanical load stresses are the result of dead weight, thermal, and hydraulic loads during normal operation. The loads are obtained from Reference 6.1. Note, in Paragraph 20.1.1 of this appendix, the mechanical loads were reduced to:

Nozzle Loads

- P = 0.64 kip (Dead Weight)
- m = 21.4 in-kip
- $F_{-} = 0.15 \, kip$
- P = 4.42 kip (Thermal)
- m = 275.41 in-kip
- $F_{-} = 1.37$ kip

Thermal Sleeve Loads

- P = 0.3 kip (Dead Weight and Hydraulic)
- m = 1.2 in-kip
- $F_ = 3.0 kip$
- $F_{=} = 1.2 \text{ kip (Thermal)}$

The same procedure used in Section 3 will be used here. If more detail is required, refer to Section 3 for a reference.

22A7454 SH NO. 157 REV 1

8-158

Thermal Sleeve Load Stresses

Dead Weight

m = 1.2 + 0.3(20.12) = 7.24 in-kip

$$\sigma_{\text{BEND}} = \frac{m}{z} = \frac{7.24}{22.32} = 0.325 \text{ ksi}$$
$$\sigma_{\text{AX}} = \frac{F_z}{A} = \frac{3}{10.46} = 0.287 \text{ ksi}$$

Nozzle Load Stress

Dead Weight

m = 21.4 + 0.64(8.47) + 0.15(1.8) = 27.09 in-kip

$$\sigma_{\text{BEND}} = 0.381 \frac{\text{m}}{\text{z}} = (0.381) \frac{27.09}{22.32} = 0.463 \text{ ksi}$$

$$\sigma_{AX} = 0.381 \frac{F_z}{A} = (0.381) \frac{0.15}{10.46} = 0.006$$
 ksi

Thermal

m = 275.41 + 4.42(8.47) + 1.37(1.8) = 315.32 in-kip

 $\sigma_{\text{BEND}} = 0.381 \frac{\text{m}}{\text{z}} = (0.381) \frac{315.32}{22.32} = 5.39 \text{ ksi}$ $\sigma_{\text{AX}} = 0.381 \frac{\text{F}_{z}}{\text{A}} = (0.381) \frac{1.37}{10.46} = 0.050 \text{ ksi}$

<u>Total Stresses</u>. Primary stresses are dead weight and hydraulic stresses, while secondary stresses are thermal load stresse.

Primary Stresses

 $\sigma_{\phi} = \sigma_{BEND} + \sigma_{AX} = 1.081$ ksi

Secondary Stresses

 $\sigma_{\phi} = \sigma_{\text{BEND}} + \sigma_{AX} = 5.555 \text{ ksi}$

			8-159
NUCLEAR ENERGY	GENERAL 🍪 ELECTRIC	22A7454	SH NO. 158
BUSINESS GROUP		REV 1	

20.2.1.2 Pressure Stresses

Primary Pressure Stress

 $\sigma_{\Theta} = \frac{PD_i}{2t} = \frac{111(8.505)}{2(0.375)} = 1.26$ ksi

$$\sigma_0 = \frac{\sigma_0}{2} = 0.63$$
 ksi

 $\sigma_{-} = -0.111 \text{ ksi}$

<u>Secondary Pressure Stress</u>. The stresses in Table 4.2-9 are the P+Q pressure stresses corrosion not included. The primary stress (corrosion not included) is expected to be:

 $\sigma_{\Theta} = 0.93$ ksi $\sigma_{h} = 0.465$ ksi

The actual stress from Table 4.2-9 is given as:

 $\sigma_{\Theta} = -1.38$ ksi

 $\sigma_{h} = 3.19 \text{ ksi}$

Therefore, the secondary pressure stresses are as follows:

20.2.1.3 <u>Thermal Stresses</u>. The thermal stresses given in Table 4.2-8 for steady state normal operation are:

 $\sigma_{\Theta} = 25.12 \text{ ksi}$ $\sigma_{\bullet} = 12.08 \text{ ksi}$

 $[\]sigma_{\Theta} = -2.31$ ksi $\sigma_{\dot{\Theta}} = 2.73$ ksi



SH NO. 159

8 - 160

20.2.1.4 Peak Stresses. The peak stresses are obtained for both the pressure and thermal cases by comparing Table 4.2-8 and 4.2-9 to 4.2-17 and 4.2-18 respectively. The total peak stress is the addition of these two values.

 $\sigma_{\Theta} = -4.22 - 0.011 = -4.231$ ksi $\sigma_{\rm A} = -6.5 + 0.013 = -6.49$ ksi

The peak stresses due to mechanical loads are small and therefore are not included.

20.2.1.5 Index Calculation

Stress Summary:

* + refers to locations 180° apart

Primary Stresses

Loading	σ θ ksi	σ φ (ksi)	^o r (ksi)
Mechanical Load		<u>+</u> 1.081*	
Pressure	1.26	0.63	-0.111
TOTAL	1.26	1.711/0.451	-0.111
Secondary Stresses			- ·
Loading	^σ θ ksi	σ 0 (ksi)	^σ r (ksi)
Mechanical Load		<u>+</u> 5.555*	
Pressure	-2.31	2.73	
Therma1	25.12	12.08	
10T4L	22.81	20.365/9.255	

	-		
NUCLEAR ENERGY	GENERAL 🍪 ELECTRIC	22A7454	SH NO. 160
BUSINESS GROUP		REV 1	-

8-161

20.2.1.5 (Continued)

Peak Stresses

$$\sigma_{\Theta} = -4.231$$
 ksi

$$\sigma_0 = -6.49$$
 ksi

For <u>SA-350 (LF2) Carbon Stee1</u>

 $S_{v} = 27.85$ ksi

$$E = 26.0 \times 10^3 ksi$$

RESID =
$$39.5$$
 ksi

Therefore, based on stress intensities

$$SI = \frac{1.822}{27.85} + \frac{22.81 - 4.231 + 39.5}{27.85 + 52}$$

= 0.0655 + 0.7274 = 0.7929 < 1.0 allowed

20.2.2 Section I

20.2.2.1 Mechanical Load Stress

Thermal Sleeve Load Stresses

Dead Weight

m = 1.2 + 0.3(20.12) = 7.24 in-kip

$$\sigma_{\text{BEND}} = \frac{m}{z} = \frac{7.24}{29.07} = 0.249 \text{ ksi}$$

$$\sigma_{AX} = \frac{F_z}{A} = \frac{3}{13.78} = 0.218$$
 ksi

Thermal

$$\sigma_{AX} = \frac{F_z}{A} = \frac{1.2}{13.78} = 0.087$$
 ksi

SH NO. 161

20.2.2.1 (Continued)

Nozzle Load Stresses

Dead Weight

m = 21.4 + 0.64(8.47) + 0.15(1.8) = 27.09 in-kip

 $\sigma_{\text{BEND}} = 0.381 \frac{\text{m}}{\text{z}} = (0.381) \frac{27.09}{29.07} = 0.355 \text{ ksi}$ $\sigma_{\text{AX}} = 0.381 \frac{\text{F}_z}{\text{A}} = (0.381) \frac{0.15}{13.78} = 0.005 \text{ ksi}$

Thermal [

m = 275.41 + 4.42(8.47) + 1.37(1.8) = 315.32 in-kip

$$\sigma_{\text{BEND}} = 0.381 \frac{\text{m}}{\text{z}} = (0.381) \frac{315.32}{29.07} = 4.133 \text{ ksi}$$

 $\sigma_{\text{AX}} = 0.381 \frac{\text{F}_z}{\text{A}} = (0.381) \frac{1.37}{13.78} = 0.038 \text{ ksi}$

Total Stresses

Primary Stresses

 $\sigma_{\phi} = \sigma_{BEND} = \sigma_{AX} = 0.827$ ksi

Secondary Stresses

 $\sigma_{b} = \sigma_{BEND} = \sigma_{AX} = 4.258$ ksi

20.2.2.2 Pressure Stresses

Primary Pressure Stress

$$\sigma_{\phi} = \frac{PD_{i}}{2t} = \frac{111(8.386)}{2(0.494)} = 0.943 \text{ ksi}$$

$$\sigma_{\phi} = \frac{\sigma_{\theta}}{2} = 0.471 \text{ ksi}$$

$$\sigma_{a} = -0.111 \text{ ksi}$$

NEBG-807A (6/80)

GENERAL 🚱 ELECTR	
------------------	--

8-163

4 SH NO. 162

20.2.2.2 (Continued)

<u>Scondary Pressure Stress</u>. The stresses in Table 4.2-9 are the P+Q pressure stresses corrosion not included. The primary stress (corrosion not included) is expected to be:

 $\sigma_{\rm A} = 0.93$ ksi

 $\sigma_A = 0.465$ ksi

The actual stress from Table 4.2-9 is given as:

 $\sigma_{\Delta} = -1,381 \text{ psi}$

 $\sigma_{h} = 3,289 \text{ psi}$

Therefore, the secondary pressure stresses are as follows:

 $\sigma_{\Theta} = -2.311$ ksi

 $\sigma_{h} = 2.824 \text{ ksi}$

20.2.2.3 <u>Thermal Stresses</u>. The thermal stresses given in Table 4.2-8 for steady state normal operation are:

 $\sigma_{\Theta} = -1.322$ ksi $\sigma_{b} = 12.77$ ksi

20.2.2.4 <u>Peak Stresses</u>. The peak stresses are obtained for both the pressure and thermal case by comparing Tables 4.2-8 and 4.2-9 to 4.2-17 and 4.2-18 respectively. The total peak stress is the addition of these two values.

 $\sigma_{\Theta} = 5.845 + 0.005 = 5.85$ ksi

 $\sigma_{b} = 7.323 + 0.001 = 7.324$ ksi

20.2.2.5 Index Calculations

Stress Summary:

+ refers to locations 180° apart

NEBG-807A (6/80)

8-164

GENERAL 🍘 ELECTRIC

NUCLEAR ENERGY BUSINESS GROUP 22A74 REV

22A7454 ^{Rev} 1 8-164 SH NO. 163

20.2.2.5 (Continued)

Primary Stresses

Loading	^σ θ ksi	^σ ≬ (ksi)	^σ r (ksi)
Mechanical Load		<u>+</u> 0.827*	
Pressure	0.943	0.471	-0.111
TOTAL	0.943	1.298/-0.356	-0.111
Secondary Stresses			
Loading	^o θ ksi	•) (Isi)	^o r (ksi)
Mechanical Load		<u>+</u> 4.258	
Pressure	-2.311	2.824	
The rms1	-1.322	12.77	
TOTAL	-3.633	19.852/11.336	
<u>Peak Stresses</u>			

 $\sigma_{\Theta} = 5.85$ ksi

 $\sigma_{\dot{0}} = 7.324$ ksi

For <u>SA-351 (CF3)</u> Stainless Steel

$$S_y = 17.75$$
 ksi
 $E = 25.7 \times 10^3$ ksi
RESID = 27.5 ksi

Therefore, based on stress intensities,

$$SI = \frac{1.409}{17.75} + \frac{27.176 + 27.5}{17.75 + 51.4}$$

= 0.0794 + 0.7907 = 0.8701 < 1.0 allowed

22A7454

REV 1

20.3 <u>Conclusion</u>. All stress indices are less than allowable of 1.0. The calculated indices are as follows.

	S.	I	
Location	(1)	(2)	
C	1.002	0.965	
H	0.7929	-	
I	0.8701		

(1) Based on Stress Intensities

(2) Based on Positive Principle Stresses

SH NO. 164

GENERAL 🕼 ELECTRIC

NUCLEAR ENERGY **BUSINESS OPERATIONS**

22A7454

REV 1

165 SH NO.

8-166

APPENDIX 30 RECALCULATIONS REQUIRED DUE TO MANUFACTURING DEVIATIONS

This attachment analyzes the effects of the manufacturing deviations on the feedwater safe end and thermal sleeve. The deviations are described in detail in DDR Numbers 15139, 26521, and 15127, dated April 29, 1981, July 2, 81, and May 7, 1981, respectively.

30.1 <u>Deviations Due to DDR Number 15127</u>. The deviations reported within DDR Number 15127 are two undersize locations on the thermal sleeve pads. The undersize amounts are two mils and four mils on the 7.812 inch diameter and the 7.625 inch diameter, respectively. It is noted, however, that the deviations are on the thermal sleeve pads, and within the previous calculations the pads are neglected conservatively. Therefore, these deviations will have no effect on the previous analysis and will not require recalculations of stresses.

30.2 <u>Deviations Due to DDR Number 26521</u>. The deviation reported in DDR Number 15140 is a tool undercut along the tapered surface between the 10.84 inch diameter zone and the 12.00 inch diameter zone. However, this tool undercut was weld repaired, heat treated, and machined to original finish size. This type of repair is allowed per ASME Code, Reference 6.2. Post-weld heat treatment ensures stress relief and an acceptable metallurgical condition. The part is restored to the original specified dimensions. Therefore, these deviations will have no effect on the previous analysis and requires no recalculation of stresses.

30.3 <u>Deviations Due to DDR Number 15139</u>. This paragraph analyzes the effects of two manufacturing deviations on the Monticello feedwater safe end. The deviations are described in detail in DDR Number 15139, dated April 30, 1981, and illustrated on Figure 30.3-1.

30.3.1 <u>Summary of Results.</u> The results obtained for these deviations are compared below with those from the previous nominal calculations.

NEO 807A [REV. 10/81]

NUCLEAR ENERGY BUSINESS OPERATIONS

GENERAL 🍪 ELECTRIC

REV 1


TABLE 30.3.1-1 PRIMARY STRESS ANALYSIS

(All stresses in ksi)

		After Deviations		Before I	Deviations	Allowables	
Case	Location	Pm	Pm+B	Pm	Pm+B	Pm	P ±+ B
Design	F	13.96	24.38	13.70	23.94	18.6	27,90
	G	2.83	14.90	2.74	14.54	18.6	27.90
Service Level	F	15.36	33.89	15.07	33.28	27.85	41.77
C	G	4.25	23.37	4.11	22.77	27.85	41.77

NEO \$07A (REV. 10/81)

8-167 Sh NO. 166



GENERAL 🍘 ELECTRIC

SH NO. 168

TABLE 30.3.1-2 PRIMARY PLUS SECONDARY STRESS ANALYSIS

(All stresses in ksi)

	After D	eviations	Before D		
Location	P + Q	P + Q*	P + Q	P + Q*	Allowable
F	62.3	37.23	61.68	36.61	55.8
G	62.82	45.94	62.29	45.42	55.8

* Thermal Bending Removed

TABLE 30.3.1-3 FATIGUE ANALYSIS

	After Deviation	Before Deviation
Location	Fatigue Usage	Fatigue Usage
F	0.439	0.279
G	0.41	0.409



30.3.2 <u>Primary Stress Analysis</u> a. <u>Section F (As Built)</u> $t = 0.576 \text{ in} - (\frac{1/32 \text{ in} + 1/16 \text{ in}}{\text{corrosion}}) = 0.4822 \text{ in}$ $D_0 = 10.831 - 2(1/32) = 10.7685 \text{ in}$ $D_1 = 9.679 + 2(1/16) = 9.804 \text{ in}$ Area = 15.584 in² $Z = \frac{I}{C} = 38.365$




FIGURE 30.3.2.a SECTION F (AS BUILT)

8-170

170

SH NO.

30.3.2.a (Continued) (1) <u>Design Conditions</u> Design Pressure Stress $\sigma_{\theta} = \frac{1250(9,804)}{2(0,4822)} = 12,708 \text{ psi}$ $\sigma_{\phi} = \frac{\sigma_{\theta}}{2} = 6354 \text{ psi}$ $\sigma_r = -1250 \text{ psi}$ Stress Due to Nozzle Loads $P = 4.05 \, kip$ M = 534.4 in-kip $F_{-} = 2.28 \text{ kip}$ M = 534.4 + 4.05(1.62) = 541 in-kip $\sigma_{\rm BEND} = \frac{M}{Z} = \frac{541}{38.365} = 14.102$ ksi $\sigma_{AX} = \frac{F_t}{A} = \frac{2.28}{15.584} = 0.147$ ksi Stress Due to Thermal Sleeve Loads P = 2.57 kip M = 3.124 in-kip $F_{-} = 5.7 \, kip$ M = 3.124 + 2.54(26.97) + 5.7(1.8) = 82.7 in-kip $\sigma_{\rm BEND} = \frac{M}{Z} = \frac{82.7}{38.365} = 2.156 \text{ ksi}$ $\sigma_{AX} = \frac{F_z}{A} = \frac{5.7}{15.584} = 0.366$ ksi

NEO 807A (REV. 10/81)

8-172

30.3.2.a.(1) (Continued) Total Stress $\sigma_{\phi} = 6,354 + 14,102 + 147 + 2,156 + 366 = 23,125 \text{ psi}$ $\sigma_{\theta} = 12,708 \text{ psi}$ $\sigma_{r} = -1250 \text{ psi}$ (2) <u>Service Level C Conditions</u> <u>Service Level C Pressure Stress</u> $\sigma_{\theta} = \frac{1375(9.804)}{2(0.4822)} = 13,978 \text{ psi}$

> $\sigma_{\phi} = \frac{\sigma_{\theta}}{2} = 6989 \text{ psi}$ $\sigma_{r} = -1375 \text{ psi}$

Stress Due to Nozzle Loads P = 6.44 kip M = 789.3 in-kip $F_z = 4.61$ kip M = 789.3 + 6.44(1.62) = 799.8 in-kip $\sigma_{\text{BEND}} = \frac{799.8}{38.365} = 20.847$ ksi

$$\sigma_{AX} = \frac{4.61}{15.584} = 0.296$$
 ksi

		22A7454	8-
CLEAR ENERGY SINESS GROUP	GENERAL 🍪 ELECTRIC	REV 1	SH NO. 172
		,,,	
30.3.2.1.(2)	Continued)		
	Due to Thermal Sleeve Loads		
$\mathbf{P} = 5$.08 kip		
M = 5	.39 in-kip		
F _z = (5.0 kip		
M = 5	.39 + 5.08(26.97) + 6.0(1.8) = 153.2 in	n-kip	
o P Part	$= \frac{153.2}{38.365} = 3.994 \text{ ksi}$		·
σ _{AX} =	$\frac{6.0}{15.584} = 0.385$ ksi		
<u>Total</u>	Stress		
σ _φ =	5989 + 20,847 + 296 + 3994 + 385 = 32,	511 psi	
σ_θ =	13,978 psi		
σ_ =	-1375 psi		

(3) Thickness Requirement for Section F

Treating the safe end as a 'nozzle', the safe end thickness adjacent to the attaching pipe shall not be thinner than the greater of the pipe thickness or the quantity (S_{mp}/S_{mn}) .

Where: t = Pipe Nominal Thickness S = Pipe Allowable (S) S = Safe End Allowable (S) m

NEBG-807A (6/80)

30.3.2.a.(3) (Continued)

For our geometry;

$$t_{p} = 0.5405 \text{ in}$$

 $S_{mp} = 18.1 \text{ ksi}$
 $s_{mn} = 18.6 \text{ ksi}$
 $t_{p}(S_{mp}/S_{mn}) = 0.526 \text{ in}$

Assuming Section F is the safe end thickness,

Safe end thickness = 0.576 in > 0.5405 in

CRITERIA MET

LEAR ENERGY	GENERAL	🛞 ELECTRIC	22A7454 SH NO. 17
NESS GROUP			REV 1
30.3.2 (Contin	ned)		
b. <u>Section G (</u>			
t =	<u>(9.39 - 8.378)</u> - 2	(2 * 1/16) = 0.381 in	1 .
		corrosion	
t assumed "	$\frac{(9.39 - 8.413)}{2}$	(2 * 1/16) = 0.3635	in
$D_{0} = 9.390$	-2(1/16) = 9.265	in	
$D_{i} = 8.413$	+2(1/16) = 8.538	in	
Area = 10.:	166 in ²		
$Z = \frac{I}{C} = 21$.77 in ³		
			_
<u> </u>	 	<u> </u>	
	8 (13)		
	8.413φ Ι		8.378 ¢
1		1 1	

.

•

FIGURE 30.3.2-2 SECTION G (AS BUILT)

NEBG-807A (6/80)

30.3.2.b (Continued)

(1) Design Conditions Design Pressure Stress $\sigma_{\theta} = \frac{222(8.538)}{2(0.3635)} = 2,608 \text{ psi}$ $\sigma_{\phi} = \frac{\sigma_{\theta}}{2} = 1304 \text{ psi}$ $\sigma_r = -222 \text{ psi}$ Stress Due to Thermal Sleeve Loads $P = 2.57 \, kip$ M = 3.124 in-kip $F_z = 5.7 \text{ kip}$ M = 3.124 + 2.57(23.87) = 64.47 in-kip $\sigma_{\rm BEND} = \frac{64.47}{21.77} = 2.962$ ksi $\sigma_{AX} = \frac{5.7}{10.166} = 0.561$ ksi Stress Due to Nozzle Loads P = 4.05 kipM = 534.4 in-kip · $F_z = 2.28$ kip

Dj

G	E	N	E	R	A	L	<i>9</i> 6	E	LE	C	T	R	I	C	
---	---	---	---	---	---	---	------------	---	----	---	---	---	---	---	--

......

8-177 SH NO. 176

30.3.2.b(1) (Continued)
"The same ratio used in the previous nominal calculations
(Pago 35) will be used here. This ratio simply accounts for the
stiff nozzle influence.

$$M = 534.4 + 4.05(4.72) + 2.28(1.8) = 557.62$$
 in-kip
 $\sigma_{\text{BEND}} = (0.381) \frac{M}{Z} = (0.381) \frac{557.62}{21.77} = 9.759$ ksi
 $\sigma_{\text{AX}} = (0.381) \frac{F_z}{A} = (0.381) \frac{2.28}{10.166} = 0.086$ ksi
Total Stress
 $\sigma_{\phi} = 1304 + 2962 + 561 + 9759 + 86 = 14,672$ psi
 $\sigma_{\theta} = 2608$ psi

 $\sigma_r = -222 \text{ psi}$

(2) <u>Service Level 'C' Conditions</u>

Service Level 'C' Pressure Stress

$$\sigma_{\theta} = \frac{333(8.538)}{2(0.3635)} = 3911 \text{ psi}$$

 σ_{θ}

$$\sigma_{\phi} = \frac{\theta}{2} = 1956 \text{ psi}$$

 $\sigma_r = -333 \text{ psi}$

NEBG-807A (6/80)

8-178

177

SH NO.

- GENERAL 🛞 ELECTRIC NUCLEAR ENERGY BUSINESS OPERATIONS

22A7454

REV 1

30.3.2.b.(2) (Continued) Stress due to Thermal Sleeve P = 5.08 kipM = 5.39 in-kip $F_{-} = 6.0$ kip M = 5.39 + 5.08(22.87) = 126.65 in-kip $\sigma_{\rm BEND} = \frac{M}{Z} = \frac{126.65}{21.77} = 5.818$ ksi $\sigma_{AX} = \frac{F_z}{A} = \frac{6.0}{10.166} = 0.591$ ksi Stress Due to Thermal Sleeve P = 6.44 kip M = 789.3 in-kip $F_{-} = 4.61 \, kip$ The same ratio used in the nominal calculations (Page 35) will be used here. This ratio simply accounts for the stiff nozzle influence on the thermal sleeve. M = 789.3 + 6.44(4.72) + 4.61(1.8) = 828.0 in-kip $\sigma_{\text{BEND}} = 0.381 \frac{M}{Z} = (3.81) \frac{828}{21.77} = 14.491 \text{ ksi}$ $\sigma_{AX} = 0.381 \frac{F}{A} = (.381) \frac{4.61}{10.166} = 0.173$ ksi Total stress .σ = 1956 + 5818 + 591 + 14,491 + 173 = 23,029 psi σ = 3911 psi

 $\sigma_{r} = -333 \text{ psi}$

NEO 807A (REV. 10/81)

GENERAL 🍘 ELECTRIC

22A7454 REV 1 8–179 SH NO. 178

30.3.2 (Continued)

c. Summary

NUCLEAR ENERGY BUSINESS OPERATIONS

Condition	Section		P m Allow	$\underline{P_m} + \underline{P_B}$	$\underline{P}_{\underline{m}} + \underline{P}_{\underline{B}} $ Allow
Design	F	13.96	18.6	24.38	27.90
Event	G	2.83	18.6	14.90	27.90
Service	F	15.36	27.85	33.89	41.77
Level 'C' Event	G	4.25	27.85	23.37	41.77

(All stresses in ksi)

All conditions are met for primary stress analysis.

30.3.3 <u>Primary Plus Secondary Stress Analysis</u>. This portion of the report discusses the detailed stress evaluation of the thermal stress, pressure stress, mechanical stress, stress ranges, and fatigue usage for selected locations of the geometry.

30.3.3.1 <u>Thermal Stress.</u> Sections F and G are thinner than their corresponding sections in the previous nominal calculations. The reduction in thickness for these sections is 1.65 percent and 2.3 percent (Section F and G, respectively). This small change will have no significant effect on the heat transfer coefficients and thus will be directly proportional to the change in the biot's number. For Section F, the biot's numbers before and after the reduction are 1.067 and 1.0494, respectively. For Section G, the biot's numbers before and after are 1.1785 and 1.1514, respectively. For both sections, the biot number is in such a range that the small percentage change in it due to the thickness change will have no significant impact on the stresses in the region. This, along with the fact that, as the thicknesses are reduced, the relative stiffnesses are lowered, causing thermal stresses, which are secondary or displacement controlled stresses, to be lowered. Therefore, the stresses obtained in the previous nominal calculations will be conservatively used here.

30.3.3.2 <u>Mechanical Load Stress</u>. The stresses obtained by mechanical loading are recalculated to account for the reduced thicknesses.



			0-10
UCLEAR ENERGY GENER	AL 🍪 ELECTRIC	22A7454 Rev 1	sн _{NO.} 179
····· ································	·	——— <u>—</u>	
Section F			
Nozzle_Loads	(P + Q)		
P = 4.42 kip	P =	<u>+</u> 3.136 kip	
M = 275.4 in-kip	Ж =	<u>+</u> 390.9 in-kip	
$F_z = 1.37$ kip	F _z =	<u>+</u> 0.26 kip	
M = 275.4 + 4.42 (1.62)	M = 390.	9 + 3.136 (1.62)	
= 282.56 in-kip	= 395.	98 in-kip	
$\sigma_{\rm BEND} = \frac{282.56}{38.365} = 7.365$ ksi	$\sigma_{\rm BEND} = \frac{39}{38}$	$\frac{5.98}{.365} = 10.322$ ks	i
$\sigma_{\rm AX} = \frac{1.37}{15.584} = 0.088$ ksi	$\sigma_{AX} = \frac{1}{15}$	<u>26</u> .584 = 0.017 ksi	
Thermal Sleeve Loads	P =	<u>+</u> 2.52 kip	
$F_z = 3.7 kip$		<u>+</u> 2.333 in-kip	
	F _z =	<u>+</u> 1.5 kip	
M = 3.7 (1.8) = 6.66 in-kip	M = 2.33	3 + 2.52 (26.97)	+ 1.5 (1.8)
	= 73.0	in-kip	
$a = \frac{6.66}{174} = 0.174$ ksi		$\frac{3.0}{1.00} = 1.903$ ks	i

. .

 $\sigma_{\rm BEND} = \frac{0.00}{33.365} = 0.174$ ksi $\sigma_{AX} = \frac{3.7}{15.584} = 0.238$ ksi <u>Total Stress</u> **σ•** = 7,539 psi BEND $\sigma_{\phi_{AX}} = 326 \text{ psi}$

 $\sigma_{\rm BEND} = \frac{73.0}{38.365} = 1.903$ ksi $\sigma_{\rm AX} = \frac{1.5}{15.584} = 0.097$ ksi 8-180

= <u>+</u> 12,225 psi

= <u>+</u> 114 psi

GENERAL	ELECTRIC	22A7454 SH NO. 180 REV 1
		·
<u>Section G</u> (P + Q))	
Nozzle Loads	1	
P = 4.42 kip	P =	<u>+</u> 3.136 kip
M = 275.4 in-kip	M =	<u>+</u> 390.9 in-kip
$F_z = 1.37 \text{ kip}$	$F_z = $	<u>+</u> 0.26 kip
M = 275.4 + 4.42 (4.72) + 1.37 (1.8)	M = 390.	9 + 3.136 (4.72) + 0.26 (1.
= 298.73 in-kip		17 in-kip
$\sigma_{bend} = (0.381) \frac{298.73}{21.77} = 5.229 \text{ ksi}$	$\sigma_{b_{BEND}} = ($	0.381) $\frac{406.17}{21.77} = 7.109$ ksi
$\sigma_{\phi_{AX}} = (0.381) \frac{1.37}{10.166} = 0.052$ ksi		$(0.381) \frac{0.2}{10.166} = 0.010 \text{ ksi}$
Thermal Sleeve Loads	P =	<u>+</u> 2.52 kip
$F_z = 3.7 kip$	M =	<u>+</u> 2.333 in-kip
	$F_z =$	<u>+</u> 1.5 kip
	M = 2.33	33 + 2.52 (23.87) = 62.49 is
$\sigma_{AX} = \frac{3.7}{10.166} = 0.364$ ksi	$\sigma_{\rm BEND} = \frac{62}{22}$	$\frac{2.49}{1.77} = 2.871$ ksi
	$\sigma_{AX} = \frac{1}{10}$	$\frac{2.49}{1.77} = 2.871 \text{ ksi}$ $\frac{1.5}{0.166} = 0.148 \text{ ksi}$
Total Stress	1	
σ _{BEND} = 5,229 psi	$= \pm 9,98$ $= \pm 158$	0 psi
$\sigma_{AX} = 416 \text{ psi}$	= + 158	psi

NEO 807A (REV. 10/81)

8-181

GENERAL 🍪 ELECTRIC

22A7454 REV 1

SH NO.

8-182

181

30.3.3.3 Pressure Stress. At Section F and G, the thicknesses are 0.576 inch and 0.4885 inch compared to thicknesses of 0.5855 inch and 0.50 inch, respectively, in the previous nominal calculations. This thickness disparity is expected to affect only the primary stress component, leaving the secondary and peak stresses the same. Therefore, the stresses in these sections are equal to the stresses obtained in the previous nominal calculations, plus a correction stress. This correction stress is calculated as follows:

Section F

NUCLEAR ENERGY BUSINESS OPERATIONS

> Pressure = 1111 psi Thickness = 0.576 in; 0.5855 in Diameter = 9.679 in; 9.669 in

Hoop <u>Arial</u>

 $\sigma_{\Theta} = \frac{PD}{2t}$ $\sigma_{d} = \frac{PD}{4t}$

 $\Delta \sigma_{\rm Hoop} = \Delta \sigma_{\Theta} = 161 \text{ psi}$

 $\Delta \sigma_{Axial} = \Delta \sigma_{b} = 81 \text{ psi}$

			8-183
NUCLEAR ENERGY	GENERAL 🍘 ELECTRIC	22A7454	SH NO. 182
BUSINESS OPERATIONS		REV 1	

30.3.3.3 (Continued)

Section G

Pressure = 111 psi

Thickness = 0.4885 in; 0.500 in

Diameter = 8.413 in; 8.38 in

Hoop Arial

 $\sigma_{\Theta} = \frac{PD}{2t} \qquad \sigma_{\dot{\Phi}} = \frac{PD}{4t}$

 $\Delta \sigma_{\rm Hoop} = \Delta \sigma_{\theta} = 26 \text{ psi}$

 $\Delta \sigma_{Axial} = \Delta \sigma_{\phi} = 13 \text{ psi}$

30.3.3.4 <u>Total Primary Plus Secondary Stress Ranges</u>. Calculations of P + Q stress intensity ranges at Sections F and G will be performed to validate the subsequent fatigue analysis. These stresses are calculated in the same manner as those in Paragraph 4.2.5.

30.3.3.4.1 <u>Thermal Stress Ranges.</u> The thermal stress ranges are identical to those found in the previous nominal calculations (refer to Page 110).

<u>Section</u>	P + Q (ksi) (Membrane_Plus_Bending)	P + Q (ksi) <u>(Membrane_Only)</u>
F	28.78	3.71
G	34.86	17.98

NEO \$07A (REV. 10/81)

 GENERAL	ELECTRIC	22A7454
	WO'LFFOILIO	

.

REV 1

8-184

SH NO. 183

30.3.3.4.2 Mechanical Load Stress Range

Section	P + Q (ksi) (Seismic Incl)	P + Q ((ksi) (Seismic Not Incl)
F	24.68	7.87
G	20.28	5.65

30.3.3.4.3 <u>Pressure Load Stress Range</u>. These stress ranges are exactly the same as those found in the previous nominal calculations (refer to Page 111), plus the added stress calculated earlier.

Section	P + Q (Isi)
F	8.84
G	7.68

30.3.3.4.4 Total P + Q Range. The total P + Q stress range is as follows:

Section	<u>P + Q Range (ksi)</u>	P + Q Range (ksi) <u>No Thermal Bending</u>
F	62.3	37.23
g	62.82	45.94

The allowable range is 3 S = 55.8 ksi. Both locations are acceptable with thermal bending removed.

22A7454 SH NO. REV 1 184

30.3.4 <u>Fatigue Analysis</u>. This section provides all the detailed fatigue analysis required to show an acceptable design.

GENERAL 🍘 ELECTRIC

30.3.4.1 Stress Concentration Factors

Section F

The geometry of Section F is illustrated in Figure 30.3.4.1-1. To calculate the stress concentration factor, Reference 6.6 will be used. The concentration factors used prior, (refer to Page 124), are (inner) 1.59, and (Onter) 1.48. The deviaton affects the outer factor only.

Assume: r = 0, hence $K_0 = 4.0$

Then, using Paragraph 4.7.2.4 of Reference 6.6,

$$\frac{(X' - 1)}{(X_0 - 1)} = 1 - \frac{\beta}{90}$$

Solving for K', using $\beta = (90 - 29)^\circ = 61^\circ$

K' outer = 1.97

Section G

The geometry of Section G is illustrated in Figure 30.3.4.1-2. To calculate the stress concentration factor, Reference 6.6 will be used. The concentration factors used prior (refer to Page 126) are (inner) 1.0, (outer) 1.80. The deviation affects the inner factor only.

Assume: r = 0, hence, $K_0 = 4.0$

Then using Paragraph 4.7.2.4 of Reference 6.6,

$$\frac{(K' - 1)}{(K_0 - 1)} = 1 - \frac{\beta}{90}$$

Solving for K', using $\beta = (90 - 10)^\circ = 80^\circ$

$$K'$$
 inner = 1.333


Since K' outer is larger than K' inner, K' outer will be used in the fatigue analysis.

$$K' = 1.80$$

NEO 807A (REV. 10/81)

NUCLEAR ENERGY GENERAL CE ELECTRIC 22A7454 SH NO. 185 BUSINESS OPERATIONS GENERAL CE ELECTRIC REV 1

8-186







FIGURE 30.3.4.1-1 SECTION F DEVIATION AFTER BLENDING

			8-187
NUCLEAR ENERGY	GENERAL 🍘 ELECTRIC	22A7454	SH NO. 186
BUSINESS OPERATIONS		REV 1	






FIGURE 30.3.4.1-2 SECTION G DEVIATION AFTER BLENDING

NEO 807A (REV. 10/81)

8-188

187

GENERAL 🍘 ELECTRIC

NUCLEAR ENERGY BUSINESS OPERATIONS

4 SH NO.

30.3.4.2 <u>Alternating Stress Range</u>. To calculate the altenating stress range, the following equation is needed:

$$S_{a1t} = 1/2 K_e (K_t S_N + F_1)$$

where:

$$\mathbf{X}_{e} = \begin{cases} 1.0 \text{ for } S_{N} < 3S_{m} \\ 1 + \frac{(1 - n)}{n(m-1)} & \frac{S_{N}}{3S_{m}} - 1 \text{ for } 3S_{m} < S_{N} < m3S_{m} \\ \frac{1}{n} \text{ for } S_{N} > m3S_{m} \end{cases}$$

For carbon steel n = 0.2; m = 3.0 $K_t = stress$ concentration factor $S_N = P + Q$ stress intensity range $F_1 = peak$ stress

For Sections F and G, the peak stresses calculated in the previous nominal calculations are assumed to be identical. The deviations are not severe enough to significantly vary these stresses.

<u>Location</u>	Mechanical Range (Seismic)	Mechanical Range <u>(No Seismic)</u>	Thermal <u>Range</u>	Pressure <u>Range</u>	S _N (Seismic)	S _N (No Seismic)
F	24.68	7.87	28.78	8.84	62.30	45.49
G	20.28	5.65	34.86	7.68	62.82	48.19

(All stress in ksi)

NUCLEAR ENERGY	GENERAL 🍪 ELECTRIC	22A7454	SH NO. 188
BUSINESS GROUP		REV 1	FINAL

8-189

30.4.3.2 (Continued)

Location	S _N (Seismic)	S _N (No Seismic)	<u> </u>		K _e (Seismic)	S _{alt} (Seismic)	S alt (No Seismic)
		45.49					50.78
G	62.82	48,19	1.80	6.45	1.252	74.8	46.6

Using the total alternating stress range, the fatigue usage factors can be solved. From the design specification (Reference 6.1), there are 1,500 thermal cycles and it is assumed there are 10 seismic cycles. (Note: SA-350-LF2 has UTS \langle 80,000 psi.)

<u>(Seismic)</u>

Location	(ksi) S _{alt}	Elastic Modulus Factor	(ksi) S _A	Allowable <u>Cycles</u>	Usage <u>Factor</u>
F	83.0	1.103	91.55	750	0.0133
G	74.8	1.103	82.50	1000	0.010

(No Seismic)

Location	(ksi) S _{alt}	Elastic Modulus Factor	(ksi) S _A	Allowable Cycles	Usage <u>Factor</u>
F	50.78	1.103	56.01	3500	0.4257
G	46.6	1.103	51.40	3750	0.3973

Location	Total Usage Factor
F	0.439
G	0.407

For these sections (F and G), the high cycle and existing fatigue usage are negligible. Therefore, the above is the total fatigue usage.

NEBG-807A (6/80)

MONTICELLO

9-1

EXHIBIT 9

REACTOR VESSEL RAPID CYCLING (STRESS REPORT)

REV 5 12/86

GENERAL CELECTRIC				9-2	
			22A7227		
			CONT ON SHEET 2	<u>ын NO. 1</u>	
	ERGY DIVISION			MNTS- 80-03-74	
DOCUMENT TITLE -	REACTOR VESSEL (RAPID CYCLING)				
		TYPE_	STRESS REPORT		
	- · ·	FMF_	MONTICELLO		
LEGENO OR DECCRI	TION OF GROUPS	LEPL No	N/A		

• •

•

	REVISIORS
0	DMH-1131
	889R 722C
	PS
	PRINTS TO
JI Y	REE JULY DET 30 1980 M. A. MAUNO W Maurie NED SAN JOSE
CHROE RE H	HAMILTON OCT 30, 1980 GA BAYLIS NUV 2 6 1980 CONT ON SHEET 2 SH NO. 1
	(\$/74) R ET

• • • • •

- - - - .-

NUCLEAR ENERGY BUSINESS GROUP

Certification of Stress_Report

GENERAL 💮 ELECTRIC

This certification for the Reactor Vessel (Rapid Cycling) Stress Report, and accompanying documents, constitute the basis for the Stress Report required by Paragraph NCA-3550 of the ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, 1977 Edition, with addenda to and including Summer 1978. I hereby certify that this stress report was prepared under my direct supervision and that I am a duly registered Professiontl Engineer under the laws of the state of Minnesota. I certify that, to the best of my knowledge and belief, the Stress Report for the Reactor Vessel (Rapid Cycling) is correct and complete and in compliance with the requirements of Article NB-3000 of the ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, 1977 Edition, with Addenda to and including Summer 1978.

Listed Documents

Type of	Title	Document	Revision
Document		<u>Number</u>	<u>Number</u>
Design Specification	Reactor Vessel (Rapic Cycling)	22A7111	0

Certified By: Registered Professional Engineer JAMES ED-ARD CHARN-EY

P.E. Number 14372

2217227

0

REV

State:

Date: 26 nov 1980

Thi

9-3

SH NO. 2

NEBG 807A

22A7227 ^{REV} 0

9-4

SH NO. 3

1. SCOPE

1.1 This report documents a rapid cycling fatigue analysis of the feedwater nozzle replacement safe end and thermal sleeve assembly for the 'removable' type sparger at Monticello. The analysis was performed in accordance with the ASME Code, Section III (Reference 6.3). The detailed analysis is contained in Appendix 10 of this report.

2. SUMMARY AND CONCLUSIONS

2.1 The calculations presented in this stress report for the feedwater nozzle replacement safe end assembly show that, with no leakage, the fatigue usage factor due to rapid cycling is very low (less than 0.0001 during 40 years).

3. DESIGN

3.1 The feedwater nozzle replacement safe end and thermal sleeve assembly shown in Figure 1 are designed and analyzed in accordance with the documents referenced in Paragraphs 6.1 and 6.2.

4. ANALYSIS

4.1 <u>Thermal Stress Cycles.</u> There are two types of thermal cycles defined in the specifications referenced in Paragraphs 6.1 and 6.2: (1) system cycles and (2) rapid cycles. System cycles are the result of operational transients such as startup, initiation of feedwater flow, scrams, etc, being imposed on the nozzle. Rapid temperature cycling results in the unstable turbulent mixing of hot and cold water around the feedwater nozzle at steady state operating conditions. Since the system cycle transient stresses cause the maximum thermal stresses that can be produced, the rapid cycle stresses are not linearly additive to the maximum system cycle stresses, ie, the stresses and fatigue damage due to system cycles and rapid cycling may be calculated independently of each other and the usage factors may be added.

4.2 System Cycle Fatigue Analysis. The system cycles defined in Reference 4.2 will be analyzed elsewhere.

4.3 <u>Rapid Cycle Fatigue Analysis</u>. The equations and procedures for determining rapid cycle fatigue, as defined in Reference 6.1 were programmed into a timeshare computer code. The details of this code are presented in Appendix 10. In this code, the usage factor is calculated for a design life of 40 years, as specified in Reference 6.1.

NEBG 807A

SH NO. 4

5. RESULTS


5.1 Based on the data obtained from a ference 6.1, the fatigue usage factor caused by rapid cycling in the nozzle, safe end and thermal sleeve was calculated, as shown in detail in Appendix 10. The assumption that no feedwater, or an insignificant amount, leaks the only the interference fit between the sparger tee and the replacement there is allow (inner thermal sleeve, Figure 1) was made. For a design life 0. If years, the rapid cycling usage factor will be less than 0.0001 for all locations.

6. REFERENCES

6.1 General Electric Company, Reactor Vessel (Rapid Cycling), Design Specification 22A7111, Rev. 0.

6.2 Reactor Vessel (System Cycling), Design Specification 22A6996, Rev. 0.

6.3 ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, 1977 Edition with Addenda through 1978.



9–6

GENERAL 💮 ELECTRIC

SH NO. 6

APPENDIX 10 RAPID CYCLING FATIGUE CALCULATION

10.1 Introduction

10.1.1 The purpose of this malysis is to determine the rapid thermal cycling effects on the feedwater reache and safe end for the design life of the system.

10.1.2 Rapid temperature cycling (on the order of \hat{U} .1 to 1.0 Πz) occurs as a result of cold feedwater being injected into a hot reactor. The most dominant cause of this cycling in the nozzle bore and on the blend radius is turbulent mixing of leakage flow with Region A fluid (see Figure 10.1). Repid cycling is caused in the absence of leakage flow by turbulent Region A fluid causing the thermal boundary layer around the cold thermal sleeve to be broken up and swept against the nozzle. Incompletely mixed sparger discharge flow and Region A fluid that is carried back to the nozzle also causes some rapid cycling.

10.2 Procedure

NEBG BOTA

10.2.1 The procedure for determining rapid cycle fatigue is given in Reference 6.1. A computer program was developed, based on this procedure. The following includes a detailed description of the method and a listing of the program used to calculate the effect of rapid cycling.

10.3 Fatigue Evaluation

10.3.1 Stress Calculation. The following information established the condition for rapid cycling:

a. Amplitude and frequency from Table 10-1.

b. Feedwater flow, temperature, and time data from Table 10-3.

For each of the 26 data points in Table 10-3, there are 11 data points in Table 10-1.

9-8

10.3.1 (Continued)

The metal surface temperature range is calculated to determine the alternating stress produced by rapid cycling. Metal surface temperature range is calculated according to the formula (given in the design specification, Reference 4.1):

$$\Lambda T_{p-p} = \overline{A} [(C)(T_A - T_{FW})]$$

where

 ΔT_{p-p} = Metal surface peak to peak temperature range, °F

A = amplitude coefficient for a given frequency of cycling, from Table 10-1

C = coefficient from Table 10-2

 T_{FW} = feedwater temperature from Table 10-3

 T_A = Region A reactor water temperature from Table 10-3

NEBG 807A

SH NO. 8

.

Locations a to .

Index I	Ampl <u>i</u> tude <u> </u>	Frequency Cycles/Hr		
1	1.00	15		
2	0.98	15		
3	0.955	15		
4	0.91	30		
5	0.84	75		
6	0.75	120		
7	0.65	150		
8	0.55	180		
9	0.45	4 5 0		
10	0.35	1200		
11	0.20	7500		

TABLE 10-2 COEFFICIENT C FOR NOZZLE SURFACE DOWNSTREAM OF THERMAL SLEEVE JUNCTION (See Figure 10.1 and Notes 1 and 2)

Location	<u>c</u>
8	0.10
Ъ	0.09
c	0.10
đ	0.10
e	0.10
f	0.12

NOTES:

1. Interpolate linearly between defined points.

2. The coefficients are zero for locations not specified.


•

SH NO. 9

TABLE 10-3 FLOW, TEMPERATURE AND TIME DATA FOR RAPID CYCLING

Feedwater Index Flow JRated_		Feedwater Temperature OF	Region A Temperature F	<u>Time 5</u>	Nours Per Year	
1	100	375	546	67.87	5945	
2	100	360	546	7.37	646	
3	82	345	543	14.75	1292	
4	46	300	538	0.98	86	
5	36	280	537	0.45	39	
6	20	260	540	0.36	31.5	
7	6	225	540	0.32	28	
8	6	185	540	0.08	7	
9	2.5	185	540	0.12	10.5	
10	2.5	240	525	0.16	- 14	
11	2.5	280	480	0.52	45.5	
12	2.5	265	450	0.12	10.5	
13	2.5	210	420	0.16	14	
14	2.5	185	365	0.56	49	
15	2.5	185	470	0.04	3.5	
16	2.5	125	450	0.76	66.5	
17	2.5	80	215	0.32	28	
18	2.5	80	170	0.36	31.5	
19	0	300	340	0.49	43	
20	1	350	360	0.005	0.4	
21	2	190	350	0.013	1.1	
22	2	125	340	0.009	0.8	
23	2	70	330	0.005	0.4	
24	2	190	400	0.013	1.1	
25	3	200	340	0.002	0.2	
26	0	70	70	4.17	365.5	

NEBG 107A



í

9-11

SH NO. 11

Alternating stress is calculated according to the formula

$$\sigma_{alt} = \frac{Ea\Delta T_{p-p}}{2(1-v)}$$

where

NEBG 107A

- $E = Young's Modules = 30.0 \times 10^6$ = Poisson's Ratio 0.3From Reference 6.1
- a = Instantaneous coelficient of thermal expansion interpolated between points given in Table I-5.0 of ASE Code, Section III, Subsection AN where a is evaluated at a temperature of

$$T = T_A - 0.5 (\Delta T_{p-p})$$





10.3.2 <u>Usare Factor</u>. The number of cycles and the allowable number of cycles are calculated to determine the rapid cycling usage factor.

The number of cycles allowed is determined from the ASME Code (Figure I-9.1) (Reference 6.3) for a given alternating stress, σ_{alt} .

The number of cycles accumulated from rapid thermal cycling is calculated according to the equation


 $Cycles = t \cdot f \cdot D \cdot L$

where

Cycles = cycle: induced by rapid cycling
f = frequency of cycling from Table 10-1 in cycles/hr
t = time at each feedwater/flow/temperature combination from
Table 10-3 in %
D = design life of nozzle and safe end = 40 years
(from the design specification)

L = 8,760 hrs/yr

The usage factor is given by the following equation:



where

U = nsage factor due to rapid cycling

U_{ij} = usage factor due to ith amplitude and frequency (Table 10-1) and for the jth flow, temperature and time (Table 10-3)

NEBG 807A

NUCLEAR ENERGY BUSINESS GROUP

NEBG 107A

22A7227 ^{Rev} 0

sh no. 13

10.3.3 <u>Computer Program</u>. A computer program based on the preceeding procedure was developed. Table 10-4 is a listing of the program.

10.3.4 <u>Output</u>. The tabulated results of the computer program, Table 10-4, are listed in Table 10-5.

TABLE 10-4

MAMFWS

THIS PROGRAM IS USED TO CALCULATE RAFID CYCLING ON THE FEEDWATER (FW) NOZZLE AND SAFE END BY DETERNING THE TEMPERATURE GRADIENTS (DELTA T) AT 6 FOINTS ON THE SAFE END. THE DELTA T'S ARE CALCULATED AS A T 6 FOINTS ON THE SAFE END. THE DELTA T'S ARE CALCULATED AS A TURDULENT FLOW, ETC. AND THE AF THET. AND FLOW OF THE SAFE END. THE DELTA T'S ARE THEN NUMBER OF CYCLES ALLOWALE FROM THE AST TO CONTRESSIVE STATES IN CRUENT TO DETERMINE THE NUMBER OF CYCLES ALLOWALE FROM THE AST TO THE OF THE AST. ALPHA/6.07, 6.20, 6.44, 6.67, 6.89, 7.10, 7.33, 7.54, 7.76, 7.76, 8.16/ ALPHAT/70, 100, 150, 200, 250, 350, 350, 400, 450, 500, 550, 7 RATED FW FLOW (RATEWF), FW TEMPERATURE (TEMPEW), ARELITUDE OF THE RAPID CYCLING (AMP) AND FREQUENCY OF THE RAVID CYCUIUG (FREQ) ARE GIVEN BY "DESIGN SPECIFICATION FOR FEEMATCR NOZALE AND SAFE END REPAIR". THERMAL EXPANSION (ALPHA), MOCHUUS OF ELASTICITY (ENOD), AMD FOISSON'S RATIO (POISSON) ARE GIVEN BY ASHE RAPV SECTION AFF, TABLES 1-5.0 AND 1-6.0. DATA AMP/1.0,0.096,0.955,0.91,0.94,0.75,0.65,0.55,0.45,0.35,0.20/ DATA FREO/15,15,15,30,75,120,150,100,450,1200,7500,7 DATA TENPDC/546,543,530,537,540,540,540,540,550,550,7500,7 480,450,420,355,470,450,515,170,340,300,300, DATA POISSON/0,3/ CALCULATE THE NUMBER OF CYCLES FOR EACH DELTA T AS A FUNCTION REAL RATEWE(26), TENPEW(26), FWTIME(26), AMP(11) FREQ(11) Real Alpha(11), Alphat(11), Tenp(6,26), Tenp(6(26) Real Deltat(6,26), Stress(6,26), Alphint(6), (3(5,26) PRINT: "MONTICELLO RAPID CYCLE FATIGUE AMALYSIS" VALUES FROM NEW ECKERT FLOW MAP PRINT: VALUES FROM NEW ECKE PRINT: " DESIGN LIFE = ",DLIFE OF RATEWF AND TEMPFW 0417/ DATA DLIFE/40.0/ PRINT: " " PRINT:" " : PRINT: " DATA DATA C150C 0420C 0430C 0360 0500 0510C 0440C

22A7227 HEV.

SH. NO.

HEV. 0 LINEARLY INTERPOLATE TO DETERMINE ALPHA AS A FUNCTION OF TEMPERATURE Where temperature is given from the Spe CAS T= TDC-0,5+delta T CYCLES = FWTME(J) = FREQ(I) = 0760. = DLIFE STRESS(K,J' = DELTAT(K,J) = ALPHINT(K) = 30.0/(2.0*(1.0-F0ISSON)) IF (STRESS(K,J) .0T. 5.0E5) CYALLOW = (STRESS(K,J)/1.4E6) = (-2.2363) IF(STRESS(K,J) .LE. 5.0E5 .AND. STRESS(K,J) .GT. 2.0E5) IF(STRESS(K,J) .LE. 5.0E5 .AND. STRESS(K,J) .GT. 2.4E4) IF(STRESS(K,J) .LE. 2.0E5 AND. STRESS(K,J) .GT. 0.4E4) CYALLOW = (STRESS(K,J)/1133787.) = (-2.65428) IF(STRESS(K,J) .LE. 8.4E4 .AND. STRESS(K,J) .GT. 3.75E4) IF(STRESS(K,J) .LE. 8.4E4 .AND. STRESS(K,J) .GT. 3.75E4) CALCULATE FOR EACH OF G POINTS ON THE THERMAL SLFEVE THE APPROPRIATE DELTA T WHERE K=1 FOR POINT A; K=2 FUE FOLME B; K=5 FOR FULME F; AND K=5 FOR POINT F. DO 10 L=1,11 IF (TEMP(K,J).LT, ALPHAT(L).OR. TEMP(K,J).GT. ALPHAT(L+1)) GO 10 SLOPE = (ALPPAT(L+1) - ALPHAT(L))/(ALPHA(L+1) - ALPHA(L4)) ALPHINT(K) : ALPHA(L) + (TEMP(K,J) - ALPHAT(L))/SLOPE FESS(K, J) LE. 3.75E4 AND. STRESS(K, J) 61. 2.0E4)
CYALLOW = (STRESS(K, J)/463486.) **(-3.6629)
RESS(K, J) LE. 2.0E4 AND. STRESS(K, J) 61. 1.24E4)
CYALLOW = (STRESS(K, J)/218309.) **(-4.81676)
RESS(K, J) LE. 1.24E4 AND. STRESS(K, J) 61. 9.4E3)
RESS(K, J) LE. 1.24E4 AND. STRESS(K, J) 61. 9.4E3)
RESS(K, J) LE. 7.7E3 AND. STRESS(K, J) 61. 7.7E3)
RESS(K, J) LE. 7.7E3 AND. STRESS(K, J) 61. 7.0E3)
RESS(K, J) LE. 7.7E3 AND. STRESS(K, J) 61. 7.0E3)
RESS(K, J) LE. 7.7E3 AND. STRESS(K, J) 61. 7.0E3)
RESS(K, J) LE. 7.7E3 AND. STRESS(K, J) 61. 7.0E3)
RESS(K, J) LE. 7.7E3 AND. STRESS(K, J) 61. 7.0E3)
RESS(K, J) LE. 7.7E3 AND. STRESS(K, J) 61. 7.0E3)
RESS(K, J) LE. 7.7E3 AND. STRESS(K, J) 61. 7.0E3) DELTATIK,J) = AMP(1) = C3(K,J) = (TEMPDC(J) - TEMP=W(J)) TEMP(K,J) = TEMPDC(J) - 0.5 = DELTATIK,J) 7.0C3) GO TO 100 USGFA C= C/CLES/CYALLOW IF(STRESS(K, J) .LE. IF(STRESS(K, J) .L no 100 l = 1,11 0.000 IF(STRESS(K, J) IF(STRESS(K, J) IF(STRESS(K, J) 0.10 0.09 0 ZUSGFA C= 0.0 DO 1000 K=1,F 0 IF (STRESS (K SUSGFA C= DO 500 J=1 c3:5,J) = c3(6,J) = = (r'l)co CONTINUE C3(2,J) C3(3,J) C3(4,J) 2 05300 05300 05400 05500 05500 05500 0930 6960**8** 0970 0.10% 07200 80060 0008 0208 03700 09208 00406 0690 0700 07100 07400 000 0580 0230 0620 0630 0630 0650 0080 0160 0030 0660 0101 060 00100

9-16

15

SH. NO.

22A7227

22A7227	sh. nu. 16	_
HEV. O		

 1070
 ZUSGFA C= ZUSSFA C+ USGFAC

 1000
 SUSGFA C= SUSGFA C+ USGFAC

 1090
 TOD CONTINUE

 2000
 PRINT:
 AT ZONE ", J

 2010
 PRINT:
 STRESS (SIGMA ALT) = ", STRESS(K, J)/O. 20

 2020
 PRINT:
 STRESS (SIGMA ALT) = ", STRESS(K, J)/O. 20

 2030
 PRINT:
 SUM OF USAGE FACTORS = ", ZUSGFAC

 2030
 PRINT:
 SUM OF USAGE FACTORS = ", SUGFAC

 2030
 PRINT:
 SUM OF USAGE FACTORS = ", SUGFAC

 2030
 PRINT:
 SUM OF USAGE FACTORS = ", SUGFAC

 2030
 PRINT:
 SUM OF USAGE FACTORS = ", SUGFAC

 2040
 DOO CONTINUE
 SUM OF USAGE FACTORS = ", SUGFAC

 2030
 PRINT:
 SUM OF USAGE FACTORS = ", SUGFAC

 2040
 DOO CONTINUE
 SUM OF USAGE FACTORS = ", SUGFAC

 2030
 ENDITE
 SUM OF USAGE FACTORS = ", SUGFAC

 2040
 DOO CONTINUE
 SUM OF USAGE FACTORS = ", SUGFAC

 2040
 SOO
 SUM OF USAGE

 2050
 STOP
 SUM OF USAGE

 2000
 SOO
 SUM OF USAGE

 2000
 SOO
 SUM

 2000

9-17

SH NO. 17 22A7227 REV 0

FINAL

TABLE 10-5 TABULATED RESULTS OF COMPUTER PROGRAM

U	s	٤	2	e	F	8	с	t	0	r	s

Zone/Point	11	2	3	4	5	66
1	0	0	0	0	. 0	0
2	0	0	0	· 0	0	0
3	0	0	0	0	0	0
4	0	0	0	0	0	0
5	0	0	0	0	0	0
6	0	0	0	0	0	0
7	0	0	0	0	· 0	0
8	0	0	0	0	0	.25 E-4
9	0	0	Ο.	0	0	.38 E-4
10	0	0	0	0	0	0
11	0	0	0	· 0	0	0
12	0	0	0	0	0	0
13	0	0	0	· 0	0	0
14	0	0	0	0	0	0
15	0	0	0	0	0	0
16	0	0	0	0	0	0
17	0	0	0	0	0	0
18	0 ·	0	0	0	0	0 ·
19	0	0	0.	0	· 0	0
20	0	0	0	0	0	0
21	0	0	0	0	0	0
22	ა	0	0	0	0	0
23	0	0	0	0	0	<u>́</u> 0
24	0	0	0	0	0	0
25	0	0	0	0	0	0
26	0	00	0	0	00	0
Sum of Usage Factors	0	0	0	0	0	.63 E-4

 $Total = 0.63 \times 10^{-4}$

NEBG 807A