



Bentley K. Jones  
Director, Organizational Effectiveness  
Harris Nuclear Plant  
5413 Shearon Harris Road  
New Hill NC 27562-9300

919.362.2305

**FEB 23 2016**

Serial: HNP-16-014

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Shearon Harris Nuclear Power Plant, Unit 1  
Docket No. 50-400/Renewed License No. NPF-63

Subject: Annual Report in Accordance with Technical Specification 6.9.1.2

Ladies and Gentlemen:

In accordance with Harris Nuclear Plant (HNP) Technical Specification 6.9.1.2, Duke Energy Progress, Inc., is providing the following information regarding reactor coolant specific activity for 2015.

During 2015, specific activity of the HNP reactor coolant did not exceed 1.0  $\mu\text{Ci}/\text{gram}$  dose equivalent I-131 or 100/E-bar  $\mu\text{Ci}/\text{gram}$  gross radioactivity as set forth in Technical Specification 3.4.8.

This submittal contains no regulatory commitments. Please refer any questions regarding this submittal to John Caves, Manager – Regulatory Affairs, at (919) 362-2406.

Sincerely,

A handwritten signature in black ink, appearing to read "Bentley K. Jones", with a long horizontal flourish extending to the right.

Bentley K. Jones

cc: Mr. J. D. Austin, NRC Sr. Resident Inspector, HNP  
Ms. M. Barillas, NRC Project Manager, HNP  
NRC Regional Administrator, Region II



**Bentley K. Jones**  
Director, Organizational Effectiveness  
Harris Nuclear Plant  
5413 Shearon Harris Road  
New Hill NC 27562-9300

919.362.2305

Serial: HNP-16-014

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Shearon Harris Nuclear Power Plant, Unit 1  
Docket No. 50-400/Renewed License No. NPF-63

Subject: Annual Report in Accordance with Technical Specification 6.9.1.2

Ladies and Gentlemen:

In accordance with Harris Nuclear Plant (HNP) Technical Specification 6.9.1.2, Duke Energy Progress, Inc., is providing the following information regarding reactor coolant specific activity for 2015.

During 2015, specific activity of the HNP reactor coolant did not exceed 1.0  $\mu\text{Ci}/\text{gram}$  dose equivalent I-131 or 100/E-bar  $\mu\text{Ci}/\text{gram}$  gross radioactivity as set forth in Technical Specification 3.4.8.

This submittal contains no regulatory commitments. Please refer any questions regarding this submittal to John Caves, Manager – Regulatory Affairs, at (919) 362-2406.

Sincerely,

Bentley K. Jones

cc: Mr. J. D. Austin, NRC Sr. Resident Inspector, HNP  
Ms. M. Barillas, NRC Project Manager, HNP  
NRC Regional Administrator, Region II