



Pacific Gas and
Electric Company®

James M. Welsch
Vice President, Nuclear Generation

Diablo Canyon Power Plant
P.O. Box 56
Avila Beach, CA 93424

805.545.3242
E-Mail: JMW1@pge.com

February 24, 2016

PG&E Letter DIL-16-004

10 CFR 72.4, 10 CFR 72.44(d)(3)

ATTN: Document Control Desk
Director, Division of Spent Fuel Management
Office of Nuclear Material Safety and Safeguards,
U.S. Nuclear Regulatory Commission,
Washington, DC 20555-0001

Materials License No. SNM-2511, Docket No. 72-26
Diablo Canyon Independent Spent Fuel Storage Installation
Annual Radioactive Effluent Release Report for 2015

Dear Commissioners and Staff:

Pursuant to 10 CFR 72.4 and 10 CFR 72.44(d)(3), this letter provides the report of the quantity of radionuclides released to the environment in liquid and gaseous effluents due to the operation of the Diablo Canyon (DC) Independent Spent Fuel Storage Installation (ISFSI).

For the year 2015, there were no releases of liquid or gaseous radionuclides to the environment from the operation of the DC ISFSI. The basis for this statement, as documented in the DC ISFSI Updated Final Safety Analysis Report, is that the HI-STORM 100 System does not produce any solid, liquid, or gaseous effluents while in storage. In addition, the all-welded construction of the DC ISFSI Multi-Purpose Canisters precludes the release of radioactive effluents from the HI-STORM 100 System.

PG&E makes no new or revised regulatory commitments (as defined by NEI 99-04) in this letter.

If you have any questions regarding this submittal, please contact Mr. Clint Gans at (805) 545-3419.

Sincerely,

James M. Welsch

bnsn/64132255

cc: Diablo Distribution
John M. Goshen, NMSS Project Manager
Binesh K. Tharakan, Acting NRC Senior Resident Inspector