



Technical Specification 6.9.1.5.b

LR-N16-0010
FEB 25 2016

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Hope Creek Generating Station
Renewed Facility Operating License No. NPF-57
NRC Docket No. 50-354

Subject: Technical Specification 6.9.1.5.b
2015 Annual Report of SRV Challenges

This report is being submitted in accordance with Hope Creek Technical Specification 6.9.1.5.b, which requires the documentation of all challenges to main steam line safety/relief valves (SRVs) be provided on an annual basis.

For 2015, the SRVs were not challenged by any over pressurization events or transients that would have required the valves to respond automatically.

There are no regulatory commitments contained in this letter.

Should you have any questions, please contact Mr. Philip Duca at 856-339-1640.

Sincerely,

A handwritten signature in black ink, appearing to read "F. Kenneth Grover".

F. Kenneth Grover
Plant Manager – Hope Creek

pjd

cc: Mr. Daniel Dorman, Regional Administrator - Region 1
Nuclear Regulatory Commission
Ms. Carleen Parker, Project Manager Hope Creek USNRC
Mr. Justin Hawkins, NRC Senior Resident Inspector - Hope Creek (X24)
Mr. Thomas MacEwen, Hope Creek Commitment Coordinator (H02)
Mr. Lee Marabella, Corporate Commitment Coordinator (N21)
