

Part 21 (PAR)

Event # 51674

Rep Org: CURTISS WRIGHT NUCLEAR DIVISION	Notification Date / Time: 01/22/2016 14:09 (EST)
Supplier: CURTISS WRIGHT NUCLEAR DIVISION	Event Date / Time: 01/21/2016 (CST)
	Last Modification: 02/22/2016
Region: 1	Docket #:
City: HUNTSVILLE	Agreement State: Yes
County:	License #:
State: AL	
NRC Notified by: SAMUEL BLEDSOE	Notifications: HAROLD GRAY R1DO
HQ Ops Officer: HOWIE CROUCH	PART 21/50.55 REACTORS EMAIL
Emergency Class: NON EMERGENCY	
10 CFR Section:	
21.21(d)(3)(i) DEFECTS AND NONCOMPLIANCE	

PART 21 NOTIFICATION - POTENTIAL DEFECT IN OKONITE TAPE SPLICES

The following information was obtained from Curtiss-Wright Nuclear Division via fax and email:

"This letter is issued to provide initial notification of a potential defect in Okonite Tape Splices. The potential defect is inadequate radiation testing performed by Steris/Isomedix.

"In response to NRC Information Notice 2015-12: 'Unaccounted for Error Terms Associated with the Irradiation Testing and Environmental Qualification of Important-to-Safety Components,' an investigation was performed to determine if products had radiation testing performed by Steris/Isomedix, and any impact. This investigation commenced on November 25, 2015.

"It was determined on January 21, 2016 that the qualification of Okonite Tape Splices is affected by the unaccounted for error terms discussed in Information Notice 2015-12. This product has only been provided to James A. FitzPatrick Nuclear Power Plant. This customer will be notified today.

"As a corrective action, Qualification Report PEI-TR-842900-1 will be revised to decrease the Total Integrated Dose (TID) reported by 9.6% based upon the guidance of Information Notice 2015-012. This revision will be provided to James A. FitzPatrick Nuclear Power Plant within 30 days of this notification. Notification will be provided when this corrective action is complete.

"If additional information is required, please contact me by the methods provided below or Quality Assurance Manager Tony Gill: 256-426-4558, tgill@curtisswright.com."

*** UPDATE FROM SAMUEL BLEDSOE TO VINCE KLCO VIA FACSIMILE ON 2/22/2016 AT 1434 EDT ***

IE19
NRR

"February 22, 2016

"To whom it may concern:

"On January 22, 2016, Curtiss-Wright Nuclear issued an initial notification letter to the Nuclear Regulatory Commission and customer James A. FitzPatrick Nuclear Power Plant concerning a potential defect in Okonite Tape Splices. The potential defect was inadequate radiation testing performed by Steris/Isomedix. As a corrective action, Qualification Report PEI-TR-842900-1 has been revised to decrease the Total Integrated Dose (TID) reported by 9.6% based upon the guidance of NRC Information Notice 2015-012: 'Unaccounted for Error Terms Associated with the Irradiation Testing and Environmental Qualification of Important-to-Safety Components.' As of this date, Qualification Report PEI-TR-842900-1, Revision C has been provided to James A. FitzPatrick Nuclear Power Plant. This letter provides the final status and closeout of the above referenced 10CFR21 notification. If you require additional details or would like to discuss further, please contact me by the methods provided below or Quality Assurance Manager Tony Gill: 256-426-4558, tgill@curtisswright.com.

"Sincerely,
Samuel Bledsoe
Engineering Manager

"Nuclear Division
Curtiss-Wright
125 West Park Loop, Huntsville, AL 35806
T: 256.924.74481 M: 256.690.78521 F: 256.722.8533"

Notified R1DO (Ferdas) and Part 21 Group via email.



Fax Cover Sheet

To:

Fax Number: 3018165151

Subject: Part 21 Closeout

From: "Bledsoe, Samuel" <sbledsoe@curtisswright.com>

Fax#: 855-305-6216

Date: 02/22/16 02:31:58 PM

Total Pages: 3 including this cover page

Memo: The attached letter provides the final status and closeout of a Part 21 Notification (ref. NRC Event Notification # 51674).

Thank you,

Samuel Bledsoe
Engineering Manager

Nuclear Division
Curtiss-Wright
125 West Park Loop, Huntsville, AL 35806
T: 256.924.7448 | M: 256.690.7852 | F: 256.722.8533
sbledsoe@curtisswright.com | www.curtisswright.com/NuclearDivision

This e-mail and any files transmitted with it are proprietary and intended solely for the use of the individual or entity to whom they are addressed. If you have reason to believe that you have received this e-mail in error, please notify the sender and destroy this email and any attached files. Please note that any views or opinions presented in this e-mail are solely those of the author and do not necessarily represent those of the Curtiss-Wright Corporation or any of its subsidiaries. Documents attached hereto may contain technology subject to government export regulations. Recipient is solely responsible for ensuring that any re-export, transfer or disclosure of this information is in accordance with applicable government export regulations. The recipient should check this e-mail and any attachments for the presence of viruses. Curtiss-Wright Corporation and its subsidiaries accept no liability for any damage caused by any virus transmitted by this e-mail.

This electronic communication, including attachments, is for the exclusive use of addressee and may contain proprietary, confidential and/or privileged information. If you are not the intended recipient, any use, copying, disclosure, dissemination or distribution is strictly prohibited. If you are not the intended recipient, please notify sender immediately by phone, destroy this communication and all copies.



Nuclear Division
125 West Park Loop NW
Huntsville, AL 35806
T: 256.722.8500 | F: 256.722.8533
www.curtisswright.com/NuclearDivision

(File No.: CWN10CFR21-2015-04)

February 22, 2016

To whom it may concern:

On January 22, 2016, Curtiss-Wright Nuclear issued an initial notification letter to the Nuclear Regulatory Commission and customer James A. FitzPatrick Nuclear Power Plant concerning a potential defect in Okonite Tape Splices. The potential defect was inadequate radiation testing performed by Steris/Isomedix.

As a corrective action, Qualification Report PEI-TR-842900-1 has been revised to decrease the Total Integrated Dose (TID) reported by 9.6% based upon the guidance of NRC Information Notice 2015-012 : "Unaccounted for Error Terms Associated with the Irradiation Testing and Environmental Qualification of Important-to-Safety Components." As of this date, Qualification Report PEI-TR-842900-1, Revision C has been provided to James A. FitzPatrick Nuclear Power Plant.

This letter provides the final status and closeout of the above referenced 10CFR21 notification. If you require additional details or would like to discuss further, please contact me by the methods provided below or Quality Assurance Manager Tony Gill: 256-426-4558, tgill@curtisswright.com.

Sincerely,

A handwritten signature in black ink that reads "Samuel Bledsoe". The signature is written in a cursive, flowing style.

Samuel Bledsoe
Engineering Manager

Nuclear Division
Curtiss-Wright
125 West Park Loop, Huntsville, AL 35806
T: 256.924.7448 | M: 256.690.7852 | F: 256.722.8533
sbledsoe@curtisswright.com | www.curtisswright.com/NuclearDivision