

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

UNITED STATES

NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

-----X

In re:	Docket Nos. 50-247-LR; 50-286-LR
License Renewal Application Submitted by	ASLBP No. 07-858-03-LR-BD01
Entergy Nuclear Indian Point 2, LLC,	DPR-26, DPR-64
Entergy Nuclear Indian Point 3, LLC, and	
Entergy Nuclear Operations, Inc.	March 4, 2016

-----X

SUPPLEMENTAL WRITTEN TESTIMONY OF

DR. RICHARD T. LAHEY, JR.

REGARDING CONTENTIONS

NYS-25, NYS-26B/RK-TC-1B, AND NYS-38/RK-TC-5

Table of Contents

	<u>Page</u>
I. Introduction.....	1
II. The Inspection Response Plan and Flaw Acceptance Criteria.....	4
1. The Inspection Response Plan	6
2. The Flaw Acceptance Criteria for IP-2 and IP-3	7
III. Westinghouse's Baffle-Former Bolt Analysis.....	12
IV. Entergy's Flaw Acceptance Criteria & the Eason and Pathania Paper.....	29
V. The IP-3 Inspection Report.....	42
VI. Conclusion.....	44

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

List of Proposed New Exhibits

Proposed Exhibit No.

Document

NYS000583	"Indian Point Units 2 and 3 Inspection Response Plan for Aging Management of MRP-227-A Primary and Expansion Components" (WCAP-17941-P, Rev. 1) (IPECPROP00085900), January 12, 2016 Short title: "Inspection Response Plan"
NYS000584	"Background and Technical Basis Supporting Engineering Flaw Acceptance Criteria for Indian Point Unit-2 Reactor Vessel Internals MRP-227-A Primary and Expansion Components" (WCAP-17949-P, Rev. 0) (IPECPROP00085359), January 12, 2016 Short title: "Flaw Acceptance Criteria for IP-2"
NYS000585	"Background and Technical Basis Supporting Engineering Flaw Acceptance Criteria for Indian Point Unit-3 Reactor Vessel Internals MRP-227-A Primary and Expansion Components" (WCAP-17951-P, Rev. 0) (IPECPROP000856629), January 12, 2016 Short title: "Flaw Acceptance Criteria for IP-3"
NYS000586	"Determination of Acceptable Baffle-Former Bolting for Indian Point Units 2 and 3" (WCAP-18048-P, Rev. 0) (IPECPROP00086434), January 12, 2016 Short title: "Bolting Analysis"

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

Proposed Exhibit No.

Document

NYS000587

E. Eason and R. Pathania, "Disposition Curves for Irradiation-Assisted Stress Corrosion Cracking of Austenitic Stainless Steels in Light Water Reactor Environments," ASME PVP2015-4532, Proceedings of the ASME 2015 Pressure Vessels and Piping Conference, July 19-23, 2015

Short title:
"Eason and Pathania Paper"

NYS000588

USNRC Indian Point Nuclear Generating Unit-3 - License Renewal Inspection Report 05000286/2015011, Nov. 19, 2015 (ML15323A026)

Short title:
"IP-3 Inspection Report"

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

List of Acronyms

<u>Acronym</u>	<u>Meaning</u>
AMP	aging management plan
ASLB, the Board	Atomic Safety Licensing Board
BWR	boiling water nuclear reactor
CGR	crack growth rate
DBA	design basis accident
EPRI	Electric Power Research Institute
FMEA	failure modes and effects analysis
IASCC	irradiation-induced stress corrosion cracking
IP-2	Indian Point nuclear facility Unit-2
IP-3	Indian Point nuclear facility Unit-3
LBB	leak-before-break
LOCA	loss-of-coolant accident
LRA	license renewal application
NYS, the State	the State of New York
PEO	period of extended operation
PWR	pressurized water nuclear reactor
RTA	real-time analysis
RVI	reactor vessel internal
SSE	safe-shutdown earthquake
UFSAR	Updated Final Safety Analysis Report

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 **I. Introduction**

2 On behalf of the State of New York ("NYS" or "the State"),
3 the Office of the Attorney General hereby submits the following
4 testimony by RICHARD T. LAHEY, JR., Ph.D., regarding Contentions
5 NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5.

6 Q. Please state your full name.

7 A. Richard T. Lahey, Jr.

8 Q. Dr. Lahey, you have previously provided your
9 educational and professional qualifications and submitted
10 testimony in this proceeding, correct?

11 A. Yes. I have previously submitted testimony and reports
12 in this proceeding. My education and professional qualifications
13 and experience are described in my previously submitted
14 Curricula Vitae and were summarized in my previous testimony.

15 Q. I show you proposed exhibits NYS000583 through
16 NYS000588. Do you recognize those documents?

17 A. Yes. These documents consist of four technical reports
18 authored by Westinghouse on behalf of Entergy, one technical
19 paper authored by E. Eason and R. Pathania, and one USNRC
20 inspection report for Indian Point Unit-3.

21 Q. Have you reviewed proposed exhibits NYS000583 through
22 NYS000588?

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 A. Yes.

2 Q. Have these documents caused you to change the
3 testimony and opinions that you have previously submitted in
4 this proceeding in connection with Contentions NYS-25, NYS-
5 26B/RK-TC-1B and NYS-38/RK-TC-5?

6 A. No. In fact, I believe that these documents support
7 the concerns, opinions, and testimony that I have presented
8 previously in this proceeding. It is my opinion that the
9 documents are relevant to the technical and legal matters at
10 issue in this proceeding, and that they provide substantial
11 support for the opinions that I have presented to the Atomic
12 Safety and Licensing Board (the "Board") in my testimony and
13 written reports in this proceeding. In my opinion, these
14 documents provide further bases for the Board to conclude that
15 Entergy's license renewal application ("LRA") for the Indian
16 Point facilities fails to adequately manage the effects of aging
17 degradation such as embrittlement, fatigue, and irradiation
18 assisted stress corrosion cracking ("IASCC") on reactor vessel
19 internal ("RVI") systems, structures and components. They also
20 describe the facilities' approach to fatigue analysis and
21 confirm that certain aging management program plan ("AMP")

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 details will be deferred until well into the period of extended
2 operation ("PEO").

3 Q. In your opinion, what is the significance of the
4 proposed new exhibits?

5 A. The documents call into question whether Entergy's
6 currently proposed amended and revised AMP for RVIs and the
7 associated Inspection Plan for the Indian Point nuclear
8 facilities, e.g., exhibits NYS000496-NYS000507 ("Amended and
9 Revised RVI AMP"), provide reasonable assurance against the
10 failure of various RVI systems, structures, and components. The
11 documents also suggest that Westinghouse's approach to
12 developing flaw acceptance criteria and the associated
13 inspection intervals under Entergy's Amended and Revised RVI AMP
14 may be inadequate and non-conservative. For example,

15 [REDACTED]
16 [REDACTED]
17 [REDACTED]
18 [REDACTED]
19 [REDACTED]

20 [REDACTED]. In my testimony below, I will
21 begin by describing how three of the proposed new exhibits
22 provide specific details on the implementation of Entergy's

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 Amended and Revised RVI AMP and Inspection Plan. Next, I will
2 discuss my concern regarding Westinghouse's plant-specific
3 bolting pattern analysis for the baffle-former bolts at Indian
4 Point Unit-2 ("IP-2") and Unit-3 ("IP-3"). Thereafter, I will
5 describe my concern that Entergy's Amended and Revised RVI AMP
6 contains several non-conservative assumptions that may cause
7 IASCC cracks to grow faster at IP-2 and IP-3 than would be
8 accounted for by Entergy under its Amended and Revised RVI AMP.
9 Finally, I discuss USNRC's recent inspection report for IP-3.

10 **II. The Inspection Response Plan and Flaw Acceptance Criteria**

11 Q. I show you three of the proposed new exhibits, each of
12 which relates to Entergy's Amended and Revised RVI AMP. The
13 documents are:

14 • "Indian Point Units 2 and 3 Inspection Response Plan
15 for Aging Management of MRP-227-A Primary and Expansion
16 Components," a document that has been marked as proposed exhibit
17 NYS000583, and identified by Westinghouse as WCAP-17941-P, Rev.
18 1 ("Inspection Response Plan");

19 • "Background and Technical Basis Supporting Engineering
20 Flaw Acceptance Criteria for Indian Point Unit-2 Reactor Vessel
21 Internals MRP-227-A Primary and Expansion Components," a
22 document that has been marked as proposed exhibit NYS000584, and

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 identified by Westinghouse as WCAP-17949-P, Rev. 0 ("Flaw
2 Acceptance Criteria for IP-2"); and,

3 • "Background and Technical Basis Supporting Engineering
4 Flaw Acceptance Criteria for Indian Point Unit-3 Reactor Vessel
5 Internals MRP-227-A Primary and Expansion Components," a
6 document that has been marked as proposed exhibit NYS000585, and
7 identified by Westinghouse as WCAP-17951-P, Rev. 0 ("Flaw
8 Acceptance Criteria for IP-3").

9 Please describe how the Inspection Response Plan
10 (NYS000583) and Flaw Acceptance Criteria for IP-2 (NYS000584)
11 and IP-3 (NYS000585) each relate to the implementation of
12 Entergy's Amended and Revised RVI AMP?

13 A. According to the Inspection Response Plan and the Flaw
14 Acceptance Criteria for IP-2 and IP-3, these documents,

15 [REDACTED]
16 [REDACTED]
17 [REDACTED]
18 [REDACTED]
19 [REDACTED].

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 **1. The Inspection Response Plan**

2 Q. I show you the Inspection Response Plan (NYS000583).

3 Would you please explain your understanding of how this document
4 relates to Entergy's Amended and Revised RVI AMP?

5 A. Yes. [REDACTED]

6 [REDACTED]

7 [REDACTED]

8 [REDACTED]

9 [REDACTED]

10 [REDACTED]

11 [REDACTED]

12 [REDACTED]

13 [REDACTED]

14 [REDACTED]

15 [REDACTED]

16 [REDACTED]

17 [REDACTED]

18 [REDACTED]

19 [REDACTED]

20 [REDACTED]

21 [REDACTED]

22 [REDACTED]

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED]
2 [REDACTED]
3 [REDACTED]
4 [REDACTED]
5 [REDACTED]
6 [REDACTED]
7 [REDACTED]
8 [REDACTED]
9 [REDACTED]
10 [REDACTED]
11 [REDACTED]
12 [REDACTED]
13 [REDACTED]
14 [REDACTED]
15 [REDACTED]
16 [REDACTED]

2. The Flaw Acceptance Criteria for IP-2 and IP-3

17 Q. I now show you two documents, the Flaw Acceptance
18 Criteria for IP-2 (NYS000584), and the Flaw Acceptance Criteria
19 for IP-3 (NYS000585). Would you explain your understanding of
20 how these documents relate to Entergy's Amended and Revised RVI
21 AMP?
22

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 A. [REDACTED]

2 [REDACTED]

3 [REDACTED]

4 [REDACTED]

5 [REDACTED] [REDACTED] [REDACTED]

6 [REDACTED] [REDACTED]

7 [REDACTED] [REDACTED] [REDACTED]

8 [REDACTED]

9 [REDACTED] [REDACTED] [REDACTED]

10 [REDACTED] [REDACTED]

11 [REDACTED] [REDACTED]

12 [REDACTED] [REDACTED]

13 [REDACTED] [REDACTED] [REDACTED]

14 [REDACTED] [REDACTED] [REDACTED]

15 [REDACTED]

16 [REDACTED] [REDACTED] [REDACTED]

17 [REDACTED] [REDACTED]

18 [REDACTED]

19 [REDACTED] [REDACTED]

20 [REDACTED] [REDACTED]

21 [REDACTED]

22 [REDACTED]

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED]

2 [REDACTED]

3 [REDACTED]

4 [REDACTED]

5 [REDACTED]

6 [REDACTED] As a guide to
7 how Entergy will ultimately address any cracks or flaws in RVIs
8 identified as a result of inspections, these documents serve as
9 a key piece of Entergy's Amended and Revised RVI AMP.

10 Q. What, if any, concerns do you have about Entergy's
11 Amended and Revised RVI AMP, as described in the Inspection
12 Response Plan and the two Flaw Acceptance Criteria documents for
13 IP-2 and IP-3?

14 A. [REDACTED]

15 [REDACTED]

16 [REDACTED]

17 [REDACTED]

18 [REDACTED]

19 [REDACTED]

20 [REDACTED]

21 [REDACTED]

22 [REDACTED]

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED]; and Entergy
2 License Renewal Application - Revised Reactor Vessel Internals
3 Program and Inspection Plan, NL-12-037, Attach. 2, at Table 5-2
4 (Primary components) and Table 5-3 (Expansion components).

5 In my view, waiting 10 years between inspections is not a
6 reasonable or prudent approach for plants operating beyond their
7 originally intended design life. As I have discussed in my prior
8 testimony, many systems, structures, and components at Indian
9 Point will be significantly degraded as they approach the end of
10 their PEO. In particular, some RVIs will have accumulated
11 sufficient neutron fluence such that the effects of various age-
12 related degradation mechanisms such as irradiation-induced
13 embrittlement and IASCC will be a concern. Because degradation
14 is expected to accelerate with aging, I believe more frequent
15 inspections are warranted, particularly as these RVI systems,
16 structures, and components reach the later stages of the
17 proposed PEO when exposure to radiation is expected to meet or
18 exceed thresholds for the development of significant
19 embrittlement and IASCC.

20 Q. Do you have any other concerns about Entergy's Amended
21 and Revised RVI AMP, as described in the Inspection Response
22 Plan and the Flaw Acceptance Criteria for IP-2 and IP-3?

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 A. Yes. As I have discussed in my prior testimony, any
2 inspection-based aging management program has some probability
3 that an existing flaw will go undetected. For example,

4 [REDACTED]

5 [REDACTED]

6 [REDACTED]

7 [REDACTED]

8 [REDACTED]

9 [REDACTED]. Undetected cracks are a concern because
10 inspections will not occur for another 10 years. Not only can
11 existing cracks -- both detected and undetected -- grow, but new
12 cracks can develop and grow in the period between inspections.
13 Embrittlement results in decreased fracture toughness, with a
14 corresponding decrease in the critical flaw size that can lead
15 to accelerated component failure. Thus my concern is that with
16 embrittled components, cracks may grow to critical size, and the
17 components may fail before corrective action is taken to ensure
18 component integrity or assembly functionality. Although
19 Westinghouse's flaw evaluation procedures under Entergy's

20 Amended and Revised RVI AMP [REDACTED]

21 [REDACTED]

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED], Entergy cannot possibly evaluate and monitor
2 any cracks that it has failed to identify.

3 **III. Westinghouse's Baffle-Former Bolt Analysis**

4 Q. Dr. Lahey, as described above, one of your concerns
5 relates to Entergy's and Westinghouse's approach to evaluating
6 baffle-former bolt failures at the Indian Point facilities. How
7 does Entergy plan to address baffle-former bolt failures in the
8 two Indian Point reactors?

9 A. Proposed exhibit NYS000586, a Westinghouse report
10 entitled "Determination of Acceptable Baffle-Former Bolting for
11 Indian Point Units 2 and 3" (WCAP-18048-P, Rev. 0) ("Bolting
12 Analysis"), [REDACTED]

13 [REDACTED]
14 [REDACTED]
15 [REDACTED]
16 [REDACTED]
17 [REDACTED]. This

18 document is the site-specific bolting analysis that Entergy
19 witnesses referenced during the November 2015 evidentiary
20 hearing. See Transcript of ASLB Hearing, at 5239, 5314 (Nov. 17,
21 2016). At the time of this ASLB hearing, my understanding was
22 that this site-specific bolting analysis was not available.

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 Q. In your opinion, are bolting failures a concern at
2 Indian Point?

3 A. Yes. I have previously testified that I am concerned
4 about the possible failure of baffle-former bolts during an
5 extended 20-year period of operation, particularly because
6 failures of baffle-former bolts have been observed in other
7 similar nuclear power plants, and due to my prevailing concern
8 that Westinghouse's analyses do not consider the combined or
9 synergistic effects of multiple aging degradation mechanisms
10 acting together, and the effect of very energetic shock loads.
11 Indeed, the failure of baffle-former bolts is a significant
12 issue for aging pressurized water nuclear reactor ("PWR") plants
13 worldwide, and certainly for the two Indian Point plants.
14 Initially identified in European PWRs in 1989, numerous flaws in
15 baffle-former bolts have, in recent years, been observed in a
16 number of domestic PWRs as well. For example, failed baffle-
17 former bolts have been found in domestic PWRs at Ginna, D.C.
18 Cook, Surry, Prairie Island, Point Beach, and Robinson. Among
19 other things, bolt failures can contribute to fuel damage and
20 loose parts. Moreover, bolt failures can greatly degrade core
21 cooling capabilities and compromise safe plant operations.

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 Q. How does the Bolting Analysis (NYS000586) address
2 these concerns at Indian Point?

3 A. The Bolting Analysis [REDACTED]
4 [REDACTED]
5 [REDACTED]
6 [REDACTED]
7 [REDACTED]
8 [REDACTED]
9 [REDACTED]
10 [REDACTED]
11 [REDACTED]

12 Q. What are the LOCA conditions that Westinghouse applies
13 in the Bolting Analysis?

14 A. [REDACTED]
15 [REDACTED]
16 [REDACTED]
17 [REDACTED]
18 [REDACTED]
19 [REDACTED]
20 [REDACTED]
21 [REDACTED]
22 [REDACTED]

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED]

2 [REDACTED]

3 Q. So, in your opinion, is a bolting analysis that is
4 based on [REDACTED]
5 [REDACTED] an adequate approach?

6 A. No. In my opinion, analysis of the single and two-
7 phase the shock loads typically associated with the original
8 design basis accident ("DBA") LOCA (i.e., as specified in 10
9 C.F.R. 50 Appendix K, an instantaneous double-ended guillotine
10 break of the most limiting primary coolant line, in particular,
11 the cold leg), is much more appropriate to help ensure that the
12 RVI components will perform their intended functions during the
13 20 years of extended operation. It is therefore my opinion that
14 Entergy's and Westinghouse's proposed methodology [REDACTED]
15 [REDACTED] is non-
16 conservative and ill-advised from a safety perspective for a 20-
17 year period of extended operation beyond the original 40-year
18 license term.

19 Q. How do the shock loads differ between, for example, [REDACTED]
20 [REDACTED]?

21 A. Large energetic, instantaneous DBA LOCA cold leg
22 breaks generate substantially higher in-vessel shock loads than

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED]

2 [REDACTED]. To

3 understand the implications of this, I note that in a typical
4 structural dynamics analysis, a structure may be modeled as a
5 spring-mass-dashpot system:

6
$$\ddot{x} + 2\zeta\omega_n\dot{x} + \omega_n^2x = \frac{F}{M}$$


7 where \ddot{x} and \dot{x} are, respectively, the second and first ordinary
8 derivatives with respect to time (t) of the displacement (x) of
9 a structure. The term $\omega_n = (\frac{k}{M})^{1/2}$ is the natural frequency of the
10 structure (which has an equivalent spring constant of k, a
11 damping rate of ζ , and a mass of M), and the transient force (F)
12 acting on a structure is given by $F = \Delta pA$, where Δp is the
13 transient pressure differential acting on a structure of area A.
14 During the subcooled decompression stage of a DBA LOCA, the
15 initial Δp across the baffle plate/bolting complex (and, for
16 that matter, other in-vessel structures) can be given by a
17 Heaviside step function (U). In particular, if ΔP is the
18 magnitude of the largest transient Δp , then, $F(t) = \Delta PAU(t) =$
19 ΔPA if $t \geq 0.0$, and zero for $t < 0.0$.

20 For this type of impulsive forcing function, an underdamped
21 system, such as the baffle/bolting complex in a PWR, responds as
22 shown schematically in the hand-drawn diagram I prepared during

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 the November 2015 evidentiary hearing (exhibit NYS000582). For
2 convenience, I have reproduced this schematic below:



For step change in F : $F(t) = \Delta P A U(t)$

3 Note that there will be significant inertial overshoot of
4 the displacement, $x(t)$ before it returns to an equilibrium
5 (steady-state) displacement, x_{SS} . This figure shows a
6 hypothetical situation in which the ΔP is maintained constant,
7 while for a PWR the impulsive forcing function will be more like
8 that associated with a Dirac delta function, $F = \Delta P A \delta(t)$.
9 However, the initial inertial overshoot will be similar to the
10 step change solution but the solution will finally return to its

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 original state, $x_{ss} = 0.0$. Naturally, the smaller the size of the
2 pipe break, the less the inertial overshoot. Additionally, if
3 the $\Delta p(t)$ occurs over a finite period of time (Δt) [REDACTED]
4 [REDACTED],
5 the induced overshoot for these ramps (as opposed to steps) in
6 $\Delta p(t)$ will also be reduced. In any event, the magnitude of the
7 transient overshoot in the displacement, $x(t)$ of the structure
8 determines the maximum strain (and stress) that the structure is
9 exposed to. Because the baffle-former bolts during the period of
10 extended operations will be highly fatigued and embrittled,
11 their stress-strain curve will initially be quite steep (i.e.,
12 the linear elastic part will have a large slope due to
13 irradiation-induced hardening), and the ultimate stress (which
14 for highly embrittled stainless steel bolts will be almost the
15 same as the yield stress) will be larger than for a
16 corresponding ductile structure. However, physical failure of
17 the structure is expected once the strain associated with the
18 ultimate stress has been exceeded. Thus, for the large
19 displacements (and thus, for the large strains) associated with
20 energetic shock loads such as those for a DBA LOCA, failure of
21 many of the baffle-former bolts in IP-2 and IP-3 may occur. If
22 so, there may no longer be an intact core geometry and thus

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 adequate core cooling will no longer be assured. In addition,
2 the two-phase LOCA loads, which occur after the subcooled
3 decompression loads, may lead to crushing of the fuel rod grids
4 and the inability to insert the control rods (which are required
5 to safely shut down the reactor). See "Westinghouse Methodology
6 for Evaluating the Acceptability of Baffle-Former-Barrel Bolting
7 Distributions under Faulted Load Conditions," WCAP-15030-NP-A
8 (Mar. 2, 1999), § K at 2-6 (ENT000655).

9 Because Entergy's evaluations (performed by Westinghouse)
10 assumes [REDACTED]

11 [REDACTED]

12 [REDACTED]

13 [REDACTED]

14 [REDACTED]

15 [REDACTED]

16 [REDACTED]. As such, these

17 transient loads are non-conservative and serve to undermine the
18 validity of any future real-time analyses of acceptable bolting
19 patterns performed for IP-2 and IP-3. Significantly, [REDACTED]

20 [REDACTED]

21 [REDACTED]

22 [REDACTED], such as the DBA LOCA which

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 was required by 10 C.F.R. 50 Appendix K in the original design
2 of the Indian Point reactors. See Updated Final Safety Analysis
3 Report ("UFSAR") for IP-2, § 14.3.4.3.1 at 113 (NRC000206); §
4 4.1.2.4.2 (ENT000634). [REDACTED] [REDACTED] [REDACTED]

5 [REDACTED] [REDACTED]
6 [REDACTED] [REDACTED] [REDACTED]
7 Q. In your opinion, should Entergy's and Westinghouse's
8 consideration of dynamic shock loads in the Bolting Analysis
9 include DBA LOCA events such as an instantaneous double-ended
10 guillotine break in the main coolant piping?

11 A. Yes. I am aware that USNRC regulations require an
12 applicant to consider the impact of various size pipe ruptures,
13 including an instantaneous double-ended guillotine rupture of
14 the cold leg in the primary system of a PWR when assessing plant
15 safety under LOCA conditions. See, e.g., 10 C.F.R. 50,
16 Appendices A, K. However, I also understand that in 1998, the
17 USNRC Staff authorized the analysis of acceptable baffle-former-
18 barrel bolting distributions based on smaller auxiliary line
19 breaks and slower LBB break opening times. See "Westinghouse
20 Methodology for Evaluating the Acceptability of Baffle-Former-
21 Barrel Bolting Distributions under Faulted Load Conditions,"
22 WCAP-15030-NP-A (Mar. 2, 1999) (ENT000655), [REDACTED]

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED] [REDACTED] [REDACTED]
2 [REDACTED] Nevertheless, as I have
3 indicated in my previously filed testimony, [REDACTED]
4 [REDACTED] were never intended to be applied to
5 evaluations designed to demonstrate core cooling capability and
6 internal component integrity, and certainly not for aged and
7 degraded components that have been in use for over 40 years, the
8 original design life of these plants. Instead, this methodology
9 was developed for use in "pipe whip" evaluations within the
10 containment. Indeed, it is totally inconsistent to use [REDACTED]
11 [REDACTED] for the analysis of potential RVI failures because,
12 for example, significant baffle-former bolt failures may lead to
13 an uncoolable core geometry, while the DBA LOCA analysis
14 required by 10 C.F.R. 50, Appendix K implicitly assumes an
15 intact core geometry. Thus, the PWR plant safety analysis
16 requires the assumption of an instantaneous double-ended
17 guillotine break of the cold leg for both the transient loads on
18 RVIs and the transient core thermal-hydraulics. Anything else
19 would be inadequate, and, in my opinion, Entergy and
20 Westinghouse [REDACTED] [REDACTED] [REDACTED]
21 [REDACTED].

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 Q. In your opinion, does Westinghouse's Bolting Analysis
2 (NYS000586) demonstrate that the possible failure of baffle-
3 former bolts at IP-2 and IP-3 will be adequately addressed?

4 A. Absolutely not. Interestingly, the report reveals that

5 [REDACTED]

6 [REDACTED]

7 [REDACTED]

8 [REDACTED]

9 [REDACTED]

10 [REDACTED]

11 [REDACTED]

12 [REDACTED]

13 [REDACTED]

14 [REDACTED]

15 [REDACTED]

16 [REDACTED]

17 [REDACTED]

18 [REDACTED]

19 [REDACTED]

20 [REDACTED]

21 [REDACTED]

22 [REDACTED]

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED]
2 [REDACTED]
3 [REDACTED]
4 [REDACTED]
5 [REDACTED]

6 Q. Throughout your testimony in this proceeding, you have
7 expressed your concern that Entergy is not considering adequate
8 shock loads in the various analyses it has conducted under its
9 LRA. [REDACTED]

10 [REDACTED], are there other shock loads you believe Entergy
11 should consider in its analysis of acceptable baffle-former
12 bolting at the Indian Point facilities?

13 A. Yes. The safe operation of a nuclear plant requires
14 analyses of the plant's responses to various postulated
15 equipment failures or malfunctions. It is important to select a
16 sufficiently broad spectrum of accident and transient events to
17 evaluate. To be conservative, it is important to identify the
18 accidents or events that give rise to the most limiting or
19 challenging conditions. As a nuclear safety expert, my opinion
20 is that it is vital to consider the most limiting event -- which
21 for the Indian Point plants is a double-ended guillotine break
22 of the cold leg between the reactor coolant pump and the reactor

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 vessel, see IP-2 UFSAR, § 14.3.2.1 at 94 (NRC000206), to ensure
2 that all the RVI systems, structures and components which can
3 impact plant safety are capable of withstanding those
4 conditions. Indeed this approach is fully consistent with USNRC
5 directives: "A plant may always choose to use as a bounding
6 bolting configuration calculated for a pipe break size greater
7 than the largest size included under LBB." See "Westinghouse
8 Methodology for Evaluating the Acceptability of Baffle-Former-
9 Barrel Bolting Distributions under Faulted Load Conditions,"
10 WCAP-15030-NP-A (Mar. 2, 1999), § 2.1.1.1 at 2-7, 2-8
11 (ENT000655).

12 Q. What type of LOCAs did Entergy consider in its
13 development of Revised and Amended RVI AMP for Indian Point?

14 A. As I have noted previously, [REDACTED]
15 [REDACTED]
16 [REDACTED]
17 [REDACTED]
18 [REDACTED]
19 [REDACTED]
20 [REDACTED]
21 [REDACTED].

22 Q. Entergy appears to have a fail-safe system to ensure

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 core cooling. Does the existence of this system alleviate your
2 concern?

3 A. No. Although Entergy has emergency core cooling
4 systems in IP-2 and IP-3, they are not fail-safe. These
5 engineered safety coolant injection systems are intended to
6 maintain core cooling in the event of various pipe ruptures,
7 including a DBA LOCA, but my concern is that due to the
8 associated shock loads generated during a DBA LOCA some of the
9 highly embrittled and fatigued reactor vessel internals (e.g.,
10 the baffle-former bolting) may fail such that there will no
11 longer be a coolable core geometry. Moreover, as I have
12 previously testified, important primary coolant pressure
13 boundary components (e.g., the accumulator line and nozzles)
14 that are degraded due to fatigue and stress corrosion cracking
15 and/or embrittled due to thermal embrittlement of the welds, may
16 fail under large LOCA-induced shock loads. [REDACTED]

17 [REDACTED]
18 [REDACTED]
19 [REDACTED], it is unclear
20 whether a coolable core can be maintained in the event of a
21 large, energetic line break in IP-2 and IP-3. In my opinion,
22 [REDACTED]

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 full dynamic effects of a blowdown following a DBA LOCA in order
2 to confirm that reactor vessel internals and reactor coolant
3 piping can withstand the most limiting LOCA load in combination
4 with a SSE, which may initiate the LOCA event. That is, if a DBA
5 LOCA event ever occurs, it is most likely during the PEO when an
6 aged and degraded PWR experiences a significant seismic event.
7 Thus the safety evaluation of this postulated event is
8 essential.

9 Q. In your opinion, does the Bolting Analysis (NYS000586)
10 adequately address your previous concerns regarding the impact
11 of embrittlement, or the loss of ductility, on the ability of
12 baffle-former bolts to withstand loads?

13 A. No. [REDACTED]
14 [REDACTED]
15 [REDACTED]
16 [REDACTED]
17 [REDACTED]
18 [REDACTED]
19 [REDACTED] rather than outline corrective actions such as
20 repair or replacement to address cracked bolts. [REDACTED]
21 [REDACTED]
22 [REDACTED]

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED]
2 [REDACTED]
3 [REDACTED]
4 [REDACTED]
5 [REDACTED]
6 [REDACTED]
7 [REDACTED]

8 [REDACTED]
9 [REDACTED] My concern is that [REDACTED]
10 [REDACTED], it would likely be
11 insufficient to enable the bolts to sustain an energetic
12 impulsive shock load, such as that associated with a DBA LOCA.

13 Q: Does Westinghouse address undetected cracks in bolts?

14 A: [REDACTED]
15 [REDACTED]
16 [REDACTED].

17 Q. How do Entergy and Westinghouse propose to address
18 these undetected flaws and the risk that failed bolts pose to
19 the integrity of the structure and core coolability?

20 A. [REDACTED]
21 [REDACTED]
22 [REDACTED]

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED]

2 [REDACTED]

3 [REDACTED]

4 [REDACTED]

5 [REDACTED]

6 [REDACTED]

7 [REDACTED]

8 [REDACTED]

9 [REDACTED]

10 [REDACTED]

11 [REDACTED]

12 [REDACTED]

13 [REDACTED]

14 [REDACTED]

15 [REDACTED]

16 [REDACTED]

17 [REDACTED]

18 [REDACTED]

19 [REDACTED]

20 [REDACTED]

21 [REDACTED]

22 [REDACTED]

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED] [REDACTED] [REDACTED]
2 [REDACTED] [REDACTED]
3 [REDACTED]
4 [REDACTED] In my opinion, it is necessary to maintain
5 a substantial margin throughout the PEO because the number of
6 baffle-former bolts exceeding the stress and IASCC thresholds is
7 expected to increase -- not decrease -- over time.

8 Q. Did the Bolting Analysis identify conditions where
9 additional evaluation is required when a flaw is detected?

10 A. [REDACTED]
11 [REDACTED] [REDACTED] [REDACTED]
12 [REDACTED] [REDACTED] [REDACTED]
13 [REDACTED] [REDACTED]
14 [REDACTED]
15 [REDACTED]
16 [REDACTED]

17 **IV. Entergy's Flaw Acceptance Criteria & the Eason and Pathania**
18 **Paper**

19 Q. Dr. Lahey, as discussed above, another concern you
20 raise relates to potential non-conservatism in the flaw
21 acceptance criteria for certain RVI structures and components,
22 and particularly to the crack growth rate model used by
23 Westinghouse in developing these acceptance criteria. How does

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 Westinghouse address crack growth in its flaw acceptance
2 criteria?

3 A. As indicated in the Flaw Acceptance Criteria for IP-2
4 (NYS000584) and the Flaw Acceptance Criteria for IP-3
5 (NYS000585), for certain components, [REDACTED]

6 [REDACTED]
7 [REDACTED]
8 [REDACTED]
9 [REDACTED]

10 • [REDACTED]
11 [REDACTED]
12 [REDACTED]
13 [REDACTED]

14 • [REDACTED]
15 [REDACTED]
16 [REDACTED]
17 [REDACTED]

18 • [REDACTED]
19 [REDACTED]
20 [REDACTED]
21 [REDACTED]

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21

• [REDACTED]
[REDACTED] [REDACTED]
[REDACTED] [REDACTED]
[REDACTED]

Q. I present to you a document marked as exhibit NYS000587, a paper by E. Eason and R. Pathania, entitled "Disposition Curves for Irradiation-Assisted Stress Corrosion Cracking of Austenitic Stainless Steels in Light Water Reactor Environments," PVP2015-4532, from the Proceedings of the ASME 2015 Pressure Vessels and Piping Conference ("Eason and Pathania Paper"). Have you reviewed this document?

A. Yes.

Q. Are you familiar with the authors of this paper?

A. I have never met them but I understand that Mr. Pathania, one of the co-authors, is a technical executive with the Electric Power Research Institute ("EPRI"). Additionally, he is EPRI's "Roadmap Owner" for its BWR and PWR irradiated materials testing and the degradation models for the reactor internals project. See http://mydocs.epri.com/docs/Portfolio/P2016/Roadmaps/NUC_MAT_01-BWR-PWR-Irradiated-Materials-Testing.pdf.

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 Q. In your opinion, what in the Eason and Pathania Paper
2 is relevant to issues in this proceeding?

3 A. The Eason and Pathania Paper presents new IASCC crack
4 growth rate disposition curves for both boiling water reactors
5 ("BWRs") and PWRs. The paper summarizes the results of a multi-
6 year international effort sponsored by EPRI to collect, rank,
7 and model IASCC crack growth rate data. See Eason and Pathania
8 Paper at 1. The paper summarizes over 800 IASCC crack growth
9 rate data points collected from six laboratories worldwide, and
10 reviewed and ranked by an international panel of known IASCC
11 experts. *Id.* at 2.

12 According to the Eason and Pathania Paper, the new crack
13 growth rate disposition curves presented in the paper reflect
14 "an improvement" over the earlier BWRVIP-99-A and MRP-227-A
15 disposition curves. *Id.* at 9. The earlier BWRVIP-99-A and MRP-
16 227-A crack growth rate disposition curves were developed circa
17 2001 from then-available data, and were primarily used for
18 estimating crack growth rates in BWR environments. *Id.* at 2.
19 However, according to the Eason and Pathania Paper,
20 substantially more data is now available, and is reflected in
21 their paper. *Id.* at 2.

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 Q. What information regarding IASCC crack growth rate
2 disposition curves does the Eason and Pathania Paper disclose?

3 A. Figure-3 of the Eason and Pathania Paper presents a
4 PWR primary water crack growth rate disposition curve based on
5 the newly available data. *Id.* at 4. The new curve is plotted at
6 a temperature of 325°C and an irradiated yield stress of 700
7 MPa. *Id.* at 4. For comparison, Figure-3 also presents a plot of
8 the older MRP-227-A disposition curve. *Id.* at 4.

9 The Eason and Pathania Paper states that the new PWR
10 primary water crack growth rate disposition curve "is about a
11 factor of 5.6 higher than the dashed MRP-227-A curve." *Id.* at 4.
12 The Eason and Pathania Paper goes on to state that a higher
13 irradiated yield stress of 970 MPa (rather than 700 MPa) would
14 shift the new PWR primary water crack growth rate disposition
15 curve in Figure-3 further upward by a factor of 2.3. *Id.* at 5.

16 Taken together, the Eason and Pathania Paper suggests that
17 the PWR primary water crack growth rate disposition curve could
18 increase the older MRP-227-A IASCC crack growth rate disposition
19 curve by a factor of at least 10, depending on the operating
20 temperatures and irradiated yield stress. *Id.* at 4-5, 9. Stated
21 another way, the Eason and Pathania Paper indicates that IASCC
22 cracks can grow up to an order of magnitude faster in the PWR

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 primary water operating environment compared to earlier (mostly
2 BWR) data that was used in the MRP-227-A disposition curves.

3 Q. How does this finding relate to Entergy's Amended and
4 Revised RVI AMP?

5 A. The Eason and Pathania Paper suggests that the crack
6 growth rates [REDACTED] [REDACTED] [REDACTED] [REDACTED]
7 [REDACTED] under Entergy's Amended
8 and Revised RVI AMP are non-conservative. As I explained above,
9 the Eason and Pathania Paper indicates, based on over 800 IASCC
10 crack growth rate data points, that IASCC crack growth rates in
11 PWR primary water environments are between five and 10 times
12 greater than those set forth in MRP-227-A. [REDACTED]

13 [REDACTED] [REDACTED]
14 [REDACTED]
15 [REDACTED].

16 Q. To the extent that [REDACTED] [REDACTED] [REDACTED]
17 [REDACTED] IASCC crack growth rates that are non-
18 conservative, what are the implications for the adequacy of
19 Entergy's Amended and Revised RVI AMP?

20 A. In my opinion, the new IASCC crack growth rate
21 disposition curves developed by EPRI, and discussed in the Eason
22 and Pathania Paper, call into serious question the conservatism

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

■ [REDACTED]
■ [REDACTED]
■ [REDACTED]
■ [REDACTED]

5 [REDACTED] I am concerned, however, that possible
6 non-conservatism in these flaw acceptance criteria means that
7 both identified and undetected cracks may grow faster than
8 Entergy assumes but will not be identified during [REDACTED]
9 follow-up inspections.

10 There are at least three specific circumstances under
11 Entergy's Amended and Revised RVI AMP that, in my opinion, may
12 result in the failure of RVIs due to the faster PWR IASCC crack
13 growth rates identified in the Eason and Pathania Paper:

- 14 • First, a flaw or surface crack in an RVI system,
15 structure, or component that is not detected during baseline
16 visual inspections. This is a real possibility because any
17 visual inspection technique has an inherent limit of detection,
18 as I discussed above and in my prior testimony. Under Entergy's
19 Amended and Revised RVI AMP, the next inspection will not occur
20 for 10 years. Should the flaw or crack grow to critical size
21 before this next inspection, the component may fail. In
22 particular, given the results presented in the recent Eason and

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 Pathania Paper, it is possible, and even likely, that the flaw
2 or surface crack will grow at a faster rate [REDACTED] [REDACTED]

3 [REDACTED]

4 [REDACTED]

5 • Second, a new flaw or surface crack in an RVI system,
6 structure, or component that develops after the baseline visual
7 inspection. Again, because the next inspection will not occur
8 for 10 years, I am concerned that the component may fail if the
9 flaw or crack grows to critical size before the next inspection.
10 In particular, it is possible, even likely, that such a crack
11 will grow faster [REDACTED] [REDACTED]

12 [REDACTED] in light of the accelerated PWR IASCC
13 crack growth rate disposition curve presented in the Eason and
14 Pathania Paper.

15 • Third, a flaw or surface crack that is detected by
16 visual inspection and is indicated for Entergy's Corrective
17 Action Program, [REDACTED] [REDACTED]

18 [REDACTED] [REDACTED]

19 [REDACTED] [REDACTED]

20 [REDACTED]

21 [REDACTED] [REDACTED] [REDACTED] [REDACTED]

22 [REDACTED]

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 [REDACTED]
2 [REDACTED]
3 [REDACTED]
4 [REDACTED]. I am concerned that
5 such a crack may meet Entergy's and Westinghouse's calculated
6 [REDACTED] allowable crack size set forth under the Flaw
7 Acceptance Criteria for IP-2 and IP-3, but then grow faster than
8 anticipated. In particular, towards the end of the PEO, when the
9 fluence exposure of RVI systems, structures, and components will
10 be in the range at which IASCC is a serious concern, it is
11 possible that Entergy will not be monitoring or inspecting a
12 developing crack at all. Additional inspections at the end of
13 the PEO are important because the estimated fluence threshold
14 for IASCC is 3 dpa, or 2×10^{21} n/cm² (E > 1 MeV). See MRP-191 at
15 3-3, Table 3-2 (NYS000321). For many RVI components that
16 threshold may be reached in the latter part of the PEO, when no
17 inspections are expected to take place. *Id.* at 4-22 to 4-29,
18 Table 4-6. For example, with respect to girth welds, predicted
19 neutron fluence is expected to be 4 dpa towards the end of the
20 PEO. See USNRC Supplemental Safety Evaluation Report (SSER2)
21 (NYS000507), at 3-46.

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 In addition, Entergy's use of [REDACTED]
2 [REDACTED] for developing its flaw
3 acceptance criteria underscores my prevailing concern, as
4 discussed above and in my previous testimony, that Entergy's
5 Amended and Revised RVI AMP does not adequately protect against
6 the failure of fatigued and embrittled components that
7 experience significant shock loads (i.e., those due to a DBA
8 LOCA). [REDACTED]
9 [REDACTED] [REDACTED] [REDACTED]
10 [REDACTED] [REDACTED]
11 [REDACTED] [REDACTED] [REDACTED]
12 [REDACTED]
13 [REDACTED]
14 [REDACTED]
15 [REDACTED]
16 [REDACTED]. In my
17 opinion, Entergy should, at a minimum, implement an AMP that
18 takes into account the latest information on crack growth rates,
19 apply appropriate DBA LOCA loads, and incorporate planned
20 inspections in the years approaching the end of the PEO, when
21 IASCC may become a very serious concern. Additionally, Entergy
22 should implement shorter inspection intervals combined with

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 regular, follow-up examinations to minimize the number of cracks
2 that escape detection and to properly monitor crack growth.

3 Q. Do you have any other opinions with regard to the new
4 PWR primary water crack growth rate disposition curve presented
5 in the Eason and Pathania Paper?

6 A. Yes. As Entergy concedes, in the event that its LRA
7 for the Indian Point reactors is granted, it will not be
8 compelled to undertake future actions to incorporate the new
9 crack growth rate curves for PWRs into its Amended and Revised
10 RVI AMP. See Testimony of Entergy Witnesses Nelson F. Azevedo,
11 Robert J. Dolansky, Alan B. Cox, Jack R. Strosnider, Timothy J.
12 Griesbach, Randy G. Lott, and Mark A. Gray Regarding Contention
13 NYS-25 at A136 (ENT000616). Rather, such actions by Entergy
14 would be entirely voluntary. *Id.*

15 Q. Does Entergy's Amended and Revised RVI AMP and
16 Inspection Plan incorporate margin into its flaw acceptance
17 methodology?

18 A. [REDACTED]
19 [REDACTED]
20 [REDACTED]
21 [REDACTED]
22 [REDACTED]

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22

[REDACTED]

I am also concerned that this possible non-conservatism in margin in Westinghouse's flaw acceptance criteria creates a source of uncertainty in addition to the non-conservatisms that I have discussed previously. According to Entergy, the ASME code's adjustment factors of 2 on stress and 20 on cycles in the fatigue design curves provide "substantial margin." See *Entergy Revised Testimony on NYS-26B/RK-TC-1B (ENT000679), 43 (A70). However, as explained in NUREG-6909, Revision 1, the factors of 2 on stress and 20 on cycles used in the ASME Code Section III air fatigue design curves were intended to cover the effects of variables that influence fatigue lives (i.e., material variability, different heats, surface finish, size, mean stress, and loading sequence) and are not per se safety margins. See "Effect of LWR Coolant Environments on the Fatigue Life of Reactor Materials - Draft Report," NUREG-6909, Rev. 1 (NYS000490A), at XXV, 5. Because these factors were not investigated in the laboratory tests that provided the data for the curves, it is therefore not clear how much conservatism is actually embedded in the ASME code. See NYS000490B at 147-148.

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 Studies on vessel steels, piping and other components have shown
2 that ASME Code Section III fatigue design procedures do not
3 always contain large conservatisms and that cracks can initiate
4 before they are predicted to occur. *Id.* In my opinion, Entergy's
5 reliance on the "inherent" margins in the ASME code for fatigue
6 evaluations is misplaced.

7 **V. The IP-3 Inspection Report**

8 Q. I now show you a document marked as exhibit NYS000588,
9 which has the title, "USNRC Indian Point Nuclear Generating
10 Unit-3 - License Renewal Inspection Report 05000286/2015011,"
11 and is dated November 19, 2015 ("IP-3 Inspection Report"). Can
12 you describe this document?

13 A. The IP-3 Inspection Report appears to be a document
14 authored by USNRC Staff that summarizes the Staff's view
15 concerning the status of Entergy's commitments for IP-3. More
16 specifically, the IP-3 Inspection Report sets forth Staff's
17 conclusion that Entergy has fulfilled its remaining commitments
18 with respect to metal fatigue (Commitment 49), but that its
19 commitment to develop a plant-specific safety analysis for
20 reactor vessel plate B2803-03 three years prior to reaching the
21 pressurized thermal shock reference temperature (Commitment 32)
22 still remains outstanding.

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 With respect to Commitment 49, which requires Entergy to
2 recalculate cumulative usage factors for certain reactor vessel
3 internals taking into account environmental effects, the IP-3
4 Inspection Report notes that initial application of the maximum
5 stainless steel F_{en} of 15.348 to the CUF values for those
6 components resulted in CUF_{en} values in excess of the limit of 1.0
7 for five components and locations (i.e., upper support plate
8 assembly, upper support plate flange, lower core plate, lower
9 core support plate, and lower support columns) for IP-2 and
10 three components and locations (i.e., upper support assembly,
11 instrumentation columns, and lower support columns) for IP-3.
12 The report states that refined fatigue calculations were
13 performed for these components and locations to qualify them for
14 service. Significantly, the report summarizes the manner in
15 which Entergy has systematically removed conservatisms in order
16 to reduce the CUF_{en} values to below 1.0. The document also
17 presents the USNRC Inspector's view that such refinement through
18 reduction of conservatisms "obviates the need for further CUF
19 re-analysis, and/or repair or replacement." See IP-3 Inspection
20 Report (NYS000583), at 7. Clearly this iterative process is
21 troubling since the so-called conservatisms which were
22 eliminated may well be needed design margins.

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 **VI. Conclusion**

2 Q. Would you summarize your testimony?

3 A. In summary, it is my opinion that these new documents
4 provide additional bases for the Board to conclude that
5 Entergy's Amended and Revised RVI AMP for IP-2 and IP-3 fails to
6 adequately manage the effects of aging, and does not provide
7 reasonable assurance that the safety functions of these plants
8 will be maintained during the period of extended operation.

9 Q. It that the end of your supplementary testimony today?

10 A. Yes it is. However, I reserve the right to supplement
11 my testimony if new information is disclosed or introduced.

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*

**Contains Westinghouse and Entergy Designated Proprietary Information
Subject to Nondisclosure Agreement**

1 UNITED STATES

2 NUCLEAR REGULATORY COMMISSION

3 BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

4 -----x
5 In re: Docket Nos. 50-247-LR; 50-286-LR
6 License Renewal Application Submitted by ASLBP No. 07-858-03-LR-BD01
7 Entergy Nuclear Indian Point 2, LLC, DPR-26, DPR-64
8 Entergy Nuclear Indian Point 3, LLC, and
9 Entergy Nuclear Operations, Inc. March 4, 2016

10 -----x
11 **DECLARATION OF RICHARD T. LAHEY, JR.**

12 I, Richard T. Lahey, Jr., do hereby declare under penalty
13 of perjury that my statements in the foregoing testimony and my
14 statement of professional qualifications are true and correct to
15 the best of my knowledge and belief.

16 Executed in Accord with 10 C.F.R. § 2.304(d)



17
18
19 _____
Dr. Richard T. Lahey, Jr.

20 *The Edward E. Hood Professor Emeritus of Engineering*

21 Rensselaer Polytechnic Institute, Troy, NY 12180

22 (518)495-3884, laheyr@rpi.edu

*Supplemental Written Testimony
of Richard T. Lahey, Jr.
Contentions NYS-25, NYS-26B/RK-TC-1B, and NYS-38/RK-TC-5*