

NRR-PMDAPem Resource

From: Yale, Ken (DEQ) <YALEK@michigan.gov>
Sent: Tuesday, March 08, 2016 7:33 AM
To: Goetz, Sujata
Cc: Rankin, Jennivine; Skutt, David (DEQ); Keyes, Jennifer (DEQ)
Subject: [External_Sender] RE: Fermi 2 - NRC Issuance of Amendment associated with Surveillance Requirement (SR) 3.5.1.4

Follow Up Flag: Follow up
Flag Status: Flagged

Dear Ms. Goetz,

The State of Michigan has no comment on the license amendment described below.

If you need anything else, please let me know.

V/R.

Ken

Ken Yale
Chief, Radiological Protection Section
Office of Waste Management and Radiological Protection
Michigan Dept. of Environmental Quality
Constitution Hall, 4th Floor South
525 West Allegan
PO Box 30241, Lansing, MI 48909-7741
Telephone: **517-930-5784**
Fax: 517-373-4797
email: yalek@michigan.gov
Website: www.michigan.gov/deq

From: Goetz, Sujata [mailto:Sujata.Goetz@nrc.gov]
Sent: Monday, March 07, 2016 4:17 PM
To: Yale, Ken (DEQ)
Cc: Rankin, Jennivine
Subject: RE: Fermi 2 - NRC Issuance of Amendment associated with Surveillance Requirement (SR) 3.5.1.4

Mr. Yale,

The Nuclear Regulatory Commission (NRC) is in the process of approving a license amendment request from DTE Electric Company, for Fermi 2.

The amendment revises Surveillance Requirements (SRs) to verify that the system locations susceptible to gas accumulation are sufficiently filled with water and to provide allowances which permit performance of the verification. The changes address the concerns discussed in NRC Generic Letter (GL) 2008-01, "Managing Gas Accumulation in

Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems” as described in NRC-approved Technical Specifications Task Force (TSTF) – 523, Revision 2, “Generic Letter 2008-01, Managing Gas Accumulation.”

The NRC staff’s proposed no significant hazard consideration determination was published in the Federal Register on January 5, 2016 (81 FR 257).

Please let me know if you have any comments on this action. I can be reached at 301-415-8004.

Thanks,
Sue

Sujata Goetz
Project Manager
NRC, Office of Nuclear Reactor Regulation
NRC/NRR/DORL/LPL3-1, O8C10
Washington, DC 20555-0001
301.415.8004, 301.415.3313 (fax)
Mail Stop O8H4A

Hearing Identifier: NRR_PMDA
Email Number: 2698

Mail Envelope Properties (DM2PR09MB0729AFF22C31825E2C373E49DEB20)

Subject: [External_Sender] RE: Fermi 2 - NRC Issuance of Amendment associated with Surveillance Requirement (SR) 3.5.1.4
Sent Date: 3/8/2016 7:32:36 AM
Received Date: 3/8/2016 7:33:02 AM
From: Yale, Ken (DEQ)

Created By: YALEK@michigan.gov

Recipients:

"Rankin, Jennivine" <Jennivine.Rankin@nrc.gov>
Tracking Status: None
"Skutt, David (DEQ)" <SkuttD@michigan.gov>
Tracking Status: None
"Keyes, Jennifer (DEQ)" <KEYESJ@michigan.gov>
Tracking Status: None
"Goetz, Sujata" <Sujata.Goetz@nrc.gov>
Tracking Status: None

Post Office: DM2PR09MB0729.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	1999	3/8/2016 7:33:02 AM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: Follow up