



Tennessee Valley Authority, Post Office Box 2000, Soddy Daisy, Tennessee 37384-2000

March 7, 2016

Ms. Angela Hall
Tennessee Department of Environment
and Conservation
Division of Water Resources
William R. Snodgrass Tennessee Tower
312 Rosa L. Parks Avenue, 11th Floor
Nashville, Tennessee 37243

Dear Ms. Morgan:

TENNESSEE VALLEY AUTHORITY (TVA) - SEQUOYAH NUCLEAR PLANT (SQN) - NPDES
PERMIT NO. TN0026450 - DISCHARGE MONITORING REPORT (DMR) FOR February 2016

Enclosed is the February 2016 Discharge Monitoring Report for Sequoyah Nuclear Plant. The Turbine Building Sump was aligned to the Yard Pond on February 8, 2016 and re-aligned on the same day. Turbine Building Sump monitoring data is summarized in Attachment 1. There were no exceedances during the monitoring period. If you have any questions or need additional information, please contact Millicent Garland by email at mrmoores@tva.gov or by phone at (423) 843-6714.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

For Christopher Schwarz
Site Vice President
Sequoyah Nuclear Plant

Enclosures

cc (Enclosures):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

IE25
NRR

**TVA Sequoyah Nuclear Plant
NPDES Permit Number TN0026450
Attachment 1**

Turbine Building Sump Monitoring Data - February 2016

The turbine building sump was discharged directly to the yard drainage pond on February 8, 2016 and re-aligned on the same day. During this time, the turbine building sump was monitored in accordance with the narrative condition found in Part 1.A.2 of the NPDES Permit TN0026450. There are no permit limits applicable at this monitoring point, which flows to the yard drainage pond, mixes with other flows in the diffuser pond, then discharges to the Tennessee River at Outfall 101.

Parameter	Daily Minimum	Monthly Average	Daily Maximum	No. of Samples
Flow	-	1.36 MGD	1.36 MGD	1
pH	7.99 s.u.	-	7.99 s.u.	1
O&G	-	5.6 mg/L	5.6 mg/L	1
TSS	-	8.2 mg/L	8.2 mg/L	1

Name TVA - SEQUOYAH NUCLEAR PLANT
 Address P.O. BOX 2000
(INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility TVA - SEQUOYAH NUCLEAR PLANT
 Location HAMILTON COUNTY

MAJOR
 (SUBR 01)
 F - FINAL

TN0026450 101 G
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
 From YEAR MO DAY To YEAR MO DAY
 16 02 01 16 02 29

DIFFUSER DISCHARGE
 EFFLUENT

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN:Millicent Garland

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	24.1	04	0	29 / 29	RCORDR
00010 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	***	*****	*****	Req. Mon. DAILY MAX	DEG. C.		CONTI NUOUS	CALCTD
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	9.7	04	0	29 / 29	MODELD
00010 Z 0 INSTREAM MONITORING	PERMIT REQUIREMENT	*****	*****	***	*****	*****	30.5 DAILY MX	DEG. C.		CONTI NUOUS	CALCTD
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	1.2	04	0	29 / 29	CALCTD
00016 1 1 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	***	*****	*****	5.0 DAILY MX	DEG. C.		CONTI NUOUS	CALCTD
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****	1771	03	*****	*****	*****	**	0	29 / 29	RCORDR
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MAX	MGD	*****	*****	*****	***		CONTI NUOUS	RCORDR
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	1669	*****	03	*****	*****	*****	03	0	29 / 29	CALCTD
50050 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	Req. Mon. MO AVG	*****	MGD	*****	*****	*****	MGD		CONTI NUOUS	CALCTD
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****	0.025	0.043	19	0	8 / 29	GRAB
50060 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	0.1 MO AVG	0.1 DAILY MAX	MGIL		FIVE PER WEEK	CALCTD
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****	0.2	62	*****	*****	*****	**	0	29 / 29	CALCTD
82234 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	2.0 DAILY MX	DEG C/HR	*****	*****	*****	***		CONTI NUOUS	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 Christopher J. Schwarz
 Site Vice President
 TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Chris Schwarz
 Site Vice President
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE DATE
 423 843-7001 16 03 07
 AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 No closed mode operation. The following injection occurred: Floguard MS6236 (max calc. was 0.03 mg/L, limit 0.20 mg/L).

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)
 Name TVA - SEQUOYAH NUCLEAR PLANT
 Address P.O. BOX 2000
(INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility TVA - SEQUOYAH NUCLEAR PLANT
 Location HAMILTON COUNTY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 101 T
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 BIOMONITORING FOR OUTFALL 101
 EFFLUENT

MONITORING PERIOD
 YEAR MO DAY YEAR MO DAY
 From 16 02 01 To 16 02 29

*** NO DISCHARGE ***

ATTN:Millicent Garland

NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP3B 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	42.8 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP6C 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	42.8 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 Christopher J. Schwarz
 Site Vice President
 TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Chris Schwarz
 Site Vice President
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
423	843-7001	16	03	07
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 Toxicity was not sampled in February 2016.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)
 Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450			103 G		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 16	02	01	To 16	02	29

F - FINAL
 LOW VOL. WASTE TREATMENT POND
 EFFLUENT

*** NO DISCHARGE ***

ATTN:Millicent Garland

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**	7.7	*****	8.3	12	0	5 / 29	GRAB
00400 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		ONCE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	8.4	8.4	19	0	1 / 29	GRAB
00530 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	30.0 MO AVG	100.0 DAILY MX	MG/L		ONCE/ MONTH	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	<5.0	<5.0	19	0	1 / 29	GRAB
00556 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	**	*****	15.0 MO AVG	20.0 DAILY MX	MG/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	1.065	1.163	03	*****	*****	*****	**	0	5 / 29	INSTAN
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	**		ONCE/ WEEK	INSTAN
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 Christopher J. Schwarz
 Site Vice President
 TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Chris Schwarz
 Site Vice President
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
423	843-7001	16	03	07
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 The Turbine Building Sump (TBS) was discharged directly to the Yard Pond (YP) on February 8, 2016.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)
 Name TVA - SEQUOYAH NUCLEAR PLANT
 Address P.O. BOX 2000
(INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility TVA - SEQUOYAH NUCLEAR PLANT
 Location HAMILTON COUNTY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450	110 G
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
YEAR MO DAY	YEAR MO DAY
From 16 02 01	To 16 02 29

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

*** NO DISCHARGE ***

ATTN:Millicent Garland

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00010 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	*****	*****	REPORT DAILY MX	DEG C		CONTINUOUS	CALCTD
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00010 Z 0 INSTREAM MONITORING	PERMIT REQUIREMENT	*****	*****	**	*****	*****	30.5 DAILY MX	DEG C		CONTINUOUS	CALCTD
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
00016 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	*****	*****	5 DAILY MX	DEG C		CONTINUOUS	CALCTD
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****		03	*****	*****	*****	**			
50050 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MX	MGD	*****	*****	*****	**		CONTINUOUS	RECORD
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****			19			
50060 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	*****	0.1 MO AVG	0.1 DAILY MX	MG/L		Five per Week	CALCTD
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****		04	*****	*****	*****	**			
82234 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C	*****	*****	*****	**		CONTINUOUS	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Christopher J. Schwarz		423	843-7001	16	03	07
Site Vice President						
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
(INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)
 F - FINAL

Form Approved.
 OMB No. 2040-0004

TN0026450 **110 T**
 PERMIT NUMBER DISCHARGE NUMBER

RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD
 From

YEAR	MO	DAY
16	02	01

 To

YEAR	MO	DAY
16	02	29

*** NO DISCHARGE ***

ATTN:Millicent Garland

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP3B 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	42.8 MINIMUM	*****	*****	PERCENT		SEMI-ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP6C 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	42.8 MINIMUM	*****	*****	PERCENT		SEMI-ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Christopher J. Schwarz
 Site Vice President
 TYPED OR PRINTED

Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Chris Schwarz
 for Chris Schwarz
 Site Vice President

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
423	843-7001	16	03	07
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)
 Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)
 F - FINAL

Form Approved.
 OMB No. 2040-0004

TN0026450	118 G
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
YEAR MO DAY	YEAR MO DAY
From 16 02 01	To 16 02 29


WASTEWATER & STORM WATER
 EFFLUENT

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN:Millicent Garland

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO)	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	19			
00300 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	***	2 MINIMUM	*****	*****	MG/L		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	***	*****	*****	100 DAILY MX	MG/L		TWICE/ WEEK	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		25			
00545 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	***	*****	*****	1 DAILY MX	ML/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*		ONCE/ BATCH	ESTIMA
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Site Vice President		TELEPHONE		DATE		
Christopher J. Schwarz				423	843-7001	16	03	07
Site Vice President		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY
TYPED OR PRINTED								

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall. No Discharge this Period