

From: Guzman, Richard
Sent: Wednesday, March 09, 2016 2:47 PM
To: 'Wanda D Craft (Generation - 6)'
Subject: RE: Review of Alternative Request IR-3-27 for Implementation of Extended Reactor Vessel ISI Interval - MPS3(CAC No. MF5868)

Wanda,

I agree that the two items you identify below are minor editorial errors. Please consider this email as an official record of the staff's acknowledgement of the identified errors in the subject NRC safety evaluation dated February 16, 2016 (ADAMS Accession No. ML16038A001).

From: Wanda D Craft (Generation - 6) [<mailto:wanda.d.craft@dom.com>]
Sent: Tuesday, March 08, 2016 3:25 PM
To: Guzman, Richard <Richard.Guzman@nrc.gov>
Subject: [External_Sender] Review of Alternative Request IR-3-27 for Implementation of Extended Reactor Vessel ISI Interval - MPS3(CAC No. MF5868)

Rich,

As we discussed, during review of the NRC Safety Evaluation for the MPS3 Alternative Request IR-3-27 for Implementation of Extended Reactor Vessel Third Inservice Inspection Interval dated Feb. 16, 2016, two minor editorial items were noted. On the top of page 4, item 1, 4th sentence, the acronym RTmaxx is defined as "Radiographic Testing – maximum." It should be "Reference Temperature – maximum." On page 6, second paragraph, the 3rd sentence states "....TWCF_{95-TOTAL} for MPS3 was 1.44×10^{-3} ,...." but the correct value for TWCF_{95-TOTAL} is 1.44×10^{-13} .

If you have any questions, please let me know. Thanks.

Wanda D. Craft
Nuclear Licensing and Operations Support
Dominion Resources Services, Inc
(804) 273-4687
tie-line 730-4687

CONFIDENTIALITY NOTICE: This electronic message contains information which may be legally confidential and or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents of this information is prohibited and may be unlawful. If you have received this electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.