

FPL Turkey Point Uprate Monitoring Project  
September 2014 Semiannual Sampling Event  
SDG: Qtr 3 2014 SW

Parameter	Units	TPBBSW-3B		TPBBSW-4B		TPBBSW-5B		TPSWC-1T		TPSWC-1B		TPSWC-2T	
		09/11/2014		09/11/2014		09/11/2014		09/02/2014		09/02/2014		09/05/2014	
Temperature	°C	29.45		28.86		28.86		30.83		30.13		32.17	
pH	SU	8.13		8.06		7.74		7.55		7.23		7.91	
Dissolved Oxygen	mg/L	4.02		4.91		2.34		3.97		0.17		6.35	
Specific Conductance	µS/cm	56080		55486	J	56215		471	J	604	J	598	
Turbidity	NTU	0.55		0.23		0.47		0.77		8.1		0.66	
Silica, dissolved	mg/L												
Calcium	mg/L	436		421		455		82.4	J	48.8	J	52.4	
Magnesium	mg/L	1180	J-	1140	J	1200	J	8.4	J	6.5	J	7.41	
Potassium	mg/L	536	J+	528	J	554	J	3.48	J	2.83	J	2.73	
Sodium	mg/L	11400		11100		11400		47	J	31.9	J	51.4	
Boron	mg/L	4.96		4.91		5.21		0.0769		0.068		0.0655	
Strontium	mg/L	8.1		7.79		8.34		0.603		0.414		0.54	
Bromide	mg/L	73.5		73.2	J	73.8		0.193		0.243		0.265	
Chloride	mg/L	21200		21400	J	21800		59.2		82.6		101	
Fluoride	mg/L	0.98	J-	0.89	J	0.89		0.024	U	0.024	U	0.024	U
Sulfate	mg/L	2890		2760	J	2970		6.24		11.4		5.14	J
Total Ammonia	mg/L as N	0.0652	J	0.915	J	0.496	J	0.827		0.817		0.829	J
Ammonium ion (NH <sub>4</sub> <sup>+</sup> )	mg/L	0.0759	J	1.08	J	0.613	J	1.03		1.04		0.991	J
Unionized NH <sub>3</sub>	mg/L	0.0075	J	0.0875	J	0.0237	J	0.0295		0.0135		0.071	J
Nitrate/Nitrite	mg/L as N	0.5	U	0.5	U	0.5	U	0.1	U	0.1	U	0.5	U
TKN	mg/L	0.3	U	0.3	UJ	0.504		1.07		1.41		1.15	
TN	mg/L	0.800		0.800	J	1.004		1.170		1.510		1.650	
ortho-Phosphate	mg/L	0.105	UJ	0.105	UJ	0.105	UJ	0.0014	U	0.00415	I	0.07	UJ
Total Phosphorus (P)	mg/L	0.003	UJ	0.003	UJ	0.003	UJ	0.0129		0.0484		0.00803	IJ
Alkalinity	mg/L	131		127	J	151		130		146		124	
Bicarbonate Alkalinity	mg/L as CaCO <sub>3</sub>	159		154	J	184		159		178		151	
Sulfide	mg/L	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U
Total Dissolved Solids	mg/L												
Salinity	*	37.1		36.7	J	37.2		0.2	J	0.3	J	0.3	J
Tritium	pCi/L	11.4 (5.7)		7.1 (5.6)		12.7 (5.6)		84.0 (7.1)		55.9 (6.3)	J	161.3 (9.3)	

NOTE: Laboratory results are reported with 3 digits although only the first 2 are significant figures.

The results in blue represent data values that were not available at time of publication of the prior annual report.

<sup>1</sup>Value is suspect based on comparisons with historic data from this station and expected ranges for that season substantially deviates fi

FPL Turkey Point Uprate Monitoring Project  
September 2014 Semiannual Sampling Event  
SDG: Qtr 3 2014 SW

Parameter	Units	TPSWC-2B		TPSWC-3T		TPSWC-3B		TPSWC-4T		091014-Dup		TPSWC-4B		TPSWC-5T		TPSWC-5B	
		09/05/2014		09/05/2014		09/05/2014		09/10/2014		09/10/2014		09/10/2014		09/10/2014		09/10/2014	
Temperature	°C	30.96		32.79		31.34		30.25				31.73		28.42		30.00	
pH	SU	7.48		7.80		7.41		7.67				7.61		8.03		7.97	
Dissolved Oxygen	mg/L	2.89		5.44		0.49		3.96				2.63		5.91		4.31	
Specific Conductance	µS/cm	601		680		1604		24228				43816		53420		57253	
Turbidity	NTU	0.89		0.13		1.3		4.05				2.94		0.45		0.26	
Silica, dissolved	mg/L																
Calcium	mg/L	55.7		54.2		64.4		266		271		377		400		454	
Magnesium	mg/L	7.71		7.55		20.7		494		497		888	J	1100	J-	1520	J
Potassium	mg/L	2.8		3.15		8.24		222		227		411	J	516	J+	583	J
Sodium	mg/L	50.8		63		183		4450		4490		8270		11100		11800	
Boron	mg/L	0.0647		0.0604		0.112		1.84		1.9		3.73		4.85		5.39	
Strontium	mg/L	0.54		0.578		0.701		4.47		4.58		6.85		7.86		8.86	
Bromide	mg/L	0.271		0.332		1.17		29.9		29.6		56.2		69		75.7	
Chloride	mg/L	96.9		123		372		8430		8310		15900		20200		21900	
Fluoride	mg/L	0.024	U	0.024	U	0.024	U	0.45		0.44		0.69		0.87		0.87	
Sulfate	mg/L	6.81	J	4.53	J	36.5		1060		1050		2130		2720		2940	
Total Ammonia	mg/L as N	0.812	J	1.12	J	0.713	J	0.975		1.2		1.12	J	0.0995	J	0.94	J
Ammonium ion (NH <sub>4</sub> <sup>+</sup> )	mg/L	1.02	J	1.36	J	0.896	J	1.21				1.39	J	0.119	J	1.12	J
Unionized NH <sub>3</sub>	mg/L	0.025	J	0.0787	J	0.0192	J	0.0437				0.0484	J	0.00868	J	0.0798	J
Nitrate/Nitrite	mg/L as N	0.5	U	0.5	U	0.5	U	0.5	U	0.5	U	0.5	U J	0.5	U J-	0.5	U J
TKN	mg/L	1.13		1.24		1.15		1.37		1.27		0.768	J	0.336	I	0.414	J
TN	mg/L	1.630		1.740		1.650		1.870		1.770		1.268	J	0.836	J	0.914	J
ortho-Phosphate	mg/L	0.07	U J	0.07	U J	0.07	U J	0.07	U J	0.07	U	0.07	U J	0.07	U J	0.07	U J
Total Phosphorus (P)	mg/L	0.00872	I J	0.00745	I J	0.0103	J	0.00547	I J	0.00269	I	0.00395	I J	0.0022	U J	0.0022	U J
Alkalinity	mg/L	134		128		139		189		190		181		130		141	
Bicarbonate Alkalinity	mg/L as CaCO <sub>3</sub>	163		157		169		231		232		221		159		172	
Sulfide	mg/L	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U
Total Dissolved Solids	mg/L																
Salinity	*	0.3	J	0.3	J	0.8	J	14.6				28.1		35.2		38.0	
Tritium	pCi/L	128.4 (8.5)		119.2 (7.1)		85.9 (7.6)		145.8 (8.1)		128.3 (7.6)		64.6 (6.1)		22.5 (5.3)		20.2 (5.3)	

rom concurrent values for neighboring CCS monitoring stations.

FPL Turkey Point Uprate Monitoring Project  
September 2014 Semiannual Sampling Event  
SDG: Qtr 3 2014 SW

Parameter	Units	TPSWC-6T		TPSWC-6B		TPSWID-1T		TPSWID-1B		TPSWID-2T		TPSWID-2B		TPSWID-3T		TPSWID-3B	
		09/03/2014		09/03/2014		09/04/2014		09/04/2014		09/04/2014		09/04/2014		09/04/2014		09/04/2014	
Temperature	°C	26.00		26.16		32.48		31.43		32.08		29.94		31.32		31.53	
pH	SU	7.42		7.38		7.90		7.74		7.68		7.04		7.76		7.40	
Dissolved Oxygen	mg/L	0.93		0.95		9.14		6.60		6.69		1.80		6.79		3.00	
Specific Conductance	µS/cm	821		849		5584		5648		4226		6157		4403		8307	
Turbidity	NTU	0.14		0.06		1.07		0.52		0.86		1.51		0.61		1.09	
Silica, dissolved	mg/L																
Calcium	mg/L	86.2		83.4		141		144		131		178		121		151	
Magnesium	mg/L	9.98		10.4		82.4		85.5		57.9		79.2		59.2		121	
Potassium	mg/L	11.4		10.9		38		39.1		27.3		37.8		27.9		60.3	
Sodium	mg/L	59.3		64		770		787		575		844		541		1140	
Boron	mg/L	0.0855		0.0846		0.358		0.375		0.23		0.292		0.221		0.476	
Strontium	mg/L	0.984		0.956		1.75		1.78		1.59		2.15		1.41		1.95	
Bromide	mg/L	0.511		0.56		5.26		5.17		3.8		5.77		3.99		8.39	
Chloride	mg/L	112		128		1540		1550		1130		1810		1270		2400	
Fluoride	mg/L	0.11		0.11		0.14		0.15		0.12		0.13		0.14		0.17	
Sulfate	mg/L	52.4		58.8		166		168		116		160		119		291	
Total Ammonia	mg/L as N	0.646	J	0.465	J	0.534	J	0.472	J	0.898	J	1.16	J	0.794		0.587	J
Ammonium ion (NH <sub>4</sub> <sup>+</sup> )	mg/L	0.817	J	0.589	J	0.638	J	0.579	J	1.11	J	1.48	J	0.972		0.738	J
Unionized NH <sub>3</sub>	mg/L	0.0124	J	0.00824	J	0.0456	J	0.0268	J	0.0464	J	0.0123	J	0.0465		0.0157	J
Nitrate/Nitrite	mg/L as N	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U	0.5	U	0.1	U	0.1	U
TKN	mg/L	0.3	U J	0.3	U J	0.656		0.702		0.644	J	0.902	J	0.904		0.66	
TN	mg/L	0.400	J	0.400	J	0.756		0.802		0.744	J	1.402	J	1.004		0.760	
ortho-Phosphate	mg/L	0.0014	U	0.0014	U	0.07	U J	0.07	U J	0.07	U J	0.07	U J	0.07	U J	0.07	U J
Total Phosphorus (P)	mg/L	0.00466	I	0.0022	U	0.0034	I J	0.0028	I J	0.0022	U J	0.00398	I J	0.00619	I J	0.00281	I J
Alkalinity	mg/L	192		197		282		292		246		292		229		226	
Bicarbonate Alkalinity	mg/L as CaCO <sub>3</sub>	234		241		344		356		300		357		279		276	
Sulfide	mg/L	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U
Total Dissolved Solids	mg/L																
Salinity	*	0.4	J	0.4	J	3.0		3.0		2.2		3.3		2.3		4.6	
Tritium	pCi/L	23.0 (4.1)		11.7 (3.7)		261.9 (10.6)		276.0 (11.4)		196.7 (9.3)	J	90.2 (6.4)	J	149.8 (7.9)	J	127.6 (7.5)	J

FPL Turkey Point Uprate Monitoring Project  
September 2014 Semiannual Sampling Event  
SDG: Qtr 3 2014 SW

Parameter	Units	090414-Dup		TPSWCCS-1B	
		09/04/2014		09/04/2014	
Temperature	°C			38.90	
pH	SU			7.65	
Dissolved Oxygen	mg/L			0.12	
Specific Conductance	µS/cm			118575	J
Turbidity	NTU			59.53	
Silica, dissolved	mg/L			10.5	J-
Calcium	mg/L	154		1120	J
Magnesium	mg/L	123		2560	J-
Potassium	mg/L	61.5		1360	J+
Sodium	mg/L	1170		26200	
Boron	mg/L	0.486		13.2	
Strontium	mg/L	1.98		23.9	
Bromide	mg/L	8.3		179	J
Chloride	mg/L	2390		52700	J
Fluoride	mg/L	0.16		0.89	J-
Sulfate	mg/L	325		7420	J
Total Ammonia	mg/L as N	0.707		0.882	
Ammonium ion (NH <sub>4</sub> <sup>+</sup> )	mg/L			1.06	
Unionized NH <sub>3</sub>	mg/L			0.0654	
Nitrate/Nitrite	mg/L as N	0.1	U	0.1	U J-
TKN	mg/L	0.616		13.4	
TN	mg/L	0.716		13.500	J
ortho-Phosphate	mg/L	0.07	U	0.07	U
Total Phosphorus (P)	mg/L	0.00277	I	0.0847	
Alkalinity	mg/L	236		220	J
Bicarbonate Alkalinity	mg/L as CaCO <sub>3</sub>	287		268	J
Sulfide	mg/L	0.1	U	0.1	U
Total Dissolved Solids	mg/L				
Salinity	*			88.3	J
Tritium	pCi/L	128.7 (7.4)	J	537.6 (515.2)	16

FPL Turkey Point Uprate Monitoring Project

September 2014 Semiannual Sampling Event

SDG: Qtr 3 2014 SW

Parameter	Units	TPSWCCS-2B		TPSWCCS-3B		TPSWCCS-4T		TPSWCCS-5T		TPSWCCS-7B		090214-EB		090314-FB		090414-FB1	
		09/05/2014		09/04/2014		09/04/2014		09/04/2014		09/04/2014		09/02/2014		09/03/2014		09/04/2014	
Temperature	°C	37.55		35.61		34.34		34.49		38.27							
pH	SU	7.70		7.67		7.72		7.72		7.69							
Dissolved Oxygen	mg/L	1.27		0.27		0.61		0.21		0.96							
Specific Conductance	µS/cm	120417	J	117724		120344	J	119703	J	119981	J						
Turbidity	NTU	60.18		54.82		56.48		57.78		61.78							
Silica, dissolved	mg/L	10	J	9.26	J	9.91	J	9.62	J	10.8	J	0.05	U	0.05	U	0.05	U
Calcium	mg/L	1170	J	1100		1110	J	1130	J	1120	J	0.1	U	0.577		0.1	U
Magnesium	mg/L	2630	J	2520	J	2560	J	2580	J	2590	J	0.02	U	0.02	U	0.0201	I
Potassium	mg/L	1380	J	1370	J	1420	J	1410	J	1360	J	0.19	U	0.19	U	0.19	U
Sodium	mg/L	26700	J	26900		26600	J	26000	J	26900	J	0.31	U	0.31	U	0.31	U
Boron	mg/L	14.3		13.4		13.8		13.6		13.5		0.01	U	0.01	U	0.01	U
Strontium	mg/L	24.9		24		24.8		24.5		23.8		0.001	U	0.001	U	0.001	U
Bromide	mg/L	185	J	183		188	J	182	J	187	J	0.013	U	0.013	U	0.013	U
Chloride	mg/L	53700	J	53700		53900	J	51700	J	52500	J	0.25	U	0.25	U	0.25	U
Fluoride	mg/L	0.86	J	0.86	J	0.84	J	0.84	J	0.87	J	0.024	U	0.024	U	0.024	U
Sulfate	mg/L	7190	J	7310		7480	J	6920	J	7180	J	0.25	U	0.389	I	0.25	U
Total Ammonia	mg/L as N	0.452	J	1.03		0.946		0.904		0.722		0.0677		0.0629		0.0653	
Ammonium ion (NH <sub>4</sub> <sup>+</sup> )	mg/L	0.545	J	1.26		1.15		1.1		0.869							
Unionized NH <sub>3</sub>	mg/L	0.0344	J	0.0651		0.0616		0.0594		0.0561							
Nitrate/Nitrite	mg/L as N	0.5	U	0.1	U J	0.1	U J	0.1	U J	0.1	U J	0.1	U	0.1	U	0.5	U
TKN	mg/L	2.82		12.4		3.98		3.38		12.8		0.15	U	0.15	U	0.15	U
TN	mg/L	3.320		12.500	J	4.080	J	3.480	J	12.900	J	0.250		0.250		0.650	
ortho-Phosphate	mg/L	0.07	U	0.07	U	0.07	U	0.07	U	0.07	U	0.0014	U	0.0014	U	0.07	U
Total Phosphorus (P)	mg/L	0.106		0.0863		0.0843		0.0852		0.0761		0.0022	U	0.0022	U	0.0022	U
Alkalinity	mg/L	227		222		224	J	214	J	219	J	1	U	1	U	1	U
Bicarbonate Alkalinity	mg/L as CaCO <sub>3</sub>	277		271		273	J	261	J	267	J	1	U	1	U	1	U
Sulfide	mg/L	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U	0.1	U
Total Dissolved Solids	mg/L											5	U			5	U
Salinity	*	90.2	J	87.9		90.4	J	89.7	J	89.7	J						
Tritium	pCi/L	280.5 (501.1)		14599.7 (447.8)		15350.8 (475.0)		15542.7 (452.4)		29659.2 (915)	Outlier <sup>1</sup>	6.5 (3.6)		-1.2 (3.4)	UJ	21.4 (5.4)	

FPL Turkey Point Uprate Monitoring Project  
September 2014 Semiannual Sampling Event  
SDG: Qtr 3 2014 SW

Parameter	Units	090514-FB1		091014-FB1		091114-FB1	
		09/05/2014		09/10/2014		09/11/2014	
Temperature	°C						
pH	SU						
Dissolved Oxygen	mg/L						
Specific Conductance	µS/cm						
Turbidity	NTU						
Silica, dissolved	mg/L	0.05	U	0.05	U	0.05	U
Calcium	mg/L	0.1	U	0.1	U	0.1	U
Magnesium	mg/L	0.02	U	0.02	U	0.02	U
Potassium	mg/L	0.19	U	0.19	U	0.19	U
Sodium	mg/L	0.31	U	0.31	U	0.31	U
Boron	mg/L	0.01	U	0.01	U	10	U
Strontium	mg/L	0.001	U	0.001	U	1	U
Bromide	mg/L	0.013	U	0.013	U	0.013	U
Chloride	mg/L	0.575		0.25	U	0.25	U
Fluoride	mg/L	0.024	U	0.024	U	0.024	U
Sulfate	mg/L	1.96		0.25	U	0.25	U
Total Ammonia	mg/L as N	0.223		0.0554		0.0524	
Ammonium ion (NH <sub>4</sub> <sup>+</sup> )	mg/L						
Unionized NH <sub>3</sub>	mg/L						
Nitrate/Nitrite	mg/L as N	0.5	U	0.5	U	0.5	U
TKN	mg/L	0.15	U	0.15	U	0.15	U
TN	mg/L	0.650		0.650		0.650	
ortho-Phosphate	mg/L	0.0014	U	0.0014	U	0.0021	U
Total Phosphorus (P)	mg/L	0.0022	U	0.0022	U	0.003	U
Alkalinity	mg/L	1	U	1	U	1	U
Bicarbonate Alkalinity	mg/L as CaCO <sub>3</sub>	1	U	1	U	1	U
Sulfide	mg/L	0.1	U	0.1	U	0.1	U
Total Dissolved Solids	mg/L	5	U	5	U	5	U
Salinity	*						
Tritium	pCi/L	7.8 (5.9)		2.3 (5.0)	UJ	2.1 (5.5)	UJ

**FPL Turkey Point Uprate Monitoring Project**  
**September 2014 Semiannual Sampling Event**  
SDG: Qtr 3 2014 SW

Notes

Laboratory results are reported with 3 digits although only the first 2 are significant figures.

\* PSS-78 salinity is unitless.

\*\* Schemel, L.E., 2001. Simplified conversions between specific conductance and salinity units for use with data from monitoring stations. Interagency Ecological Program for the San Francisco Estuary Newsletter. 14(1):17-18.

Sample 091014-DUP is a duplicate of TPSWC-4T.

Sample 090414-DUP1 is a duplicate of TPSWID-3B.

Key

°C = Degrees Celsius.

µg/L = Microgram(s) per liter.

µmho/cm = Micromho(s) per centimeter.

µS/cm = MicroSiemen(s) per centimeter.

ABS = Absolute value.

CaCO<sub>3</sub> = Calcium carbonate.

DEP SOP = Department of Environmental Protection Standard Operating Procedure.

mg/L = Milligram(s) per liter.

N.A. = Not applicable.

NH<sub>3</sub> = Ammonia.

NH<sub>4</sub><sup>+</sup> = Ammonium ion.

NTU = Nephelometric Turbidity Units(s).

pCi/L = PicoCuries per liter.

ppt = Parts per thousand.

PQL = Practical Quantitation Limit.

PSS-78 = Practical Salinity Scale of 1978.

RPD = Relative Percent Difference.

SC = Specific conductance.

SDG = Sample Delivery Group.

SU = Standard Unit(s).

TDS = Total Dissolved Solids.

TKN = Total Kjeldahl nitrogen.

TN = Total nitrogen.

TPBBSW = Turkey Point Biscayne Bay Surface Water

TPSWC = Turkey Point Surface Water Canal

TPSWID = Turkey Point Surface Water Interceptor Ditch

TPSWCCS = Turkey Point Surface Water Cooling Canal System

**FPL Turkey Point Uprate Monitoring Project**  
**September 2014 Semiannual Sampling Event**  
SDG: Qtr 3 2014 SW

<b>Summary of Table Modifications</b>					
<b>Date of Original Document</b>	<b>Old Value</b>	<b>New Value</b>	<b>Reason</b>	<b>Date of Revision</b>	<b>Revision by</b>
2/23/2015			added Tritium results	1/18/2016	JR