



L-2016-046  
10 CFR 52.3

March 10, 2016

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555-0001

Re: Florida Power & Light Company  
Proposed Turkey Point Units 6 and 7  
Docket Nos. 52-040 and 52-041  
Supplemental Response to NRC Request for Additional Information Letter  
No. 58 (eRAI 6434) - Concerning Implementation of Fukushima Near-Term  
Task Force Recommendations

References:

1. FPL Letter L-2013-303 to NRC dated October 28, 2013, Supplemental Response to NRC Request for Additional Information Letter No. 58 (eRAI 6434) - Concerning Implementation of Fukushima Near-Term Task Force Recommendations
2. NRC Letter to FPL dated May 1, 2012, Request for Additional Information Letter No. 58 - Concerning Implementation of Fukushima Near-Term Task Force Recommendations for the Turkey Point Units 6 and 7 Combined License Application
3. Letter from Christopher Fallon (PEF) to Nuclear Regulatory Commission (NRC), dated May 13, 2013, Supplement 7 to Response to NRC RAI Letter 108 - Implementation of Fukushima Near-Term Task Force Recommendations. Serial: NPD-NRC-2013-022. (ML13135A174)

Florida Power & Light Company (FPL) provided a supplemental response in a letter to the Nuclear Regulatory Commission's (NRC) request for additional information (RAI) No. 01.05-3 (eRAI 6434).

That supplemental response inserted a paragraph following DCD Subsection 9.1.3.7.D. However, the left margin annotation was not included. The addition of the LMA will provide consistency with the AP1000 lead plant - Levy Nuclear Plant, Units 1 and 2.

If you have any questions, or need additional information, please contact me at 561-904-3794.

ADID  
DD97  
NRD

Proposed Turkey Point Units 6 and 7  
Docket Nos. 52-040 and 52-041  
L-2016-046 Page 2

I declare under penalty of perjury that the foregoing is true and correct.

Executed on March 10, 2016.

Sincerely,

A handwritten signature in black ink, appearing to read 'W. Maher', written in a cursive style.

William Maher  
Senior Licensing Director – New Nuclear Projects

WDM/ETC

Enclosure: Associated Future COLA Revision (2 Pages)

cc:  
PTN 6 & 7 Project Manager, AP1000 Projects Branch 1, USNRC DNRL/NRO  
Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant 3 & 4

Proposed Turkey Point Units 6 and 7  
Docket Nos. 52-040 and 52-041  
L-2016-046 Enclosure Page 1 of 2

**Enclosure**

**ASSOCIATED FUTURE COLA REVISION**

(2 Total Pages)

The following left hand annotation will be added in FSAR Subsection 9.1.3.7 in a future COLA revision.

---

### **9.1.3.7 Instrumentation Requirements**

---

Add the following left hand margin annotation after the first paragraph of DCD Subsection 9.1.3.7.D.

**PTN SUP 9.1-1**

All three safety-related spent fuel pool level instruments and associated instrument tubing lines are located below the fuel handling area operating deck and the cask washdown pit. This location provides protection from missiles that may result from damage to the structure over the spent fuel pool. The SFP level instruments associated with PMS divisions A and C are physically separated from the SFP level instrument associated with PMS division B. The safety-related spent fuel pool level instruments measure the water level from the top of the spent fuel pool to the top of the fuel racks. These instruments are conservatively calibrated at a reference temperature suitable for normal spent fuel pool operation on a regular basis and accuracy is not affected by power interruptions.