

1 **Draft Interim Review of PRM-50-93/95 Issues Related to**
2 **Loss-of-Coolant Accident Simulations in the National Research Universal (NRU)**
3 **Reactor**
4
5

6 **Disclaimer:**
7

8 Public availability of this draft interim review is intended to inform stakeholders of
9 the current status of the NRC review of the issues raised in PRM-50-93/95. This
10 draft interim review is subject to further revisions during resolution of PRM-50-
11 93/95. The NRC is not soliciting public comments on these interim conclusions,
12 and will not provide a formal response to any comments received. The NRC
13 findings on PRM-50-93/95 issues will not be final until the NRC publishes a
14 notice of final action on this petition for rulemaking in the *Federal Register*.
15

16
17 **1.0 Issues Raised in the Petitions and Associated Comments**
18

19 A petition for rulemaking was docketed as PRM-50-93 on November 17, 2009 (Leyse, 2009).
20 The petitioner is requesting revisions to section 50.46 of Title 10 of the *Code of Federal*
21 *Regulations* (10 CFR) "Acceptance Criteria for Emergency Core Cooling Systems for Light
22 Water Nuclear Power Reactors" and to 10 CFR Part 50, Appendix K "ECCS Evaluation Models,"
23 as well as associated regulatory guidance. The petitioner, Mark Edward Leyse, discussed the
24 Zircaloy assembly tests performed at the National Research Universal (NRU) Reactor as part of
25 the basis for the assertion in the petition that 1) low reflood rates do not prevent Zircaloy
26 cladding temperatures from having substantial increases and 2) the zirconium-water reaction
27 equations (Baker-Just and Cathcart-Pawel) are both non-conservative for calculating the
28 temperature at which an autocatalytic (runaway) oxidation reaction of Zircaloy would occur in
29 the event of a LOCA.
30

31 Petition Arguments
32

33 The petitioner raises several issues related to the NRU thermal-hydraulic tests. The first of
34 which is related to the reflood rate. Specifically, the petition states:
35

36 "it can be extrapolated from experimental data that, in the event a LOCA, a constant
37 core reflood rate of approximately one inch per second or lower (1 in./sec. or lower)
38 would not prevent Zircaloy fuel cladding, that at the onset of reflood had cladding
39 temperatures of approximately 1200°F or greater, from exceeding the 10 C.F.R. §
40 50.46(b)(1) PCT limit of 2200°F."
41

42 "The NRU Thermal-Hydraulic Experiment 1 ("TH-1") tests illustrate that low reflood rates
43 do not prevent Zircaloy cladding temperatures from having substantial increases."
44

45 The petitioner then goes on to present temperature increases and peak cladding temperatures
46 for several NRU tests with different reflood rates. Petitioner then states that if these results are
47 extrapolated to some hypothetical set of conditions, that the PCT would exceed the 2,200°F
48 limit.
49

1 The second issue related to the NRU tests is use of the Baker-Just and Cathcart-Pawel metal-
2 water reaction equations. The petitioner makes a comparison between the data from NRU TH-1
3 test 128 and a sample code prediction (using the Baker-Just correlation) from Westinghouse's
4 "PWR FLECHT Final Report." Based on results of this comparison, petitioner states:

5
6 "it is evident that analyses using the Baker-Just correlation under-predict the amount of
7 heat generated by Zircaloy oxidation in TH-1 test no. 128."
8

9 "So with similar parameters (but with a lower fuel rod power) TH-1 test no. 128 had an
10 overall PCT increase that was more than 100°F greater than the overall PCT increase
11 predicted in the UO₂ Zircaloy fuel assembly example discussed in "PWR FLECHT Final
12 Report." This indicates that analyses using the Baker-Just correlation under-predict the
13 amount of heat that Zircaloy oxidation generated in TH- 1 test no. 128, a thermal
14 hydraulic experiment simulating LOCA conditions."
15

16 The petitioner also discusses TH-1 test 130. The petitioner states:

17
18 "the reactor shutdown when the PCT was approximately 1850°F; and after the reactor
19 shutdown, cladding temperatures kept increasing because of the heat generated from
20 the Zircaloy-steam reaction (of course, there would have also been a small amount of
21 actual decay heat) and the peak measured cladding temperature was 2040°F. So the
22 peak cladding temperature increased by 190°F after the reactor shutdown, because of
23 the heat generated from the Zircaloy-steam reaction."
24

25 "It is highly unlikely that analyses using the Baker-Just and Cathcart-Pawel correlations
26 would predict a peak cladding temperature increase of 190°F in TH-1 test no. 130, after
27 the reactor shutdown."
28


29 "So data from thermal hydraulic experiments indicates that the Baker-Just and Cathcart-
30 Pawel correlations are not adequate for use in ECCS evaluation calculations that
31 calculate the metal-water reaction rates that would occur in the heat transfer conditions
32 of loss-of-coolant accidents."
33
34

35 **2.0 Staff Response to Assertions**

36 37 2.1 Reflood Rate

38
39 The petitioner states that the TH-1 tests illustrate that low reflood rates do not prevent Zircaloy
40 cladding temperatures from having substantial increases. There are numerous parameters that
41 are known to have an important effect on reflood hydraulics in a light water reactor. No single
42 parameter completely controls the peak cladding temperature for a particular transient. Basing
43 a conclusion on any single parameter can be misleading. Part of the basis for the petitioners
44 request for a limit on reflood rate, is the significant temperature increases observed in the NRU
45 reflood tests. Starting from initial cladding temperatures less than 1,000°F, several NRU tests
46 produced temperature increases of over 1,000°F. The petition cites several NRU tests as
47 examples (tests no. 127 and 130). The petition implies that similar, or larger, temperature
48 increases would occur if the initial cladding temperatures had been 1,200°F or more. This is not
49 correct, however. Thermal radiation becomes more important in transferring heat away from hot
50 spots, and as rod temperatures increase the temperature difference between the cladding and
51 the coolant increases. Figure 1 below shows the temperature at the start of reflood –vs– the

1 temperature rise for all the NRU TH-1 tests. These include various reflood rates and delay
 2 times. As seen in the figure, as the cladding temperature at the start of reflood increases, the
 3 overall temperature rise decreases. The red line on the figure shows the margin to a PCT of
 4 2,200°F. Thus, contrary to the claim made in the petition, “extrapolation” of data does not show
 5 “with high probability” that peak cladding temperatures will exceed 2,200°F.
 6



7
 8
 9 **Figure 1.** Temperature at start of reflood –vs- temperature rise for all NRU TH-1 tests

10
 11
 12 **2.2 Metal-water reaction**

13
 14 **NRU Test no 128.**

15
 16 The petitioner argues that the Baker-Just metal-water reaction correlation is non-conservative
 17 based on comparison of the NRU TH-1 test no. 128 against some PWR FLECHT code
 18 calculations. The petitioner specifically states:

19
 20 “So with similar parameters (but with a lower fuel rod power) TH-1 test no. 128 had an
 21 overall PCT increase that was more than 100°F greater than the overall PCT increase
 22 predicted in the UO₂ Zircaloy fuel assembly example discussed in “PWR FLECHT Final
 23 Report.” This indicates that analyses using the Baker-Just correlation under-predict the
 24 amount of heat that Zircaloy oxidation generated in TH-1 test no. 128, a thermal
 25 hydraulic experiment simulating LOCA conditions.”
 26

27 The calculations that the petitioner is comparing TH-1 test no. 128 against are described in
 28 Section 4 of WCAP-7665. The code calculations were performed to show the difference
 29 between electrically heated rods with either stainless steel or Zr cladding and UO₂ heated rods

1 with Zr cladding under a hypothetical LOCA with two different reflood rates. The calculations
 2 were done with an unnamed "conduction code" which includes the Baker-Just parabolic rate
 3 equation. It is the staffs' opinion that this type of indirect comparison (between code results for
 4 one facility used for a specific purpose and experimental data from a specific test in a different
 5 test facility) should not form the basis for any decisions when direct comparisons are available
 6 and can be investigated. However, the results of the PWR FLECHT code runs are still useful
 7 and comparisons can be made between PWR FLECHT experimental data and NRU
 8 experimental data (TH-1 test no 128).

9
 10 While the petitioner compared NRU TH-1 test no. 128 against some PWR FLECHT code
 11 calculations, the staff compared test no. 128 against PWR FLECHT run no. 4129 (Table 1
 12 below). As seen in the table, the parameters and results from the two tests are similar. Both
 13 tests started with an initial temperature around 1,600°F and reflood rate around 2 in/s. In the
 14 case of the PWR FLECHT test with the stainless steel rods, the temperature at the hot rod mid-
 15 plane elevation increased 372°F while the TH-1 test with Zr rods increased 387°F. The small
 16 difference in temperature rise between the two cases (15°F) shows that the zirconium metal-
 17 water reaction is not substantial at these temperatures (just below 2,000°F).

18
 19 **Table 1.** Comparison of selected TH-1 and PWR FLECHT tests
 20

Parameter	TH-1 test no. 128	PWR FLECHT run no. 4129
Cladding material	Zr	Stainless steel
Flooding rate	2 in/s	1.9 in/s
Initial temperature ¹	1,604°F	1,596°F
Temperature rise	387°F	372°F
Peak clad temperature ¹	1,991°F	1,968°F

21 ¹ The FLECHT temperature is not the peak clad temperature, rather it is the mid-plane temperature
 22
 23

24 The PWR FLECHT code calculations referred to by the petitioner were not performed to
 25 simulate a specific test, rather they were performed to show the difference between electrically
 26 heated rods with either stainless steel or Zr cladding and UO₂ heated rods with Zr cladding
 27 under a hypothetical LOCA. However, the conditions are very similar to PWR FLECHT run
 28 no. 4225 and comparisons are shown in Table 2. In the case of the stainless steel fuel rods,
 29 there is no metal-water reaction simulated and the code results are with a few °F of the
 30 experiment. When UO₂ heated rods with Zr cladding are used in the code, the temperature rise
 31 was 27°F larger than the stainless steel code run. This difference is mainly due to the metal-
 32 water reaction (using the Baker-Just metal-water correlation). This difference is larger than the
 33 difference of 15°F seen when comparing TH-1 test no. 128 and PWR FLECHT run no. 4129.

34
 35 Based on comparisons of NRU TH-1 test no 128, PWR FLECHT run nos. 4129 and 4225 along
 36 with the PWR FLECHT code calculations referenced by the petitioner, there is no evidence that
 37 the Baker-Just (or Cathcart-Pawel) metal-water reaction correlation is non-conservative, or that
 38 the metal-water reaction is significant at temperatures < 2,000°F as asserted in the petition.
 39

1 **Table 2.** Comparison of PWR FLECHT test and code results
2

Parameter	PWR FLECHT run no. 4225 ¹	PWR FLECHT code calculation ²	PWR FLECHT code calculation ²
Cladding material	Stainless steel	Stainless steel	Zr
Flooding rate	1.9 in/s	2 in/s	2 in/s
Pressure	59 psia	60 psia	60 psia
Peak power	1.24 kW/ft	1.24 kW/ft	1.24 kW/ft
Initial temperature	1,596°F	1,600°F	1,600°F
Temperature rise	247°F	244°F	271°F
Peak clad temperature	1,843°F	1,844°F	1,871°F

3 ¹ Data from Table 3-1 of WCAP-7665

4 ² Data from Figure 4-1 of WCAP-7665
5
6

7 NRU Test no 130.
8

9 The petitioner argues that the experimental data from multi-rod thermal hydraulic experiments
10 (specifically TH1 test no. 130) demonstrates that the Zircaloy-steam reaction is substantial
11 below 1,900°F. The petitioner states:
12

13 “In TH-1 test no. 130, the reactor tripped (shutdown) when the PCT was approximately
14 1,850°F; and after the reactor shutdown, cladding temperatures kept increasing because
15 of the heat generated from the metal-water reaction (of course, there would have also
16 been a small amount of actual decay heat) and the peak measured cladding
17 temperature was 2,040°F. So because of the heat generated from the metal-water
18 reaction, the peak cladding temperature increased by 190°F, after the reactor
19 shutdown.”
20

21 The values quoted by the petitioner were obtained from NUREG/CR-1882 (Table 1 on page 13).
22 In NUREG/CR-1882, it states in a footnote to Table 1 for test no. 130, “Reactor tripped at
23 ~1,850°F.” The petitioners claim is based on this temperature being the peak cladding
24 temperature, however, this is not correct. Section 9.7 of NUREG/CR-1208 describes the
25 reactor trip conditions and requirements as well as the neutron power decay. There are several
26 transient phase trips, including:

- 27
- 28 • Hanger tube high temperature trip.
 - 29 • Outlet piping high temperature trip.
 - 30 • Low reflood flow standby trip.
 - 31 • High fuel cladding temperature trip.
 - 32 • Manual trip.

33 The description for the fuel cladding temperature trip states that the temperature signal used is
34 an average of the guard fuel rods (located on the peripheral region of the assembly) and not the
35 test fuel rods (located in the center region of the assembly). This average of all the guard fuel
36 rod thermocouples (at a given axial level) is then averaged over a ten second time period,


1 resulting in a lag of the actual temperature response. Given the fact that the peak temperature
2 will occur in the test fuel rods and the fact that the temperature signal used in the trip logic is a
3 lagged average of the guard fuel rods, the peak cladding temperature will be larger than the trip
4 setpoint of 1,850°F at the time of trip. In addition, there is an approximately 0.75 second delay
5 after the initiation of trip before the power begins to decline as seen in Figure 9.3 of
6 NUREG/CR-1208. Therefore, since the temperatures are all increasing, by definition the peak
7 cladding temperature must be larger than the 1,850°F reactor trip setpoint when the reactor
8 power begins to decline.

9
10 To investigate this further, applicable portions of several temperature plots for TH-1 test no. 130
11 (shown in Figures 1.2.3.30, 1.2.4.30 and 3.2.2.30 of the Appendix to NUREG/CR-1882) were
12 digitized and recreated and shown in Figure 2 below. The highest temperature shown in the
13 plots for test no. 130 is 1,968°F, which is lower than the 2,040°F given in Table 1 of
14 NUREG/CR-1882, so the peak cladding temperature location is not shown in the plots and it
15 cannot be determined exactly how much the peak cladding temperature increased after reactor
16 power was stopped. While it is not known at exactly what time the reactor was tripped, it would
17 be expected that there would be some change in the rate of temperature increase when the
18 reactor trips and power begins to decline. Looking at the slope of the temperature curves
19 (dT/dt) shows no noticeable change in any dT/dt prior to 100 s. While the temperature may
20 continue to increase at some locations (due to the metal-water reaction), it is extremely unlikely
21 that it would continue to increase at the same rate at all locations shown in the temperature
22 plots, particularly those below 1,800°F. Assuming the reactor was tripped and power began
23 decreasing at 102 s (the first observed change in dT/dt), then thermocouple TC153B1R4 would
24 be at 1,940°F and reach a maximum of 1,968°F, a difference of 28°F. While this is not the
25 location of the peak cladding temperature, this is the thermocouple with the highest temperature
26 plotted in NUREG/CR-1882 and is representative of the thermal transient. This is a significantly
27 smaller temperature increase than the 190°F quoted by the petitioner. Given that the reactor
28 did not trip at a PCT of 1,850°F, there is no basis for the petitioners' claim that a temperature
29 increase of 190°F was due to the metal-water reaction after the reactor shutdown.

30
31 The petitioner also states:

32
33 "It is clear that, in TH-1 test no. 130, if the reactor had not shutdown when the PCT was
34 approximately 1850°F, that the overall PCT would have been greater than 2040°F. In
35 fact, it is highly probable that the multi-rod bundle in the TH-1 test no. 130, would have
36 incurred autocatalytic oxidation if the reactor had not shutdown when the PCT was
37 approximately 1850°F."

38
39 While the peak cladding temperature would have gone higher than 2,040°F if the reactor was
40 not tripped, there is no justification or evidence provided by the petitioner to substantiate the
41 claim that autocatalytic oxidation would have occurred.



1
2 **Figure 2.** Temperatures for NRU TH-1 Test 130 from NUREG/CR-1882
3
4

5 **3.0 Summary and Conclusions**

6
7 This draft interim evaluation examined the NRU thermal hydraulic tests for issues related to
8 reflood and the metal-water reaction. In the case of reflood, the petitioner claims through
9 extrapolation that a high temperature at the start of reflood along with a low reflood rate will
10 result in a large temperature rise. This extrapolation was shown to be invalid as the
11 temperature increase declines as the temperature at the start of reflood increases due to effects
12 not considered by the petitioner.
13

14 For the metal-water reaction, the petitioner argues that the Baker-Just correlation is non-
15 conservative based on comparison of the NRU TH-1 test no. 128 against some PWR FLECHT
16 code calculations. The petitioner was making an indirect comparison by comparing code results
17 from one test facility (used for a specific purpose) to experimental results from a specific test in
18 another facility. Staff compared NRU TH-1 test no. 128 against PWR FLECHT test 4129 and
19 found only a small difference in PCT between the test with stainless steel rods and with Zr rods,
20 demonstrating that the metal-water reaction is not significant at temperatures below 2,000°F.
21 The PWR FLECHT code calculations were then compared against PWR FLECHT test 4225 and
22 showed excellent agreement for stainless steel rods. When Zr rods were simulated in the code,
23 the PCT increased by 27°F (mainly due to the metal-water reaction). A comparison between
24 TH-1 test no. 128 (with Zr cladding) and PWR FLECHT run no. 4129 (with stainless steel
25 cladding) showed a 15°F difference in temperature rise with the Zr rods, demonstrating that the
26 metal-water reaction is not significant at these temperatures. Based on these comparisons,
27 there is no evidence that the Baker-Just metal-water reaction correlation is non-conservative.
28

1 The petitioner argues that the experimental data from TH1 test no. 130 demonstrates that the
2 Zircaloy-steam reaction is substantial below 1,900°F. The petitioner claims that the peak
3 cladding temperature increased 190°F after the reactor was tripped. TH1 test no. 130 was
4 examined and it was determined that the reactor was not tripped at a peak cladding temperature
5 of 1,850°F as the petitioner claims, rather the 1,850°F trip setpoint is based on a time lagged
6 average of the guard fuel rods. While the exact peak cladding temperature at the time reactor
7 power begins to decline is unknown, it is by necessity higher than the 1,850°F trip setpoint,
8 therefore, there is no basis for the statement that the peak cladding temperature increased
9 190°F after the reactor was tripped. There is also no justification or evidence provided by the
10 petitioner to substantiate the claim that autocatalytic oxidation would have occurred had the
11 reactor not been tripped.
12
13

14 **4.0 References**

15
16 Leyse, M. E., Petition for Rulemaking (Docketed as PRM 50-93), November 17, 2009, ADAMS
17 Accession No. ML093290250
18

19 C. L. Mohr, et al., Pacific Northwest Laboratory, "Safety Analysis Report: Loss-of-Coolant
20 Accident Simulations in the National Research Universal Reactor," NUREG/CR-1208,
21 PNL-3093, 1981.
22

23 C. L. Mohr, et al., Pacific Northwest Laboratory, "Prototypic Thermal-Hydraulic Experiment in
24 NRU to Simulate Loss-of-Coolant Accidents," NUREG/CR-1882, PNL-3681, 1981.
25

26 F. F. Cadek, et al., "PWR FLECHT (Full Length Emergency Cooling Heat Transfer) Final
27 Report," WCAP-7665, 1971.
28

29 M. Leyse, Comments on PRM-50-93 and PRM-50-95; NRC-2009-0554, July 30, 2011, ADAMS
30 accession number ML11213A211.
31

32 M. Leyse, Comments on PRM-50-93; NRC-2009-0554, March 15, 2010, ADAMS accession
33 number ML100820229.
34

35 M. Leyse, Comments on PRM-50-93; NRC-2009-0554, April 28, 2010, ADAMS accession
36 number ML101230118.
37

38 M. Leyse, Comments on PRM-50-93 and PRM-50-95; NRC-2009-0554, November 23, 2010,
39 ADAMS accession number ML103340249.
40

41 M. Leyse, Comments on PRM-50-93 and PRM-50-95; NRC-2009-0554, November 23, 2010,
42 ADAMS accession number ML103340248.
43

44 M. Leyse, Comments on PRM-50-93 and PRM-50-95; NRC-2009-0554, December 27, 2010,
45 ADAMS accession number ML110050023.
46

47 M. Leyse, Comments on PRM-50-93 and PRM-50-95; NRC-2009-0554, July 21, 2011, ADAMS
48 accession number ML11209C489.
49