

NRR-PMDAPem Resource

From: Kuntz, Robert
Sent: Tuesday, March 22, 2016 1:33 PM
To: Adams, Glenn D. (Glenn.Adams@xenuclear.com)
Subject: Monticello February 10, 2016 license amendment request RE: ILRT Type A extension, Result of NRC staff acceptance review

Dear Mr. Adams,

By letter dated February 10, 2016, (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16047A336), Northern States Power Company – Minnesota (NSPM, the licensee), doing business as Xcel Energy, Inc., submitted a license amendment for the Monticello Nuclear Generating Plant (Monticello). The proposed amendment would revise Technical Specification 5.5.11 “Primary Containment Leakage Rate Testing Program,” to increase the containment integrated leakage rate test program Test A interval from 10 to 15 years. The purpose of this letter is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff’s acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the Code of Federal Regulations (10 CFR), an amendment to the license (including the technical specifications) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff’s ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. You will be advised of any further information needed to support the NRC staff’s detailed technical review by separate correspondence.

If you have any questions, please contact me.

Robert Kuntz
Sr. Project Manager, Monticello and Prairie Island
NRR/DORL/LPL3-1
(301) 415-3733

Hearing Identifier: NRR_PMDA
Email Number: 2725

Mail Envelope Properties (Robert.Kuntz@nrc.gov20160322133200)

Subject: Monticello February 10, 2016 license amendment request RE: ILRT Type A extension, Result of NRC staff acceptance review
Sent Date: 3/22/2016 1:32:47 PM
Received Date: 3/22/2016 1:32:00 PM
From: Kuntz, Robert

Created By: Robert.Kuntz@nrc.gov

Recipients:
"Adams, Glenn D. (Glenn.Adams@xenuclear.com)" <Glenn.Adams@xenuclear.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	2600	3/22/2016 1:32:00 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: