

DTE Energy
One Energy Plaza, Detroit, MI 48226-1279

DTE Energy®



March 21, 2016
NRC3-16-0001

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

References: 1) Fermi 3
NRC Docket No. 52-033
NRC License No. NPF-95

Subject: DTE Electric Company Submittal of Application for Renewal of the Fermi 3
National Pollutant Discharge Elimination System (NPDES) Permit

On March 21, 2016, DTE Electric Company (DTE) submitted its application for renewal of the Fermi 3 NPDES permit to the Michigan Department of Environmental Quality (MDEQ). Section 3.0 of the Fermi 3 Environmental Protection Plan (EPP) requires that DTE provide a copy of the application for renewal of this permit to the NRC when it is submitted to the permitting agency (MDEQ). The purpose of this letter is to transmit the required copy of the renewal application.

Applications for NPDES permits and renewals are now submitted electronically to the MDEQ. The attachment to this letter contains a hardcopy version of the electronic submittal of the Fermi 3 NPDES permit renewal application.

If you have any questions, or need additional information, please contact Mr. Michael K. Brandon at (313) 235-0443.

Sincerely,

A handwritten signature in black ink, appearing to read 'PWS', followed by a horizontal line.

Peter W. Smith, Director
Nuclear Development – Licensing and Engineering
DTE Electric Company

D095
NRO

USNRC
NRC3-16-0001
Page 2

Attachment: Fermi 3 NPDES Permit Renewal Application

cc: Adrian Muniz, NRC Fermi 3 Project Manager
Mallecia Sutton, NRC Fermi 3 Environmental Project Manager
Fermi 2 Resident Inspector (w/o Attachment)
NRC Region III Regional Administrator (w/o Attachment)
NRC Region II Regional Administrator (w/o Attachment)
Supervisor, Electric Operators, Michigan Public Service Commission (w/o Attachment)
Michigan Department of Natural Resources and Environment
Radiological Protection Section (w/o Attachment)
Regina A. Borsh, Dominion Energy, Inc. (w/o Attachment)
Barry C. Bryant, Dominion Energy, Inc. (w/o Attachment)
Patricia L. Campbell, General Electric (w/o Attachment)

Fermi 3 NPDES Permit Renewal Application
(114 pages)

National Pollutant Discharge Elimination System (NPDES) Industrial/Commercial Application Form

version 1.7

(Submission #: 2CR-RKTN-J193, version 1)

PRINTED ON 3/21/2016

Summary

| | | | |
|----------------------|---|------------------------|-------------------|
| Submission #: | 2CR-RKTN-J193 | Date Submitted: | 3/21/2016 2:23 PM |
| Form: | National Pollutant Discharge Elimination System (NPDES) Industrial/Commercial Application Form | Status: | Submitted |
| Applicant: | Nicholas | Active Steps: | |
| Reference #: | | | |
| Description: | National Pollutant Discharge Elimination System (NPDES) Industrial/Commercial Application Form | | |

Notes

There are currently no Submission Notes.

Details**Applicant Information**

The name of the company OR individual requesting any type of authorization must be provided as part of the contact information below.

Applicant Information**Contact**

Prefix: NONE PROVIDED

First Name: Nicholas

Last Name: Chuey

Company: DTE Energy, DTE Electric Company

Title: Senior Environmental Engineer

Ext: NONE PROVIDED

Phone: 3132355569

FAX: NONE PROVIDED

Email: chueyn@dteenergy.com

Address

Address Line 1: One Energy Plaza

Address Line 2: Room 655 G.O.

Description: NONE PROVIDED

City: Detroit

State: MI

Postal Code: 48226

Country: US

Section IA. – General Facility Information (Required of All Applicants)

SITE ID/DEQ Reference Number (pre-populated, if applicable)

7744842549919779824

SITE or FACILITY NAME

DECO-Fermi 3 Power Plt

Section I shall be completed by all permit applicants. Instructions for completing Section I are on Page 2 of the Appendix.

Appendix to the Permit Application

NPDES Permit Number

NONE PROVIDED

Facility Location

41.960833,-83.261944

Facility Name 1

DTE Energy, DTE Electric Company

Facility Name 2

DECO - Fermi 3 Power Plant

Facility Name 3

NONE PROVIDED

Site/Facility Physical Address

6400 North Dixie Highway
Newport, MI 48166

Facility Website Address

NONE PROVIDED

Section IB. – General Facility Contacts (Required of All Applicants) (1)**4. CONTACTS**

Provide contact information for each person as required for each area; a person may be identified for more than one category.

Contact

Annual Permit Billing Contact
Application Contact
Storm Water Billing Contact

Section I shall be completed by all permit applicants. Instructions for completing Section I are on Page 2 of the Appendix.

Appendix to the Permit Application

Contact**Contact**

| | | |
|---|---|------------------------------------|
| Prefix: Mr. | First Name: Nicholas | Last Name: Chuey |
| Company: DTE Energy Corporate Services LLC | Title: Senior Environmental Engineer | Ext: NONE PROVIDED |
| Phone: 3132355569 | FAX: NONE PROVIDED | Email: chueyn@dteenergy.com |

Address

Address Line 1: One Energy Plaza

Address Line 2: Room 655 G.O.

Description: NONE PROVIDED

City: Detroit

State: MI

Postal Code: 48226

Country: US

Section IB. – General Facility Contacts (Required of All Applicants) (2)**4. CONTACTS**

Provide contact information for each person as required for each area; a person may be identified for more than one category.

Contact

Certified Operator
DMR Contact
SW Operator

Section I shall be completed by all permit applicants. Instructions for completing Section I are on Page 2 of the Appendix.

Appendix to the Permit Application

Contact**Contact**

Prefix: NONE PROVIDED

First Name: TBD

Last Name: TBD

Company: NONE PROVIDED

Title: TBD

Ext: NONE PROVIDED

Phone: 3132355569

FAX: NONE PROVIDED

Email: chueyn@dteenergy.com

Address

Address Line 1: One Energy Plaza

Address Line 2: NONE PROVIDED

Description: NONE PROVIDED

City: Detroit

State: MI

Postal Code: 48226

Country: USA

Section IB. – General Facility Contacts (Required of All Applicants) (3)**4. CONTACTS**

Provide contact information for each person as required for each area; a person may be identified for more than one category.

Contact

Other

Section I shall be completed by all permit applicants. Instructions for completing Section I are on Page 2 of the Appendix.

Appendix to the Permit Application

Contact**Contact**

Prefix: Mr.

First Name: Michael

Last Name: Brandon

Company: DTE Electric Company

Title: Manager - Licensing

Ext: NONE PROVIDED

Phone: 3132350443

FAX: NONE PROVIDED

Email: brandonm@dteenergy.com

Address

Address Line 1: One Energy Plaza

Address Line 2: Room 509 G.O.

Description: NONE PROVIDED

City: Detroit

State: MI

Postal Code: 48226

Country: USA

Section IC. – General Facility Information (Required of All Applicants) (1)**5. RULE 98 – ANTIDEGRADATION REQUIREMENTS.**

In accordance with Rule 323.1098 of the Michigan Water Quality Standards, the applicant is required to submit an Antidegradation Demonstration for any new or increased loading of pollutants to the surface waters of the state. An Antidegradation Demonstration must contain the information specified in Rule 1098, outlined on Pages 8-9 of the Appendix. For assistance in completing this item, contact the Permits Section.

Appendix to the Permit Application

ANTIDEGRADATION REQUIREMENTS Attachment - Attachment(s)

NONE PROVIDED

Comment: NONE PROVIDED

Will this discharge be an increased loading of pollutants to the surface waters of the state?

No (You may skip the next two questions)

Select one of the following.**Select all that apply**

A) A short-term (weeks to months) or temporary lowering of water quality B) Bypasses that are not prohibited by regulations set forth in 40 CFR 122.41(m) C) Response actions undertaken to alleviate a release of pollutants into the environment that may pose an imminent and substantial danger to the public health or welfare D) Discharges of pollutant quantities from the intake water at a facility if the intake and discharge are to the same body of water E) Increases in flow at a POTW if the increase is within the design flow of the facility, there is no increased loading of BCCs that are not specifically limited in the current permit, and there is no significant change expected in the characteristics of the wastewater collected F) Intermittent increased loading related to wet-weather conditions G) New or increased loading due to DEQ-approved controls related to wet-weather conditions H) Discharges authorized by Certificates of Coverage (COC) and Notices of Coverage I) Increased loadings within the authorized levels of a limit in an existing control document, except those loadings that result from actions by the permittee that would otherwise require submittal of an increased use request J) Increased loadings of a pollutant which do not involve Bioaccumulative Chemicals of Concern and which use less than 10 percent of the unused loading capacity that exists at the time of the request

Select all that apply

NONE PROVIDED

6. ADDITIONAL FACILITY LOCATION INFORMATION.**Local Unit of Government (LUG)**

Frenchtown Charter Township

LUG Contact E-Mail Address

jim@frenchtownchartertp.org

Private (French) Land Claim

NONE PROVIDED

7. CERTIFIED OPERATOR**Does the facility have a DEQ-certified operator at the appropriate level?**

No

CERTIFIED OPERATOR**Contact**

Prefix: NONE PROVIDED

First Name: TBD

Last Name: TBD

Company: DTE Electric Company

Title: TBD

Ext: NONE PROVIDED

Phone: 3132355569

FAX: NONE PROVIDED

Email: chueyn@dteenergy.com

Address

Address Line 1: 6400 North Dixie Highway

Address Line 2: NONE PROVIDED

Description: NONE PROVIDED

City: Newport

State: MI

Postal Code: 48166

Country: USA

Certification Number

TBD

Certification Classification(s)

TBD

9. OTHER ENVIRONMENTAL PERMITS

Provide the information requested in the table for any other federal, state, or local environmental permits in effect or applied for at the time of submittal of this Application, including, but not limited to, permits issued under any of the following programs: Air Pollution Control, Hazardous Waste Management, Wetlands Protection, Soil Erosion and Sedimentation Control, and other NPDES permits.

Table Data

| Issuing Agency | Permit or COC Number | Permit Type |
|----------------|----------------------|-----------------|
| MDEQ | 10-58-0011-P | Parts 303 & 325 |

10. WATER FLOW DIAGRAM AND NARRATIVE DESCRIPTION

Provide a flow diagram (using 8½" x 11" paper if possible) and a narrative description that explains the diagram. The diagram should show the wastewater flow through the facility (from intake through discharge), including all processes, treatment units, including any lagoons or ponds (lagoon / pond construction and liner information should be included) used for wastewater treatment or storage (identify treatment units that operate intermittently), and bypass piping. Show all operations contributing wastewater and the locations of flow meters, chemical feeds, and monitoring and discharge points. The water balance shall show the daily average flow rates at the intake and discharge points, and approximate daily flow rates between treatment units, including influent and treatment rates. Use actual measurements whenever available, otherwise use the best estimate. Show all significant losses of water to products, atmosphere, and discharge. In addition, provide a flow diagram for any storm water discharges from secondary structures that are required by state or federal law and for storm water runoff from any Site of Environmental Contamination, pursuant to Part 201 of the NREPA. Do not send blueprints. Provide black-and-white reproducible diagrams. Treatment Works Treating Domestic Sewage – The narrative description shall briefly describe the history of the wastewater treatment facility and collection system, including the initial construction, facility improvements, future plans for upgrade, location of all constructed emergency overflows, and other pertinent information. Industrial / Commercial Facilities – The diagram shall include all operations contributing wastewater, including process and production areas, sanitary flows, cooling water, and storm water runoff. Include a narrative that provides a brief description of the nature of the business and the manufacturing processes. Concentrated Animal Feeding Operations – Refer to the requirements set forth in Section V.

10. WATER FLOW DIAGRAM AND NARRATIVE DESCRIPTION - Attachment(s)

1.C.10 Water Use Diagram a.pdf

1.C.10 Water Use Narrative & Supplemental Information.pdf

Comment: NONE PROVIDED

11. MAP OF FACILITY AND DISCHARGE LOCATION - Attachment(s)

1.C.11 Map of Facility and Discharge Loc.pdf

Comment: NONE PROVIDED

12. CONTRACT LABORATORIES THAT PROVIDE ANALYTICAL SUPPORT

Provide the name and address of each contract laboratory or consulting firm that performed any analyses submitted as part of this Application. To add additional laboratory click the + at the top of the page.

Laboratory Name

Trimatrix Laboratories, Inc.

Laboratory Address

Section I.C.10 - Fermi 3 Water Use Diagram

Figure 3.3-1, Fermi 3 Environmental Report, Rev. 2
(following 3 pages: 3-21 through 3-23)

Figure 3.3-1 Water Use Diagram (Sheet 1 of 3)

NOTE:
FOR FLOWS ASSOCIATED WITH NUMBERED
WATER AVENUES, PLEASE SEE SHEET 2
OF THIS DRAWING.




Figure 3.3-1 Water Use Diagram (Sheet 2 of 3)

| Flow | Description | Value (gpm) Maximum Normal Power Operation ¹ Discharged Radwaste | Value (gpm) Minimum Normal Power Operation ² Discharged Radwaste | Value (gpm) Average Normal Power Operation ³ Discharged Radwaste | Value (gpm) Average Shutdown Operation Discharged Radwaste |
|------|---|--|--|--|---|
| 1 | Total Makeup Water Intake | 34,264 | 23,780 | 28,993 | 1,166 |
| 2 | Cooling Tower Makeup Water | 34,234 | 23,750 | 28,963 | 1,136 |
| 3 | Demineralizer Makeup Water | 160 | 160 | 160 | 639 |
| 4 | Normal Power Heat Sink Drift & Evaporation | 17,124 | 11,882 | 14,488 | 0 |
| 5 | Normal Power Heat Sink Discharge | 17,110 | 11,868 | 14,474 | 0 |
| 6 | Auxiliary Heat Sink Drift & Evaporation | 0 | 0 | 0 | 569 |
| 7 | Auxiliary Heat Sink Discharge | 0 | 0 | 0 | 567 |
| 8 | Inflow to Main Condenser | 684,000 | 684,000 | 684,000 | 0 |
| 9 | Total Plant Service Water System Flow | 40,000 | 40,000 | 40,000 | 40,000 |
| 10 | Total Circulating Water System Flow | 724,000 | 724,000 | 724,000 | 0 |
| 11 | Inflow to Condensate Storage | 58 | 58 | 58 | 232 |
| 12 | Inflow to Station Uses | 49 | 49 | 49 | 196 |
| 13 | Outflow to Equipment Drains | 58 | 58 | 58 | 232 |
| 14 | Outflow to Floor Drains | 8 | 8 | 8 | 30 |
| 15 | Outflow to Laundry & Chemical Drains | 24 | 24 | 24 | 95 |
| 16 | Outflow to Miscellaneous Periodic Drains | 18 | 18 | 18 | 71 |
| 17 | Inflow to the Radwaste System | 107 | 107 | 107 | 428 |
| 18 | Loss in Solid Radwaste | 2 | 2 | 2 | 9 |
| 19 | Radwaste Discharge (Liquid Radwaste Loss) | 105 | 105 | 105 | 419 |
| 20 | Makeup Demineralizer Blowdown | 53 | 53 | 53 | 211 |
| 21 | Total Discharge | 17,215 | 11,973 | 14,579 | 987 |
| 22 | Total Drift & Evaporation | 17,124 | 11,882 | 14,488 | 569 |
| 23 | Fire Protection Uses | 30 | 30 | 30 | 30 |
| 24 | Potable Water Discharge to Sewer | 200 | 35 | 35 | 47 |
| 25 | Domestic Uses | 200 | 35 | 35 | 47 |
| 26 | Total Discharge to Monroe County sewer system | 253 | 88 | 88 | 258 |
| 27 | Liquid Radwaste Recycled | 0 | 0 | 0 | 0 |

Station Water Uses:

Standby Liquid Control System
 Reactor Component Cooling Water System
 Process Sampling System process use
 HVAC system

Liquid Waste System chemical addition and line flushing
 Turbine Component Cooling Water System
 Auxiliary Boiler System
 Isolation Condenser/Passive Containment Cooling Pool

Solid Waste System for line flushing
 Chilled Water System
 Post Accident Sampling station flushing

Figure 3.3-1 Water Use Diagram (Sheet 3 of 3)

| Flow | Description | Value (gpm) Maximum Normal Power Operation ¹ | Value (gpm) Minimum Normal Power Operation ² | Value (gpm) Average Normal Power Operation ³ | Value (gpm) Average Shutdown Operation |
|------|---|---|---|---|--|
| | | Recycled Radwaste | Recycled Radwaste | Recycled Radwaste | Recycled Radwaste |
| 1 | Total Makeup Water Intake | 34,264 | 23,780 | 28,993 | 1,166 |
| 2 | Cooling Tower Makeup Water | 34,234 | 23,750 | 28,963 | 1136 |
| 3 | Demineralizer Makeup Water | 3 | 3 | 3 | 13 |
| 4 | Normal Power Heat Sink Drift & Evaporation | 17,124 | 11,882 | 14,488 | 0 |
| 5 | Normal Power Heat Sink Discharge | 17,110 | 11,868 | 14,474 | 0 |
| 6 | Auxiliary Heat Sink Drift & Evaporation | 0 | 0 | 0 | 569 |
| 7 | Auxiliary Heat Sink Discharge | 0 | 0 | 0 | 567 |
| 8 | Inflow to Main Condenser | 684,000 | 684,000 | 684,000 | 0 |
| 9 | Total Plant Service Water System Flow | 40,000 | 40,000 | 40,000 | 40,000 |
| 10 | Total Circulating Water System Flow | 724,000 | 724,000 | 724,000 | 0 |
| 11 | Inflow to Condensate Storage | 58 | 58 | 58 | 232 |
| 12 | Inflow to Station Uses | 49 | 49 | 49 | 196 |
| 13 | Outflow to Equipment Drains | 58 | 58 | 58 | 232 |
| 14 | Outflow to Floor Drains | 8 | 8 | 8 | 30 |
| 15 | Outflow to Laundry & Chemical Drains | 24 | 24 | 24 | 95 |
| 16 | Outflow to Miscellaneous Periodic Drains | 18 | 18 | 18 | 71 |
| 17 | Inflow to the Radwaste System | 107 | 107 | 107 | 428 |
| 18 | Loss in Solid Radwaste | 2 | 2 | 2 | 9 |
| 19 | Radwaste Discharge (Liquid Radwaste Loss) | 0 | 0 | 0 | 0 |
| 20 | Makeup Demineralizer Blowdown | 1 | 1 | 1 | 4 |
| 21 | Total Discharge | 17,110 | 11,868 | 14,474 | 567 |
| 22 | Total Drift & Evaporation | 17,124 | 11,882 | 14,488 | 569 |
| 23 | Fire Protection Uses | 30 | 30 | 30 | 30 |
| 24 | Potable Water Discharge to Sewer | 200 | 35 | 35 | 47 |
| 25 | Domestic Uses | 200 | 35 | 35 | 47 |
| 26 | Total Discharge to Monroe County sewer system | 201 | 36 | 36 | 52 |
| 27 | Liquid Radwaste Recycled | 105 | 105 | 105 | 419 |

1. Summer months (Design/maximum)

2. Winter months (January/minimum)

3. Spring and fall months (Average)

Section I.C.10 - Water Use Narrative and Supplemental Information

Water Use Narrative (following 1 page)

Section 3.3 - Plant Water Use, Fermi 3 Environmental Report, Rev. 2
(5 pages: 3-16 through 3-20)

Section 3.4 - Cooling System, Fermi 3 Environmental Report, Rev. 2
(13 pages: 3-24 through 3-36)

Section 3.6 - Nonradioactive Waste Systems, Fermi 3 Environmental Report, Rev. 2
(8 pages: 3-42 through 3-49)

Section 1.C.10 – Fermi 3 Water Use Narrative

Fermi 3 Power Plant will be a closed-cycle steam electric power generation unit with a net electrical output of approximately 1535 ± 50 MWe. Lake Erie will provide water for cooling and operational uses. Potable water will be used as makeup water for the demineralizer and for various station uses. Attachment 2 details the water uses, discharges and recycled flows.

The predominant uses of Lake Erie water at the Fermi 3 Power Plant will be as cooling water in the Circulating Water System and in the Plant Service Water System. The maximum intake has been calculated to be approximately 50 million gallons per day (MGD). A small portion of the intake water, 43,200 gallons per day (gpd), will be used in the Fire Protection System. The maximum daily discharge to Lake Erie, which includes cooling water and miscellaneous low volume wastes, has been calculated to be approximately 25 MGD. The low volume wastes will include equipment drains and floor drains that will be treated in the plant's Radwaste System, with a calculated discharge of about 0.2 MGD. The low volume wastes that cannot be treated and discharged from the Radwaste System will be disposed of in accordance with applicable local, state and federal regulations. Approximately half (~ 25MGD) of the cooling and plant service water is used consumptively, and will be discharged as drift and evaporation via the cooling tower and reservoir.

A detailed description of all plant water uses and discharges are contained in the Fermi 3 Combined License Application on pages 3-16 to 3-23, 3-24 to 3-36, and 3-42 to 3-49, all of which are attached.

3.3 Plant Water Use

Fermi 3 requires water for cooling and operational uses. Lake Erie provides water for plant cooling, including the normal power heat sink (NPHS) and auxiliary heat sink (AHS).

[Subsection 3.3.1](#) discusses water consumption and discharges by the various plant components and systems, including the NPHS, AHS, Ultimate Heat Sink (UHS), potable water and sanitary waste, demineralized water, and fire protection. Additionally, [Figure 3.3-1](#) presents a water use diagram for Fermi 3 outlining normal plant power operating conditions as well as non-power/shutdown conditions.

[Subsection 3.3.2](#) discusses methods of water treatment used in the plant and discharged back to the receiving water body (i.e., Lake Erie). Plant service water treatment is discussed in this subsection and also further discussed in [FSAR Subsection 9.2.1](#). Makeup water is also discussed in this subsection, as well as in [FSAR Subsection 9.2.3](#).

3.3.1 Water Consumption

Plant water systems discussed in this subsection include the CIRC, PSWS, Station Water System (SWS), Potable Water System (PWS), Sanitary Waste Discharge System (SWDS), demineralized system, and Fire Protection System (FPS). The CIRC, PSWS, SWS, and FPS share a common intake from Lake Erie. Potable water is being supplied for the demineralized system from the Frenchtown Township municipal water supply. The design of the intake structure is based on record low water levels for Lake Erie, thus even under these conditions plant operation is able to carry on normally. Under normal conditions, Lake Erie water levels remain relatively constant except during extreme seiche events. The intake structure is not designed for extreme seiche events. During extreme seiche events, the water supply to the SWS could be degraded and the unit operationally controlled to limit makeup requirements. The Ultimate Heat Sink (UHS) for Fermi 3, described in [FSAR Subsection 9.2.5](#), contains a separate water supply for safety-related cooling. Lake Erie is not used for safety-related water withdrawal for Fermi 3. Therefore, a seiche event will not affect a safety-related water supply for Fermi 3. This is discussed further in [Subsection 3.4.2.1](#). The SWS provides makeup water to the NPHS and AHS cooling tower basins, and the FPS. The SWS is further described in [FSAR Subsection 9.2.10](#). Various drains in the plant produce effluent liquid radwaste. This flow can either be treated and discharged to Lake Erie, or recycled. Blowdown from several sources, including both NPHS and AHS cooling towers; optional treated liquid radwaste, including chemical waste is combined and shares a common discharge to Lake Erie. The demineralized water waste is discharged to the Fermi 3 SWDS.

3.3.1.1 Circulating Water System and Normal Power Heat Sink

The CIRC is used to remove the waste heat from the main condenser discharging to the NPHS. A more detailed description of the CIRC is presented in [Subsection 3.4.1.1](#). During normal operation the NPHS may provide cooling to the AHS loads. Makeup water to the NPHS cooling tower replenishes water losses due to evaporation, drift, and blowdown. [Figure 3.3-1](#) shows the water use (makeup, blowdown, evaporation, etc.) by the NPHS for Fermi 3. [Figure 3.3-1](#) describes the flow rates for power and shutdown operations. Power operations are further subdivided into the

maximum heat load (expected during summer months), minimum heat load (expected during the winter months), and the average heat load (expected during the spring and fall months). The maximum makeup water flow is approximately 34,000 gpm for the NPHS.

The maximum blowdown from the NPHS cooling tower is approximately 17,000 gpm, and the minimum blowdown is approximately 12,000 gpm. The annual average blowdown flow is approximately 14,000 gpm. The maximum blowdown value represents the design condition, at the warmest temperatures. The minimum value represents winter conditions under the coldest temperatures, which occur in the month of January. The average value represents the average of all monthly flows; this value would be representative of flows in the spring or fall months. [Table 3.4-1](#) outlines the monthly variation in evaporation, blowdown and makeup flows. The blowdown is directed to an outfall that discharges into Lake Erie.

3.3.1.2 Plant Service Water System and Auxiliary Heat Sink

The PSWS provides nonsafety-related cooling to the Reactor Building and Turbine Building systems. During operation of Fermi 3, PSWS cooling is provided by either the NPHS cooling tower or the AHS cooling towers. While in shutdown condition, the PSWS is cooled by the AHS cooling towers. The AHS requires makeup water to replenish water losses due to evaporation, drift, and blowdown. Blowdown from the AHS is mixed with the NPHS cooling tower blowdown. The flow requirements for makeup flow for the PSWS are a maximum of approximately 1100 gpm. The makeup water requirements are included in the flow values stated in [Subsection 3.3.1.1](#). A more detailed description of the PSWS is provided in [Subsection 3.4.1.3](#).

3.3.1.3 Ultimate Heat Sink

The ESBWR design has no separate emergency water cooling system. The UHS function is provided by safety systems integral and interior to the reactor plant. These systems ultimately use the atmosphere as the eventual heat sink. These systems do not rely on cooling towers, basins, or cooling water intake/discharge structures external to the reactor plant. ([Reference 3.3-1](#))

3.3.1.4 Potable Water and Sanitary Waste Discharge System

The PWS and SWDS are designed to provide potable water supply and sewage treatment necessary for normal plant operation and shutdown periods. The source of the potable water supply is the Frenchtown Township municipal water system. The PWS is designed to supply up to 200 gpm of potable water during peak demand period with a monthly average usage of 35 gpm, as outlined on [Figure 3.3-1](#). The Demineralized water waste and the effluent from the auxiliary boiler are routed to the Fermi 3 SWDS. Sanitary waste is routed to the Frenchtown Township Sewage Treatment Facility.

3.3.1.5 Demineralized Water

The required flow for makeup water to the demineralization subsystem when using the option of discharging liquid radwaste to Lake Erie, is expected to be a monthly average of 160 gpm, with short term maximum flow expected to be 639 gpm during outages. The required flow for makeup water to the demineralization subsystem when using the option of recycling liquid radwaste is bounded by the makeup flow with liquid radwaste discharged to Lake Erie. The option to operate

with liquid radwaste recycled supports zero discharge of liquid radwaste. The makeup water is supplied from the Frenchtown Township water line as depicted on [Figure 3.3-1](#). Flows for various modes of operation, as well as liquid radwaste effluent are also outlined on this figure.

3.3.1.6 Fire Protection

Fire protection water is provided to the FPS from onsite storage tanks that have makeup supplied from the SWS. After the FPS is initially filled, maximum usage is about 30 gpm for activities such as maintaining the system filled and pressurized and periodic testing.

3.3.2 Water Treatment

As outlined in [Subsection 3.3.1](#), plant makeup water is taken from a common intake from Lake Erie. This intake is treated with sodium hypochlorite, a biocide/algaecide, thus disseminating to the appropriate water use systems. Sodium hypochlorite is used to eradicate the presence of biologicals in the systems, both in the form of plant life such as algae and animals such as zebra mussels and corbicula. During select periods in spring and fall, sodium hypochlorite levels are elevated to ensure the absence of zebra mussels.

The SWS supplies makeup water to the PSWS, CIRC, and FPS. There are viable treatment options for mussel control in these systems, which include: chlorination and thermal shock treatment. The chlorination option will consist of isolation of the PSWS and elevation of chlorine levels within the PSWS for a specific duration of time. This will cause the eradication of any zebra mussel population within the system. Upon returning the PSWS to service, the chlorinated PSWS water will be combined with the much larger portion of blowdown from the NPHS, thus diluting the chlorine to acceptable discharge levels. The thermal shock treatment option would consist of raising the temperature of the CIRC to greater than 95°F for at least 60 minutes. This method is less practical for the PSWS due to system thermal limitations.

3.3.2.1 Station Water System

The SWS draws water from Lake Erie as the source of makeup to the plant. The SWS is described in [FSAR Subsection 9.2.10](#). Makeup water to the plant is treated with a biocide, sodium hypochlorite, as it enters through the SWS pump house intake. Water treatment chemistry is provided in [Table 3.3-1](#).

3.3.2.2 Circulating Water

The CIRC provides cooling water for removal of the power cycle heat from the main condensers and transfers this heat to the NPHS. The CIRC is described in [FSAR Section 10.4](#). Chemical additions are made to both influent and effluent flows. System chemistry control is provided by the incorporation of an injection system at the inlet to the condenser that introduces a biocide, corrosion inhibitor, and scale inhibitor. The necessity of using a biocide is outlined in [Subsection 3.4.2.2](#). The corrosion inhibitor is needed in order to reduce the effects of corrosion on the piping and condenser. The scale inhibitor is needed to reduce the build-up of scaling that could affect the efficiency of the condenser. Quantities and identification of these various chemicals are shown in [Table 3.3-1](#). Discharge must also be treated before exiting to Lake Erie. Dehalogenation must occur in order to maintain oxidant within reasonable discharge limits. As discussed in [Section 1.2](#), permits, e.g.,

National Pollution Discharge Elimination System (NPDES) permit and Section 401 Water Quality Certification, will be obtained for the discharge from Fermi 3. Additionally, [Section 5.2](#) provides a discussion on effluent limitations and permit conditions.

3.3.2.3 Plant Service Water System

PSWS chemistry control is maintained in a similar fashion to that of the CIRC, i.e., with the addition of biocide, corrosion inhibitor, scale inhibitor, as well as dispersant chemicals to break up sedimentation when lake water is highly turbid. Water treatment chemistry is provided in [Table 3.3-1](#). There are no expected changes to water treatment operating procedures based on seasonal variations. The PSWS is described in [FSAR Subsection 9.2.1](#).

3.3.2.4 Potable Water and Sanitary Waste

The potable water for the Fermi site is supplied from the Frenchtown Township municipal water system. This water supply does not require any additional chemical treatment or additives. The sanitary waste system effluent is discharged to the Frenchtown Township Sewage Treatment Facility without addition of chemical treatments. [FSAR Subsection 9.2.4](#) provides further description of the PWS and SWDS.

3.3.3 References

- 3.3-1 GE-Hitachi Nuclear Energy, "ESBWR Design Control Document – Tier 2," Revision 6, August 2009.

Table 3.3-1 Chemical Additives for Water Treatment

| System/Injection Point | Chemical | | Approximate Usage |
|--|--|---------------|---|
| Circulating Water System/ Cooling tower basin/ Station Water System | Biocide/Algaecide – Sodium Hypochlorite (15%) | 1200 gal/week | Normal Power Operating Conditions/ Shutdown Conditions |
| Circulating Water System/ Makeup water line discharge | Corrosion Inhibitor - Sodium Silicate | 400 gal/day | Normal Power Operating Conditions/ Shutdown Conditions |
| Circulating Water System / Makeup water line discharge | Scale Inhibitor/Dispersant | 220 gal/day | Normal Power Operating Conditions/ Shutdown Conditions |
| Circulating Water System blowdown | Dehalogenation – Sodium Bisulfite | 175 gal/day | Normal Power Operating Conditions/ Shutdown Conditions |

3.4 Cooling System

Fermi 3 requires cooling water for the normal power heat sink in the CIRC and the auxiliary heat sink in the PSWS. Thermal energy is transferred via air or water through these heat sinks. Major system components include the intake and discharge portions.

[Subsection 3.4.1](#) gives a description of the various cooling water systems and the operational modes for Fermi 3. The NPHS is discussed in this section, as well as in [Section 3.3](#) and [Subsection 5.3.2](#). Discharge to the air is also discussed in this section, as well as in [Subsection 5.3.3](#).

[Subsection 3.4.2](#) provides a description of the major components of the systems. Major components are contained within the intake structure and discharge piping. Further clarification of the intake structure is provided on [Figure 3.4-1](#) and [Figure 3.4-2](#). Additional discussion on the impacts of the discharge can be found in [Subsection 5.3.2](#) and [Subsection 5.3.3](#).

3.4.1 Description and Operational Modes

3.4.1.1 Circulating Water System

The CIRC provides cooling water during startup, normal plant operations, and hot shutdown for removal of power cycle heat from the main condensers and rejects this heat to the NPHS. The NPHS is comprised of a natural draft cooling tower. The main condensers contribute the majority of the heat to the NPHS with additional heat load introduced by the PSWS.

The main condenser rejects heat to the atmosphere at a rate of approximately 9.883×10^9 Btu/hr during normal full-power operation. Water from the NPHS basin is pumped through the main condenser and then back to the cooling tower where heat, transferred to the cooling water in the main condenser, is dissipated to the environment (the atmosphere) by evaporation.

As a result of the heat dissipation process, some water is evaporated. This results in an increase in the solids level in the NPHS cooling tower. To control solids levels or concentrations, a portion of the recirculated water is discharged. In addition to this blowdown from the CIRC, and evaporative losses, a small percentage of water in the form of droplets (drift) is lost from the cooling tower. Water pumped from Lake Erie via the intake structure is used to replace water lost by evaporation, drift and blowdown from the cooling tower. Blowdown water is returned to Lake Erie via an outfall into the lake ([Subsection 3.4.2](#)). A portion of the waste heat is thus dissipated to Lake Erie through the blowdown process.

The maximum, minimum and average Fermi 3 blowdown flow rates from the CIRC during normal full power operation are provided in [Figure 3.3-1](#). [Table 3.4-1](#) provides the monthly values for evaporation, blowdown, and makeup for the NPHS. The maximum temperature of the blowdown after passing through the NPHS is 86°F at the discharge to Lake Erie. The heat rejected to Lake Erie via blowdown is estimated based on these maximum blowdown flow and temperature conditions ([Subsection 5.3.2](#)). During other operating modes, heat dissipation to the environment is less than the bounding values for the normal full-power operational mode for the NPHS, except

when the Turbine Bypass System (TBS) is in operation. In this condition, it is possible for the temperature of the discharge to rise to 96°F.

3.4.1.2 Station Water System

The SWS draws water from Lake Erie through an intake bay into the pump house located on the west shore of Lake Erie. The SWS provides makeup water to various plant systems. For example, the SWS provides makeup water to the NPHS cooling tower basin for the CIRC and to the AHS cooling tower basin for the PSWS. The pump configuration consists of three 50 percent capacity Plant Cooling Tower Makeup System (PCTMS) pumps that supply makeup to the cooling towers, and two 100 percent capacity Pretreated Water Supply System (PWSS) pumps. The PWSS pumps are capable of supplying makeup to the FPS as well as the AHS in shutdown conditions. The PCTMS pump configuration allows for one pump to be out of service and the other two maintaining design flow. This is also discussed in [Subsection 3.4.2.1](#) and [FSAR Subsection 9.2.10](#). The AHS can be used in conjunction with the NPHS during normal power operation. However during certain shutdown conditions, heat rejection is performed entirely with the AHS. The AHS operates during startup, hot shutdown, stable shutdown, cold shutdown, and refueling.

3.4.1.3 Plant Service Water System

The PSWS provides cooling water to the Turbine Component Cooling Water System (TCCWS) heat exchangers and the Reactor Component Cooling Water System (RCCWS) heat exchangers and rejects the heat back to the NPHS and/or the AHS during normal power operations. During shutdown conditions, the heat is rejected to the AHS. Further discussion of the PSWS can be found in [FSAR Subsection 9.2.1](#). A simplified flow diagram is provided in [FSAR Figure 9.2-205](#). [Subsection 3.3.1.2](#) further discusses flows associated with PSWS, and [Figure 3.3-1](#) outlines flow paths and values for maximum, minimum and average normal power conditions and average shutdown conditions. Chemical treatment of the PSWS is discussed in [Subsection 3.3.2.3](#) and [Table 3.3-1](#).

3.4.1.4 Ultimate Heat Sink

The Fermi 3 ESBWR design has no separate emergency water cooling system. The UHS function is provided by safety systems integral and interior to the reactor plant. This system ultimately uses the atmosphere as the eventual heat sink. These systems do not have cooling towers, basins, or cooling water intake/discharge structures external to the reactor plant.

3.4.1.5 Discharges to Lake Erie

Lake Erie is subject to liquid discharges during plant operation. Discharge from the heat dissipation system consists of blowdown from the CIRC and PSWS, as well as optional treated liquid radwaste. The thermal aspect of the discharge is covered in this subsection. [Section 3.5](#) and [Section 3.6](#) complete the description of the discharge characteristics.

The rate of discharge into Lake Erie is constant under normal full power operating conditions. The discharge is approximately 17,000 gpm ([Figure 3.3-1](#)), with a maximum temperature of 86°F. [Table 3.4-1](#) contains a summary of the monthly discharge temperatures. A discussion of thermal plume predictions is contained in [Subsection 5.3.2](#). The discharge pipe is fortified with riprap to reduce

the effects of scouring; additional discussion of scouring can be found in [Subsection 5.3.2.1.2](#). The current NPDES permit for Fermi 2 (Permit No. MI0037028) was renewed in 2005 with an expiration date in 2009. As discussed in [Section 1.2](#), permits, e.g., NPDES permit and Section 401 Water Quality Certification, will be obtained for the discharge from Fermi 3. The discharge of chemicals that have been added to various systems as treatments such as biocide, corrosion inhibitor, and scale inhibitor are closely monitored in the NPDES permit, as well as the presence of metals and the temperature of effluent flow. [Section 3.6](#) provides discussion and comparison to regulatory limitations on effluent flow from Fermi 3.

3.4.1.6 Discharges to Air

At the normal full-power design condition, the natural draft tower requires a maximum of 5.6×10^7 cfm of ambient air to dissipate about 10.72×10^9 Btu/hr of waste heat from the natural draft cooling tower at Fermi 3. Heat dissipated by the natural draft cooling tower includes contributions from the main condenser and the PSWS system. The heat load used for determining parameters associated with the natural draft cooling tower is conservative relative to the design heat loads ([Reference 3.4-2](#)).

The cooling tower used at Fermi 3 provides the only plant effluents with a potential for influencing local meteorology. The effluent types of concern are commonly described as visible plumes (fog) and cooling tower drift. Cooling tower drift is limited to no greater than 0.001 percent of the total tower water flow. Drift eliminators exist as a design feature of the natural draft cooling tower meant to reduce the volume of drift from the tower. These effluent types and their impacts on local weather are described in [Subsection 5.3.3](#).

In addition to the heat discharged to the air, auditory discharges are considered. The noise from the NPHS is primarily the result of water splash. The sound level is estimated as being between 55 and 60 dBA at 1000 ft. [Subsection 5.3.4](#) also discusses the estimated noise levels from the NPHS operation. The noise generated by the AHS is from water splash and fan motors. The sound level for the AHS is estimated at between 55 and 60 dBA at 1000 ft. ([Reference 3.4-1](#))

3.4.1.7 Operational Modes

For the purposes of the design of the cooling systems, Fermi 3 is based on an estimated capacity factor of 96 percent (annualized). This considers a 24 month fuel cycle combined with an assumed 30-day refueling outage period. On a long term average, the heat load is 10.29×10^9 Btu/hr, which is 96 percent of the rated head load of 10.72×10^9 Btu/hr. There are six modes of plant operation; normal full-power operation, startup, hot shutdown, stable shutdown, cold shutdown and refueling. These can be generally grouped into two predominant modes, normal full power operation and shutdown operation. During normal full power operation, the NPHS, or a combination of the NPHS and the AHS, handle the heat dissipation to the atmosphere. Under normal full power operation, the heat load is rejected either entirely by the NPHS or by both the NPHS and the AHS. The AHS is capable of exchanging 2.98×10^8 Btu/hr. During shutdown operations, approximately 4 percent of plant operation annually, the AHS handles heat dissipation to the atmosphere.

3.4.2 Component Description

3.4.2.1 Intake System

The lake water intake and makeup water system is composed of two main parts: a wet pit pump house structure containing five vertical wet pit pumps, trash racks and traveling screens, and piping routed from the pump house structure to the cooling tower basin and the plant.

The SWS draws lake water via an intake bay ([Figure 3.4-1](#) and [Figure 3.4-2](#)) from Lake Erie. This inlet bay is formed by two rock groins that extend 600 ft into Lake Erie. The intake bay is periodically dredged to maintain appropriate operating conditions.

At the inlet to the pump house structure a trash rack is positioned which is equipped with a trash rake. Trash collected from the trash racks is disposed of. There are three dual flow traveling screens arranged side by side to further prevent debris from entering the pump house. Aquatic organisms are first washed from the traveling screens using low pressure water spray. The remaining trash is then removed using high pressure wash sprays. Strainers are in place at the pump discharge and strainer backwash is directed back to Lake Erie. Strainer backwash is controlled to ensure that the limits of the applicable NPDES permit are adhered to.

The SWS pumps take suction from an intake bay through the makeup water pump house. The three PCTMS pumps supply makeup water to the cooling tower basins. Each pump has capacity to supply 50 percent of the total flow requirements. Two pumps are normally operated and the third is reserved for standby operation. This ensures makeup flow can be delivered in the event that one pump is out of service. The two operating pumps are capable of delivering the maximum cooling tower makeup water requirement of approximately 34,000 gpm, ([Figure 3.3-1](#)). The two PWSS pumps supply makeup water to the FPS under normal power operating conditions. They are 100 percent capacity pumps capable of supplying the necessary makeup water to the AHS and FPS in shutdown conditions.

The velocity of the water flowing through the dual flow intake traveling screens is approximately 0.5 fps at record low lake water levels, and no more than 0.5 fps under all operating conditions, as required by Section 316(b) of the Clean Water Act. The mesh size on each traveling screen is $\frac{3}{8}$ -inch. Each screen is capable of handling approximately 20,000 gpm of flow. The flow is designed to be sufficiently low that fish are not caught or trapped against the traveling screens. Fish which have entered the intake bay to this point are free to return to the lake in the same way they came. The pump house intake structure is sized such that the formation of vortices or other abnormal flow conditions that would interfere with the operation of the pumps is minimized. If fouling occurs, the screens are cleaned by backwashing. The formation of frazil ice on the screens is prevented by the low intake flow rate and by recirculating warmed water that has been rerouted from the discharge. A profile view of the intake screens and pumps suction is shown on [Figure 3.4-2](#). This system is designed such that the intake structure has a minimal impact on the wildlife present in Lake Erie. This is consistent with good engineering design and environmental practices.

The addition of a biocide/algaecide, sodium hypochlorite, takes place as water enters the pump house structure. Once the water has passed through the trash rack and the traveling screens, a diffuser injects the biocide into the flow before the flow proceeds into the pump suction. Further chemical treatments are discussed in [Subsection 3.3.2](#).

The elevation reference in use at Fermi is NAVD88. The elevation of the bottom of the intake bay at the entrance to the pump house is 559 ft. The record low level of Lake Erie water is 563'-11" and the record high level is 576'-6". The elevation of the base of the bay at the location of the pump suction is 553 ft. This is more than 10 ft below the record low water level for Lake Erie, thus pump suction should not be a concern. Impacts to SWS pump suction due to seiche events are discussed in [Subsection 3.3.1](#).

3.4.2.2 Discharge System

Dilution and dissipation of the discharge heat as well as other effluent constituents are affected by both the design of the discharge and the flow characteristics of the receiving water, in this case Lake Erie. Normal plant effluent flow from all sources (cooling tower blowdown, and optional treated liquid radwaste) is approximately 17,000 gpm. The NPHS cooling tower blowdown is the major contributor to the total flow, and its maximum return temperature is estimated at 86°F and the average temperature is 68°F. [Table 3.4-1](#) contains the monthly discharge flow rates and the discharge temperatures (cold water temperature) to Lake Erie. [Figure 3.4-4](#) and [Figure 3.4-5](#) are used in the development of [Table 3.4-1](#). The temperature rise across the main condenser is 31.2°F.

The 4-ft diameter discharge pipe is located approximately 1300 ft into Lake Erie to avoid recirculation. Another consideration in the length of the discharge pipe was to preclude the discharge plume from intruding on environmentally sensitive onsite areas (such as wetlands) during wind-driven rises in Lake Erie water level (seiche events). The pipe is buried in the bank as it is routed into Lake Erie where the discharge is located, below the water surface, see [Figure 5.3-1](#). The pipe discharges through a diffuser, as described in [Subsection 5.3.2.1.1.1](#). The analysis of the thermal plume that results from the discharge is discussed in [Subsection 5.3.2.1](#). The analysis includes consideration of seiche events. As discussed in [Subsection 3.3.1](#) and [Subsection 5.3.2.1](#), due to potential for the water supply to the SWS to be degraded during extreme seiche events, the unit could be operationally controlled to limit makeup water requirements. These seiche events are relatively short-lived. As part of the operational controls in response to an extreme seiche event, the discharge could be reduced and or secured.

For a total discharge flow rate of approximately 17,000 gpm, the exit jet velocity is approximately 8.5 fps. The submerged jet mixes rapidly with the ambient lake water, accompanied by a reduction of momentum and kinetic energy through turbulent action. The environmental impact of discharged heat on Lake Erie is discussed in [Subsection 5.3.2](#). The use of cooling towers for Fermi 3 provides good engineering design and represents the best technology available under Phase I of Section 316(a) of the Clean Water Act and also acts to greatly reduce the thermal loading to Lake Erie. Discharges from the AHS are directed to the CIRC basin. As shown in [Figure 3.3-1](#), the discharge from the AHS is small in comparison to the NPHS discharge (less than 5 percent). When the

PSWS is operating without the CIRC operating, discharges from the AHS are controlled to ensure that the resultant thermal plume is bounded by the thermal plume from operating the NPHS.

3.4.2.3 Heat Dissipation System

The main source of heat dissipation is the NPHS. The NPHS is a natural draft cooling tower, as shown on [Figure 3.4-3](#). The AHS consists of two mechanical draft cooling towers. The AHS is further discussed in [FSAR Subsection 9.2.1](#).

Makeup flow to the NPHS cooling tower basin is supplied by the SWS through the intake structure located on Lake Erie. The NPHS is located approximately 2200 ft from the pump house intake structure. At the cooling tower basin, there are four CIRC pumps, each 25 percent capacity, which supply a total flow of 744,000 gpm. The flow is directed to the main condenser, and is then directed back to the cooling towers so that the heat can be rejected to the atmosphere. The cooling tower basin is located approximately 1100 ft from the main condenser.

The NPHS cooling tower discharges water to the basin, which receives makeup from Lake Erie. Intake water temperatures from Lake Erie can be seen in [Subsection 2.3.1](#), and meteorological data can be found in [Section 2.7](#). Cooling tower performance curves for wet bulb temperature and evaporation, as well as wet bulb and cold water temperature are seen on [Figure 3.4-4](#) and [Figure 3.4-5](#). The information in [Table 3.4-1](#) is developed using these cooling tower performance curves. The design of the heat dissipation system does not present any major departures from acceptable cooling system design practices, nor does it contain any additional components for consideration, beyond the NPHS in the form of a natural draft cooling tower. This system is consistent with good engineering practices.

The PSWS and AHS are discussed in [FSAR Section 9.2](#) and [FSAR Table 9.2-201](#).

3.4.3 References

- 3.4-1 Edison Electric Institute, "Electric Power Plant Environmental Noise Guide," New York, 1978.
- 3.4-2 GE-Hitachi Nuclear Energy, "ESBWR Design Control Document – Tier 2," Revision 6, August 2009.

Table 3.4-1 Monthly Cooling Tower Temperatures and Flows

| Month | Wet Bulb Temperature (°F) | Cold Water Temperature (°F) * | Evaporation Flow rate (gpm) | Drift Flow rate (gpm) | Blowdown Flow rate (gpm) | Makeup Flow rate (gpm) |
|-----------|------------------------------|----------------------------------|--------------------------------|--------------------------|-----------------------------|---------------------------|
| January | 23.7 | 53.8 | 11875 | 7.2 | 11867.8 | 23750 |
| February | 25.7 | 55.3 | 12200 | 7.2 | 12192.8 | 24400 |
| March | 32.3 | 59.4 | 13100 | 7.2 | 13092.8 | 26200 |
| April | 42.6 | 66 | 14300 | 7.2 | 14292.8 | 28600 |
| May | 52.7 | 72.7 | 15400 | 7.2 | 15392.8 | 30800 |
| June | 61.7 | 78.4 | 16300 | 7.2 | 16292.8 | 32600 |
| July | 65.9 | 81.5 | 16750 | 7.2 | 16742.8 | 33500 |
| August | 65 | 80.8 | 16700 | 7.2 | 16692.8 | 33400 |
| September | 58.1 | 76.3 | 16100 | 7.2 | 16092.8 | 32200 |
| October | 47 | 68.8 | 14800 | 7.2 | 14792.8 | 29600 |
| November | 37.5 | 62.7 | 13750 | 7.2 | 13742.8 | 27500 |
| December | 28 | 56.6 | 12500 | 7.2 | 12492.8 | 25000 |

* Cold Water temperatures are calculated based on ambient wet bulb temperatures, however the temperature of the discharge from the NPHS cooling tower basin will be maintained at 55°F or above.

Figure 3.4-1 Station Water Intake Structure




Figure 3.4-2 Station Water Intake Structure – Elevation View




Figure 3.4-3 NPHS Cooling Tower




Figure 3.4-4 Cooling Tower Performance Curve






Figure 3.4-5 Cooling Tower Evaporation Curves



Time: 19:30:54 Date: 11-26-2007 Drawn By: JDD

Figure 3.4-6 Outfall Diffuser Arrangement



3.6 Nonradioactive Waste Systems

The nonradioactive waste from Fermi 3 is discussed in this section. [Subsection 3.6.1](#) describes effluent wastes expected from the CIRC, PSWS, PWS, various drains within the plant, and other miscellaneous gaseous, liquid and solid effluents. The effluent from the SWDS is discussed in [Subsection 3.6.2](#). [Subsection 3.6.3](#) discusses other effluent streams from Fermi 3, including gaseous effluents, stormwater, various plant drains, and other waste.

3.6.1 Effluents Containing Chemicals or Biocides

This subsection discusses the CIRC, PSWS, PWS, and other chemically treated systems, and for completeness, the FPS. The flows associated with these systems are outlined on [Figure 3.3-1](#). Effluent flow from the Fermi site must remain within the limits outlined by the NPDES permit, or other appropriate limits as specified by the Michigan Department of Environmental Quality. As discussed in [Section 1.2](#), permits, e.g., NPDES permit and Section 401 Water Quality Certification, will be obtained for the discharge from Fermi 3.

There are four categories of water treatment chemicals: biocide, algacide, corrosion inhibitor, and scale inhibitor. Specific chemicals anticipated to be used are determined by site specific water conditions, based on a conservative determination. The amount of chemicals added per year in pounds is outlined in [Table 3.6-1](#). Effluent chemical constituents from Fermi 3 are shown in [Table 3.6-2](#). Values specified in the Fermi 2 NPDES permit include Total Suspended Solids (TSS) and Total Residual Chlorine (TRC). The TSS specified in the permit is 100 ppm as a daily maximum; the maximum concentration discharged from Fermi 3 ([Table 3.6-2](#)) is 15.9 ppm, well within acceptable permitting limits. The TRC specified in the NPDES permit is 38 ppb or less, the amount discharged from Fermi 3 is zero. The addition of sodium hypochlorite does introduce chlorine into the water; however the addition of sodium bisulfite nullifies the presence of the chlorine. Regardless of the water systems' sources or constituents, each constituent discharged to the environment would be limited (i.e., volume and concentration) by the NPDES permit as discussed in [Section 6.6](#).

The main body of water that receives effluent from Fermi 3 is Lake Erie. There is one discharge from Fermi 3 that includes the blowdown from the CIRC and PSWS, as well as optional treated liquid radwaste discharge. Effluent from these sources is in liquid form; no sludge disposal is necessary from these systems. The location and other details pertaining to this discharge into Lake Erie are discussed in [Subsection 3.4.2.2](#).

In addition to the liquid discharge paths, discharge of some chemical constituents will be entrained in the fallout from the spray from the CIRC and PSWS Cooling Towers. This effect is discussed in [Subsection 5.3.3.1](#).

The current status of the water quality in Lake Erie, as well as other water sources in proximity to the plant, is discussed in [Subsection 2.3.3](#). The ecology of Fermi 3 is discussed in [Section 2.4](#). Ecology is of particular importance due to the prevalence of zebra mussels in Lake Erie. They present an additional need for the use of biocides such as sodium hypochlorite.

3.6.1.1 Circulating Water System

The chemical treatment of the CIRC is discussed in [Subsection 3.3.2.2](#) and [Table 3.3-1](#). This system is treated with a biocide, algaecide, corrosion inhibitor, and scale inhibitor. The blowdown from the CIRC is also treated with dehalogenation. The effluent from the CIRC is discharged to Lake Erie, as described in [Subsection 3.4.2.2](#).

The CIRC operates on two cycles of concentration under normal full power operating conditions; additional operating parameters of the CIRC are discussed in [Subsection 3.4.1.1](#). Effluent chemical constituents discharged in the blowdown from the CIRC are shown in [Table 3.6-2](#).

3.6.1.2 Plant Service Water System

The chemical treatment of the PSWS is discussed in [Subsection 3.3.2.3](#) and [Table 3.3-1](#). This system is treated with a biocide, algaecide, corrosion inhibitor, and scale inhibitor. The effluent from the PSWS is discharged to Lake Erie. Chemical constituents discharged in the effluent from the PSWS are shown in [Table 3.6-2](#).

3.6.1.3 Potable Water System

The operation of the PWS is designed to supply water for domestic use and human consumption to Fermi 3. The source of the PWS is the Frenchtown Township Municipal Water System, and any chemicals present in the water are those added by the Frenchtown Township Water Treatment Facility. The water is treated to meet applicable drinking water standards; no additional onsite treatment is provided. The water is discharged to the SWDS which is routed offsite to the Frenchtown Township Sewage Treatment Facility.

3.6.1.4 Fire Protection System

The FPS receives no additional chemical treatment (makeup to the FPS is discussed in [Subsection 3.3.1.6](#)) and does not normally discharge any liquid effluent.

3.6.2 Sanitary System Effluents

This subsection discusses the sanitary waste systems effluent, including quantities and treatment of the waste products, during construction and operation of the plant.

Sanitary waste systems needed at Fermi 3 during construction activities include portable toilets supplied and serviced by an offsite vendor. There is no sanitary waste system discharge into the effluent stream.

Permanent SWDS components at Fermi 3 include waste basin, wet well, septic tank, settling tank, wet well pumps, sewage discharge pumps and associated valves, piping, and controls. The SWDS is discussed in [FSAR Subsection 9.2.4](#). The system is designed to accommodate 60 gallons/day/person for up to 840 people during normal power operation and 1140 people during shutdown operation. This design condition drives the flow values that are outlined on [Figure 3.3-1](#).

In addition to sanitary waste generated by domestic uses, the demineralized water waste and effluent from the auxiliary boiler are also routed to the SWDS.

The effluent of the SWDS is sewage that is pumped from the septic tank to the Frenchtown Township Sewage Treatment Facility for ultimate disposal. The SWDS does not come into contact with any systems that may contain radioactive waste; however measures are in place to ensure that no radioactive waste could be transmitted offsite. Since the effluent from the SWDS is routed to a waste treatment facility, and not discharged to the environment, it is not necessary for the effluent to meet NPDES permit requirements. It is, however, necessary to meet the limits outlined in the Industrial/Non-domestic User Discharge permit with the Frenchtown Township Sewage Treatment Facility. Chemical treatments applied to the waste are those within the Frenchtown Township Sewage Treatment Facility, in keeping with the municipal sewage treatment standards. Further discussion of the chemical treatment of the SWDS can be found in [Subsection 3.3.2.4](#).

3.6.3 Other Effluents

This subsection discusses miscellaneous solid, liquid and gaseous effluents not addressed in [Subsection 3.6.1](#) or [Subsection 3.6.2](#). Gaseous effluents consist of exhaust from diesel generators, diesel-driven fire pumps, and the auxiliary boiler system (Aux Boiler). Stormwater, various plant drains, and other wastes are also discussed in the following subsections.

3.6.3.1 Gaseous Effluents

There are four main sources of gaseous nonradioactive effluent at Fermi 3, the standby diesel generators (SDG), ancillary diesel generators (ADG), Aux Boiler, and the diesel-driven fire pumps. The applicable regulations, permits, and consultation required by Federal, State, regional, and potentially affected Native American tribal agencies are addressed in [Section 1.2](#). Proper maintenance and operating procedures, described in [FSAR Section 13.5](#), assure that emissions are controlled consistent with system design to meet the standards from [Section 1.2](#).

There are two 17.1 MW SDGs that are expected to operate approximately four hours per month for each engine. The proposed SDG for Fermi 3 will meet emission standards for owners and operators listed in 40 CFR 60.4205 at the time of purchase. Emission standards for stationary compression ignition internal combustion engines with a cylinder displacement greater than 30 liters per cylinder are displayed in [Table 3.6-3](#). The non-road diesel fuel used to operate the two SDGs will also be required by 40 CFR 80.510 to meet sulfur content levels of 15 ppm effective June 1, 2010.

There are two 1650 kW ADGs that are expected to operate for approximately two hours every three months, for an annual total of 8 hours of operation for each engine. The manufacturers of the ADGs proposed for Fermi 3 will be required to meet emission standards listed in Table 1 of 40 CFR 1039.101 at the time of purchase. Tier 4 emission standards for compression ignition internal combustion engines manufactured after the model year 2014 with a rating greater than 560 kW are displayed in [Table 3.6-4](#). The non-road diesel fuel used to operate the two ADGs will also be required by 40 CFR 80.510 to meet sulfur content levels of 15 ppm effective June 1, 2010.

Fermi 3 has one package Aux Boiler, rated at 50 tons of steam per hour (112 MBTU/hr or about 33 MW). The maximum expected operation on an annual basis is 30 days. Emissions are shown in [Table 3.6-5](#), based on ASTM D-975 No. 2 fuel oil ([Reference 3.6-1](#)).

The fourth source of emissions at Fermi 3 are the two diesel-driven fire pumps. Each pump is approximately 200 kW and is expected to operate approximately 48 hours annually. The manufacturers of diesel-driven fire pumps proposed for Fermi 3 will be required to meet emission standards listed in Table 4 to Subpart IIII of Part 60.4202(d) at the time of purchase. Emission standards for stationary compression ignition internal combustion engines that are fire pumps with a maximum engine rating of 200 kW manufactured after 2009 are displayed in [Table 3.6-6](#). The non-road diesel fuel used to operate the two fire pumps will also be required by 40 CFR 80.510 to meet sulfur content levels of 15 ppm effective on June 1, 2010.

In addition to the gaseous effluents emitted from the aforementioned combustion sources, a natural draft cooling tower (NDCT) and two 4-cell mechanical draft cooling towers (MDCT) will emit solid particulates. The emission estimates of particulate matter for particle sizes of 10 and 2.5 microns (PM₁₀ and PM_{2.5}) from the operation of the proposed NDCT and 4-cell MDCTs are displayed in [Table 3.6-7](#) along with design parameters that were used to derive the emission estimates. It is conservatively assumed that the PM_{2.5} emissions are the same as the PM₁₀ emissions from the cooling towers. The drift rates for the NDCT and 4-cell MDCTs are based on the values provided by the associated manufacturers of each cooling tower. The water flow rate to the NDCT, as specified in [Figure 3.3-1](#), will be supplied at a maximum rate of 724,000 gallons per minute (gpm). The water from the basin of the NDCT will supply the makeup water to the 4-cell MDCTs at a maximum flow rate of 40,000 gpm. [Section 5.3.3.1](#) states that the makeup water for the NDCT is expected to have a total dissolved solids (TDS) concentration of 420 parts per million (ppm) or 0.00042 grams of salt per gram of solution. The makeup water for the 4-cell MDCTs will be supplied from the NDCT basin; therefore, the TDS concentration for the 4-cell MDCTs is also expected to be 420 ppm. The emission rate (lb/hr) for particulates emitted from the cooling towers can be calculated by taking the product of the water flow rate, weight of one gallon of water, drift rate, and TDS concentration.

For the purpose of providing a maximum bounded value for the emissions of particulates from the cooling towers, the calculations in [Table 3.6-7](#) were developed for the operation of both the NDCT and 4-cell MDCTs simultaneously for an entire year at the maximum water flow rate. While this likely overestimates the emissions of PM₁₀ and PM_{2.5} from the operation of the NDCT and 4-cell MDCTs, it provides a maximum value for the assessment of impacts from the operation of the cooling towers. Therefore, the maximum hourly and annual emissions of PM₁₀ and PM_{2.5} from the simultaneous operation of the NDCT and 4-cell MDCTs are expected to be 1.93 lb/hr and 8.47 tons/year, respectively.

Stationary combustion sources proposed for the operation of Fermi 3 will emit carbon dioxide (CO₂). The following provides the estimated CO₂ emissions and calculation methodology for the proposed standby diesel generators, ancillary diesel generators, diesel-driven fire pumps, and auxiliary boiler.

Standby and Ancillary Diesel Generators and Diesel-Driven Fire Pumps

In order to estimate the annual emissions of CO₂ for the proposed standby diesel generators, ancillary diesel generators, and diesel-driven fire pumps, emission factors were obtained from Tables 3.3-1 and Table 3.4-1 of [Reference 3.6-2](#). The total annual emissions of CO₂ emitted from

the standby diesel generators, ancillary diesel generators, and diesel-driven fire pumps is calculated by taking the product of the emission factor, number of units, annual operating hours, and engine power rating.

Auxiliary Boiler

The estimated annual emissions of CO₂ from the proposed auxiliary boiler is calculated by taking the product of the emission factor, heat input, and the annual operating hours. The CO₂ emission factor for the auxiliary boiler is 22,300 lb/10³ gal as displayed in Table 1.3-12 of [Reference 3.6-2](#). Dividing the emission factor (22,300 lb/10³ gal) by the heating value of fuel oil (140 MBtu/10³ gal), the emission factor becomes 159.29 lb/MBtu. The heat input of the boiler is 112 MBtu/hr.

[Table 3.6-6-\(A\)](#) provides the emission rates and estimated annual emissions of CO₂ for each stationary source proposed for Fermi 3. Therefore, the estimated annual emission of CO₂ from stationary sources during the operation of Fermi 3 is 7,734 tons per year.

3.6.3.2 Stormwater

Stormwater, specifically flood and probable maximum flood (PMF) are discussed in [FSAR Subsection 2.4.2](#) and [FSAR Subsection 2.4.3](#). Stormwater from the Fermi 3 site drains to the North and South Lagoons, which are located north and south of the site respectively. Stormwater construction and operational impacts are discussed in [Chapter 4](#) and [Chapter 5](#).

3.6.3.3 Various Plant Drains

There are several drains at Fermi 3 including: equipment drains, floor drains, laundry and chemical drains, and other miscellaneous periodic drains. These drains are treated and the treated effluent joins the discharge from the CIRC and PSWS to be discharged to Lake Erie. Waste from the various plant drains that cannot be treated for onsite discharge are routed for handling as hazardous waste.

3.6.3.4 Other Waste

Low level mixed waste (LLMW) contains hazardous waste and a low-level radioactive source, special nuclear, or byproduct material. Hazardous waste is not necessarily LLMW; LLMW only includes hazardous waste that has been exposed to radioactive contamination. [Section 5.5](#) provides a more detailed discussion of the environmental impacts that could result from the operation of the non-radioactive waste systems and the storage and disposal of mixed wastes.

A summary of the hazardous waste generated at Fermi 2 for several years is shown in [Table 3.6-8](#). Some examples of LLMW generated at Fermi 2 include:

- Industrial oils and laboratory waste
- Rags/wipes
- Lead products
- Mercury products

Federal regulations governing generation, management, handling, storage, treatment, disposal and protection requirements concerning LLMW are contained in 10 CFR 10 and 10 CFR 40. Additional discussion of guidelines and standards pertaining to waste disposal is found in [Section 1.2](#). Treatment of LLMW from Fermi 3 is handled in a similar manner as that of Fermi 2, with eventual offsite transportation and disposal by properly licensed organizations. Fermi 2 is a Small Quantity Generator, as Fermi 3 will likely be. Further discussion of LLMW is provided in [Section 5.5](#).

Universal waste is also disposed of properly at Fermi 3. Universal waste includes:

- Batteries
- Light bulbs
- Computer monitors and equipment

Handling of universal waste is done in accordance with State of Michigan regulations, with eventual offsite disposal by a properly permitted organization. Additional discussion of guidelines and standards pertaining to waste disposal is found in [Section 1.2](#). When possible, materials are recycled with the proper facilities.

Fermi 2 practices recycling when possible; Fermi 3 also recycles. Examples of items recycled from the Fermi site include:

- Batteries
- Circuit Boards
- Recyclable lead

Used oil is also recycled. The used oil program in use at Fermi 2 will be similarly implemented with Fermi 3. In this program the used oil from site is sent to St. Clair power station for power generation.

In addition to mixed waste and universal waste, another form of waste that must be handled at Fermi 3 is the waste that is disposed of from trash racks and traveling water screens. The trash racks and traveling water screens of the SWS pumps are discussed in [Subsection 3.4.2.1](#). Once the racks and screens are cleaned and the trash is present in the trash cart or trash basket, it is necessary to dispose of the waste. This waste is disposed of offsite.

3.6.4 References

- 3.6-1 "Standard Specification for Diesel Fuel Oils," ASTM D 975, American Society of Testing and Materials, Philadelphia, PA, 2007.
- 3.6-2 U.S. Environmental Protection Agency (USEPA), "Compilation of Air Pollutant Emission Factors (AP-42)," Fifth Edition, Vol. I., Tables 1.3-1, 1.3-12, 3.3-1, and 3.4-1, October 1996.

Table 3.6-1 Chemicals Added to Liquid Effluent Streams

| System | Chemical | Maximum Amount | Average Amount | Frequency of Use | Concentration in Waste Streams |
|-----------|---|-------------------|-------------------|-----------------------------|---|
| CIRC/ SWS | Biocide/Algaecide - Sodium Hypochlorite (15%) | 620,000 lb/year | 620,000 lb/year | Approximately 4.5 hour/week | Non-detectable, neutralized by sodium bisulfite TRC < 38ppb* |
| CIRC | Corrosion Inhibitor – Sodium Silicate | 1,700,000 lb/year | 1,400,000 lb/year | Continuous | Non-detectable, dissociates in system |
| CIRC | Scale Inhibitor/Dispersant | 830,000 lb/year | 700,000 lb/year | Continuous | Non-detectable, dissociates in system |
| CIRC | Dehalogenation – Sodium Bisulfite | 650,000 lb/year | 550,000 lb/year | Continuous | Non-detectable, neutralizes sodium hypochlorite |

*Fermi 2 NPDES permit


Table 3.6-2 Effluent Chemical Constituents*

| Ion/Chemical | As | Max Conc. (ppm) | Avg Conc. (ppm) |
|-------------------------------|-------------------|-----------------|-----------------|
| Sodium | Na | 46.6 | 34.3 |
| Calcium | Ca | 71.9 | 71.9 |
| Magnesium | Mg | 17.4 | 17.4 |
| Silica | SiO ₂ | 19.9 | 19.5 |
| Chloride | Cl | 61.3 | 42.5 |
| Sulphate | SO ₄ | 38.5 | 38.5 |
| Potassium | K | 3.6 | 3.6 |
| Scale Inhibitor/Dispersant | Chemical | 11.6 | 11.6 |
| Bicarbonate Alk. | CaCO ₃ | 167.8 | 167.7 |
| TDS | - | 428.5 | 397.4 |
| TSS | - | 16.0 | 16.0 |

*Based on 2 cycles of concentration

Section I.C.11 – Map of Facility

Figure 2.1-4, Fermi 3 Environmental Report, Rev. 2
(following 1 page)



| FACILITY LEGEND | |
|-----------------|---|
| 01 | REACTOR BUILDING |
| 02 | AUXILIARY BLOWER |
| 03 | TURBINE BUILDING |
| 04 | CONTROL ROOM |
| 05 | ELECTRICAL BLDG/TECH SUPPORT CENTER |
| 06 | MAIN TRANSFORMERS |
| 07 | UNIT AUXILIARY TRANSFORMER |
| 08 | RESERVE AUXILIARY TRANSFORMER |
| 09 | SPARE TRANSFORMER |
| 10 | ADB |
| 11 | RADWASTE BUILDING |
| 12 | FUEL BUILDING |
| 13 | DIESEL FUEL OIL STORAGE TANK |
| 14 | WATER TREATMENT/SERVICE WATER BLDG |
| 15 | NOT USED |
| 16 | SERVICE WATER COOLING TOWER |
| 17 | FIRE WATER TANK AND PUMPS |
| 18 | WATER STORAGE TANKS |
| 19 | CONDENSATE STORAGE TANKS |
| 20 | SERVICE BUILDING/OPERATION SUPPORT CENTER |
| 21 | HOT MACHINE SHOP AND STORAGE |
| 22 | WASH DOWN BAYS |
| 23 | NPHD COOLING TOWER |
| 24 | PUMPHOUSE |
| 25 | SECURITY BOUNDARY |
| 26 | STATION WATER INTAKE |
| 27 | CRIC WATER OUTFALL |
| 28 | EF3 SWITCHYARD |
| 29 | EF2/EF3 ADMIN BUILDING |
| 30 | EF3 SIMULATOR |
| 31 | PARKING GARAGE |
| 32 | EF2/EF3 HAZARDOUS WASTE WAREHOUSE |
| 33 | BARGE SLIP |
| 34 | RAD MATERIAL WAREHOUSE |
| 35 | EF2/EF3 MAINTENANCE SHOPS |
| 36 | NOT USED |
| 37 | EF2/EF3 COMMON WAREHOUSE |
| 38 | PARKING GARAGE AND EPS SHOPS |
| 39 | FERMI 2 ISFSI |
| 40 | PAP/VIS |

5560 Corporate Exchange Court SE
Grand Rapids, MI 49512

Laboratory Phone

6169754500

Laboratory Email

ricejl@trimatrixlabs.com

Analysis Performed

See Additional Information section - Attached analysis from Fermi 2 Plt NPDES Application (3-31-14)

13. LIST ADJACENT PROPERTY OWNERS

List the names and mailing addresses of all property owners for all properties adjacent to the facility, treatment systems, and discharge locations. For vacant lots or empty buildings, supply the owner's mailing address – NOT the lot or building property address.

Table Data

| Business or Lake Board / Lake Association (if applicable) | Individual Property Owner or Business Contact | Address | City | State | ZIP Code | Country |
|--|---|---------------------------------|---------------|-------|------------|---------|
| | MASSERANT ROBERT D & LISA S | 5645 TROMBLEY | NEWPORT | MI | 48166 | USA |
| | PARKER ORVAL | 5121 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| | NOTHNAGEL DARLIN EDWARD | 4704 ST CLAIR ST | NEWPORT | MI | 48166 | USA |
| | MCCARTY GORDON M | 5194 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| MICHIGAN LAND CONTRACT VENDOR | HUDICK MARY LOU | P O BOX 351 | NEWPORT | MI | 48166 | USA |
| | VEY MATTHEW & PLUFF ASHLYN FAYE | 5182 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| | ELLISON MICHAEL & LAURIE | 4702 LONG | NEWPORT | MI | 48166 | USA |
| CITY OF MONROE WATER WORKS | | 120 E FIRST | MONROE | MI | 48161 | USA |
| LYON SAND & GRAVEL COMPANY | | 8800 DIX AVE | DETROIT | MI | 48209 | USA |
| | HOLMES JIMMY & REBECCA | 6200 LANGTON | NEWPORT | MI | 48166 | USA |
| UNITED STATES OF AMERICA AND IT'S ASSIGNS, WASHINGTON D C | | 5600 AMERICAN BLVD WEST STE 990 | BLOOMINGTON | MN | 55437-1458 | USA |
| INTERNATIONAL TRANSMISSION CO ITC TRANSMISSION 0/0 TAX DEPT | | 27175 ENERGY WAY | NOVI | MI | 48377 | USA |
| UNITED STATES FISH & WILDLIFE SERV BISHOP HENRY WHIPPLE FED BLDG | C/O LOIS A LAWSON | 1 FEDERAL DRIVE | FORT SMELLING | MN | 55111-4056 | USA |
| MICHIGAN NATURE ASSOCIATION | | 2310 SCIENCE PARKWAY, SUITE 100 | OKEMOS | MI | 48864 | USA |
| | MASSERANT RANDY | 6001 TOLL | NEWPORT | MI | 48166 | USA |
| | BARCZEWSKI JAMIE DON | 5701 TOLL | NEWPORT | MI | 48166 | USA |

| | | | | | | |
|---|-------------------------------------|-----------------------|---------|----|------------|-----|
| | YOUNG DAVID & DEBRA | 4957 RAYMOND | NEWPORT | MI | 48166 | USA |
| | CHILDRESS CHARLES & BARBARA | 6170 LEROUX | NEWPORT | MI | 48166 | USA |
| DEWEYS STONY POINT ASSOC INC | | P O BOX 66272 | NEWPORT | MI | 48166 | USA |
| SQUIER BETH E ESTATE | C/O DONALD SQUIER | 5820 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| | STERLING DAVID L | 5838 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| | MCDEVITT KAY | 2682 NADEAU RD | NEWPORT | MI | 48162 | USA |
| CAPITAL ONE N A | | 7933 PRESTON RD | PLANO | TX | 75024 | USA |
| | BOERNER LAUREN & KELLY | 5884 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| | RORKE MICHAEL JAMES JR | 5908 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| | GONZALEZ MARIA D & GONZALEZ SHIRLEY | 3276 CHIPPEWA | MONROE | MI | 48162 | USA |
| | WRIGHT JUSTIN C | 5944 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| | QASSIS JULIET | 37119 MUIRFIELD DRIVE | LIVONIA | MI | 48152 | USA |
| | BONDY ERIC & ROBIN | 6211 HIGHLAND | NEWPORT | MI | 48166 | USA |
| | DRUMMONDS PATRICIA | 6148 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| | MAMAU MICHELLE ANN | 4720 LONG | NEWPORT | MI | 48166 | USA |
| | C/O: JOHN J QUALEY | 4730 LONG | NEWPORT | MI | 48166 | USA |
| | DIEHL JOHN H & DEBORAH L | 4772 LONG | NEWPORT | MI | 48166 | USA |
| | LIEDEL THOMAS D & ANNA L | 4802 LONG | NEWPORT | MI | 48166 | USA |
| | SERES LONNY & LINDA | 4834 LONG | NEWPORT | MI | 48166 | USA |
| MONROE FRENCHTOWN RAW WATER SUPPLY CO-PARTNERSHIP | | 120 E FIRST ST | MONROE | MI | 48161 | USA |
| LONG EST SUMMER RESORT ASSOC | C/O TREASURER | 4720 LONG | NEWPORT | MI | 48166 | USA |
| | MCLAUGHLIN MICHAEL & BRIDGET | 6108 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| | CARTWRIGHT ROBERT & VALERIE | 6098 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| | C/O LOWELL & SHELLY YOAS | 6900 WILLIAMS | NEWPORT | MI | 48166 | USA |
| | FLIPPIN TODD D & DIANA | 9147 DOLD DRIVE | FINDLAY | OH | 45840-1684 | USA |
| | OLIVER ROXANNE D | 3938 LAKESHORE | NEWPORT | MI | 48166 | USA |
| | BODENMILLER EDWARD J | 4771 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |

| | | | | | | |
|---|------------------------------|--------------------------|---------|----|-------|-----|
| FRENCHTOWN CHARTER TOWNSHIP FIRE HALL #4 | | 2744 VIVIAN | MONROE | MI | 48162 | USA |
| LANGTON VALARIAN (LL) LIFE LEASE ESTATE HOLDER | | 6445 LEROUX | NEWPORT | MI | 48166 | USA |
| FIX FAMILY FARM LLC | C/O MICHAEL S FIX | 6394 LEROUX | NEWPORT | MI | 48166 | USA |
| | BASIC APRELL | 5928 POINTE AUX PEAUX | NEWPORT | MI | 48166 | USA |
| MICHIGAN DEPT OF NATURAL RESOURCES | MICHIGAN DEPT OF TREASURY | PO BOX 30722 | LANSING | MI | 48909 | USA |
| | MADISH JON W & KAREN E | 6394 STERLING | NEWPORT | MI | 48166 | USA |

This completes Section I.

Section IIIA. Facility Information – Industrial / Commercial Facilities (1)

A. Facility Information

1. BUSINESS INFORMATION

A. Provide up to four Standard Industrial Classification (SIC) or North American Industry Classification System (NAICS) codes, in order of economic importance, which best describe the major products or services provided by this facility

4911

Appendix to the Permit Application

B. Indicate if this facility is a primary industry (refer to Table 1 of the Appendix to determine if this facility is a primary industry).

Yes, this facility is a primary industry. Indicate the primary industry (see Table 1 of the Appendix)

Indicate the primary industry (see Table 1 of the Appendix):

Steam Electric Power

2. Water Sources

A. Identify all water sources entering the facility and treatment systems, and provide average flows. The volume may be estimated from water supply meter readings, pump capacities, etc. Provide the name of the source where appropriate (i.e., Grand River, Lake Michigan, City of, Millpond).

Table Data

| Water Supply Type | Name and Location of Source | Average Volume or Flow Rate | Units |
|----------------------|-----------------------------|-----------------------------|-------|
| Municipal Supply | Frenchtown Township | 0.52 | MGD |
| Surface Water Intake | Lake Erie | 50 | MGD |
| Private Well | | | |

Other

Precipitation

5

MGD/event

3. Discharge Types

B. Identify water discharged by the facility and treatment systems, and provide average flows. If water is first used for one purpose and then is subsequently used for another purpose, indicate the type and amount of the last use. For example, if water is initially used for noncontact cooling water and then for process water, indicate the amount of process water. The amount of water from sources should approximate the amount of water usage. If the amounts are different, provide an explanation. Enter the information in excel.

Table Data

| Type | Average Flow Rate | Units |
|--------------------------|-------------------|-------|
| Process Wastewater | 9,125 | MGY |
| Contact Cooling Water | None | |
| Noncontact Cooling Water | None | |
| Groundwater Cleanup | None | |
| Sanitary Wastewater | 365,000 | GPD |
| Regulated Storm Water | 2.6 | MGD |
| High Pressure Test Water | None | |
| Other | None | |

Note: For A. and B. above, indicate units as MGD (million gallons per day), MGY (million gallons per year), GPD (gallons per day), or other appropriate unit.

Section IIIB. Outfall Information – Industrial / Commercial Facilities (1)

Use the "+" (repeat section) button on the top of the page for each outfall present.

A. Receiving Water

Lake Erie

Feature Type

Outfall

Outfall Number or ID

001

Outfall Description

DECO-Fermi 3 Power Plt

Outfall Location

41.9608,-83.2619

1. OUTFALL INFORMATION.

Instructions for this item are on Page 3 of the Appendix. Use the "+" button on the top of this section to repeat this section and add additional outfalls.

[Appendix to the Permit Application](#)

B. Hydrologic Unit Code

04100001

Type of Wastewater Discharged (check all that apply to this outfall):

Process Wastewater

Storm Water - regulated

E. Comment: identify the storm water effluent guideline category or describe the wastewaters included in the 'other' category selected above.
NONE PROVIDED

F. The Maximum Design Flow Rate for this outfall is (MGD)

25

G. What is the Maximum Authorized Daily Discharge Flow for this outfall for the next five years? (Seasonal dischargers should enter flow using MGY and continue to Item H.; continuous discharges should enter flow using MGD and continue to Item I.)

25

H. Seasonal Discharge

List the discharge periods by month and the volume discharged using the excel template below. Then enter the Actual Annual Total volume discharged in the field below.

Table Data

NONE PROVIDED

Actual Annual Total

NONE PROVIDED

I. Continuous Discharge

How often is there a discharge from this outfall (on average)? Hours/Day

24

How often is there a discharge from this outfall (on average)? Days/Year

365

Batch dischargers are required to provide the following additional information. Is there effluent flow equalization?

What is the batch peak flow rate?

NONE PROVIDED

How many batches are discharged per day?

NONE PROVIDED

Batch Discharge Volumes and Duration

Enter the information into excel.

Table Data

NONE PROVIDED

2. PROCESS STREAMS CONTRIBUTING TO OUTFALL DISCHARGE

The information requested below is used to determine the applicable federal regulations for this facility. For each industrial process at the facility, provide the name, the SIC or the NAICS code, and a brief description of the process. As part of each description, identify a reasonable measure of the facility's actual long-term daily production and average number of production days per year. In many cases, this is the average daily or average annual production rate from the last five years. Some federal regulations require that certain industries report different information, depending on the type of process. The Summary of

Information to Be Reported by Industry Type, pages 10-11 of the Appendix, includes an abbreviated list of industrial categories and their specific Application requirements. If the industrial process does not have specific Application requirements and recent long-term production rates are not an appropriate measure of future production, report the expected annual production rate for the next five (5) years, or for the life of the permit.

[Appendix to the Permit Application](#)

PROCESS STREAMS CONTRIBUTING TO OUTFALL DISCHARGE

Enter the information into excel.

Table Data

| Name of the process contributing to the discharge | SIC or NAICS code | Describe the process and provide measures of production |
|---|-------------------|--|
| Closed-cycle Cooling System Blowdown | 4911 | Blowdown from the plant's closed-cycle condenser cooling system cooling tower blowdown. Maximum total expected discharge = 25 MGD. |
| Processed Radwaste System Discharge | 4911 | Process radwaste from the plant floor drafins and equipment drains. Maximum expected discharge (included in total above) = 0.2 MGD |

[Appendix to the Permit Application](#)

3. EFFLUENT CHARACTERISTICS - CONVENTIONAL POLLUTANTS. Instructions for this item are on Page 4 of the Appendix.

Check this box if additional information is included as an attachment.

Please Note: Rule 323.1062 allows the use of either Escherichia coli or Fecal Coliform Bacteria as an indicator that effluent has been disinfected. The DEQ will use the indicator selected below in the permit issued based on this Application.

NONE PROVIDED

3. EFFLUENT CHARACTERISTICS - CONVENTIONAL POLLUTANTS

Enter the information into excel.

Table Data

| Submitted via e-DMRs | Waiver Request and the Rationale Behind the Request | Parameter | Maximum Monthly Concentration | Maximum Daily Concentration | Units | Number of Analyses | Sample Type |
|----------------------|---|---|-------------------------------|-----------------------------|-------|--------------------|-------------------|
| | | Biochemical Oxygen Demand – five day (BOD5) | | | mg/l | | Grab / 24-Hr Comp |
| | | Chemical Oxygen Demand (COD) | | | mg/l | | Grab / 24-Hr Comp |
| | | Total Organic Carbon (TOC) | | | mg/l | | Grab / 24-Hr Comp |
| | | Ammonia Nitrogen (as N) | | | mg/l | | Grab / 24-Hr Comp |
| | | Total Suspended Solids | | | mg/l | | Grab / 24-Hr Comp |
| | Waiver Request Not Required | Total Dissolved Solids | | | mg/l | | Grab / 24-Hr Comp |

| | | | | | | | |
|---|---------------------------------------|---|------------|---------------|----------------|--|-------------------|
| | Waiver Request Not Required | Total Phosphorus (as P) | | | mg/l | | Grab / 24-Hr Comp |
| | Waiver Request Not Required | Fecal Coliform Bacteria (report geometric means) | | Maximum 7-day | counts/100ml | | Grab |
| | Waiver Request Not Required | Escherichia coli (report geometric means) | | Maximum 7-day | counts/100 ml | | Grab |
| X | Waiver Request Not Required | Total Residual Chlorine | | | mg/l or mg/l | | Grab |
| | Waiver Request Not Required | Dissolved Oxygen | Do Not Use | Minimum Daily | mg/l | | Grab |
| X | (See Fermi 2 DMRs - Permit MI0037028) | pH (report maximum and minimum of individual samples) | Minimum | Maximum | standard units | | Grab |
| X | | Temperature, Summer | | | °F °C | | Grab |
| X | | Temperature, Winter | | | °F °C | | Grab |
| | Waiver Request Not Required | Oil & Grease | | | mg/l | | Grab |

Note: For the following questions, Tables 1 – 6 are located in the Appendix.

Appendix to the Permit Application

4. PRIMARY INDUSTRY PRIORITY POLLUTANT INFORMATION

Existing primary industries that discharge process wastewater are required to submit the results of at least one permittee-collected effluent analysis for selected organic pollutants identified in Table 2 (as determined from Table 1, Testing Requirements for Organic Toxic Pollutants by Industrial Category), and all of the pollutants identified in Table 3. Existing primary industries are required to also provide the results of at least one permittee-collected effluent analysis for any other chemical listed in Table 2 known or believed to be present in the facility's effluent. In addition, submit the results of all other effluent analyses performed within the last three years for any chemical listed in Tables 2 and 3. New primary industries that propose to discharge process wastewater are required to provide an estimated effluent concentration for any chemical listed in Tables 2 and 3 expected to be present in the facility's effluent.

5. DIOXIN AND FURAN CONGENER INFORMATION

Existing industries that use or manufacture 2,3,5-trichlorophenoxy acetic acid (2,4,5-T); 2-(2,3,5-trichlorophenoxy) propanoic acid, (Silvex, 2,3,5-TP); 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate (Erbon); 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothionate (Ronnel); 2,4,5-trichlorophenol (TCP); or hexachlorophrene (HCP), or knows or has reason to believe that 2,3,7,8-Tetrachlorodibenzo-p-dioxin (TCDD) is present in the facility's effluent, are required to submit the results of at least one effluent analysis for the dioxin and furan congeners listed in Table 6. All effluent analyses for dioxin and furan congeners shall be conducted using USEPA Method 1613. In addition, submit the results of all other effluent analyses performed within the last three (3) years for any dioxin and furan congener listed in Table 6. New industries that expect to use or manufacture 2,3,5-trichlorophenoxy acetic acid (2,4,5-T); 2-(2,3,5-trichlorophenoxy) propanoic acid (Silvex, 2,3,5-TP); 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate (Erbon); 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothionate (Ronnel); 2,4,5-trichlorophenol (TCP); or hexachlorophrene (HCP), or knows or has reason to believe that 2,3,7,8-Tetrachlorodibenzo-p-dioxin (TCDD) is present in the facility's effluent, shall provide estimated effluent concentrations for the dioxin and furan congeners listed in Table 6.

6. OTHER INDUSTRY PRIORITY POLLUTANT INFORMATION

Existing secondary industries or existing primary industries that discharge nonprocess wastewater are required to submit the results of at least one effluent analysis for any chemical listed in Tables 2 and 3 known or believed to be present in the facility's effluent. In addition, submit the results of all other effluent analyses performed within the last three years for any chemical listed in Tables 2 and 3. New secondary industries or new primary industries that propose to

discharge nonprocess wastewater are required to provide an estimated effluent concentration for any chemical listed in Tables 2 and 3 expected to be present in the facility's effluent.

7. ADDITIONAL TOXIC AND OTHER POLLUTANT INFORMATION

All existing industries, regardless of discharge type, are required to provide the results of at least one analysis for any chemical listed in Table 4 known or believed to be present in the facility's effluent, and a measured or estimated effluent concentration for any chemical listed in Table 5 known or believed to be present in the facility's effluent. In addition, submit the results of any effluent analysis performed within the last three years for any chemical listed in Tables 4 and 5. New industries, regardless of discharge type, are required to provide an estimated effluent concentration for any chemical listed in Tables 4 and 5 expected to be present in the facility's effluent.

8. INJURIOUS CHEMICALS NOT PREVIOUSLY REPORTED

New or existing industries, regardless of discharge type, are required to provide a measured or estimated effluent concentration for any toxic or otherwise injurious chemicals known or believed to be present in the facility's effluent that have not been previously identified in this Application. Quantitative effluent data for these chemicals that is less than five years old shall be reported.

NOTE: All effluent data submitted in response to questions 4, 5, 6, 7, and 8 above should be recorded using the excel spreadsheet below. If the effluent concentrations are estimated, place an "E" in the "Analytical Method" column. The following fields shall be completed for each data row: Parameter, CAS No., Concentration(s), Sample Type, and Analytical Method. For analytical test requirements, or if Alternate Test Procedures were approved for any parameter listed above, see Item 5 of the General Provisions section preceding the Application for additional instruction.

[Appendix to the Permit Application](#)

9. WATER TREATMENT ADDITIVES

Water treatment additives (WTAs) include any material that is added to water used at the facility or to wastewater generated by the facility to condition or treat the water. Examples of WTAs include biocides, flocculants, water conditioners, pH adjusting agents, etc. WTA approvals are authorized by the DEQ under separate correspondence. The issuance of an NPDES permit does not constitute approval to use and discharge the WTAs for which approval is requested as part of this Application.

A. Are any WTAs added to water used at the facility or to wastewater generated by the facility?

Yes. Proceed to Item 9.B.

B. Have these WTAs been previously approved by the DEQ?

No. Continue to 9.C.

If you answered yes to the previous question. - Attachment(s)

NONE PROVIDED

Comment: NONE PROVIDED

C. Submit a list of WTAs that are or may be discharged from the facility. A request to discharge WTAs shall include all of the following usage and discharge information for each WTA proposed to be discharged:

1. Safety Data Sheet (formerly known as Material Safety Data Sheet), AND product label if the product is a pesticide; 2. the proposed WTA discharge concentration with supporting calculations; 3. the discharge frequency (i.e., number of hours per day and number of days per year); 4. the outfall and monitoring point from which the product is to be discharged; 5. the type of removal treatment, if any, that the WTA receives prior to discharge; 6. the product's function (e.g., microbiocide, flocculant, etc.); 7. a 48-hour LC50 or EC50 for a North American freshwater planktonic crustacean (either *Ceriodaphnia* sp., *Daphnia* sp., or *Simocephalus* sp.); and 8. the results of a toxicity test for one (1) other North American freshwater aquatic species (other than a planktonic crustacean) that meets a minimum requirement of R 323.1057(2)(a) of the Water Quality Standards. Examples of tests that would meet this requirement include a 96-hour LC50 for rainbow trout, bluegill, or fathead minnow.

List

- 1) Biocide/Algaecide - Sodium Hypochlorite (15%)
- 2) Corrosion Inhibitor - Sodium Silicate
- 3) Scale Inhibitor/Dispersant
- 4) Dehalogenation - Sodium Bisulfite

Note: WTA requests will be made prior to using the chemicals listed above.

Appendix to the Permit Application

10. WHOLE EFFLUENT TOXICITY (WET) TESTS. Have any acute or chronic WET tests been conducted on any discharge(s) or receiving water(s) in relation to this facility's discharge within the last three (3) years? If yes, identify the tests and report the results on the forms provided in the Appendix for WET test reporting, unless the test results have been previously submitted to the DEQ within the last three (3) years. Comments: NA

Effluent Data

Enter the information into excel.

Table Data

| | | | | | | | | |
|--|-----------|---------|--------------|--------------|--------------|--------------|-------------|-------------------|
| Outfall Number / ID: 001 | | | Sample Date | Sample Date | Sample Date | Sample Date | | |
| Submitted via e-DMRs? | | | | | | | | |
| (Yes/No) | PARAMETER | CAS No. | Conc. (µg/l) | Conc. (µg/l) | Conc. (µg/l) | Conc. (µg/l) | Sample Type | Analytical Method |
| See the analytical report attached to this application. This report was previously submitted with the NPDES permit application for DECO- Fermi 2 Plt (permit no. MI0037028) on March 31, 2014. | | | | | | | | |

This completes Section III.

Section IV – Storm Water (Required of All Applicants) (1)

1. STORM WATER DISCHARGES: Storm water is defined herein as storm water runoff, snow melt runoff, and surface runoff and drainage.

A. Is this facility engaged in a regulated "industrial activity" as defined in 40 CFR 122.26(b)(14)? To make this determination, see the DEQ Storm Water website (<http://www.michigan.gov/deqstormwater>, then click on Industrial Program, then click on Primary Activities & Standard Industrial Classification (SIC) Codes.

Yes. Continue to question B

B. Is the storm water from this facility discharged to a surface water of the state either directly or through another conveyance (e.g., municipal separate storm sewer system)? Note: If storm water is discharged to a municipal combined storm sewer system, a municipal wastewater treatment system, or a privately-owned activated sludge treatment system, check the "No" box.

Yes. Provide the name(s) of the surface water(s) of the state: Continue to question C.

Names

Lake Erie, Swan Creek

C. Are any industrial activities or materials exposed to storm water at this facility?

Yes. Complete the remainder of Section IV.

Use the link to make a determination

[Click here to see the No Exposure Certification Guidance page](#)

D. Does this facility have an Industrial Storm Water Certified Operator who has supervision over the facility's industrial storm water treatment and control measures?

No. STOP: Applicants without an Industrial Storm Water Certified Operator cannot be authorized to discharge industrial storm water.

For information go to the link below then click on Industrial Program, then look under Storm Water Program Certified Operator Training.

[For more information click here](#)

Name and Number

TBD

E. Has a Storm Water Pollution Prevention Plan (SWPPP) been developed and implemented for this facility?

No. STOP: Applicants who have not developed and implemented a SWPPP for this facility cannot be authorized to discharge industrial storm water.

For information go to the link below, then click on Industrial Program, then look under Storm Water Pollution Prevention Plans.

[For more information click here](#)

F. READ ALL PARTS OF THE FOLLOWING QUESTION BEFORE RESPONDING: Does this facility discharge storm water to a surface water of the state or a municipal separate storm sewer system from a Special-Use Area?

Yes. 1) Check all Special-Use Area(s) that apply. Continue to question F.2):

A) Secondary containment structure(s) required by state or federal law. Attach a list of the materials stored in this area. B) Areas identified on Michigan's list of Sites of Environmental Contamination, pursuant to the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended, Part 201 (formerly 307) C) A facility that the DEQ has determined discharges storm water that is a significant contributor of pollutants to surface waters of the state

Check all Special-Use Area(s) that apply. Continue to question F.2):

A)

2) Has a Short-Term Storm Water Characterization Study (STSWCS) Plan been approved by the DEQ for this facility?

No. Continue to G.

Have any changes occurred at the facility which could result in the discharge of pollutants that differ from those identified in the previously approved STSWCS Plan?

G. Additional Information - Attachment(s)

[section IV.4.G Material Stored in Secondary Containment Structures.pdf](#)

Comment: NONE PROVIDED

This completes Section IV.

Section VI – Cooling Water Intake Structures (1)

1. COOLING WATER INTAKE STRUCTURES

The withdrawal of cooling water removes and kills hundreds of billions of aquatic organisms from waters of the United States each year, including fish, shellfish, fish eggs, and larvae. Aquatic organisms drawn through cooling water intake structures (CWIS) are either impinged (I) against components of the intake structure or get drawn into or entrained (E) in the cooling water system itself. Most impacts are to the early life stages of aquatic organisms. Due to the adverse environmental impact of I and E on aquatic organisms, USEPA has promulgated rules under section 316(b) of the Clean Water Act to set national performance standards to minimize the mortality of aquatic organisms from I and E for new and existing industrial facilities. Section 316(b) requires that the

Section IV.1.G – Material Stored In Secondary Containment Structures

1. No. 2 Fuel Oil
2. Sodium Hypochlorite
3. Mineral Oil

location, design, construction, and capacity of CWMSs reflect the best technology available (BTA) for minimizing adverse environmental impacts (I and E). All new or existing facilities utilizing a surface water intake structure to provide cooling water shall submit information for review as specified below. Please complete the following questions, compile the requested information, and submit the information as an attachment to this Application. The rules and requirements referenced below can be accessed at <http://www.michigan.gov/deqnpdes>. Under the Information banner, click on 316(b) Cooling Water Intake Structure Guidance.

A. Does or will the facility use a surface water intake structure as a cooling water source for the facility? Use of an intake structure includes obtaining water by any sort of contract or arrangement with an independent supplier if the supplier is itself not a facility covered by the requirements of

Yes. Continue to question B.

B. Does or will the intake structure have a design intake flow (DIF) rate (instantaneous maximum) greater than 2 MGD and does or will the facility use at least twenty-five percent of water withdrawn exclusively for cooling purposes?

Yes. Continue to question C.

If you selected no for the previous question. In accordance with 40 CFR 125.90(b), CWMSs that do not meet these threshold requirements are required to be evaluated on a case-by-case, best professional judgment (BPJ) basis. Please submit the information specified in 40 CFR 122.21(r)(2), (3), and (5). In addition, please identify the DIF rate and actual intake flow (AIF) rate, which is the annual average intake flow rate over the three previous years, and any significant changes to operations expected for the facility or CWMS over the next five years. Also include a summary of any available data for I and E for the CWMS (including data, estimates, or descriptions on the volume or number of fish removed by trash removal systems). Stop: Do not complete the rest of Section VI.

C. Check the appropriate box(es) below to identify whether the facility is new or existing, and provide the additional information as specified within each classification selected:

New Facility

If it is a new facility. In accordance with the Final Rules promulgated by USEPA under 316(b) and effective January 17, 2002, new facilities shall submit the information specified in 40 CFR 122.21(r) and 40 CFR 125.86. If it is an existing facility. In accordance with the Final Rules promulgated by USEPA under 316(b) and effective October 14, 2014, existing facilities (including those utilizing a closed-cycle recirculating cooling system) shall submit the information specified in 40 CFR 122.21(r)(2), (3), (4), (5), (6), (7), and (8), AND one or both of the following if applicable (check one or both as applicable):

A) Existing Facilities Greater than 125 MGD AIF. In addition to submitting the information listed above for existing facilities, these facilities shall also submit the information specified in §122.21(r)(9), (10), (11), (12), and (13). B) New Units at Existing Facilities. In addition to submitting or updating the information listed above for existing facilities, these facilities shall also submit the information specified in §122.21(r)(14).

Existing Facility
NONE PROVIDED

Attach the compiled information described in the previous questions. - Attachment(s)

NONE PROVIDED
Comment: NONE PROVIDED

Note: In accordance with 40 CFR 125.95, permittees whose current permit expires PRIOR to July 14, 2018, may request an alternate schedule for the submittal of these Application requirements if they can demonstrate that they could not develop all of the required information by the date of Application submission. For Applications due April 2015 through April 2017, the Application shall include the information requested in §122.21(r)(2), (3), (5), (7), and (8); the permittee may submit a demonstration and request an alternate schedule for the Application requirements specified in §122.21(r)(4), (6), (9), (10), (11), (12), or (13). Any demonstration should include a proposed alternate schedule for submission of these Application requirements; the proposed schedule should be as soon as practicable. The Department will consider the proposed schedule in setting the alternate submittal dates. Permittees whose Applications are due in April 2018, MUST submit the required Application materials with the Application for permit reissuance. If the Final Rules promulgated under 316(b) are stayed or otherwise modified, the Department may revise these Application and permitting requirements.

This completes Section VI.

Additional Information**Comments (As needed)**

NONE PROVIDED

Additional Documents (As needed) - Attachment(s)

[Add. Info - Resubmittal of Fermi 2 Analytical Data a.pdf](#)

[Fermi 3 2016 NPDES Application Cover Letter 3212016.pdf](#)

Comment: NONE PROVIDED

Attachments

| Date | Attachment Name | Context |
|------|-----------------|---------|
|------|-----------------|---------|

Status History

| Date | User | Processing Status |
|-----------|-----------------|-------------------|
| 3/21/2016 | Michael Brandon | Submitted |

Processing Steps

| Step Name | Assigned To/Completed By | Date Completed |
|----------------|--------------------------|---------------------|
| Form Submitted | Michael Brandon | 03/21/2016 02:23 PM |

**Additional Information –
Fermi 3 Resubmittal of
Fermi 2 2014 NPDES Renewal Application
Intake and Outfall 001 Analyses**

TriMatrix Laboratories Analytical Results for Fermi 2 2014 NPDES Permit Renewal
(following 59 pages)



December 19, 2013

DTE - Fermi-2
Attn: Ms. Mary Hana
6400 North Dixie Highway, 200 TAC
Newport, MI 48166

Project: Permit Renewal - Fermi, 2013

Déar Ms. Mary Hana,

Enclosed is a copy of the laboratory report for the following work order(s) received by TriMatrix Laboratories:

| Work Order | Received | Description |
|------------|------------|---------------------|
| 1312032 | 12/03/2013 | Laboratory Services |

This report relates only to the sample(s) as received. Test results are in compliance with the requirements of the National Environmental Laboratory Accreditation Program (NELAP) and/or one of the following certification programs:

ACCLASS DoD-ELAP/ISO17025 (#ADE-1542); Arkansas DEP (#88-0730/12-056-0); Florida DEP (#E87622-24); Georgia EPD (#E87622-24); Illinois DEP (#200026/003059); Kansas DPH (#E-10302); Kentucky DEP (#0021); Louisiana DEP (#83658); Michigan DPH (#0034); Minnesota DPH (#491715); New York ELAP (#11776/48855); North Carolina DNRE (#659); Texas CEQ (#T104704495-13-3); Virginia DCLS (#460153/1622); Wisconsin DNR (#999472650); USDA Soil Import Permit (#P330-12-00236).

Any qualification or narration of results, including sample acceptance requirements and test exceptions to the above referenced programs, is presented in the Statement of Data Qualifications and Project Technical Narrative sections of this report. Estimates of analytical uncertainties and certification documents for the test results contained within this report are available upon request.

If you have any questions or require further information, please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Jennifer L. Rice".

Jennifer L. Rice
Project Chemist



TRIMATRIX
LABORATORIES

PROJECT TECHNICAL NARRATIVE(s)

Polychlorinated Biphenyls (PCBs) by EPA Method 608

Narrative: Due to sample volumes, matrix specific quality control (QC) was not performed on this batch. A blank and a Laboratory Control Sample make up the batch QC.

Analysis: USEPA-608

Sample/Analyte: 1312032-14 Intake Composite

1312032-15 001 Composite



PROJECT TECHNICAL NARRATIVE(s)

Volatile Organic Compounds by EPA Method 624

Narrative: Sample was not preserved per 40 CFR Part 136.3, Table II: a sample collected for Acrolein must be pH adjusted to a range of 4-5 or analyzed within 3 days of collection.

Analysis: USEPA-624

Sample/Analyte: 1312032-06 Outfall 001 VOC Lab Composite
1312032-13 Intake VOC Lab Composite



PROJECT TECHNICAL NARRATIVE(s)

Semivolatile Organic Compounds by EPA Method 625

Narrative: Due to sample volumes, matrix specific quality control (QC) was not performed on this batch. A blank and a Laboratory Control Sample make up the batch QC.

Analysis: USEPA-625

Sample/Analyte: 1312032-14 Intake Composite

1312032-15 001 Composite



PROJECT TECHNICAL NARRATIVE(s)

Total Metals by EPA 200 Series Methods

Narrative: The CRL recovery for this analyte was outside of the laboratory control limits.

Analysis: USEPA-200.8

3L09035-CRL2

Selenium

PROJECT TECHNICAL NARRATIVE(s)

Physical/Chemical Parameters by EPA/APHA/ASTM Methods

Narrative: The CRL recovery for this analyte was outside of the laboratory control limits.

Analysis: SM 5540 C-2011

3L04037-CRL1

Surfactants, MBAS

Narrative: The MS or MSD recovery, but not both, was outside the control limit. The RPD is within the control limit.

Analysis: USEPA-351.2 Rev. 2.0

Sample/Analyte: 1312032-15 001 Composite

Nitrogen, Total Kjeldahl

Narrative: The RL for this analysis was elevated due to insufficient sample volume or weight received.

Analysis: USEPA-1664A

Sample/Analyte: 1312032-10 Intake Grab Day 2

HEM; Oil & Grease

Narrative: A.C.U. stands for Apparent Color Units. Color is pH dependent and its value increases proportionally with pH. The method requires that the pH of the sample be determined and reported along with the A.C.U value. The sample pH was: 7.12.

Analysis: SM 2120 B-2011

Sample/Analyte: 1312032-14 · Intake Composite

Color (Apparent)

1312032-15 001 Composite

Color (Apparent)

Narrative: The referenced method requires analysis occur within 15 minutes of sample collection. Analysis was performed at the laboratory on 12-4-13..

Analysis: SM 4500-SO3 B-2011

Sample/Analyte: 1312032-14 Intake Composite

Sulfite

. 1312032-15 001 Composite

- Sulfite

Narrative: The mg/L MBAS result reported should be considered mg MBAS/L (calculated as LAS, molecular weight 320).

Analysis: SM 5540 C-2011

Sample/Analyte: 1312032-14 Intake Composite

Surfactants, MBAS

1312032-15 .001 Composite

Surfactants, MBAS

Narrative: Distillation pretreatment was not performed. Common interfering ions were complexed by a buffer solution. Fluoroborates (if present) may result in a low bias of the reported concentration.

Analysis: SM 4500-F C-2011

Sample/Analyte: 1312032-14 Intake Composite

Fluoride

1312032-15 001 Composite

Fluoride



STATEMENT OF DATA QUALIFICATIONS

Volatile Organic Compounds by EPA Method 624

Qualification: The corresponding CCV for this analytical batch had a recovery exceeding the upper control limit of the method. A positive result for this analyte in any associated samples are considered estimated. Non-detectable results are not qualified.

Analysis: USEPA-624

| | | | |
|-----------------|------------|-------------------------------|--------------|
| Sample/Analyte: | 1312032-06 | Outfall 001 VOC Lab Composite | Chloroethane |
| | 1312032-13 | Intake VOC Lab Composite | Chloroethane |

Qualification: The chemical utilized to preserve this sample has the potential to degrade 2-chloroethyl vinyl ether through polymerization or other rapid chemical reaction. The reporting limit and/or any positive result must be considered estimated.

Analysis: USEPA-624

| | | |
|---------|------------|-------------------------------|
| Sample: | 1312032-06 | Outfall 001 VOC Lab Composite |
| | 1312032-13 | Intake VOC Lab Composite |



TRIMATRIX
LABORATORIES

STATEMENT OF DATA QUALIFICATIONS

Physical/Chemical Parameters by EPA/APHA/ASTM Methods

Qualification: The following reported test methods and analyte(s) are exceptions to our NELAP Fields of Accreditation, or for which accreditation is not required, applicable, or available.

Analysis: EPA-351.2/4500-NH3G

Analyte(s): Nitrogen, Organic

Analysis: SM 4500-SO3 B-2011

Analyte(s): Sulfite



ANALYTICAL REPORT

Client: **DTE - Fermi-2** Work Order: **1312032**
Project: Permit Renewal - Fermi, 2013 Description: Laboratory Services
Client Sample ID: **Outfall 001 Grab Day 1** Sampled: 12/2/13 13:00
Lab Sample ID: **1312032-01** Sampled By: J. Elsey
Matrix: Waste Water Received: 12/3/13 17:00

Physical/Chemical Parameters by EPA/APHA/ASTM Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|----------------------------------|-------------------|------|----------|-----------------|------------------|--------------------|-----|----------|
| Chlorine, Total Residual (Field) | <0.20 | 0.20 | mg/L | 1 | HACH-8167 | 12/02/13 13:00 | JAE | 1313078 |
| Oxygen, Dissolved (Field) | 7.57 | 0.10 | mg/L | 1 | SM 4500-O G | 12/02/13 13:00 | JAE | 1313078 |
| pH (Field) | 8.31 | 1.00 | pH Units | 1 | SM 4500-H B-2011 | 12/02/13 13:00 | JAE | 1313078 |
| Temperature °C (Field) | 16.0 | 0.1 | °C | 1 | SM 2550 B | 12/02/13 13:00 | JAE | 1313078 |



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|--------------|---------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | Outfall 001 LLHg | Sampled: | 12/2/13 12:44 |
| Lab Sample ID: | 1312032-02 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |

Total Metals by EPA 1600 Series Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|---------|-------------------|------|------|-----------------|-------------|--------------------|-----|----------|
| Mercury | 7.84 | 2.50 | ng/L | 5 | USEPA-1631E | 12/05/13 12:43 | MSM | 1313075 |



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
Project: **Permit Renewal - Fermi, 2013**
Client Sample ID: **Outfall 001 Grab Day 2**
Lab Sample ID: **1312032-03**
Matrix: **Waste Water**

Work Order: **1312032**
Description: **Laboratory Services**
Sampled: **12/3/13 12:35**
Sampled By: **J. Elsey**
Received: **12/3/13 17:00**

Physical/Chemical Parameters by EPA/APHA/ASTM Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|----------------------------------|-------------------|--------|----------|-----------------|------------------|--------------------|-----|----------|
| Phenolics, Total | <0.0500 | 0.0500 | mg/L | 1 | USEPA-420.4 | 12/09/13 10:39 | LMA | 1313065 |
| Chlorine, Total Residual (Field) | <0.20 | 0.20 | mg/L | 1 | HACH-8167 | 12/03/13 12:35 | JAE | 1313078 |
| Oxygen, Dissolved (Field) | 6.89 | 0.10 | mg/L | 1 | SM 4500-O G | 12/03/13 12:35 | JAE | 1313078 |
| pH (Field) | 8.56 | 1.00 | pH Units | 1 | SM 4500-H B-2011 | 12/03/13 12:35 | JAE | 1313078 |
| Temperature °C (Field) | 19.0 | 0.1 | °C | 1 | SM 2550 B | 12/03/13 12:35 | JAE | 1313078 |
| Cyanide, Available | <2.0 | 2.0 | ug/L | 1 | USEPA OIA-1677 | 12/09/13 12:10 | LMA | 1313173 |
| HEM; Oil & Grease | <5.00 | 5.00 | mg/L | 1 | USEPA-1664A | 12/10/13 08:00 | WAH | 1313184 |



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
Project: Permit Renewal - Fermi, 2013
Client Sample ID: **Outfall 001 LLHg Duplicate**
Lab Sample ID: **1312032-04**
Matrix: Waste Water

Work Order: **1312032**
Description: Laboratory Services
Sampled: 12/2/13 12:47
Sampled By: J. Elsey
Received: 12/3/13 17:00

Total Metals by EPA 1600 Series Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|---------|-------------------|-------|------|-----------------|-------------|--------------------|-----|----------|
| Mercury | 7.51 | 0.500 | ng/L | 1 | USEPA-1631E | 12/05/13 12:01 | MSM | 1313075 |



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
Project: Permit Renewal - Fermi, 2013
Client Sample ID: **Outfall 001 Field Blank**
Lab Sample ID: **1312032-05**
Matrix: Waste Water

Work Order: **1312032**
Description: Laboratory Services
Sampled: 12/2/13 12:41
Sampled By: J. Eisey
Received: 12/3/13 17:00

Total Metals by EPA 1600 Series Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|---------|-------------------|-------|------|-----------------|-------------|--------------------|-----|----------|
| Mercury | <0.500 | 0.500 | ng/L | 1 | USEPA-1631E | 12/05/13 12:05 | MSM | 1313075 |



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
Project: Permit Renewal - Fermi, 2013
Client Sample ID: **Outfall 001 VOC Lab Composite**
Lab Sample ID: **1312032-06**
Matrix: Waste Water
Unit: ug/L
Dilution Factor: 1
QC Batch: 1313145

Work Order: **1312032**
Description: Laboratory Services
Sampled: 12/3/13 12:35
Sampled By: J. Elsey
Received: 12/3/13 17:00
Prepared: 12/6/13 7:00 By: DLV
Analyzed: 12/6/13 16:34 By: DLV
Analytical Batch: 3L09003

*Volatile Organic Compounds by EPA Method 624

| CAS Number | Analyte | Analytical Result | RL |
|------------|-----------------------------|-------------------|-----|
| 107-02-8 | Acrolein | <5.0 | 5.0 |
| 107-13-1 | Acrylonitrile | <1.0 | 1.0 |
| 71-43-2 | Benzene | <1.0 | 1.0 |
| 75-27-4 | Bromodichloromethane | <1.0 | 1.0 |
| 75-25-2 | Bromoform | <1.0 | 1.0 |
| 74-83-9 | Bromomethane | <1.0 | 1.0 |
| 56-23-5 | Carbon Tetrachloride | <1.0 | 1.0 |
| 108-90-7 | Chlorobenzene | <1.0 | 1.0 |
| *75-00-3 | Chloroethane | <1.0 | 1.0 |
| 110-75-8 | 2-Chloroethyl Vinyl Ether | <10 | 10 |
| 67-66-3 | Chloroform | <1.0 | 1.0 |
| 74-87-3 | Chloromethane | <1.0 | 1.0 |
| 124-48-1 | Dibromochloromethane | <1.0 | 1.0 |
| 75-34-3 | 1,1-Dichloroethane | <1.0 | 1.0 |
| 107-06-2 | 1,2-Dichloroethane | <1.0 | 1.0 |
| 75-35-4 | 1,1-Dichloroethene | <1.0 | 1.0 |
| 542-75-6 | 1,3-Dichloropropene (Total) | <2.0 | 2.0 |
| 156-60-5 | trans-1,2-Dichloroethene | <1.0 | 1.0 |
| 78-87-5 | 1,2-Dichloropropane | <1.0 | 1.0 |
| 100-41-4 | Ethylbenzene | <1.0 | 1.0 |
| 75-09-2 | Methylene Chloride | <5.0 | 5.0 |
| 79-34-5 | 1,1,2,2-Tetrachloroethane | <1.0 | 1.0 |
| 127-18-4 | Tetrachloroethene | <1.0 | 1.0 |
| 108-88-3 | Toluene | <1.0 | 1.0 |
| 71-55-6 | 1,1,1-Trichloroethane | <1.0 | 1.0 |
| 79-00-5 | 1,1,2-Trichloroethane | <1.0 | 1.0 |
| 79-01-6 | Trichloroethene | <1.0 | 1.0 |
| 75-01-4 | Vinyl Chloride | <1.0 | 1.0 |

Continued on next page

*See Statement of Data Qualifications

Page 14 of 59

This report shall not be reproduced, except in full, without written authorization of TriMatrix Laboratories, Inc.

Individual sample results relate only to the sample tested.

5560 Corporate Exchange Court SE ♦ Grand Rapids, MI 49512 ♦ 616.975.4500 ♦ Fax 616.942.7463 ♦ www.trimatrixlabs.com



ANALYTICAL REPORT

| | | | |
|-------------------|-------------------------------|-------------------|---------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | Outfall 001 VOC Lab Composite | Sampled: | 12/3/13 12:35 |
| Lab Sample ID: | 1312032-06 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |
| Unit: | ug/L | Prepared: | 12/6/13 7:00 |
| Dilution Factor: | 1 | Analyzed: | 12/6/13 16:34 |
| QC Batch: | 1313145 | Analytical Batch: | 3L09003 |

*Volatile Organic Compounds by EPA Method 624 (Continued)

| Surrogates: | % Recovery | Control Limits |
|-----------------------|------------|----------------|
| Dibromofluoromethane | 98 | 85-118 |
| 1,2-Dichloroethane-d4 | 99 | 87-122 |
| Toluene-d8 | 98 | 85-113 |
| 4-Bromofluorobenzene | 93 | 82-110 |

*See Statement of Data Qualifications

Page 15 of 59

This report shall not be reproduced, except in full, without written authorization of TriMatrix Laboratories, Inc.

Individual sample results relate only to the sample tested.

5560 Corporate Exchange Court SE ♦ Grand Rapids, MI 49512 ♦ 616.975.4500 ♦ Fax 616.942.7463 ♦ www.trimatrixlabs.com



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|--------------|---------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | Fermi LLHg Trip Blank | Sampled: | 12/2/13 0:00 |
| Lab Sample ID: | 1312032-07 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |

Total Metals by EPA 1600 Series Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|---------|-------------------|-------|------|-----------------|-------------|--------------------|-----|----------|
| Mercury | <0.500 | 0.500 | ng/L | 1 | USEPA-1631E | 12/05/13 12:08 | MSM | 1313075 |



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
Project: Permit Renewal - Fermi, 2013
Client Sample ID: **Intake Grab Day 1**
Lab Sample ID: **1312032-08**
Matrix: Waste Water

Work Order: **1312032**
Description: Laboratory Services
Sampled: 12/2/13 12:25
Sampled By: J. Elsey
Received: 12/3/13 17:00

Physical/Chemical Parameters by EPA/APHA/ASTM Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|----------------------------------|-------------------|------|----------|-----------------|------------------|--------------------|-----|----------|
| Chlorine, Total Residual (Field) | <0.20 | 0.20 | mg/L | 1 | HACH-8167 | 12/02/13 12:25 | JAE | 1313078 |
| Oxygen, Dissolved (Field) | 6.43 | 0.10 | mg/L | 1 | SM 4500-O G | 12/02/13 12:25 | JAE | 1313078 |
| pH (Field) | 7.51 | 1.00 | pH Units | 1 | SM 4500-H B-2011 | 12/02/13 12:25 | JAE | 1313078 |
| Temperature °C (Field) | 5.0 | 0.1 | °C | 1 | SM 2550 B | 12/02/13 12:25 | JAE | 1313078 |



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
Project: Permit Renewal - Fermi, 2013
Client Sample ID: **Intake LLHg**
Lab Sample ID: **1312032-09**
Matrix: Waste Water

Work Order: **1312032**
Description: Laboratory Services
Sampled: 12/2/13 12:02
Sampled By: J. Elsey
Received: 12/3/13 17:00

Total Metals by EPA 1600 Series Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|---------|-------------------|-------|------|-----------------|-------------|--------------------|-----|----------|
| Mercury | 3.61 | 0.500 | ng/L | 1 | USEPA-1631E | 12/19/13 10:56 | MSM | 1313536 |



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
Project: Permit Renewal - Fermi, 2013
Client Sample ID: **Intake Grab Day 2**
Lab Sample ID: **1312032-10**
Matrix: Waste Water

Work Order: **1312032**
Description: Laboratory Services
Sampled: 12/3/13 12:00
Sampled By: J. Elsey
Received: 12/3/13 17:00

Physical/Chemical Parameters by EPA/APHA/ASTM Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|----------------------------------|-------------------|--------|----------|-----------------|------------------|--------------------|-----|----------|
| Phenolics, Total | <0.0500 | 0.0500 | mg/L | 1 | USEPA-420.4 | 12/09/13 10:39 | LMA | 1313065 |
| Chlorine, Total Residual (Field) | <0.20 | 0.20 | mg/L | 1 | HACH-8167 | 12/03/13 12:00 | JAE | 1313078 |
| Oxygen, Dissolved (Field) | 7.56 | 0.10 | mg/L | 1 | SM 4500-O G | 12/03/13 12:00 | JAE | 1313078 |
| pH (Field) | 7.57 | 1.00 | pH Units | 1 | SM 4500-H B-2011 | 12/03/13 12:00 | JAE | 1313078 |
| Temperature °C (Field) | 12.0 | 0.1 | °C | 1 | SM 2550 B | 12/03/13 12:00 | JAE | 1313078 |
| Cyanide, Available | <2.0 | 2.0 | ug/L | 1 | USEPA OIA-1677 | 12/09/13 12:11 | LMA | 1313173 |
| HEM; Oil & Grease | <5.10 | 5.10 | mg/L | 1 | USEPA-1664A | 12/10/13 08:00 | WAH | 1313184 |



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
Project: Permit Renewal - Fermi, 2013
Client Sample ID: **Intake LLHg Duplicate**
Lab Sample ID: **1312032-11**
Matrix: Waste Water

Work Order: **1312032**
Description: Laboratory Services
Sampled: 12/2/13 12:05
Sampled By: J. Elsey
Received: 12/3/13 17:00

Total Metals by EPA 1600 Series Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|---------|-------------------|-------|------|-----------------|-------------|--------------------|-----|----------|
| Mercury | 3.50 | 0.500 | ng/L | 1 | USEPA-1631E | 12/19/13 09:14 | MSM | 1313536 |



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|--------------|---------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | Intake LLHg Field Blank | Sampled: | 12/2/13 11:59 |
| Lab Sample ID: | 1312032-12 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |

Total Metals by EPA 1600 Series Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|---------|-------------------|-------|------|-----------------|-------------|--------------------|-----|----------|
| Mercury | <0.500 | 0.500 | ng/L | 1 | USEPA-1631E | 12/05/13 12:19 | MSM | 1313075 |



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|-------------------|-----------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | Intake VOC Lab Composite | Sampled: | 12/3/13 12:00 |
| Lab Sample ID: | 1312032-13 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |
| Unit: | ug/L | Prepared: | 12/6/13 7:00 By: DLV |
| Dilution Factor: | 1 | Analyzed: | 12/6/13 17:03 By: DLV |
| QC Batch: | 1313145 | Analytical Batch: | 3L09003 |

*Volatile Organic Compounds by EPA Method 624

| CAS Number | Analyte | Analytical Result | RL |
|------------|-----------------------------|-------------------|-----|
| 107-02-8 | Acrolein | <5.0 | 5.0 |
| 107-13-1 | Acrylonitrile | <1.0 | 1.0 |
| 71-43-2 | Benzene | <1.0 | 1.0 |
| 75-27-4 | Bromodichloromethane | <1.0 | 1.0 |
| 75-25-2 | Bromoform | <1.0 | 1.0 |
| 74-83-9 | Bromomethane | <1.0 | 1.0 |
| 56-23-5 | Carbon Tetrachloride | <1.0 | 1.0 |
| 108-90-7 | Chlorobenzene | <1.0 | 1.0 |
| *75-00-3 | Chloroethane | <1.0 | 1.0 |
| 110-75-8 | 2-Chloroethyl Vinyl Ether | <10 | 10 |
| 67-66-3 | Chloroform | <1.0 | 1.0 |
| 74-87-3 | Chloromethane | <1.0 | 1.0 |
| 124-48-1 | Dibromochloromethane | <1.0 | 1.0 |
| 75-34-3 | 1,1-Dichloroethane | <1.0 | 1.0 |
| 107-06-2 | 1,2-Dichloroethane | <1.0 | 1.0 |
| 75-35-4 | 1,1-Dichloroethene | <1.0 | 1.0 |
| 542-75-6 | 1,3-Dichloropropene (Total) | <2.0 | 2.0 |
| 156-60-5 | trans-1,2-Dichloroethene | <1.0 | 1.0 |
| 78-87-5 | 1,2-Dichloropropane | <1.0 | 1.0 |
| 100-41-4 | Ethylbenzene | <1.0 | 1.0 |
| 75-09-2 | Methylene Chloride | <5.0 | 5.0 |
| 79-34-5 | 1,1,2,2-Tetrachloroethane | <1.0 | 1.0 |
| 127-18-4 | Tetrachloroethene | <1.0 | 1.0 |
| 108-88-3 | Toluene | <1.0 | 1.0 |
| 71-55-6 | 1,1,1-Trichloroethane | <1.0 | 1.0 |
| 79-00-5 | 1,1,2-Trichloroethane | <1.0 | 1.0 |
| 79-01-6 | Trichloroethene | <1.0 | 1.0 |
| 75-01-4 | Vinyl Chloride | <1.0 | 1.0 |

Continued on next page

*See Statement of Data Qualifications

Page 22 of 59

This report shall not be reproduced, except in full, without written authorization of TriMatrix Laboratories, Inc.

Individual sample results relate only to the sample tested.

5560 Corporate Exchange Court SE ♦ Grand Rapids, MI 49512 ♦ 616.975.4500 ♦ Fax 616.942.7463 ♦ www.trimatrixlabs.com



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
Project: Permit Renewal - Fermi, 2013
Client Sample ID: **Intake VOC Lab Composite**
Lab Sample ID: **1312032-13**
Matrix: Waste Water
Unit: ug/L
Dilution Factor: 1
QC Batch: 1313145

Work Order: **1312032**
Description: Laboratory Services
Sampled: 12/3/13 12:00
Sampled By: J. Elsey
Received: 12/3/13 17:00
Prepared: 12/6/13 7:00 By: DLV
Analyzed: 12/6/13 17:03 By: DLV
Analytical Batch: 3L09003

*Volatile Organic Compounds by EPA Method 624 (Continued)

| <i>Surrogates:</i> | <i>% Recovery</i> | <i>Control Limits</i> |
|------------------------------|-------------------|-----------------------|
| <i>Dibromofluoromethane</i> | <i>98</i> | <i>85-118</i> |
| <i>1,2-Dichloroethane-d4</i> | <i>98</i> | <i>87-122</i> |
| <i>Toluene-d8</i> | <i>99</i> | <i>85-113</i> |
| <i>4-Bromofluorobenzene</i> | <i>95</i> | <i>82-110</i> |

*See Statement of Data Qualifications



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|-------------------|-----------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | Intake Composite | Sampled: | 12/3/13 12:20 |
| Lab Sample ID: | 1312032-14 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |
| Unit: | ug/L | Prepared: | 12/6/13 7:31 By: ALK |
| Dilution Factor: | 1 | Analyzed: | 12/13/13 3:08 By: ASC |
| QC Batch: | 1313086 | Analytical Batch: | 3L13025 |

Polychlorinated Biphenyls (PCBs) by EPA Method 608

| CAS Number | Analyte | Analytical Result | RL |
|------------|----------|-------------------|------|
| 12674-11-2 | PCB-1016 | <0.20 | 0.20 |
| 11104-28-2 | PCB-1221 | <0.20 | 0.20 |
| 11141-16-5 | PCB-1232 | <0.20 | 0.20 |
| 53469-21-9 | PCB-1242 | <0.20 | 0.20 |
| 12672-29-6 | PCB-1248 | <0.20 | 0.20 |
| 11097-69-1 | PCB-1254 | <0.20 | 0.20 |
| 11096-82-5 | PCB-1260 | <0.20 | 0.20 |

Surrogates:

Decachlorobiphenyl
Tetrachloro-m-xylene

% Recovery

86
71

Control Limits

45-134
27-126



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
Project: Permit Renewal - Fermi, 2013
Client Sample ID: **Intake Composite**
Lab Sample ID: **1312032-14**
Matrix: Waste Water
Unit: ug/L
Dilution Factor: 1
QC Batch: 1313027

Work Order: **1312032**
Description: Laboratory Services
Sampled: 12/3/13 12:20
Sampled By: J. Elsey
Received: 12/3/13 17:00
Prepared: 12/5/13 8:00 By: ALK
Analyzed: 12/11/13 6:36 By: DWJ
Analytical Batch: 3L11050

Semivolatile Organic Compounds by EPA Method 625

| CAS Number | Analyte | Analytical Result | RL |
|------------|------------------------------|-------------------|-----|
| 83-32-9 | Acenaphthene | <5.0 | 5.0 |
| 208-96-8 | Acenaphthylene | <5.0 | 5.0 |
| 120-12-7 | Anthracene | <5.0 | 5.0 |
| 92-87-5 | Benzidine | <50 | 50 |
| 56-55-3 | Benzo(a)anthracene | <5.0 | 5.0 |
| 50-32-8 | Benzo(a)pyrene | <5.0 | 5.0 |
| 205-99-2 | Benzo(b)fluoranthene | <5.0 | 5.0 |
| 207-08-9 | Benzo(k)fluoranthene | <5.0 | 5.0 |
| 191-24-2 | Benzo(g,h,i)perylene | <5.0 | 5.0 |
| 101-55-3 | 4-Bromophenyl Phenyl Ether | <5.0 | 5.0 |
| 85-68-7 | Butyl Benzyl Phthalate | <5.0 | 5.0 |
| 59-50-7 | 4-Chloro-3-methylphenol | <5.0 | 5.0 |
| 111-91-1 | Bis(2-chloroethoxy)methane | <5.0 | 5.0 |
| 111-44-4 | Bis(2-chloroethyl) Ether | <5.0 | 5.0 |
| 108-60-1 | Bis(2-chloroisopropyl) Ether | <5.0 | 5.0 |
| 91-58-7 | 2-Chloronaphthalene | <5.0 | 5.0 |
| 95-57-8 | 2-Chlorophenol | <5.0 | 5.0 |
| 7005-72-3 | 4-Chlorophenyl Phenyl Ether | <5.0 | 5.0 |
| 218-01-9 | Chrysene | <5.0 | 5.0 |
| 53-70-3 | Dibenz(a,h)anthracene | <5.0 | 5.0 |
| 84-74-2 | Di-n-butyl Phthalate | <5.0 | 5.0 |
| 95-50-1 | 1,2-Dichlorobenzene | <5.0 | 5.0 |
| 541-73-1 | 1,3-Dichlorobenzene | <5.0 | 5.0 |
| 106-46-7 | 1,4-Dichlorobenzene | <5.0 | 5.0 |
| 91-94-1 | 3,3'-Dichlorobenzidine | <20 | 20 |
| 120-83-2 | 2,4-Dichlorophenol | <5.0 | 5.0 |
| 84-66-2 | Diethyl Phthalate | <5.0 | 5.0 |
| 105-67-9 | 2,4-Dimethylphenol | <5.0 | 5.0 |
| 131-11-3 | Dimethyl Phthalate | <5.0 | 5.0 |

Continued on next page



ANALYTICAL REPORT

| | | | |
|-------------------|-------------------------------|-------------------|-----------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013. | Description: | Laboratory Services |
| Client Sample ID: | Intake Composite | Sampled: | 12/3/13 12:20 |
| Lab Sample ID: | 1312032-14 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |
| Unit: | ug/L | Prepared: | 12/5/13 8:00 By: ALK |
| Dilution Factor: | 1 | Analyzed: | 12/11/13 6:36 By: DWJ |
| QC Batch: | 1313027 | Analytical Batch: | 3L11050 |

Semivolatile Organic Compounds by EPA Method 625 (Continued)

| CAS Number | Analyte | Analytical Result | RL |
|------------|-----------------------------|-------------------|-----|
| 534-52-1 | 4,6-Dinitro-2-methylphenol | <20 | 20 |
| 51-28-5 | 2,4-Dinitrophenol | <20 | 20 |
| 121-14-2 | 2,4-Dinitrotoluene | <5.0 | 5.0 |
| 606-20-2 | 2,6-Dinitrotoluene | <5.0 | 5.0 |
| 117-84-0 | Di-n-octyl Phthalate | <5.0 | 5.0 |
| 122-66-7 | 1,2-Diphenylhydrazine | <5.0 | 5.0 |
| 117-81-7 | Bis(2-ethylhexyl) Phthalate | <5.0 | 5.0 |
| 206-44-0 | Fluoranthene | <5.0 | 5.0 |
| 86-73-7 | Fluorene | <5.0 | 5.0 |
| 118-74-1 | Hexachlorobenzene | <5.0 | 5.0 |
| 87-68-3 | Hexachlorobutadiene | <5.0 | 5.0 |
| 77-47-4 | Hexachlorocyclopentadiene | <5.0 | 5.0 |
| 67-72-1 | Hexachloroethane | <5.0 | 5.0 |
| 193-39-5 | Indeno(1,2,3-cd)pyrene | <5.0 | 5.0 |
| 78-59-1 | Isophorone | <5.0 | 5.0 |
| 91-20-3 | Naphthalene | <5.0 | 5.0 |
| 98-95-3 | Nitrobenzene | <5.0 | 5.0 |
| 100-02-7 | 4-Nitrophenol | <20 | 20 |
| 88-75-5 | 2-Nitrophenol | <5.0 | 5.0 |
| 62-75-9 | N-Nitroso-dimethylamine | <5.0 | 5.0 |
| 86-30-6 | N-Nitroso-diphenylamine | <5.0 | 5.0 |
| 621-64-7 | N-Nitroso-di-n-propylamine | <5.0 | 5.0 |
| 87-86-5 | Pentachlorophenol | <20 | 20 |
| 85-01-8 | Phenanthrene | <5.0 | 5.0 |
| 108-95-2 | Phenol | <5.0 | 5.0 |
| 129-00-0 | Pyrene | <5.0 | 5.0 |
| 120-82-1 | 1,2,4-Trichlorobenzene | <5.0 | 5.0 |
| 88-06-2 | 2,4,6-Trichlorophenol | <5.0 | 5.0 |

Continued on next page



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|-------------------|-----------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | Intake Composite | Sampled: | 12/3/13 12:20 |
| Lab Sample ID: | 1312032-14 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |
| Unit: | ug/L | Prepared: | 12/5/13 8:00 By: ALK |
| Dilution Factor: | 1 | Analyzed: | 12/11/13 6:36 By: DWJ |
| QC Batch: | 1313027 | Analytical Batch: | 3L11050 |

Semivolatile Organic Compounds by EPA Method 625 (Continued)

| CAS Number | Analyte | Analytical Result | RL |
|----------------------|-------------------|-----------------------|----|
| Surrogates: | | | |
| | % Recovery | Control Limits | |
| | 40 | 18-74 | |
| 2-Fluorophenol | 26 | 12-47 | |
| Phenol-d6 | 80 | 34-122 | |
| Nitrobenzene-d5 | 81 | 36-136 | |
| 2-Fluorobiphenyl | 56 | 19-131 | |
| 2,4,6-Tribromophenol | 84 | 27-138 | |
| o-Terphenyl | | | |



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|--------------|---------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | Intake Composite | Sampled: | 12/3/13 12:20 |
| Lab Sample ID: | 1312032-14 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |

Total Metals by EPA 200 Series Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|------------|-------------------|-------|------|-----------------|-------------|--------------------|-----|----------|
| Aluminum | 0.65 | 0.050 | mg/L | 1 | USEPA-200.7 | 12/09/13 12:12 | KLV | 1313073 |
| Antimony | <1.0 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Arsenic | 1.1 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Barium | 26 | 5.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Beryllium | <1.0 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Boron | 27 | 20 | ug/L | 1 | USEPA-200.8 | 12/10/13 10:19 | MSM | 1313011 |
| Cadmium | <0.20 | 0.20 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Chromium | <10 | 10 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Cobalt | <10 | 10 | ug/L | 1 | USEPA-200.7 | 12/09/13 12:12 | KLV | 1313073 |
| Copper | 3.7 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Iron | 1.0 | 0.010 | mg/L | 1 | USEPA-200.7 | 12/09/13 15:40 | CKD | 1313073 |
| Lead | 1.2 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Magnesium | 11 | 0.50 | mg/L | 1 | USEPA-200.7 | 12/09/13 15:40 | CKD | 1313073 |
| Manganese | 0.031 | 0.010 | mg/L | 1 | USEPA-200.7 | 12/09/13 12:12 | KLV | 1313073 |
| Molybdenum | <0.10 | 0.10 | mg/L | 1 | USEPA-200.7 | 12/05/13 09:54 | KLV | 1312991 |
| Nickel | <5.0 | 5.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Selenium | <1.0 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Silver | <0.50 | 0.50 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Thallium | <1.0 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |
| Tin | <0.20 | 0.20 | mg/L | 1 | USEPA-200.7 | 12/05/13 09:54 | KLV | 1312991 |
| Titanium | <0.10 | 0.10 | mg/L | 1 | USEPA-200.7 | 12/05/13 09:54 | KLV | 1312991 |
| Zinc | 11 | 10 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:27 | MSM | 1313011 |



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|--------------|---------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | Intake Composite | Sampled: | 12/3/13 12:20 |
| Lab Sample ID: | 1312032-14 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |

Physical/Chemical Parameters by EPA/APHA/ASTM Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|-----------------------------|-------------------|--------|--------|-----------------|----------------------|--------------------|-----|----------|
| Hardness as CaCO3 | 147 | 2 | mg/L | 1 | SM 2340 C-2011 | 12/06/13 14:30 | KAR | 1313099 |
| BOD, (5-Day) | <4.0 | 4.0 | mg/L | 1 | SM 5210 B-2011 | 12/04/13 11:37 | SKA | 1313038 |
| Bromide | <0.50 | 0.50 | mg/L | 1 | ASTM D 1246-05 | 12/11/13 13:00 | SLL | 1313240 |
| Chemical Oxygen Demand | 22 | 5.0 | mg/L | 1 | SM 5220 D-2011 | 12/04/13 14:59 | SLL | 1313025 |
| Color (Apparent) | 15.0 | 5.00 | A.C.U. | 1 | SM 2120 B-2011 | 12/04/13 14:23 | CAC | 1313019 |
| Fluoride | 0.16 | 0.10 | mg/L | 1 | SM 4500-FC-2011 | 12/13/13 10:40 | SLL | 1313326 |
| Surfactants, MBAS | <0.0250 | 0.0250 | mg/L | 1 | SM 5540 C-2011 | 12/04/13 12:14 | WAH | 1313020 |
| Phosphorus, Total | 0.148 | 0.0100 | mg/L | 1 | SM 4500-P E-2011 | 12/10/13 10:09 | KAR | 1313144 |
| Residue, Dissolved @ 180° C | 190 | 50 | mg/L | 1 | SM 2540 C-2011 | 12/05/13 13:00 | WAH | 1313033 |
| Residue, Suspended | 25.7 | 3.3 | mg/L | 1 | SM 2540 D-2011 | 12/05/13 15:30 | WAH | 1313036 |
| Sulfate | 30 | 5.0 | mg/L | 1 | ASTM D516-90 (07) | 12/12/13 09:45 | LMA | 1313298 |
| Sulfide, Total | <0.020 | 0.020 | mg/L | 1 | SM 4500-S2 D-2011 | 12/06/13 15:28 | WAH | 1313149 |
| Sulfite | <1.0 | 1.0 | mg/L | 1 | SM 4500-SO3 B-2011 | 12/04/13 13:50 | CAC | 1313110 |
| Carbon, Total Organic | 3.6 | 0.50 | mg/L | 1 | SM 5310 C-2011 | 12/05/13 19:16 | KAR | 1313095 |
| Nitrogen, Ammonia | 0.079 | 0.050 | mg/L | 1 | SM 4500-NH3 G-2011 | 12/11/13 11:15 | CLB | 1313163 |
| Nitrogen, Nitrate+Nitrite | 0.48 | 0.050 | mg/L | 1 | SM 4500-NO3 F-2011 | 12/04/13 13:19 | CAC | 1313118 |
| Nitrogen, Organic | <0.50 | 0.50 | mg/L | 1 | EPA-351.2/4500-NH3G | 12/12/13 14:35 | CLB | 1313201 |
| Nitrogen, Total Kjeldahl | <0.50 | 0.50 | mg/L | 1 | USEPA-351.2 Rev. 2.0 | 12/09/13 11:45 | CLB | 1313050 |
| Nitrogen, Inorganic | 0.56 | 0.050 | mg/L | 1 | [CALC] | 12/11/13 11:15 | CAC | [CALC] |



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|-------------------|-----------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | 001 Composite | Sampled: | 12/3/13 12:55 |
| Lab Sample ID: | 1312032-15 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |
| Unit: | ug/L | Prepared: | 12/6/13 7:31 By: ALK |
| Dilution Factor: | 1 | Analyzed: | 12/13/13 3:36 By: ASC |
| QC Batch: | 1313086 | Analytical Batch: | 3L13025 |

Polychlorinated Biphenyls (PCBs) by EPA Method 608

| CAS Number | Analyte | Analytical Result | RL |
|--------------------|----------------------|-------------------|-----------------------|
| 12674-11-2 | PCB-1016 | <0.20 | 0.20 |
| 11104-28-2 | PCB-1221 | <0.20 | 0.20 |
| 11141-16-5 | PCB-1232 | <0.20 | 0.20 |
| 53469-21-9 | PCB-1242 | <0.20 | 0.20 |
| 12672-29-6 | PCB-1248 | <0.20 | 0.20 |
| 11097-69-1 | PCB-1254 | <0.20 | 0.20 |
| 11096-82-5 | PCB-1260 | <0.20 | 0.20 |
| Surrogates: | | | |
| | | % Recovery | Control Limits |
| | Decachlorobiphenyl | 73 | 45-134 |
| | Tetrachloro-m-xylene | 64 | 27-126 |



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|-------------------|-----------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | 001 Composite | Sampled: | 12/3/13 12:55 |
| Lab Sample ID: | 1312032-15 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |
| Unit: | ug/L | Prepared: | 12/5/13 8:00 By: ALK |
| Dilution Factor: | 1 | Analyzed: | 12/11/13 7:08 By: DWJ |
| QC Batch: | 1313027 | Analytical Batch: | 3L11050 |

Semivolatile Organic Compounds by EPA Method 625

| CAS Number | Analyte | Analytical Result | RL |
|------------|------------------------------|-------------------|-----|
| 83-32-9 | Acenaphthene | <5.0 | 5.0 |
| 208-96-8 | Acenaphthylene | <5.0 | 5.0 |
| 120-12-7 | Anthracene | <5.0 | 5.0 |
| 92-87-5 | Benzidine | <5.0 | 5.0 |
| 56-55-3 | Benzo(a)anthracene | <5.0 | 5.0 |
| 50-32-8 | Benzo(a)pyrene | <5.0 | 5.0 |
| 205-99-2 | Benzo(b)fluoranthene | <5.0 | 5.0 |
| 207-08-9 | Benzo(k)fluoranthene | <5.0 | 5.0 |
| 191-24-2 | Benzo(g,h,i)perylene | <5.0 | 5.0 |
| 101-55-3 | 4-Bromophenyl Phenyl Ether | <5.0 | 5.0 |
| 85-68-7 | Butyl Benzyl Phthalate | <5.0 | 5.0 |
| 59-50-7 | 4-Chloro-3-methylphenol | <5.0 | 5.0 |
| 111-91-1 | Bis(2-chloroethoxy)methane | <5.0 | 5.0 |
| 111-44-4 | Bis(2-chloroethyl) Ether | <5.0 | 5.0 |
| 108-60-1 | Bis(2-chloroisopropyl) Ether | <5.0 | 5.0 |
| 91-58-7 | 2-Chloronaphthalene | <5.0 | 5.0 |
| 95-57-8 | 2-Chlorophenol | <5.0 | 5.0 |
| 7005-72-3 | 4-Chlorophenyl Phenyl Ether | <5.0 | 5.0 |
| 218-01-9 | Chrysene | <5.0 | 5.0 |
| 53-70-3 | Dibenz(a,h)anthracene | <5.0 | 5.0 |
| 84-74-2 | Di-n-butyl Phthalate | <5.0 | 5.0 |
| 95-50-1 | 1,2-Dichlorobenzene | <5.0 | 5.0 |
| 541-73-1 | 1,3-Dichlorobenzene | <5.0 | 5.0 |
| 106-46-7 | 1,4-Dichlorobenzene | <5.0 | 5.0 |
| 91-94-1 | 3,3'-Dichlorobenzidine | <20 | 20 |
| 120-83-2 | 2,4-Dichlorophenol | <5.0 | 5.0 |
| 84-66-2 | Diethyl Phthalate | <5.0 | 5.0 |
| 105-67-9 | 2,4-Dimethylphenol | <5.0 | 5.0 |
| 131-11-3 | Dimethyl Phthalate | <5.0 | 5.0 |

Continued on next page



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|-------------------|-----------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | 001 Composite | Sampled: | 12/3/13 12:55 |
| Lab Sample ID: | 1312032-15 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |
| Unit: | ug/L | Prepared: | 12/5/13 8:00 By: ALK |
| Dilution Factor: | 1 | Analyzed: | 12/11/13 7:08 By: DWJ |
| QC Batch: | 1313027 | Analytical Batch: | 3L11050 |

Semivolatile Organic Compounds by EPA Method 625 (Continued)

| CAS Number | Analyte | Analytical Result | RL |
|------------|-----------------------------|-------------------|-----|
| 534-52-1 | 4,6-Dinitro-2-methylphenol | <20 | 20 |
| 51-28-5 | 2,4-Dinitrophenol | <20 | 20 |
| 121-14-2 | 2,4-Dinitrotoluene | <5.0 | 5.0 |
| 606-20-2 | 2,6-Dinitrotoluene | <5.0 | 5.0 |
| 117-84-0 | Di-n-octyl Phthalate | <5.0 | 5.0 |
| 122-66-7 | 1,2-Diphenylhydrazine | <5.0 | 5.0 |
| 117-81-7 | Bis(2-ethylhexyl) Phthalate | <5.0 | 5.0 |
| 206-44-0 | Fluoranthene | <5.0 | 5.0 |
| 86-73-7 | Fluorene | <5.0 | 5.0 |
| 118-74-1 | Hexachlorobenzene | <5.0 | 5.0 |
| 87-68-3 | Hexachlorobutadiene | <5.0 | 5.0 |
| 77-47-4 | Hexachlorocyclopentadiene | <5.0 | 5.0 |
| 67-72-1 | Hexachloroethane | <5.0 | 5.0 |
| 193-39-5 | Indeno(1,2,3-cd)pyrene | <5.0 | 5.0 |
| 78-59-1 | Isophorone | <5.0 | 5.0 |
| 91-20-3 | Naphthalene | <5.0 | 5.0 |
| 98-95-3 | Nitrobenzene | <5.0 | 5.0 |
| 100-02-7 | 4-Nitrophenol | <20 | 20 |
| 88-75-5 | 2-Nitrophenol | <5.0 | 5.0 |
| 62-75-9 | N-Nitroso-dimethylamine | <5.0 | 5.0 |
| 86-30-6 | N-Nitroso-diphenylamine | <5.0 | 5.0 |
| 621-64-7 | N-Nitroso-di-n-propylamine | <5.0 | 5.0 |
| 87-86-5 | Pentachlorophenol | <20 | 20 |
| 85-01-8 | Phenanthrene | <5.0 | 5.0 |
| 108-95-2 | Phenol | <5.0 | 5.0 |
| 129-00-0 | Pyrene | <5.0 | 5.0 |
| 120-82-1 | 1,2,4-Trichlorobenzene | <5.0 | 5.0 |
| 88-06-2 | 2,4,6-Trichlorophenol | <5.0 | 5.0 |

Continued on next page



ANALYTICAL REPORT

| | | | |
|-------------------|------------------------------|-------------------|-----------------------|
| Client: | DTE - Fermi-2 | Work Order: | 1312032 |
| Project: | Permit Renewal - Fermi, 2013 | Description: | Laboratory Services |
| Client Sample ID: | 001 Composite | Sampled: | 12/3/13 12:55 |
| Lab Sample ID: | 1312032-15 | Sampled By: | J. Elsey |
| Matrix: | Waste Water | Received: | 12/3/13 17:00 |
| Unit: | ug/L | Prepared: | 12/5/13 8:00 By: ALK |
| Dilution Factor: | 1 | Analyzed: | 12/11/13 7:08 By: DWJ |
| QC Batch: | 1313027 | Analytical Batch: | 3L11050 |

Semivolatile Organic Compounds by EPA Method 625 (Continued)

| CAS Number | Analyte | Analytical Result | RL |
|--------------------|----------------------|-------------------|-----------------------|
| Surrogates: | | % Recovery | Control Limits |
| | 2-Fluorophenol | 40 | 18-74 |
| | Phenol-d6 | 26 | 12-47 |
| | Nitrobenzene-d5 | 66 | 34-122 |
| | 2-Fluorobiphenyl | 68 | 36-136 |
| | 2,4,6-Tribromophenol | 51 | 19-131 |
| | o-Terphenyl | 74 | 27-138 |



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
 Project: Permit Renewal - Fermi, 2013
 Client Sample ID: **001 Composite**
 Lab Sample ID: **1312032-15**
 Matrix: Waste Water

Work Order: **1312032**
 Description: Laboratory Services
 Sampled: 12/3/13 12:55
 Sampled By: J. Eisey
 Received: 12/3/13 17:00

Total Metals by EPA 200 Series Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|------------|-------------------|-------|------|-----------------|-------------|--------------------|-----|----------|
| Aluminum | 1.0 | 0.050 | mg/L | 1 | USEPA-200.7 | 12/09/13 12:16 | KLV | 1313073 |
| Antimony | <1.0 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Arsenic | 2.3 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Barium | 46 | 5.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Beryllium | <1.0 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Boron | 46 | 20 | ug/L | 1 | USEPA-200.8 | 12/10/13 10:20 | MSM | 1313011 |
| Cadmium | <0.20 | 0.20 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Chromium | <10 | 10 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Cobalt | <10 | 10 | ug/L | 1 | USEPA-200.7 | 12/09/13 12:16 | KLV | 1313073 |
| Copper | 7.1 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Iron | 1.6 | 0.010 | mg/L | 1 | USEPA-200.7 | 12/09/13 15:43 | CKD | 1313073 |
| Lead | 2.1 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Magnesium | 20 | 0.50 | mg/L | 1 | USEPA-200.7 | 12/09/13 15:43 | CKD | 1313073 |
| Manganese | 0.047 | 0.010 | mg/L | 1 | USEPA-200.7 | 12/09/13 12:16 | KLV | 1313073 |
| Molybdenum | <0.10 | 0.10 | mg/L | 1 | USEPA-200.7 | 12/05/13 09:58 | KLV | 1312991 |
| Nickel | <5.0 | 5.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Selenium | <1.0 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Silver | <0.50 | 0.50 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Thallium | <1.0 | 1.0 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |
| Tin | <0.20 | 0.20 | mg/L | 1 | USEPA-200.7 | 12/05/13 09:58 | KLV | 1312991 |
| Titanium | <0.10 | 0.10 | mg/L | 1 | USEPA-200.7 | 12/05/13 09:58 | KLV | 1312991 |
| Zinc | 18 | 10 | ug/L | 1 | USEPA-200.8 | 12/09/13 13:34 | MSM | 1313011 |



ANALYTICAL REPORT

Client: **DTE - Fermi-2**
 Project: **Permit Renewal - Fermi, 2013**
 Client Sample ID: **001 Composite**
 Lab Sample ID: **1312032-15**
 Matrix: **Waste Water**

Work Order: **1312032**
 Description: **Laboratory Services**
 Sampled: **12/3/13 12:55**
 Sampled By: **J. Elsey**
 Received: **12/3/13 17:00**

Physical/Chemical Parameters by EPA/APHA/ASTM Methods

| Analyte | Analytical Result | RL | Unit | Dilution Factor | Method | Date Time Analyzed | By | QC Batch |
|-------------------------------|-------------------|--------|--------|-----------------|----------------------|--------------------|-----|----------|
| Hardness as CaCO ₃ | 248 | 2 | mg/L | 1 | SM 2340 C-2011 | 12/06/13 14:30 | KAR | 1313099 |
| BOD, (5-Day) | <4.0 | 4.0 | mg/L | 1 | SM 5210 B-2011 | 12/04/13 11:31 | SKA | 1313038 |
| Bromide | <0.50 | 0.50 | mg/L | 1 | ASTM D 1246-05 | 12/11/13 13:00 | SLL | 1313240 |
| Chemical Oxygen Demand | 28 | 5.0 | mg/L | 1 | SM 5220 D-2011 | 12/04/13 14:59 | SLL | 1313025 |
| Color (Apparent) | 15.0 | 5.00 | A.C.U. | 1 | SM 2120 B-2011 | 12/04/13 14:23 | CAC | 1313019 |
| Fluoride | 0.23 | 0.10 | mg/L | 1 | SM 4500-F C-2011 | 12/13/13 10:40 | SLL | 1313326 |
| Surfactants, MBAS | <0.0250 | 0.0250 | mg/L | 1 | SM 5540 C-2011 | 12/04/13 12:15 | WAH | 1313020 |
| Phosphorus, Total | 0.667 | 0.0100 | mg/L | 1 | SM 4500-P E-2011 | 12/10/13 10:09 | KAR | 1313144 |
| Residue, Dissolved @ 180° C | 340 | 50 | mg/L | 1 | SM 2540 C-2011 | 12/05/13 13:00 | WAH | 1313033 |
| Residue, Suspended | 59.4 | 5.0 | mg/L | 1 | SM 2540 D-2011 | 12/05/13 15:30 | WAH | 1313036 |
| Sulfate | 49 | 10 | mg/L | 2 | ASTM D516-90 (07) | 12/12/13 10:38 | LMA | 1313298 |
| Sulfide, Total | <0.020 | 0.020 | mg/L | 1 | SM 4500-S2 D-2011 | 12/06/13 15:31 | WAH | 1313149 |
| Sulfite | <1.0 | 1.0 | mg/L | 1 | SM 4500-SO3 B-2011 | 12/04/13 13:50 | CAC | 1313110 |
| Carbon, Total Organic | 5.3 | 0.50 | mg/L | 1 | SM 5310 C-2011 | 12/05/13 20:20 | KAR | 1313095 |
| Nitrogen, Ammonia | 0.089 | 0.050 | mg/L | 1 | SM 4500-NH3 G-2011 | 12/11/13 11:15 | CLB | 1313163 |
| Nitrogen, Nitrate+Nitrite | 0.87 | 0.050 | mg/L | 1 | SM 4500-NO3 F-2011 | 12/04/13 13:19 | CAC | 1313118 |
| Nitrogen, Organic | 0.51 | 0.50 | mg/L | 1 | EPA-351.2/4500-NH3G | 12/12/13 14:35 | CLB | 1313201 |
| Nitrogen, Total Kjeldahl | 0.59 | 0.50 | mg/L | 1 | USEPA-351.2 Rev. 2.0 | 12/09/13 11:45 | CLB | 1313050 |
| Nitrogen, Inorganic | 0.96 | 0.050 | mg/L | 1 | [CALC] | 12/11/13 11:15 | CAC | [CALC] |



QUALITY CONTROL REPORT

Polychlorinated Biphenyls (PCBs) by EPA Method 608

| Analyte | Sample Conc. | Spike Qty. | Result | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---------|-----------------|---------------|--------|-----------------|-------------------|-----|---------------|----|
|---------|-----------------|---------------|--------|-----------------|-------------------|-----|---------------|----|

QC Batch: 1313086 608 Liquid/Liquid Extraction/USEPA-608

Method Blank

Analyzed: 12/13/2013 By: ASC

Unit: ug/L

Analytical Batch: 3L13025

| | | | | | | | |
|----------|--|--|-------|--|--|----|------|
| PCB-1016 | | | <0.20 | | | -- | 0.20 |
| PCB-1221 | | | <0.20 | | | | 0.20 |
| PCB-1232 | | | <0.20 | | | | 0.20 |
| PCB-1242 | | | <0.20 | | | | 0.20 |
| PCB-1248 | | | <0.20 | | | | 0.20 |
| PCB-1254 | | | <0.20 | | | | 0.20 |
| PCB-1260 | | | <0.20 | | | | 0.20 |

Surrogates:

| | | |
|----------------------|----|--------|
| Decachlorobiphenyl | 98 | 45-134 |
| Tetrachloro-m-xylene | 72 | 27-126 |

Laboratory Control Sample

Analyzed: 12/13/2013 By: ASC

Unit: ug/L

Analytical Batch: 3L13025

| | | | | | | |
|----------|-------|-------|----|--------|----|------|
| PCB-1248 | 0.600 | 0.552 | 92 | 38-158 | -- | 0.20 |
|----------|-------|-------|----|--------|----|------|

Surrogates:

| | | |
|----------------------|----|--------|
| Decachlorobiphenyl | 96 | 45-134 |
| Tetrachloro-m-xylene | 70 | 27-126 |



QUALITY CONTROL REPORT

Volatile Organic Compounds by EPA Method 624

| Analyte | Sample Conc. | Spike Qty. | Result | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|

QC Batch: 1313145 5030B Aqueous Purge & Trap/USEPA-624

Method Blank

Analyzed: 12/06/2013 By: DLV

Unit: ug/L

Analytical Batch: 3L09003

| | | |
|-----------------------------|------|-----|
| Acrolein | <5.0 | 5.0 |
| Acrylonitrile | <1.0 | 1.0 |
| Benzene | <1.0 | 1.0 |
| Bromodichloromethane | <1.0 | 1.0 |
| Bromoform | <1.0 | 1.0 |
| Bromomethane | <1.0 | 1.0 |
| Carbon Tetrachloride | <1.0 | 1.0 |
| Chlorobenzene | <1.0 | 1.0 |
| Chloroethane | <1.0 | 1.0 |
| 2-Chloroethyl Vinyl Ether | <10 | 10 |
| Chloroform | <1.0 | 1.0 |
| Chloromethane | <1.0 | 1.0 |
| Dibromochloromethane | <1.0 | 1.0 |
| 1,1-Dichloroethane | <1.0 | 1.0 |
| 1,2-Dichloroethane | <1.0 | 1.0 |
| 1,1-Dichloroethene | <1.0 | 1.0 |
| 1,3-Dichloropropene (Total) | <2.0 | 2.0 |
| trans-1,2-Dichloroethene | <1.0 | 1.0 |
| 1,2-Dichloropropane | <1.0 | 1.0 |
| Ethylbenzene | <1.0 | 1.0 |
| Methylene Chloride | <5.0 | 5.0 |
| 1,1,2,2-Tetrachloroethane | <1.0 | 1.0 |
| Tetrachloroethene | <1.0 | 1.0 |
| Toluene | <1.0 | 1.0 |
| 1,1,1-Trichloroethane | <1.0 | 1.0 |
| 1,1,2-Trichloroethane | <1.0 | 1.0 |
| Trichloroethene | <1.0 | 1.0 |
| Vinyl Chloride | <1.0 | 1.0 |

Surrogates:

| | | |
|-----------------------|-----|--------|
| Dibromofluoromethane | 101 | 85-118 |
| 1,2-Dichloroethane-d4 | 99 | 87-122 |
| Toluene-d8 | 100 | 85-113 |
| 4-Bromofluorobenzene | 95 | 82-110 |

Continued on next page



QUALITY CONTROL REPORT

Volatile Organic Compounds by EPA Method 624 (Continued)

| Analyte | Sample Conc. | Spike Qty. | Result | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|

QC Batch: 1313145 (Continued) 5030B Aqueous Purge & Trap/USEPA-624

Laboratory Control Sample

Analyzed: 12/06/2013 By: DLV

Unit: ug/L

Analytical Batch: 3L09003

| | | | | | | |
|-----------------------------|------|------|-----|--------|----|-----|
| Acrolein | 40.0 | 44.5 | 111 | 48-146 | -- | 5.0 |
| Acrylonitrile | 40.0 | 34.4 | 86 | 73-129 | -- | 1.0 |
| Benzene | 40.0 | 39.7 | 99 | 84-119 | -- | 1.0 |
| Bromodichloromethane | 40.0 | 37.6 | 94 | 82-124 | -- | 1.0 |
| Bromoform | 40.0 | 34.8 | 87 | 65-123 | -- | 1.0 |
| Bromomethane | 40.0 | 45.0 | 113 | 55-142 | -- | 1.0 |
| Carbon Tetrachloride | 40.0 | 38.2 | 95 | 79-127 | -- | 1.0 |
| Chlorobenzene | 40.0 | 38.0 | 95 | 84-118 | -- | 1.0 |
| Chloroethane | 40.0 | 49.2 | 123 | 76-124 | -- | 1.0 |
| Chloroform | 40.0 | 39.1 | 98 | 82-119 | -- | 1.0 |
| Chloromethane | 40.0 | 39.5 | 99 | 73-125 | -- | 1.0 |
| Dibromochloromethane | 40.0 | 34.9 | 87 | 74-121 | -- | 1.0 |
| 1,1-Dichloroethane | 40.0 | 39.2 | 98 | 80-118 | -- | 1.0 |
| 1,2-Dichloroethane | 40.0 | 37.8 | 95 | 81-122 | -- | 1.0 |
| 1,1-Dichloroethene | 40.0 | 42.6 | 107 | 77-123 | -- | 1.0 |
| 1,3-Dichloropropene (Total) | 80.0 | 65.5 | 82 | 81-116 | -- | 2.0 |
| trans-1,2-Dichloroethene | 40.0 | 39.7 | 99 | 76-126 | -- | 1.0 |
| 1,2-Dichloropropane | 40.0 | 40.5 | 101 | 82-122 | -- | 1.0 |
| Ethylbenzene | 40.0 | 38.2 | 96 | 87-119 | -- | 1.0 |
| Methylene Chloride | 40.0 | 38.6 | 97 | 75-129 | -- | 5.0 |
| 1,1,2,2-Tetrachloroethane | 40.0 | 37.5 | 94 | 70-137 | -- | 1.0 |
| Tetrachloroethene | 40.0 | 38.4 | 96 | 81-117 | -- | 1.0 |
| Toluene | 40.0 | 38.5 | 96 | 85-118 | -- | 1.0 |
| 1,1,1-Trichloroethane | 40.0 | 39.8 | 99 | 81-122 | -- | 1.0 |
| 1,1,2-Trichloroethane | 40.0 | 37.9 | 95 | 83-121 | -- | 1.0 |
| Trichloroethene | 40.0 | 39.9 | 100 | 82-119 | -- | 1.0 |
| Vinyl Chloride | 40.0 | 42.1 | 105 | 77-123 | -- | 1.0 |

Surrogates:

| | | |
|-----------------------|-----|--------|
| Dibromofluoromethane | 103 | 85-118 |
| 1,2-Dichloroethane-d4 | 97 | 87-122 |
| Toluene-d8 | 101 | 85-113 |
| 4-Bromofluorobenzene | 97 | 82-110 |



QUALITY CONTROL REPORT

Semivolatile Organic Compounds by EPA Method 625

| Analyte | Sample Conc. | Spike Qty. | Result | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|

QC Batch: 1313027 625 Liquid/Liquid Extraction/USEPA-625

| | | | | | | |
|------------------------------|--|--|------|-------------------|------------|---------|
| Method Blank | | | | Analyzed: | 12/11/2013 | By: DWJ |
| Unit: ug/L | | | | Analytical Batch: | 3L11050 | |
| Acenaphthene | | | <5.0 | | | 5.0 |
| Acenaphthylene | | | <5.0 | | | 5.0 |
| Anthracene | | | <5.0 | | | 5.0 |
| Benzidine | | | <50 | | | 50 |
| Benzo(a)anthracene | | | <5.0 | -- | | 5.0 |
| Benzo(a)pyrene | | | <5.0 | | | 5.0 |
| Benzo(b)fluoranthene | | | <5.0 | | | 5.0 |
| Benzo(k)fluoranthene | | | <5.0 | | | 5.0 |
| Benzo(g,h,i)perylene | | | <5.0 | | | 5.0 |
| 4-Bromophenyl Phenyl Ether | | | <5.0 | | | 5.0 |
| Butyl Benzyl Phthalate | | | <5.0 | | | 5.0 |
| 4-Chloro-3-methylphenol | | | <5.0 | | | 5.0 |
| Bis(2-chloroethoxy)methane | | | <5.0 | -- | | 5.0 |
| Bis(2-chloroethyl) Ether | | | <5.0 | | | 5.0 |
| Bis(2-chloroisopropyl) Ether | | | <5.0 | | | 5.0 |
| 2-Chloronaphthalene | | | <5.0 | | | 5.0 |
| 2-Chlorophenol | | | <5.0 | -- | | 5.0 |
| 4-Chlorophenyl Phenyl Ether | | | <5.0 | | | 5.0 |
| Chrysene | | | <5.0 | -- | | 5.0 |
| Dibenz(a,h)anthracene | | | <5.0 | | | 5.0 |
| Di-n-butyl Phthalate | | | <5.0 | -- | | 5.0 |
| 1,2-Dichlorobenzene | | | <5.0 | | | 5.0 |
| 1,3-Dichlorobenzene | | | <5.0 | | | 5.0 |
| 1,4-Dichlorobenzene | | | <5.0 | | | 5.0 |
| 3,3'-Dichlorobenzidine | | | <20 | | | 20 |
| 2,4-Dichlorophenol | | | <5.0 | | | 5.0 |
| Diethyl Phthalate | | | <5.0 | -- | | 5.0 |
| 2,4-Dimethylphenol | | | <5.0 | | | 5.0 |
| Dimethyl Phthalate | | | <5.0 | | | 5.0 |
| 4,6-Dinitro-2-methylphenol | | | <20 | -- | | 20 |
| 2,4-Dinitrophenol | | | <20 | | | 20 |
| 2,4-Dinitrotoluene | | | <5.0 | | | 5.0 |
| 2,6-Dinitrotoluene | | | <5.0 | | | 5.0 |
| Di-n-octyl Phthalate | | | <5.0 | | | 5.0 |
| 1,2-Diphenylhydrazine | | | <5.0 | | | 5.0 |
| Bis(2-ethylhexyl) Phthalate | | | <5.0 | -- | | 5.0 |

Continued on next page



QUALITY CONTROL REPORT

Semivolatile Organic Compounds by EPA Method 625 (Continued)

| Analyte | Sample Conc. | Spike Qty. | Result | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|

QC Batch: 1313027 (Continued) 625 Liquid/Liquid Extraction/USEPA-625

Method Blank (Continued)

Analyzed: 12/11/2013 By: DWJ

Unit: ug/L

Analytical Batch: 3L11050

| | | | | | | | | |
|----------------------------|--|--|------|--|--|----|-----|--|
| Fluoranthene | | | <5.0 | | | | 5.0 | |
| Fluorene | | | <5.0 | | | | 5.0 | |
| Hexachlorobenzene | | | <5.0 | | | | 5.0 | |
| Hexachlorobutadiene | | | <5.0 | | | | 5.0 | |
| Hexachlorocyclopentadiene | | | <5.0 | | | | 5.0 | |
| Hexachloroethane | | | <5.0 | | | | 5.0 | |
| Indeno(1,2,3-cd)pyrene | | | <5.0 | | | | 5.0 | |
| Isophorone | | | <5.0 | | | | 5.0 | |
| Naphthalene | | | <5.0 | | | | 5.0 | |
| Nitrobenzene | | | <5.0 | | | -- | 5.0 | |
| 4-Nitrophenol | | | <20 | | | | 20 | |
| 2-Nitrophenol | | | <5.0 | | | | 5.0 | |
| N-Nitroso-dimethylamine | | | <5.0 | | | | 5.0 | |
| N-Nitroso-diphenylamine | | | <5.0 | | | -- | 5.0 | |
| N-Nitroso-di-n-propylamine | | | <5.0 | | | | 5.0 | |
| Pentachlorophenol | | | <20 | | | | 20 | |
| Phenanthrene | | | <5.0 | | | | 5.0 | |
| Phenol | | | <5.0 | | | | 5.0 | |
| Pyrene | | | <5.0 | | | | 5.0 | |
| 1,2,4-Trichlorobenzene | | | <5.0 | | | | 5.0 | |
| 2,4,6-Trichlorophenol | | | <5.0 | | | | 5.0 | |

Surrogates:

| | | |
|----------------------|----|--------|
| 2-Fluorophenol | 49 | 18-74 |
| Phenol-d6 | 31 | 12-47 |
| Nitrobenzene-d5 | 87 | 34-122 |
| 2-Fluorobiphenyl | 94 | 36-136 |
| 2,4,6-Tribromophenol | 69 | 19-131 |
| o-Terphenyl | 98 | 27-138 |

Laboratory Control Sample

Analyzed: 12/11/2013 By: DWJ

Unit: ug/L

Analytical Batch: 3L11050

| | | | | | | |
|--------------|-----|------|----|--------|----|-----|
| Acenaphthene | 100 | 99.2 | 99 | 47-145 | -- | 5.0 |
|--------------|-----|------|----|--------|----|-----|

Continued on next page



QUALITY CONTROL REPORT

Semivolatile Organic Compounds by EPA Method 625 (Continued)

| Analyte | Sample Conc. | Spike Qty. | Result | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|

QC Batch: 1313027 (Continued) 625 Liquid/Liquid Extraction/USEPA-625

Laboratory Control Sample (Continued)

| | | |
|-------------------|------------|---------|
| Analyzed: | 12/11/2013 | By: DWJ |
| Analytical Batch: | 3L11050 | |

Unit: ug/L

| | | | | | | |
|------------------------------|-----|------|-----|--------|----|-----|
| Acenaphthylene | 100 | 102 | 102 | 33-145 | -- | 5.0 |
| Anthracene | 100 | 99.3 | 99 | 27-133 | -- | 5.0 |
| Benzidine | 200 | 171 | 86 | 28-120 | -- | 50 |
| Benzo(a)anthracene | 100 | 96.8 | 97 | 33-143 | -- | 5.0 |
| Benzo(a)pyrene | 100 | 96.8 | 97 | 17-163 | -- | 5.0 |
| Benzo(b)fluoranthene | 100 | 96.6 | 97 | 24-159 | -- | 5.0 |
| Benzo(k)fluoranthene | 100 | 104 | 104 | 11-162 | -- | 5.0 |
| Benzo(g,h,i)perylene | 100 | 96.5 | 96 | 1-219 | -- | 5.0 |
| 4-Bromophenyl Phenyl Ether | 100 | 83.0 | 83 | 53-127 | -- | 5.0 |
| Butyl Benzyl Phthalate | 100 | 98.3 | 98 | 1-152 | -- | 5.0 |
| 4-Chloro-3-methylphenol | 100 | 93.9 | 94 | 22-147 | -- | 5.0 |
| Bis(2-chloroethoxy)methane | 100 | 100 | 100 | 33-184 | -- | 5.0 |
| Bis(2-chloroethyl) Ether | 100 | 105 | 105 | 12-158 | -- | 5.0 |
| Bis(2-chloroisopropyl) Ether | 100 | 104 | 104 | 36-166 | -- | 5.0 |
| 2-Chloronaphthalene | 100 | 101 | 101 | 60-118 | -- | 5.0 |
| 2-Chlorophenol | 100 | 93.2 | 93 | 23-134 | -- | 5.0 |
| 4-Chlorophenyl Phenyl Ether | 100 | 93.5 | 94 | 25-158 | -- | 5.0 |
| Chrysene | 100 | 102 | 102 | 17-168 | -- | 5.0 |
| Dibenz(a,h)anthracene | 100 | 94.1 | 94 | 1-227 | -- | 5.0 |
| Di-n-butyl Phthalate | 100 | 94.5 | 94 | 1-118 | -- | 5.0 |
| 1,2-Dichlorobenzene | 100 | 97.5 | 98 | 32-129 | -- | 5.0 |
| 1,3-Dichlorobenzene | 100 | 98.3 | 98 | 1-172 | -- | 5.0 |
| 1,4-Dichlorobenzene | 100 | 100 | 100 | 20-124 | -- | 5.0 |
| 3,3'-Dichlorobenzidine | 200 | 214 | 107 | 1-262 | -- | 20 |
| 2,4-Dichlorophenol | 100 | 97.4 | 97 | 39-135 | -- | 5.0 |
| Diethyl Phthalate | 100 | 97.6 | 98 | 1-114 | -- | 5.0 |
| 2,4-Dimethylphenol | 100 | 91.0 | 91 | 32-119 | -- | 5.0 |
| Dimethyl Phthalate | 100 | 96.5 | 96 | 1-112 | -- | 5.0 |
| 4,6-Dinitro-2-methylphenol | 100 | 100 | 100 | 1-181 | -- | 20 |
| 2,4-Dinitrophenol | 100 | 76.0 | 76 | 1-191 | -- | 20 |
| 2,4-Dinitrotoluene | 100 | 93.2 | 93 | 39-139 | -- | 5.0 |
| 2,6-Dinitrotoluene | 100 | 90.8 | 91 | 50-158 | -- | 5.0 |
| Di-n-octyl Phthalate | 100 | 95.2 | 95 | 4-146 | -- | 5.0 |
| 1,2-Diphenylhydrazine | 100 | 96.5 | 96 | 62-128 | -- | 5.0 |
| Bis(2-ethylhexyl) Phthalate | 100 | 99.8 | 100 | 8-158 | -- | 5.0 |
| Fluoranthene | 100 | 99.8 | 100 | 26-137 | -- | 5.0 |

Continued on next page



QUALITY CONTROL REPORT

Semivolatile Organic Compounds by EPA Method 625 (Continued)

| Analyte | Sample Conc. | Spike Qty. | Result | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|
|---------|--------------|------------|--------|--------------|----------------|-----|------------|----|

QC Batch: 1313027 (Continued) 625 Liquid/Liquid Extraction/USEPA-625

Laboratory Control Sample (Continued)

Unit: ug/L

Analyzed: 12/11/2013 By: DWJ

Analytical Batch: 3L11050

| | | | | | | |
|----------------------------|-----|------|-----|--------|----|-----|
| Fluorene | 100 | 99.8 | 100 | 59-121 | -- | 5.0 |
| Hexachlorobenzene | 100 | 99.0 | 99 | 1-152 | -- | 5.0 |
| Hexachlorobutadiene | 100 | 104 | 104 | 24-116 | -- | 5.0 |
| Hexachlorocyclopentadiene | 100 | 92.3 | 92 | 21-138 | -- | 5.0 |
| Hexachloroethane | 100 | 102 | 102 | 40-113 | -- | 5.0 |
| Indeno(1,2,3-cd)pyrene | 100 | 92.4 | 92 | 21-196 | -- | 5.0 |
| Isophorone | 100 | 99.7 | 100 | 56-129 | -- | 5.0 |
| Naphthalene | 100 | 103 | 103 | 21-133 | -- | 5.0 |
| Nitrobenzene | 100 | 99.2 | 99 | 35-180 | -- | 5.0 |
| 4-Nitrophenol | 100 | 29.1 | 29 | 1-132 | -- | 20 |
| 2-Nitrophenol | 100 | 99.7 | 100 | 29-182 | -- | 5.0 |
| N-Nitroso-dimethylamine | 100 | 59.7 | 60 | 22-87 | -- | 5.0 |
| N-Nitroso-diphenylamine | 100 | 82.2 | 82 | 45-110 | -- | 5.0 |
| N-Nitroso-di-n-propylamine | 100 | 101 | 101 | 1-230 | -- | 5.0 |
| Pentachlorophenol | 100 | 80.9 | 81 | 14-176 | -- | 20 |
| Phenanthrene | 100 | 97.5 | 98 | 54-120 | -- | 5.0 |
| Phenol | 100 | 41.9 | 42 | 5-112 | -- | 5.0 |
| Pyrene | 100 | 95.9 | 96 | 52-115 | -- | 5.0 |
| 1,2,4-Trichlorobenzene | 100 | 95.1 | 95 | 44-142 | -- | 5.0 |
| 2,4,6-Trichlorophenol | 100 | 89.9 | 90 | 37-144 | -- | 5.0 |

Surrogates:

| | | |
|----------------------|----|--------|
| 2-Fluorophenol | 57 | 18-74 |
| Phenol-d6 | 38 | 12-47 |
| Nitrobenzene-d5 | 89 | 34-122 |
| 2-Fluorobiphenyl | 92 | 36-136 |
| 2,4,6-Tribromophenol | 82 | 19-131 |
| o-Terphenyl | 93 | 27-138 |



QUALITY CONTROL REPORT

Total Metals by EPA 200 Series Methods

| QC Type | Sample Conc. | Spike Qty. | Result | Unit | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---------------------------------------|--------------|------------|--------|------|--------------|----------------------|-----|------------|-------|
| Analyte: Aluminum/USEPA-200.7 | | | | | | | | | |
| QC Batch: 1313073 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: KLV | |
| Method Blank | | | <0.050 | mg/L | | | | | 0.050 |
| Laboratory Control Sample | | 2.00 | 1.87 | mg/L | 93 | 85-115 | | | 0.050 |
| Analyte: Antimony/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <1.0 | ug/L | | | | | 1.0 |
| Laboratory Control Sample | | 50.0 | 52.7 | ug/L | 105 | 85-115 | | | 1.0 |
| Analyte: Arsenic/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <1.0 | ug/L | | | | | 1.0 |
| Laboratory Control Sample | | 50.0 | 51.1 | ug/L | 102 | 85-115 | | | 1.0 |
| Analyte: Barium/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <5.0 | ug/L | | | | | 5.0 |
| Laboratory Control Sample | | 50.0 | 53.5 | ug/L | 107 | 85-115 | | | 5.0 |
| Analyte: Beryllium/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <1.0 | ug/L | | | | | 1.0 |
| Laboratory Control Sample | | 50.0 | 47.4 | ug/L | 95 | 85-115 | | | 1.0 |
| Analyte: Boron/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/10/2013 | | By: MSM | |
| Method Blank | | | <20 | ug/L | | | | | 20 |
| Laboratory Control Sample | | 50.0 | 45.2 | ug/L | 90 | 85-115 | | | 20 |
| Analyte: Cadmium/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <0.20 | ug/L | | | | | 0.20 |

Continued on next page



QUALITY CONTROL REPORT

Total Metals by EPA 200 Series Methods (Continued)

| QC Type | Sample Conc. | Spike Qty. | Result | Unit | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---|-----------------|---------------|--------|------|-----------------|----------------------|-----|---------------|-------|
| Analyte: Cadmium/USEPA-200.8 (Continued) | | | | | | | | | |
| QC Batch: 1313011 (Continued) (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Laboratory Control Sample | | 50.0 | 51.2 | ug/L | 102 | 85-115 | | | 0.20 |
| Analyte: Chromium/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <10 | ug/L | | | | | 10 |
| Laboratory Control Sample | | 50.0 | 43.8 | ug/L | 88 | 85-115 | | | 10 |
| Analyte: Cobalt/USEPA-200.7 | | | | | | | | | |
| QC Batch: 1313073 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: KLV | |
| Method Blank | | | <10 | ug/L | | | | | 10 |
| Laboratory Control Sample | | 400 | 379 | ug/L | 95 | 85-115 | | | 10 |
| Analyte: Copper/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <1.0 | ug/L | | | | | 1.0 |
| Laboratory Control Sample | | 50.0 | 47.5 | ug/L | 95 | 85-115 | | | 1.0 |
| Analyte: Iron/USEPA-200.7 | | | | | | | | | |
| QC Batch: 1313073 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: CKD | |
| Method Blank | | | <0.010 | mg/L | | | | | 0.010 |
| Laboratory Control Sample | | 0.400 | 0.391 | mg/L | 98 | 85-115 | | | 0.010 |
| Analyte: Lead/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <1.0 | ug/L | | | | | 1.0 |
| Laboratory Control Sample | | 50.0 | 50.3 | ug/L | 101 | 85-115 | | | 1.0 |
| Analyte: Magnesium/USEPA-200.7 | | | | | | | | | |
| QC Batch: 1313073 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: CKD | |
| Method Blank | | | <0.50 | mg/L | | | | | 0.50 |

Continued on next page



QUALITY CONTROL REPORT

Total Metals by EPA 200 Series Methods (Continued)

| QC Type | Sample Conc. | Spike Qty. | Result | Unit | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---|--------------|------------|--------|------|--------------|----------------------|-----|------------|-------|
| Analyte: Magnesium/USEPA-200.7 (Continued) | | | | | | | | | |
| QC Batch: 1313073 (Continued) (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: CKD | |
| Laboratory Control Sample | | 20.0 | 19.7 | mg/L | 98 | 85-115 | | | 0.50 |
| Analyte: Manganese/USEPA-200.7 | | | | | | | | | |
| QC Batch: 1313073 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: KLV | |
| Method Blank | | | <0.010 | mg/L | | | | | 0.010 |
| Laboratory Control Sample | | 0.400 | 0.378 | mg/L | 94 | 85-115 | | | 0.010 |
| Analyte: Molybdenum/USEPA-200.7 | | | | | | | | | |
| QC Batch: 1312991 (200.2 Digestion) | | | | | | Analyzed: 12/05/2013 | | By: KLV | |
| Method Blank | | | <0.10 | mg/L | | | | | 0.10 |
| Laboratory Control Sample | | 0.400 | 0.422 | mg/L | 106 | 85-115 | | | 0.10 |
| Analyte: Nickel/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <5.0 | ug/L | | | | | 5.0 |
| Laboratory Control Sample | | 50.0 | 47.0 | ug/L | 94 | 85-115 | | | 5.0 |
| Analyte: Selenium/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <1.0 | ug/L | | | | | 1.0 |
| Laboratory Control Sample | | 50.0 | 48.9 | ug/L | 98 | 85-115 | | | 1.0 |
| Analyte: Silver/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <0.50 | ug/L | | | | | 0.50 |
| Laboratory Control Sample | | 50.0 | 51.9 | ug/L | 104 | 85-115 | | | 0.50 |
| Analyte: Thallium/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <1.0 | ug/L | | | | | 1.0 |

Continued on next page



QUALITY CONTROL REPORT

Total Metals by EPA 200 Series Methods (Continued)

| QC Type | Sample Conc. | Spike Qty. | Result | Unit | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|--|--------------|------------|--------|------|--------------|----------------------|-----|------------|------|
| Analyte: Thallium/USEPA-200.8 (Continued) | | | | | | | | | |
| QC Batch: 1313011 (Continued) (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Laboratory Control Sample | | 50.0 | 49.8 | ug/L | 100 | 85-115 | | | 1.0 |
| Analyte: Tin/USEPA-200.7 | | | | | | | | | |
| QC Batch: 1312991 (200.2 Digestion) | | | | | | Analyzed: 12/05/2013 | | By: KLV | |
| Method Blank | | | <0.20 | mg/L | | | | | 0.20 |
| Laboratory Control Sample | | 2.00 | 2.12 | mg/L | 106 | 85-115 | | | 0.20 |
| Analyte: Titanium/USEPA-200.7 | | | | | | | | | |
| QC Batch: 1312991 (200.2 Digestion) | | | | | | Analyzed: 12/05/2013 | | By: KLV | |
| Method Blank | | | <0.10 | mg/L | | | | | 0.10 |
| Laboratory Control Sample | | 0.400 | 0.422 | mg/L | 106 | 85-115 | | | 0.10 |
| Analyte: Zinc/USEPA-200.8 | | | | | | | | | |
| QC Batch: 1313011 (200.2 Digestion) | | | | | | Analyzed: 12/09/2013 | | By: MSM | |
| Method Blank | | | <10 | ug/L | | | | | 10 |
| Laboratory Control Sample | | 50.0 | 54.0 | ug/L | 108 | 85-115 | | | 10 |



QUALITY CONTROL REPORT

Total Metals by EPA 1600 Series Methods

| QC Type | Sample Conc. | Spike Qty. | Result | Unit | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|--------------------------------------|--------------|------------|--------|------|----------------------|----------------|---------|------------|-------|
| Analyte: Mercury/USEPA-1631E | | | | | | | | | |
| QC Batch: 1313075 (1631E Digestion) | | | | | Analyzed: 12/05/2013 | | By: MSM | | |
| Method Blank | | | <0.500 | ng/L | | | | | 0.500 |
| Method Blank | | | <0.500 | ng/L | | | | | 0.500 |
| Method Blank | | | <0.500 | ng/L | | | | | 0.500 |
| Laboratory Control Sample | | 4.00 | 4.103 | ng/L | 103 | 77-123 | | | 0.500 |
| 1312032-02 [Outfall 001 LLHg] | | | | | | | | | |
| Matrix Spike | 7.843 | 4.00 | 11.74 | ng/L | 98 | 71-125 | | | 2.50 |
| Matrix Spike Duplicate | 7.843 | 4.00 | 11.43 | ng/L | 90 | 71-125 | 3 | 24 | 2.50 |
| QC Batch: 1313536 (1631E Digestion) | | | | | Analyzed: 12/19/2013 | | By: MSM | | |
| Method Blank | | | <0.500 | ng/L | | | | | 0.500 |
| Method Blank | | | <0.500 | ng/L | | | | | 0.500 |
| Method Blank | | | <0.500 | ng/L | | | | | 0.500 |
| Laboratory Control Sample | | 4.00 | 4.065 | ng/L | 102 | 77-123 | | | 0.500 |



QUALITY CONTROL REPORT

Physical/Chemical Parameters by EPA/APHA/ASTM Methods

| QC Type | Sample Conc. | Spike Qty. | Result | Unit | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---|--------------|------------|--------|--------|--------------|----------------------|-----|------------|------|
| Analyte: BOD, (5-Day)/SM 5210 B-2011 | | | | | | | | | |
| QC Batch: 1313038 (General Inorganic Prep) | | | | | | Analyzed: 12/04/2013 | | By: SKA | |
| Method Blank | | | <2.0 | mg/L | | | | | 2.0 |
| Laboratory Control Sample | | 198 | 189 | mg/L | 96 | 85-115 | | | 2.0 |
| Analyte: Bromide/ASTM D 1246-05 | | | | | | | | | |
| QC Batch: 1313240 (Method Specific Preparation) | | | | | | Analyzed: 12/11/2013 | | By: SLL | |
| Method Blank | | | <0.50 | mg/L | | | | | 0.50 |
| Laboratory Control Sample | | 5.00 | 5.20 | mg/L | 104 | 90-110 | | | 0.50 |
| 1312032-14 [Intake Composite] | | | | | | | | | |
| Matrix Spike | 0.304 | 2.50 | 2.83 | mg/L | 101 | 80-120 | | | 0.50 |
| Duplicate | 0.304 | | 0.295 | mg/L | | | 3 | 20 | 0.50 |
| Analyte: Carbon, Total Organic/SM 5310 C-2011 | | | | | | | | | |
| QC Batch: 1313095 (Method Specific Preparation) | | | | | | Analyzed: 12/05/2013 | | By: KAR | |
| Method Blank | | | <0.50 | mg/L | | | | | 0.50 |
| Laboratory Control Sample | | 2.00 | 2.24 | mg/L | 112 | 84-118 | | | 0.50 |
| 1312032-14 [Intake Composite] | | | | | | | | | |
| Matrix Spike | 3.58 | 2.00 | 5.71 | mg/L | 107 | 75-124 | | | 0.50 |
| Matrix Spike Duplicate | 3.58 | 2.00 | 5.68 | mg/L | 105 | 75-124 | 0.5 | 20 | 0.50 |
| Analyte: Chemical Oxygen Demand/SM 5220 D-2011 | | | | | | | | | |
| QC Batch: 1313025 (5220 D COD Digestion) | | | | | | Analyzed: 12/04/2013 | | By: SLL | |
| Method Blank | | | <5.0 | mg/L | | | | | 5.0 |
| Laboratory Control Sample | | 60.0 | 60.6 | mg/L | 101 | 95-105 | | | 5.0 |
| Analyte: Color (Apparent)/SM 2120 B-2011 | | | | | | | | | |
| QC Batch: 1313019 (Method Specific Preparation) | | | | | | Analyzed: 12/04/2013 | | By: CAC | |
| Method Blank | | | <5.00 | A.C.U. | | | | | 5.00 |
| Laboratory Control Sample | | 25.0 | 25.0 | A.C.U. | 100 | 80-120 | | | 5.00 |
| 1312032-14 [Intake Composite] | | | | | | | | | |
| Duplicate | 15.0 | | 15.0 | A.C.U. | | | 0 | 20 | 5.00 |

Continued on next page



QUALITY CONTROL REPORT

Physical/Chemical Parameters by EPA/APHA/ASTM Methods (Continued)

| QC Type | Sample Conc. | Spike Qty. | Result | Unit | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|--|--------------|------------|--------|------|--------------|----------------------|-----|------------|-------|
| Analyte: Cyanide, Available/USEPA OIA-1677 | | | | | | | | | |
| QC Batch: 1313173 (Method Specific Preparation) | | | | | | Analyzed: 12/09/2013 | | By: LMA | |
| Method Blank | | | <2.0 | ug/L | | | | | 2.0 |
| Laboratory Control Sample | | 20.0 | 21.5 | ug/L | 108 | 82-132 | | | 2.0 |
| 1312032-10 [Intake Grab Day 2] | | | | | | | | | |
| Matrix Spike | <2.0 | 20.0 | 20.7 | ug/L | 103 | 82-130 | | | 2.0 |
| Matrix Spike Duplicate | <2.0 | 20.0 | 21.3 | ug/L | 106 | 82-130 | 3 | 11 | 2.0 |
| Analyte: Fluoride/SM 4500-F C-2011 | | | | | | | | | |
| QC Batch: 1313326 (Method Specific Preparation) | | | | | | Analyzed: 12/13/2013 | | By: SLL | |
| Method Blank | | | <0.10 | mg/L | | | | | 0.10 |
| Laboratory Control Sample | | 2.00 | 1.98 | mg/L | 99 | 90-110 | | | 0.10 |
| Analyte: Hardness as CaCO3/SM 2340 C-2011 | | | | | | | | | |
| QC Batch: 1313099 (Method Specific Preparation) | | | | | | Analyzed: 12/06/2013 | | By: KAR | |
| Method Blank | | | <2 | mg/L | | | | | 2 |
| Laboratory Control Sample | | 86.3 | 87 | mg/L | 101 | 92-110 | | | 2 |
| Laboratory Control Sample | | 200 | 202 | mg/L | 101 | 92-110 | | | 2 |
| 1312032-14 [Intake Composite] | | | | | | | | | |
| Matrix Spike | 147 | 400 | 545 | mg/L | 100 | 86-113 | | | 4 |
| Duplicate | 147 | | 147 | mg/L | | | 0 | 20 | 2 |
| Analyte: HEM; Oil & Grease/USEPA-1664A | | | | | | | | | |
| QC Batch: 1313184 (1664A Extraction) | | | | | | Analyzed: 12/10/2013 | | By: WAH | |
| Method Blank | | | <5.00 | mg/L | | | | | 5.00 |
| Laboratory Control Sample | | 40.0 | 37.5 | mg/L | 94 | 78-114 | | | 5.00 |
| 1312032-03 [Outfall 001 Grab Day 2] | | | | | | | | | |
| Duplicate | <5.00 | | <5.00 | mg/L | | | | 18 | 5.00 |
| Analyte: Nitrogen, Ammonia/SM 4500-NH3 G-2011 | | | | | | | | | |
| QC Batch: 1313163 (4500-NH3 B Ammonia Distillation) | | | | | | Analyzed: 12/11/2013 | | By: CLB | |
| Method Blank | | | <0.050 | mg/L | | | | | 0.050 |

Continued on next page



QUALITY CONTROL REPORT

Physical/Chemical Parameters by EPA/APHA/ASTM Methods (Continued)

| QC Type | Sample Conc. | Spike Qty. | Result | Unit | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|--|--------------|------------|---------|------|--------------|----------------------|-----|------------|--------|
| Analyte: Nitrogen, Ammonia/SM 4500-NH3 G-2011 (Continued) | | | | | | | | | |
| QC Batch: 1313163 (Continued) (4500-NH3 B Ammonia Distillation) | | | | | | Analyzed: 12/11/2013 | | By: CLB | |
| Laboratory Control Sample | | 1.00 | 0.963 | mg/L | 96 | 90-110 | | | 0.050 |
| Analyte: Nitrogen, Nitrate+Nitrite/SM 4500-NO3 F-2011 | | | | | | | | | |
| QC Batch: 1313118 (General Inorganic Prep) | | | | | | Analyzed: 12/04/2013 | | By: CAC | |
| Method Blank | | | <0.050 | mg/L | | | | | 0.050 |
| Laboratory Control Sample | | 0.500 | 0.524 | mg/L | 105 | 90-110 | | | 0.050 |
| Analyte: Nitrogen, Total Kjeldahl/USEPA-351.2 Rev. 2.0 | | | | | | | | | |
| QC Batch: 1313050 (351.2 TKN Digestion) | | | | | | Analyzed: 12/09/2013 | | By: CLB | |
| Method Blank | | | <0.50 | mg/L | | | | | 0.50 |
| Laboratory Control Sample | | 2.00 | 2.09 | mg/L | 104 | 90-110 | | | 0.50 |
| 1312032-15 [001 Composite] | | | | | | | | | |
| Matrix Spike | 0.594 | 2.00 | 2.87 | mg/L | 114 | 90-110 | | | 0.50 |
| Matrix Spike Duplicate | 0.594 | 2.00 | 2.80 | mg/L | 110 | 90-110 | 3 | 20 | 0.50 |
| Analyte: Phenolics, Total/USEPA-420.4 | | | | | | | | | |
| QC Batch: 1313065 (Method Specific Preparation) | | | | | | Analyzed: 12/09/2013 | | By: LMA | |
| Method Blank | | | <0.0500 | mg/L | | | | | 0.0500 |
| Laboratory Control Sample | | 0.250 | 0.264 | mg/L | 105 | 90-110 | | | 0.0500 |
| Analyte: Phosphorus, Total/SM 4500-P E-2011 | | | | | | | | | |
| QC Batch: 1313144 (4500-P B Phosphorus Digestion) | | | | | | Analyzed: 12/10/2013 | | By: KAR | |
| Method Blank | | | <0.0100 | mg/L | | | | | 0.0100 |
| Laboratory Control Sample | | 0.800 | 0.784 | mg/L | 98 | 90-110 | | | 0.0100 |
| Analyte: Residue, Dissolved @ 180° C/SM 2540 C-2011 | | | | | | | | | |
| QC Batch: 1313033 (General Inorganic Prep) | | | | | | Analyzed: 12/05/2013 | | By: WAH | |
| Method Blank | | | <50 | mg/L | | | | | 50 |
| Laboratory Control Sample | | 200 | 200 | mg/L | 99 | 85-115 | | | 50 |

Continued on next page



QUALITY CONTROL REPORT

Physical/Chemical Parameters by EPA/APHA/ASTM Methods (Continued)

| QC Type | Sample Conc. | Spike Qty. | Result | Unit | Spike % Rec. | Control Limits | RPD | RPD Limits | RL |
|---|--------------|------------|---------|------|--------------|----------------------|-----|------------|--------|
| Analyte: Residue, Suspended/SM 2540 D-2011 | | | | | | | | | |
| QC Batch: 1313036 (General Inorganic Prep) | | | | | | Analyzed: 12/05/2013 | | By: WAH | |
| Method Blank | | | <3.3 | mg/L | | | | | 3.3 |
| Laboratory Control Sample | | 200 | 190 | mg/L | 95 | 88-104 | | | 24.8 |
| Analyte: Sulfate/ASTM D516-90 (07) | | | | | | | | | |
| QC Batch: 1313298 (General Inorganic Prep) | | | | | | Analyzed: 12/12/2013 | | By: LMA | |
| Method Blank | | | <5.0 | mg/L | | | | | 5.0 |
| Laboratory Control Sample | | 20.0 | 21.7 | mg/L | 108 | 88-112 | | | 5.0 |
| Analyte: Sulfide, Total/SM 4500-S2 D-2011 | | | | | | | | | |
| QC Batch: 1313149 (Method Specific Preparation) | | | | | | Analyzed: 12/06/2013 | | By: WAH | |
| Method Blank | | | <0.020 | mg/L | | | | | 0.020 |
| Laboratory Control Sample | | 0.336 | 0.345 | mg/L | 103 | 80-120 | | | 0.020 |
| Analyte: Sulfite/SM 4500-SO3 B-2011 | | | | | | | | | |
| QC Batch: 1313110 (Method Specific Preparation) | | | | | | Analyzed: 12/04/2013 | | By: CAC | |
| Method Blank | | | <1.0 | mg/L | | | | | 1.0 |
| Laboratory Control Sample | | 50.0 | 46.0 | mg/L | 92 | 80-120 | | | 1.0 |
| 1312032-15 [001 Composite] | | | | | | | | | |
| Matrix Spike | <1.0 | 50.0 | 41.0 | mg/L | 82 | 76-104 | | | 1.0 |
| Duplicate | <1.0 | | <1.0 | mg/L | | | | 20 | 1.0 |
| Analyte: Surfactants, MBAS/SM 5540 C-2011 | | | | | | | | | |
| QC Batch: 1313020 (Method Specific Preparation) | | | | | | Analyzed: 12/04/2013 | | By: WAH | |
| Method Blank | | | <0.0250 | mg/L | | | | | 0.0250 |
| Laboratory Control Sample | | 0.125 | 0.120 | mg/L | 96 | 80-120 | | | 0.0250 |
| 1312032-15 [001 Composite] | | | | | | | | | |
| Duplicate | <0.0250 | | <0.0250 | mg/L | | | | 20 | 0.0250 |

| For Lab Use Only | | 5560 Corporate Exchange Court SE Grand Rapids, MI 49512 Phone (616) 975-4500 Fax (616) 942-7463 www.trimatrixlabs.com | | Chain of Custody Record | | COC No. 131136695 | | Pg. 1 of 1 | |
|--------------------|----------------------|--|---------------------------------|-------------------------------|---|-------------------|------|--------------------|--------|
| Cart | 13 | | | Analyses Requested | | | | | |
| VOA Back Tray | 624-RED | Client Name | DTE - Fermi | Project Name | Permit Renewal | | | | |
| Receipt Log No. | 12-22 | Address | 6400 North Dixie Highway | Client Project No. / P.O. No. | | | | | |
| Project Chemist | Lisa Harvey JLR | City, State Zip | Newport, MI 48166 | Invoice To | <input checked="" type="radio"/> Client <input type="radio"/> Other (comments) | | | | |
| Work Order No. | 1312032 | Phone/Fax | 734-586-1839 | Contact/Report To | Mary Hana | | | | |
| Email: | hanamj@dteenergy.com | | | | | | | | |
| Schedule | Matrix Code | Sample Number | Field Sample ID | Cooler ID | Sample Date | Sample Time | COMP | GRAB | Matrix |
| 03 | WW | 01 | 1 Outfall 001 Grab Day 1 | 2503 | 12/21/13 | 1300 | X | WW | 2* |
| 05 | | 02 | 2 outfall 001 LLHg | ↓ | 12/21/13 | 1244 | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 02 | WW | 03 | 5 Outfall 001 Grab Day 2 | 2503 | 12/13/13 | 1235 | X | WW | 2* |
| 07 | WW | 04 | 6 Outfall 001 LLHg Duplicate | ↓ | 12/21/13 | 1247 | | | |
| 07 | WW | 05 | 7 Outfall 001 Field Blank | ↓ | 12/21/13 | 1241 | | | |
| | | | | | | | | | |
| 01 | WW | 06 | 9 Outfall 001 VOC Lab Composite | | | | X | WW | 4* |
| 06 | WW | 07 | 10 Fermi LLHg Trip Blank | 2503 | 12-2-13 | | | | |
| Sampled By (print) | | Jeff Elsey | | How Shipped? | | Hand X Carrier | | Comments 2RLM | |
| Sample's Signature | | [Signature] | | Tracking No. | | | | | |
| Company | | Trimatrix Laboratories | | 1. Relinquished By | | Date Time | | 2. Relinquished By | |
| | | | | 1. Received By | | Date Time | | 2. Received By | |
| | | | | 12/31/13 1410 | | 12-3-13 1700 | | 12/31/13 1700 | |

ORIGINAL - LABORATORY

COPY - FIELD/SAMPLER

DTE Fermi Permit Renewal 001 Grab COC

11/25/2013

| For Lab Use Only | | Chain of Custody Record | | COC No. 131136695 | | | | | | | |
|--|--------------------------------------|---|--|---------------------------------------|-------------|------------------|---------|--|--------------------------------|-------|-------------------------------------|
| Cart 13 | | Analyses Requested | | Pg. 1 of 1 | | | | | | | |
| VOA Rack/Tag 513-RED | Client Name DTE - BRRP Fermi | Project Name Permit Renewal | | PRESERVATIVES | | | | | | | |
| Receipt Log No. 42-51 | Address 6400 North Dixie Highway | Client Project No. / P.O. No. Mary Ott | | A NONE pH~7 | | | | | | | |
| Project Chemist Lisa Harvey | City, State Zip Newport, MI 48166 | Invoice To <input checked="" type="radio"/> Client <input type="radio"/> Other (comments) | | B HNO ₃ pH<2 | | | | | | | |
| Work Order No. 1312032 | Phone/Fax 734-585-1839 | Contact/Report To Mary Hana | | C H ₂ SO ₄ pH<2 | | | | | | | |
| | Email: hanami@dteenergy.com | | | D 1+1 HCl pH<2 | | | | | | | |
| | | | | E NaOH pH>12 | | | | | | | |
| | | | | F ZnAc/NaOH pH>9 | | | | | | | |
| | | | | G MeOH | | | | | | | |
| | | | | H Other (note below) | | | | | | | |
| Schedule | Matrix Code | Sample Number | Field Sample ID | Cooler ID | Sample Date | Sample Time | Matrix | Container Type (corresponds to Container Packing List) | Number of Containers Submitted | Total | Sample Comments |
| 03 | WW | 08 | 1 Intake Grab Day 1 | 2503 | 12/21/13 | 1205 | X WW 2* | X | | 2 | pH 7.51 |
| 07 | | 09 | 2 Intake LLHg | | 12/21/13 | 1202 | | | 2 | 2 | Temp 5 °C |
| | | | | | | | | | | | TRC 10.20mg/L |
| | | | | | | | | | | | DO 6.45 |
| 02 | WW | 10 | 5 Intake Grab Day 2 | 2503 | 12/23/13 | 1200 | X WW 2* | X | 1 2 2 | 9 | pH 7.57 |
| 07 | WW | 11 | 6 Intake LLHg Duplicate | | 12/23/13 | 1205 | | | 2 | 2 | Temp 12 °C |
| 07 | WW | 12 | 7 Intake LLHg Field Blank | | 12/21/13 | 1159 | | | 2 | 2 | TRC 10.20mg/L |
| | | | | | | | | | | | DO 7.50 |
| 01 | WW | 13 | 9 Intake VOC Lab Composite | | | | X WW 4* | | | 4 | *Lab: Add Day1 + Day2 VOCs together |
| | | | | | | | | | | | |
| Sampled By (print) Jeff Elsey | | | How Shipped? Hand X Carrier | | | Comments 2RLM | | | | | |
| Sampler's Signature <i>Jeff Elsey</i> | | | Tracking No. | | | | | | | | |
| Company Trimatrix Laboratories | | | 1. Relinquished By <i>Neil Tate</i> | | | Date 12/13/13 | | | Time 1410 | | |
| | | | 2. Relinquished By <i>Neil Tate</i> | | | Date 12-3-13 | | | Time 1700 | | |
| | | | 3. Relinquished By <i>Neil Tate</i> | | | Date 12-3-13 | | | Time 1700 | | |

ORIGINAL - LABORATORY

COPY - FIELD/SAMPLER

DTE Fermi Permit Renewal Intake Grab COC

11/25/2013



Phone (616) 975-4500 Fax (616) 942-7463
www.trimatrixlabs.com

COC No. 131136695

Analyses Requested

Pg. / of /

[illegible]

COPY - FIELD/SAMPLER

DTE Fermi Permit Renewal Composite COC


11/25/2013

This report shall not be reproduced, except in full, without written authorization of TriMatrix Laboratories, Inc.
Individual sample results relate only to the sample tested.

Individual sample results relate only to the sample tested.

55560 Corporate Exchange Court SE ♦ Grand Rapids, MI 49512 ♦ 616.975.4500 ♦ Fax 616.942.7463 ♦ www.trimatrixlabs.com

SAMPLE RECEIVING / LOG-IN CHECKLIST

| | | | | | |
|--|--|---|--|--|--|
|  TRIMATRIX LABORATORIES | | Client: <u>DTE-FERMI</u> Receipt Record Page/Line #: <u>41-30</u> | | Work Order #: <u>1312032</u> New / Add To: _____ Project Chemist: _____ Sample #: _____ | |
| Recorded by (initials/date): <u>JNL 12-3-13</u> | | <input checked="" type="checkbox"/> Cooler <input type="checkbox"/> Box <input type="checkbox"/> Other: _____ | | City Received: <u>2</u> Thermometer Used: <input checked="" type="checkbox"/> IR Gun (#202) <input type="checkbox"/> Digital Thermometer (#54) <input type="checkbox"/> See Additional Cooler Information Form <input type="checkbox"/> Other (# _____) | |

| Cooler # | Time | Cooler # | Time | Cooler # | Time | Cooler # | Time |
|---------------|-------------|---------------|-------------|----------|------|----------|------|
| <u>112819</u> | <u>1810</u> | <u>110410</u> | <u>1815</u> | | | | |

| | | | |
|---|---|--|--|
| Custody Seals: <input checked="" type="checkbox"/> None <input type="checkbox"/> Present / Intact <input type="checkbox"/> Present / Not Intact Coolant Location: <u>Dispersed / Top / Middle / Bottom</u> Coolant/Temperature Taken Via: <input checked="" type="checkbox"/> Loose Ice / Avg 2-3 containers <input type="checkbox"/> Bagged Ice / Avg 2-3 containers <input type="checkbox"/> Blue Ice / Avg 2-3 containers <input type="checkbox"/> None / Avg 2-3 containers Alternate Temperature Taken Via: <input checked="" type="checkbox"/> Temperature Blank (TB) <input type="checkbox"/> 1 Container | Custody Seals: <input checked="" type="checkbox"/> None <input type="checkbox"/> Present / Intact <input type="checkbox"/> Present / Not Intact Coolant Location: <u>Dispersed / Top / Middle / Bottom</u> Coolant/Temperature Taken Via: <input checked="" type="checkbox"/> Loose Ice / Avg 2-3 containers <input type="checkbox"/> Bagged Ice / Avg 2-3 containers <input type="checkbox"/> Blue Ice / Avg 2-3 containers <input type="checkbox"/> None / Avg 2-3 containers Alternate Temperature Taken Via: <input checked="" type="checkbox"/> Temperature Blank (TB) <input type="checkbox"/> 1 Container | Custody Seals: <input type="checkbox"/> None <input type="checkbox"/> Present / Intact <input type="checkbox"/> Present / Not Intact Coolant Location: <u>Dispersed / Top / Middle / Bottom</u> Coolant/Temperature Taken Via: <input type="checkbox"/> Loose Ice / Avg 2-3 containers <input type="checkbox"/> Bagged Ice / Avg 2-3 containers <input type="checkbox"/> Blue Ice / Avg 2-3 containers <input type="checkbox"/> None / Avg 2-3 containers Alternate Temperature Taken Via: <input type="checkbox"/> Temperature Blank (TB) <input type="checkbox"/> 1 Container | Custody Seals: <input type="checkbox"/> None <input type="checkbox"/> Present / Intact <input type="checkbox"/> Present / Not Intact Coolant Location: <u>Dispersed / Top / Middle / Bottom</u> Coolant/Temperature Taken Via: <input type="checkbox"/> Loose Ice / Avg 2-3 containers <input type="checkbox"/> Bagged Ice / Avg 2-3 containers <input type="checkbox"/> Blue Ice / Avg 2-3 containers <input type="checkbox"/> None / Avg 2-3 containers Alternate Temperature Taken Via: <input type="checkbox"/> Temperature Blank (TB) <input type="checkbox"/> 1 Container |
|---|---|--|--|

| Recorded °C | Correction Factor °C | Actual °C | Recorded °C | Correction Factor °C | Actual °C | Recorded °C | Correction Factor °C | Actual °C | Recorded °C | Correction Factor °C | Actual °C |
|---|----------------------|-----------|--|----------------------|-----------|---|----------------------|-----------|---|----------------------|-----------|
| Temp Blank: <u>0</u> <u>17</u> <u>0</u> <u>32</u> TB Inactive: <u>Representative</u> / <u>Not Representative</u> | | | | | | | | | | | |
| 1 | 3.0 | 0 | 3.0 | 1 | 3.3 | 0 | 3.3 | 1 | | | |
| 2 | 3.1 | 0 | 3.1 | 2 | 4.8 | 0 | 4.8 | 2 | | | |
| 3 | 3.1 | 0 | 3.1 | 3 | 4.9 | 0 | 4.9 | 3 | | | |
| Average °C: <u>3.1</u> | | | Average °C: <u>4.4</u> | | | Average °C: _____ | | | Average °C: _____ | | |
| <input checked="" type="checkbox"/> Cooler ID on COC? <input type="checkbox"/> VOC Trip Blank received? | | | <input checked="" type="checkbox"/> Cooler ID on COC? <input type="checkbox"/> VOC Trip Blank received? | | | <input type="checkbox"/> Cooler ID on COC? <input type="checkbox"/> VOC Trip Blank received? | | | <input type="checkbox"/> Cooler ID on COC? <input type="checkbox"/> VOC Trip Blank received? | | |

If any shaded areas checked, complete Sample Receiving Non-Conformance and/or Inventory Form

| | |
|--|---|
| Paperwork Received Yes No <input checked="" type="checkbox"/> Chain of Custody record(s)? If No, Initiated By _____ <input checked="" type="checkbox"/> Received for Lab Signed/Date/Time? <input type="checkbox"/> Shipping document? <input type="checkbox"/> Other: <u>FIELD DATA</u> COC Information <input checked="" type="checkbox"/> TriMatrix COC <input type="checkbox"/> Other _____ COC ID Numbers: <u>131136695</u> | Check Sample Preservation N/A Yes No <input checked="" type="checkbox"/> Average sample temperature ≤ 5° C? <input type="checkbox"/> Was thermal preservation required? If "No", Project Chemist Approval Initials: _____ <input type="checkbox"/> If "Yes" Completed Non Con Cooler - Cont Inventory Form? <input type="checkbox"/> Completed Sample Preservation Verification Form? <input checked="" type="checkbox"/> Samples chemically preserved correctly? <input type="checkbox"/> If "No", added orange tag? <input checked="" type="checkbox"/> Received pre-preserved VOC soils? <input type="checkbox"/> MeOH <input type="checkbox"/> Na ₂ SO ₄ |
|--|---|

| | |
|---|---|
| Check COC for Accuracy Yes No <input type="checkbox"/> Analysis Requested? <input checked="" type="checkbox"/> Sample ID matches COC? <input checked="" type="checkbox"/> Sample Date and Time matches COC? <input checked="" type="checkbox"/> Container type completed on COC? <input checked="" type="checkbox"/> All container types indicated are received? | Check for Short Hold-Time Prep/Analyses <input type="checkbox"/> Bacteriological <input type="checkbox"/> Air Bags <input type="checkbox"/> EnCores / Methanol Pre-Preserved <input type="checkbox"/> Formaldehyde/Aldehyde <input checked="" type="checkbox"/> Green-tagged containers <input type="checkbox"/> Yellow/White-tagged 1L ambers (SV Prep-Lab) |
|---|---|

| | |
|---|--|
| Sample Condition Summary N/A Yes No <input type="checkbox"/> Broken containers/lids? <input type="checkbox"/> Missing or incomplete labels? <input type="checkbox"/> Illegible information on labels? <input type="checkbox"/> Low volume received? <input type="checkbox"/> Inappropriate or non-TriMatrix containers received? <input type="checkbox"/> VOC vials / TOX containers have headspace? <input type="checkbox"/> Extra sample locations / containers not listed on COC? | Notes <input type="checkbox"/> Trip Blank received <input type="checkbox"/> Trip Blank not listed on COC Cooler Received (Date/Time) <u>JNL 12-3-13</u> Paperwork Delivered (Date/Time) <u>12-3-13</u> ≤ 1 Hour Goal Met? <u>Yes / No</u> |
|---|--|



SAMPLE RECEIVING / LOG-IN CHECKLIST

| | | | | | |
|--|--|---|--|--|--|
| | | Client: <u>DTE - BRPP</u> Receipt Record Page/Line #: <u>42-21</u> | | Work Order #: <u>1312032</u> New / Add To: _____ Project Chemist: _____ Sample #: _____ | |
| | | Recorded by (initials/date): <u>DN 12-3-13</u> | | Thermometer Used: <input checked="" type="checkbox"/> IR Gun (#202) <input type="checkbox"/> Digital Thermometer (#54) <input type="checkbox"/> See Additional Cooler Information Form <input type="checkbox"/> Other (# _____) | |

| Cooler # | Time | Cooler # | Time | Cooler # | Time | Cooler # | Time |
|---------------|-------------|----------|------|----------|------|----------|------|
| <u>111503</u> | <u>1837</u> | | | | | | |

| | | | |
|---|---|---|---|
| Custody Seals: <input checked="" type="checkbox"/> None <input type="checkbox"/> Present / Intact <input type="checkbox"/> Present / Not Intact Coolant Location: <u>Dispersed</u> / Top / Middle / Bottom Coolant/Temperature Taken Via: <input checked="" type="checkbox"/> Loose Ice / Avg 2-3 containers <input type="checkbox"/> Bagged Ice / Avg 2-3 containers <input type="checkbox"/> Blue Ice / Avg 2-3 containers <input type="checkbox"/> None / Avg 2-3 containers Alternate Temperature Taken Via: <input checked="" type="checkbox"/> Temperature Blank (TB) <input type="checkbox"/> 1 Container | Custody Seals: <input type="checkbox"/> None <input type="checkbox"/> Present / Intact <input type="checkbox"/> Present / Not Intact Coolant Location: Dispersed / Top / Middle / Bottom Coolant/Temperature Taken Via: <input type="checkbox"/> Loose Ice / Avg 2-3 containers <input type="checkbox"/> Bagged Ice / Avg 2-3 containers <input type="checkbox"/> Blue Ice / Avg 2-3 containers <input type="checkbox"/> None / Avg 2-3 containers Alternate Temperature Taken Via: <input type="checkbox"/> Temperature Blank (TB) <input type="checkbox"/> 1 Container | Custody Seals: <input type="checkbox"/> None <input type="checkbox"/> Present / Intact <input type="checkbox"/> Present / Not Intact Coolant Location: Dispersed / Top / Middle / Bottom Coolant/Temperature Taken Via: <input type="checkbox"/> Loose Ice / Avg 2-3 containers <input type="checkbox"/> Bagged Ice / Avg 2-3 containers <input type="checkbox"/> Blue Ice / Avg 2-3 containers <input type="checkbox"/> None / Avg 2-3 containers Alternate Temperature Taken Via: <input type="checkbox"/> Temperature Blank (TB) <input type="checkbox"/> 1 Container | Custody Seals: <input type="checkbox"/> None <input type="checkbox"/> Present / Intact <input type="checkbox"/> Present / Not Intact Coolant Location: Dispersed / Top / Middle / Bottom Coolant/Temperature Taken Via: <input type="checkbox"/> Loose Ice / Avg 2-3 containers <input type="checkbox"/> Bagged Ice / Avg 2-3 containers <input type="checkbox"/> Blue Ice / Avg 2-3 containers <input type="checkbox"/> None / Avg 2-3 containers Alternate Temperature Taken Via: <input type="checkbox"/> Temperature Blank (TB) <input type="checkbox"/> 1 Container |
|---|---|---|---|

| Recorded °C | Correction Factor °C | Actual °C | Recorded °C | Correction Factor °C | Actual °C | Recorded °C | Correction Factor °C | Actual °C | Recorded °C | Correction Factor °C | Actual °C |
|--|----------------------|------------|----------------------|----------------------|-----------|----------------------|----------------------|-----------|----------------------|----------------------|-----------|
| Temp Blank: <u>0</u> | | <u>9.3</u> | Temp Blank: <u>0</u> | | | Temp Blank: <u>0</u> | | | Temp Blank: <u>0</u> | | |
| TB location: Representative / Not Representative 1 <u>10.4</u> <u>0</u> <u>10.4</u> 2 <u>8.4</u> <u>0</u> <u>8.4</u> 3 <u>8.0</u> <u>0</u> <u>8.0</u> Average °C: <u>9.0</u> | | | | | | | | | | | |

| | |
|--|---|
| Paperwork Received Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Chain of Custody record(s)? If No, Initiated By: _____ Received for Lab Signed/Date/Time? _____ <input type="checkbox"/> Shipping document? <input type="checkbox"/> Other _____ COC Information <input checked="" type="checkbox"/> TriMatrix COC <input type="checkbox"/> Other _____ COC ID Numbers: <u>131136695</u> | Check Sample Preservation N/A <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> <input type="checkbox"/> Average sample temperature ≤ 6° C? <input type="checkbox"/> Was thermal preservation required? If "No", Project Chemist Approval Initials: _____ <input type="checkbox"/> If "Yes" Completed Non Con Cooler - Cont Inventory Form? <input type="checkbox"/> Completed Sample Preservation Verification Form? <input checked="" type="checkbox"/> Samples chemically preserved correctly? If "No", added orange tag? <input type="checkbox"/> Received pre-preserved VOC soils? <input type="checkbox"/> MeOH <input type="checkbox"/> Na ₂ SO ₄ |
|--|---|

| | |
|---|--|
| Check COC for Accuracy Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> <input type="checkbox"/> Analysis Requested? <input checked="" type="checkbox"/> Sample ID matches COC? <input checked="" type="checkbox"/> Sample Date and Time matches COC? <input checked="" type="checkbox"/> Container type completed on COC? <input checked="" type="checkbox"/> All container types indicated are received? | Check for Short Hold-Time Prep/Analyses <input type="checkbox"/> Bacteriological <input type="checkbox"/> Air Bags <input type="checkbox"/> EnCores / Methanol Pre-Preserved <input type="checkbox"/> Formaldehyde/Aldehyde <input checked="" type="checkbox"/> Green-tagged containers <input type="checkbox"/> Yellow/White-tagged 1L ambers (SV Prep-Lab) <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> AFTER HOURS ONLY: COPIES OF COC TO LAB AREA(S) <input checked="" type="checkbox"/> NONE RECEIVED <input type="checkbox"/> RECEIVED, COCs TO LAB(S) </div> |
|---|--|

| | |
|--|---|
| Sample Condition Summary N/A <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> <input type="checkbox"/> Broken containers/lids? <input type="checkbox"/> Missing or incomplete labels? <input type="checkbox"/> Illegible information on labels? <input type="checkbox"/> Low volume received? <input type="checkbox"/> Inappropriate or non-TriMatrix containers received? <input type="checkbox"/> VOC vials / TOX containers have headspace? <input type="checkbox"/> Extra sample locations / containers not listed on COC? | Notes <input type="checkbox"/> Trip Blank received <input type="checkbox"/> Trip Blank not listed on COC Cooler Received (Date/Time): <u>DN 12-3-13</u> Paperwork Delivered (Date/Time): <u>DN 12-3-13</u> ≤ 1 Hour Goal Met? <u>Yes / No</u> |
|--|---|

Log In Forms - Receiving Log-In Checklist

revision: 3.4



SAMPLE PRESERVATION VERIFICATION FORM

page 1 of 1

| | |
|-----------------------------|--|
| Client: <u>DTE-BRPP</u> | Work Order #: <u>1312037</u> |
| Receipt Log #: <u>42-21</u> | Complied By (Initials/Date): <u>JN 12-3-13</u> |
| Project Chemist: | |

| | | | | | | | |
|---------------------------|--------------------|--|--------------------------------|-------|------------------|------------------|--|
| COC ID # <u>131136695</u> | Adjusted by: _____ | DO NOT ADJUST pH FOR THESE CONTAINER TYPES | | | | | |
| | Date: _____ | | | | | | |
| Container Type | 5 / 23 | 4 | 13 | 3 | 6 | 15 | |
| Tag Color | Lt. Blue | Blue | Brown | Green | Red | Red Stripe | |
| Preservative | NaOH | H ₂ SO ₄ | H ₂ SO ₄ | None | HNO ₃ | HNO ₃ | |
| Expected pH | >12 | <2 | <2 | 6-8 | <2 | <2 | |
| COC Line #1 | | | | | | | |
| COC Line #2 | | | | | | | |
| COC Line #3 | | | | | | | |
| COC Line #4 | | | | | | | |
| COC Line #5 | ✓ | | ✓ | | | | |
| COC Line #6 | | | | | | | |
| COC Line #7 | | | | | | | |
| COC Line #8 | | | | | | | |
| COC Line #9 | | | | | | | |
| COC Line #10 | | | | | | | |

Comments

Ph Strip Lot #

HC378115

Aqueous Samples: For each sample and container type, check the box if pH is acceptable. If pH is not acceptable for any sample container, record pH in box, and note on Sample Receiving Checklist and on Sample Receiving Non-Conformance Form. If approved by Project Chemist, add acid or base to the sample to achieve the correct pH. Add up to, but do not exceed 2x the volume initially added at container prep (see table below for initial volumes used). Add orange pH tag to sample container and record information requested. Record adjusted pH on this form. Do not adjust pH for container types 3, 6, and 15.

| | | | | | | | |
|----------------|--------------------|--|--------------------------------|-------|------------------|------------------|--|
| COC ID # | Adjusted by: _____ | DO NOT ADJUST pH FOR THESE CONTAINER TYPES | | | | | |
| | Date: _____ | | | | | | |
| Container Type | 5 / 23 | 4 | 13 | 3 | 6 | 15 | |
| Tag Color | Lt. Blue | Blue | Brown | Green | Red | Red Stripe | |
| Preservative | NaOH | H ₂ SO ₄ | H ₂ SO ₄ | None | HNO ₃ | HNO ₃ | |
| Expected pH | >12 | <2 | <2 | 6-8 | <2 | <2 | |
| COC Line #1 | | | | | | | |
| COC Line #2 | | | | | | | |
| COC Line #3 | | | | | | | |
| COC Line #4 | | | | | | | |
| COC Line #5 | | | | | | | |
| COC Line #6 | | | | | | | |
| COC Line #7 | | | | | | | |
| COC Line #8 | | | | | | | |
| COC Line #9 | | | | | | | |
| COC Line #10 | | | | | | | |

Comments

| Container Size (mL) | Original Vol. of Preservative (mL) |
|---------------------|------------------------------------|
| Container Type 5 | NaOH |
| 500 | 2.5 |
| 1000 | 5.0 |
| Container Type 4 | H ₂ SO ₄ |
| 125 | 0.5 |
| 250 | 1.0 |
| 500 | 2.0 |
| 1000 | 4.0 |
| Container Type 13 | H ₂ SO ₄ |
| 500 | 2.5 |

Log In Forms.xls -- Sample_Preserve_Verification

version: 3.0



SAMPLE PRESERVATION VERIFICATION FORM

page 1 of 1

| | | | | |
|---------------|-----------|------------------------------|--------------|---------|
| Client | JTE-FERMI | | Work Order # | 1312032 |
| Receipt Log # | 42-22 | Completed By (initials/date) | JN 12-3-13 | |

| | | | | | | | | | |
|----------------|-------------|--------------------------------|--------------------------------|--------------------|------------------|------------------|--|--|--|
| COC ID # | 131136695 | | | Adjusted by: _____ | | | DO NOT ADJUST pH FOR THESE CONTAINER TYPES | | |
| | Date: _____ | | | | | | | | |
| Container Type | 5 / 23 | 4 | 13 | 3 | 6 | 15 | | | |
| Tag Color | Lt. Blue | Blue | Brown | Green | Red | Red Stripe | | | |
| Preservative | NaOH | H ₂ SO ₄ | H ₂ SO ₄ | None | HNO ₃ | HNO ₃ | | | |
| Expected pH | >12 | <2 | <2 | 6-8 | <2 | <2 | | | |
| COC Line #1 | | | | | | | | | |
| COC Line #2 | | | | | | | | | |
| COC Line #3 | | | | | | | | | |
| COC Line #4 | | | | | | | | | |
| COC Line #5 | ✓ | | ✓ | | | | | | |
| COC Line #6 | | | | | | | | | |
| COC Line #7 | | | | | | | | | |
| COC Line #8 | | | | | | | | | |
| COC Line #9 | | | | | | | | | |
| COC Line #10 | | | | | | | | | |

Comments

Ph Strip Lot #

HC378115

Aqueous Samples: For each sample and container type, check the box if pH is acceptable. If pH is not acceptable for any sample container, record pH in box, and note on Sample Receiving Checklist and on Sample Receiving Non-Conformance Form. If approved by Project Chemist, add acid or base to the sample to achieve the correct pH. Add up to, but do not exceed 2x the volume initially added at container prep (see table below for initial volumes used). Add orange pH tag to sample container and record information requested. Record adjusted pH on this form. Do not adjust pH for container types 3, 6, and 15.

| | | | | | | | | | |
|----------------|-------------|--------------------------------|--------------------------------|--------------------|------------------|------------------|--|--|--|
| COC ID # | | | | Adjusted by: _____ | | | DO NOT ADJUST pH FOR THESE CONTAINER TYPES | | |
| | Date: _____ | | | | | | | | |
| Container Type | 5 / 23 | 4 | 13 | 3 | 6 | 15 | | | |
| Tag Color | Lt. Blue | Blue | Brown | Green | Red | Red Stripe | | | |
| Preservative | NaOH | H ₂ SO ₄ | H ₂ SO ₄ | None | HNO ₃ | HNO ₃ | | | |
| Expected pH | >12 | <2 | <2 | 6-8 | <2 | <2 | | | |
| COC Line #1 | | | | | | | | | |
| COC Line #2 | | | | | | | | | |
| COC Line #3 | | | | | | | | | |
| COC Line #4 | | | | | | | | | |
| COC Line #5 | | | | | | | | | |
| COC Line #6 | | | | | | | | | |
| COC Line #7 | | | | | | | | | |
| COC Line #8 | | | | | | | | | |
| COC Line #9 | | | | | | | | | |
| COC Line #10 | | | | | | | | | |

Comments

| Container Size (mL) | Original Vol. of Preservative (mL) |
|---------------------|------------------------------------|
| Container Type 5 | NaOH |
| 500 | 2.5 |
| 1000 | 5.0 |
| Container Type 4 | H ₂ SO ₄ |
| 125 | 0.5 |
| 250 | 1.0 |
| 500 | 2.0 |
| 1000 | 4.0 |
| Container Type 13 | H ₂ SO ₄ |
| 500 | 2.5 |

Log In Forms.xls -- Sample_Preserve_Verification

version: 3.0



SAMPLE PRESERVATION VERIFICATION FORM

page 1 of 1

| | | | | |
|---------------|--------------|------------------------------|--------------|---------|
| Client | DTE - FERRIS | | Work Order # | 1312032 |
| Receipt Log # | 4120 | Completed By (initials/date) | JN12-3-13 | |

| | | | | | | | | | | | | |
|----------------|-----------|--------------------------------|--------------------------------|-------------|------------------|------------------|--|--|--|--|----------------|----------|
| COC ID # | 131136695 | | | Adjusted by | | | | DO NOT ADJUST pH FOR THESE CONTAINER TYPES | | | Ph Strip Lot # | HC378115 |
| | Date: | | | | | | | | | | | |
| Container Type | 5 / 23 | 4 | 13 | 3 | 6 | 15 | | | | | | |
| Tag Color | Lt. Blue | Blue | Brown | Green | Red | Red Stripe | | | | | | |
| Preservative | NaOH | H ₂ SO ₄ | H ₂ SO ₄ | None | HNO ₃ | HNO ₃ | | | | | | |
| Expected pH | >12 | <2 | <2 | 6-8 | <2 | <2 | | | | | | |
| COC Line #1 | | ✓ | | ✓ | ✓ | | | | | | | |
| COC Line #2 | | ✓ | | ✓ | ✓ | | | | | | | |
| COC Line #3 | | | | | | | | | | | | |
| COC Line #4 | | | | | | | | | | | | |
| COC Line #5 | | | | | | | | | | | | |
| COC Line #6 | | | | | | | | | | | | |
| COC Line #7 | | | | | | | | | | | | |
| COC Line #8 | | | | | | | | | | | | |
| COC Line #9 | | | | | | | | | | | | |
| COC Line #10 | | | | | | | | | | | | |
| Comments | | | | | | | | | | | | |

Aqueous Samples: For each sample and container type, check the box if pH is acceptable. If pH is not acceptable for any sample container, record pH in box, and note on Sample Receiving Checklist and on Sample Receiving Non-Conformance Form. If approved by Project Chemist, add acid or base to the sample to achieve the correct pH. Add up to, but do not exceed 2x the volume initially added at container prep (see table below for initial volumes used). Add orange pH tag to sample container and record information requested. Record adjusted pH on this form. Do not adjust pH for container types 3, 6, and 15.

| | | | | | | | | | | | | | |
|----------------|----------|--------------------------------|--------------------------------|-------------|------------------|------------------|--|--|--|--|---------------------|------------------------------------|--------------------------------|
| COC ID # | | | | Adjusted by | | | | DO NOT ADJUST pH FOR THESE CONTAINER TYPES | | | Container Size (mL) | Original Vol. of Preservative (mL) | |
| | Date: | | | | | | | | | | | | |
| Container Type | 5 / 23 | 4 | 13 | 3 | 6 | 15 | | | | | | Container Type 5 | NaOH |
| Tag Color | Lt. Blue | Blue | Brown | Green | Red | Red Stripe | | | | | | 500 | 2.5 |
| Preservative | NaOH | H ₂ SO ₄ | H ₂ SO ₄ | None | HNO ₃ | HNO ₃ | | | | | | 1000 | 5.0 |
| Expected pH | >12 | <2 | <2 | 6-8 | <2 | <2 | | | | | | Container Type 4 | H ₂ SO ₄ |
| COC Line #1 | | | | | | | | | | | | 125 | 0.5 |
| COC Line #2 | | | | | | | | | | | | 250 | 1.0 |
| COC Line #3 | | | | | | | | | | | | 500 | 2.0 |
| COC Line #4 | | | | | | | | | | | | 1000 | 4.0 |
| COC Line #5 | | | | | | | | | | | | Container Type 13 | H ₂ SO ₄ |
| COC Line #6 | | | | | | | | | | | | 500 | 2.5 |
| COC Line #7 | | | | | | | | | | | | | |
| COC Line #8 | | | | | | | | | | | | | |
| COC Line #9 | | | | | | | | | | | | | |
| COC Line #10 | | | | | | | | | | | | | |
| Comments | | | | | | | | | | | | | |

Log In Forms.xls -- Sample_Preserve_Verification

version: 3.0

DTE Electric Company
One Energy Plaza, Detroit, MI 48226



March 21, 2016

Ms. Christine Alexander, Unit Chief
Lakes Erie and Huron Permits Unit
MDEQ Cashiers Office
WB – NP2
P.O. Box 30657
Lansing, Michigan 48909

Re: Application for Renewal of NPDES Permit
DECO - Fermi 3 Power Plant
NPDES Permit No. MI0058892

Dear Ms. Alexander:

In accordance with the Michigan Department of Environmental Quality Authorization to Discharge under NPDES Permit No. MI0058892, the DTE Electric Company has submitted the application via MiWaters for the renewal of the DECO - Fermi 3 Power Plant permit. The \$750.00 application fee was paid at the time the application was submitted.

Comments Regarding the Application on MiWaters

- Section IA: The application did not allow the NPDES permit number to be entered.
- Additional Information: The analytical data and this cover letter are attached to the application.

The Company would appreciate your expeditious review of this application and an acknowledgement of its receipt and administrative completeness as soon as practical.

If you have any questions relative to this application or desire additional information, please contact me at (313) 235-5569 or via e-mail at chueyn@dteenergy.com.

Sincerely,
DTE Energy Corporate Services, LLC

Nicholas J. Chuey
Senior Environmental Engineer
Environmental Management & Resources