

## Saxton, John

---

**From:** Mike Gaither <mike.gaither@UR-Energy.com>  
**Sent:** Thursday, March 24, 2016 5:25 PM  
**To:** Saxton, John  
**Cc:** Kurt Brown; John Cash; Steven Hatten  
**Subject:** [External\_Sender] Lost Creek Storage Pond Sump Update

FYI. Sump levels in the two sumps were recorded as over 6 inches on Monday March 21, 2016 due to the continued residual seepage.

North Pond Sump: 8.75 inches

South Pond Sump: 6.5 inches

The levels were elevated since the purge lines from the sumps were frozen and would not allow the sump levels to be drawn down. The levels have since been maintained under the 6 inch level. A sample will be collected from each sump and the recharge rates are being monitored. Details will be forthcoming in the quarterly report.

**Michael Gaither**  
Manager EHS and Regulatory Affairs  
Ur-Energy USA Inc.  
5880 Enterprise Dr. Suite 200  
Casper, WY 82609 USA  
(307) 265-2373 ext. 321

