

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 12168
FILE: ENVIRO

FROM: Duke Power Company Charlotte, N.C. 28201 A.C. Thies		DATE OF DOC 11-29-74	DATE REC'D 12-2-74	LTR X	TWX	RPT	OTHER
TO: Mr. A. Giambusso		ORIG 1 signed	CC	OTHER	SENT AEC PDR <u>XX</u>		SENT LOCAL PDR <u>XX</u>
CLASS	UNCLASS XXXX	PROP INFO	INPUT	NO CYS REC'D 1	DOCKET NO: 50-269(270)287		
DESCRIPTION: Ltr adv of fish weighing 1,150 grams collecting on the screens & trans:				ENCLOSURES: Oconee Nuclear Station Summary of Fish Impingement Data Per Intake Screen Dated Nov. 21, 1974.....			
PLANT NAME: Oconee Units 1,2&3				<p align="right">ACKNOWLEDGED</p> <p align="right">Do Not Remove</p>			
FOR ACTION INFORMATION							

DHL 12-2-74

- | | | | |
|-------------------------|----------------------------|-----------------------------|------------------------|
| BUTLER (L)
W/ Copies | SCHWENCER (L)
W/ Copies | ZIEMANN (L)
W/ Copies | REGAN (E)
W/ Copies |
| CLARK (L)
W/ Copies | STOLZ (L)
W/ Copies | DICKER (E)
W/ 2 Copies | LEAR (L)
W/ Copies |
| PARR (L)
W/ Copies | VASSALLO (L)
W/ Copies | KNIGHTON (E)
W/ Copies | W/ Copies |
| KNIEL (L)
W/ Copies | PURPLE (L)
W/ Copies | YOUNGBLOOD (E)
W/ Copies | W/ Copies |

INTERNAL DISTRIBUTION

- | | | | | |
|---------------------|------------------|-----------------|---------------------|-------------------------|
| <u>REG FILE (2)</u> | TECH REVIEW | <u>SEXTON</u> | LIC ASST | A/T IND |
| <u>AEC PDR (3)</u> | <u>SCHROEDER</u> | GRIMES | DIGGS (L) | BRAITMAN |
| OGC, ROOM P-806A | MACCARY | GAMMILL | GEARIN (L) | SALTZMAN |
| MUNTZING, STAFF | KNIGHT | KASTNER | GOULBOURNE (L) | B. HURT |
| CASE | PAWLICKI | BALLARD | KREUTZER (E) | PLANS |
| GIAMBUSO | SHAO | SPANGLER | LEE (L) | MCDONALD |
| BOYD | STELLO | ENVIRO | MAIGRET (L) | CHAPMAN |
| MOORE (L) (BWR) | HOUSTON | <u>MULLER</u> | REED (E) | DUBE w/ PDR |
| DEYOUNG (L) (PWR) | NOVAK | DICKER | SERVICE (L) | E. COUPE |
| SKOVHOLT (L) | ROSS | KNIGHTON | <u>SHEPPARD (L)</u> | D. THOMPSON (2) |
| <u>GOLLER (L)</u> | IPPOLITO | YOUNGBLOOD | SLATER (E) | KLECKER |
| P. COLLINS | TEDESCO | REGAN | SMITH (L) | EISENHUT |
| DENISE | LONG | PROJECT LDR | TEETS (L) | <u>PURPLE / Ziemann</u> |
| <u>REG ORR</u> | LAINAS | <u>Scalitti</u> | WILLIAMS (E) | |
| FILE & REGION (3) | BENAROYA | HARLESS | WILSON (L) | |
| MORRIS | VOLIMER | | | |
| STEELE | | | | |

EXTERNAL DISTRIBUTION

Enrico H

- | | | |
|---------------------------------|-----------------------------|-------------------------|
| <u>LOCAL PDR</u> Walhalla, S.C. | NATIONAL LABS <u>ORNL</u> | 1 - PDR SAN LARRY |
| TIC (ALTERNATIVE) | ASLAVE W/ Bldg. Rem EOC | 1 - BROOKHAVEN NAT LAB |
| NSIC (BUCHANAN) | W. PENNINGTON, Rm E-201 GT | 1 - G. ULTRON, CIVIL |
| ASLB | B&S SWINE ROAD, Rm E-201 GT | 1 - AGYED (RUTH) LARSEN |
| ACR | CONSULTANTS | 1 - R. D. MUELLE |
| SENT TO | NEWARK BY ONE AGRABIAN | |
| LIC ASST. KREUTZER 12-2-74 | | |

Regulatory
Eve Cy.

DUKE POWER COMPANY

POWER BUILDING


422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201

A. C. THIES
SENIOR VICE PRESIDENT
PRODUCTION AND TRANSMISSION

P. O. Box 2178

November 29, 1974

Mr. Angelo Giambusso
Deputy Director for Reactor Projects
Directorate of Licensing
Office of Regulation
U. S. Atomic Energy Commission
Washington, D. C. 20545



Re: Oconee Nuclear Station
Docket Nos. 50-269, 270, -287

Dear Mr. Giambusso:


On November 21, 1974, six of the 24 condenser cooling water (CCW) intake screens at the Oconee Nuclear Station were inspected. A total of 685 small fingerling fish, weighing 1,150 grams, had collected on the screens. The fish, averaging 1.7 grams per fish, were removed from the screens and categorized, where possible, as to screen location, type, size, degree of decomposition, and weight. This information is tabulated in Enclosure 1. It is concluded that the mortality of these 1,150 grams of fish had an insignificant effect on fisheries resources in Lake Keowee.

Very truly yours,

A. C. Thies

ACT:gje
Enclosure

cc: Mr. H. J. Logan
S. C. Wildlife & Marine Resources Dept.



12168

Enclosure 1

OCONEE NUCLEAR STATION

Received w/ Ltr Dated 11-29-74

SUMMARY OF FISH IMPINGEMENT

DATA PER INTAKE SCREEN

November 21, 1974

Screen 1-A-1

Total Fish Impinged - 483

<u>Species Composition</u>	<u>Size Groups</u>	<u>Decomposition*</u>	<u>Weight</u>
Bluegill - 51	2-4 cm - 333	Class 1 - 18	~ 800 gms
Yellow Perch - 14	4-6 cm - 115	Class 2 - 277	
Threadfin Shad - 243	6-8 cm - 24	Class 3 - 16	
Largemouth Bass - 1	8-10cm - 3	Class 4 - 172	
Crappie - 2	10-12cm - 8		
Unidentified - 172			

Screen 2-A-2

Total Fish Impinged - 30

<u>Species Composition</u>	<u>Size Groups</u>	<u>Decomposition*</u>	<u>Weight</u>
Yellow Perch - 1	2-4 cm - 17	Class 1 - 0	~ 50 gms
Threadfin Shad - 2	4-6 cm - 12	Class 2 - 1	
Unidentified - 27	6-8 cm - 1	Class 3 - 2	
		Class 4 - 27	

Screen 3-A-1

Total Fish Impinged - 77

<u>Species Composition</u>	<u>Size Groups</u>	<u>Decomposition*</u>	<u>Weight</u>
Bluegill - 5	2-4 cm - 3	Class 1 - 16	~ 125 gms
Yellow Perch - 18	4-6 cm - 47	Class 2 - 8	
Threadfin Shad - 5	6-8 cm - 27	Class 3 - 4	
Unidentified - 49		Class 4 - 49	

Screen 3-A-2

Total Fish Impinged - 95

<u>Species Composition</u>	<u>Size Groups</u>	<u>Decomposition*</u>	<u>Weight</u>
Bluegill - 20	2-4 cm - 22	Class 1 - 5	~ 175 gms
Yellow Perch - 27	4-6 cm - 61	Class 2 - 46	
Threadfin Shad - 23	6-8 cm - 10	Class 3 - 20	
Unidentified - 24	10-12cm - 1	Class 4 - 24	
Crappie - 1	12-14cm - 1		

- * Class 1 - No noticeable decomposition
 Class 2 - Slightly decomposed
 Class 3 - Badly decomposed, identifiable
 Class 4 - Badly decomposed, unidentifiable