

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9403300028 DOC. DATE: 94/03/24 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 GRIER, G.W. Duke Power Co. R
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk) I

SUBJECT: Responds to request for addl info re Generic Ltr 92-01, Rev 1. D

DISTRIBUTION CODE: A028D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4 S
 TITLE: Generic Letter 92-01 Responses (Reactor Vessel Structural Integrity 1 /

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME	LTR	ENCL	
	PD2-3 PD		1	1	WIENS, L	2	2	
INTERNAL:	ACRS		6	6	NRR/DE/EMCB	2	2	
	NRR/DORS/OGCB		1	1	NRR/DRPE/PDI-1	1	1	
	NRR/DRPW		1	1	NUDOCS-ABSTRACT	1	1	
	OC/LFDCB		1	0	OGC/HDS2	1	0	
	<u>REG FILE</u> 01		1	1	RES/DE/MEB	1	1	
EXTERNAL:	NRC PDR		1	1	NSIC	1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 19

R
I
D
S
/
A
D
D
S

Duke Power Company
Electric Center
P.O. Box 1006
Charlotte, N.C. 28201-1006



DUKE POWER

March 24, 1994

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555


Subject: Oconee Nuclear Station Units 1, 2 & 3
Docket Nos. 50-269, 270, 287
Response to Request for Additional Information
Concerning Generic Letter 92-01, Revision 1

Gentlemen:


By letter dated November 22, 1993, Duke Power Company submitted a response to a Request for Additional Information (RAI) for Oconee Nuclear Station. Subsequently, during a telephone conversation with a member of your staff, we were asked to provide additional information in order to complete the evaluation of the RAI. Attached is the additional information requested.

Should you have any questions regarding this submittal, please contact A. Jones-Young at (704) 382-3154.

Very truly yours,


G. W. Grier
Nuclear Generation

Attachment



A028
1/1

U. S. NRC
March 24, 1994
Page 2

xc: S. D. Ebnetter
Regional Administrator, Region II

L. A. Wiens, ONRR

P. E. Harmon
Senior Resident Inspector (ONS)

ATTACHMENT



B&W NUCLEAR TECHNOLOGIES

3315 Old Forest Road
P.O. Box 10935
Lynchburg, VA 24506-0935
Telephone: 804-385-2000
Telecopy: 804-385-3663

March 3, 1994
ESC-94-194

Mr. J. D. Gilreath
Duke Power Company
P.O. Box 1007
Charlotte, NC 28201-1007

Subject: Specimen Orientation for Estimated USE Values

- Reference:
- 1) BWNT Document 77-1228575-00 "Reply To RAI Regarding Generic Letter 92-01 - Response For Oconee 1,2,3"
 - 2) BAW 10046A Revision 2

Dear Jeff:

The reference 1) document specified the estimated Charpy V-notch Upper-Shelf Energy (USE) values for base metal plates and forgings based on the data presented in reference 2).

In response to your inquiry concerning specimen orientation for these estimated values, BWNT has determined that the specimens used as the supporting data for the estimated USE values were oriented normal to the principal working direction (ie weak direction).

If you require any supporting documentation or any additional information please call me at (804)385-3293 or Len Gross at (804)385-3194.

Very truly yours,

D. L. Howell
Program Manager
Owners Group Services

DLH/mcl