Serial No. NA3-16-008 Docket No. 52-017

# **ENCLOSURE 7**

**GEH Technical Report** 

# WG3-U73-ERD-S-0004 Revision 2

Control Building Structural Design Report



WG3-U73-ERD-S-0004 Sheet 1 of 219 Rev. 2

STRUCTURAL DESIGN REPORT

2

N/A

# **REVISION STATUS SHEET**

Document Title:

Control Building Structural Design Report

Revision #:

**Type:** Engineering Report – Design

Safety Related **Classification Code:** 

MPL No.: U73-5010

"I" Vertical Sidebar **Denotes Change** 

Rev #	DOORS BL	Change Number	MM/DD/YYYY	Preparing Organization	Issue / Release Status	Verification Status
0	N/A	ECO- 0015275	10/16/2015	GEH	Issued for Use- Design	Verified
1	N/A	ECO- 0021450	01/04/2016	GEH	Issued for Use- Design	Verified
2	N/A	ECO- 0023228	03/10/2016	GEH	Issued for Use- Design	Verified

MADE BY	APPROVALS	AUTH. DATE
Gary Ehlert	Tanya B. Kirby	10/16/2015
GEH	GEH	

Public Information Notice

This is a public version of WG3-U73-ERD-S-0003, Rev 2, from which the security-related information has been removed. Portions of the document that have been removed are indicated by white space within single brackets as shown here { }. The footer of each page where security-related information is withheld carries the notation "{{{Security-Related Information -Withheld Under 10 CFR 2.390}}}."

#### IMPORTANT NOTICE REGARDING CONTENTS OF THIS REPORT **Please Read Carefully**

The design, engineering, and other information contained in this document are furnished for the purpose(s) stated in the "Development Agreement between Virginia Electric and Power Company and the consortium of GE-Hitachi Nuclear Energy Americas LLC and Fluor Enterprises, Inc." dated April 5, 2013 as amended. The use of this information by anyone other than Virginia Electric and Power Company, or for any purpose other than that for which it is furnished by GEH is not authorized; and with respect to any unauthorized use, GEH makes no representation or warranty, express or implied, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document, or that its use may not infringe privately owned rights.

Copyright 2016, GE-Hitachi Nuclear Energy Americas LLC, All Rights Reserved

WG3-MA-08-004-D014-T01 Rev 0.0 04/23/2015, NA3 Project Structural Design Report Template



.

Υ.

# **REVISION CHART (CONT)**

Rev #	DOORS BL	Change Number	MM/DD/YYYY	Preparing Organization	Issue / Release Status	Verification Status
					-	



# **RECORD OF REVISION**

Rev #	Description
0	Initial issue
1	Incorporate comments on Rev.0
2	Incorporate comments on Rev.1



# TABLE OF CONTENTS

$1. \qquad \mathbf{Sec}$	ppe10
2. Apj	plicable Documents10
2.1 2.1.1 2.1.2 2.2 2.3 2.4	Supporting and Supplemental Documents10Supporting Documents10Supplemental Documents10Industry Codes and Standards11Regulation and Regulatory Requirements11References11
3. Stru	uctural description and geometry12
3.1 3.2 3.3 3.4	Structural Geometry and Dimensions.12Key Structural Elements and Descriptions12Floor Layout and Elevations.12Conditions of Vicinity and Support.12
4. Stru	actural material requirements12
4.1 4.2 4.3	Concrete12Reinforcement12Structural Steel13
5. Stru	actural loads13
$5.1 \\ 5.1.1 \\ 5.1.2 \\ 5.1.3 \\ 5.2 \\ 5.2.1 \\ 5.2.2 \\ 5.2.3 \\ 5.3 \\ 5.4 \\ 5.5 \\ 5.6 \\ $	Dead Loads13Structural Weight13Other Weight13Equipment Weight14Live Loads14Floor Live Loads14Static Soil Pressure14Snow Loads14Thermal Loads14Wind Loads15Tornado Loads15Seismic Loads15
6. Stru	actural Analysis and design16
6.1 6.2 6.2.1 6.2.2 6.2.3 6.2.4	General Description16Stress Analysis17Analysis Program17Analysis Model17Method of Applying Loads19Analysis Results23



63		Load Combinations	24
0.5	2 1	L'oade Complimations	24
6.	.3.1	Code Requirements	24
6.	3.2	Selection of Design Load Combinations	24
6.	.3.3	Result of Load Combinations	24
6.4		Section Design Principles	25
6.	.4.1	Section Design of Reinforced Concrete Structures	25
6.	.4.2	Section Design of Steel Structures	28
7.	Sum	nmary of Results	32
7.1		Required Sections	32
7.2		Provided Sections	32
7.3		Tabulation of Allowable Stresses versus Calculated Stresses	33
7.	3.1	Reinforced Concrete Structures	
7.	3.2	Steel Structure	34
7.4		External Wall Capacity Evaluation	34
7.5		Missile Impact Evaluations	35
8.	Con	clusions	35
	App	bendix A Comparison with DCD Data	178
	App	endix B In-plane Shear Check for the CB according to ACI 349-01	207
	App	pendix C Compression Limit Check For the CB According to ACI 349-01	215



# LIST OF TABLES

Table 3.4-1 Conditions of Applied Site Properties	36
Table 5.1-1 Equipment Load	36
Table 5.2-1 Floor Live Loads	37
Table 5.2-2 Calculation of At-Rest Pressure	37
Table 5.3-1 Result of Heat Transfer Analysis, Normal Operation: Summer	38
Table 5.3-2 Result of Heat Transfer Analysis, Normal Operation: Winter	39
Table 5.3-3 Result of Heat Transfer Analysis, DBA: Summer	.40
Table 5.3-4 Result of Heat Transfer Analysis, DBA: Winter	41
Table 5.4-1 Design Wind Pressure Loads by Floor Level	42
Table 5.5-1 Design Pressure of Tornado Wind Load	42
Table 5.6-1 Design Seismic Loads for Horizontal	43
Table 5.6-2 Vertical Acceleration	44
Table 5.6-3 Dynamic Soil Pressures	45
Table 6.2-1 Soil Spring Constants	46
Table 6.2-2 Properties of Structural Material	46
Table 6.2-3 Design Basic Load Case List	47
Table 6.2-4 Analysis Load Case List	48
Table 6.2-5 Applied Shear and Moment for Walls, NS Input	49
Table 6.2-6 Applied Shear and Moment for Walls, EW Input	50
Table 6.2-7 Additional Overturning Moments for Basemat	51
Table 6.2-8 Slab Vertical Acceleration	51
Table 6.2-9 Applied Torsional Moment	51
Table 6.2-10 Applied Force due to Torsional Moment, EL 9.06 to 13.80	52
Table 6.2-11 Applied Force due to Torsional Moment, EL 4.65 to 9.06	53
Table 6.2-12 Applied Force due to Torsional Moment, EL -2.00 to 4.65	54
Table 6.2-13 Applied Force due to Torsional Moment, EL -7.40 to -2.00	55
Table 6.2-14 Results of NASTRAN Analysis: Dead Load	56
Table 6.2-15 Results of NASTRAN Analysis: Temperature Load (DBA: Winter)	57
Table 6.2-16 Results of NASTRAN Analysis: Site-Specific Seismic Load (Horizontal: North t	to
South Direction)	58
Table 6.2-17 Results of NASTRAN Analysis: Site-Specific Seismic Load (Horizontal: East to	I
West Direction)	59
Table 6.2-18 Results of NASTRAN Analysis: Site-Specific Seismic Load (Vertical: Upward	
Direction)	60
Table 6.3-1 Load Combinations and Acceptance Criteria for Safety-Related Reinforced Concr	ete
Structures	61
Table 6.3-2 Load Combinations and Acceptance Criteria for Safety-Related Steel Structures	62
Table 6.3-3 Selected Load Combinations for Reinforced Concrete Structures	63
Table 6.3-4 Selected Load Combination for Steel Structures	63
Table 6.3-5 Detailed Load Combinations for Reinforced Concrete Structures	64
Table 6.3-6 Detailed Load Combinations for Steel Structures	65
Table 6.3-7 Combined Forces and Moments: Selected Load Combination CB-3	66

.



WG3-U73-ERD-S-0004	SH NO.	7
REV. 2	of 2	19

Table 6.3-9 Combined Forces and Moments: Selected Load Combination CB-7 ......70 Table 6.3-10 Combined Forces and Moments: Site-Specific Seismic Load Combination CB-9..72 Table 6.4-3 Allowable Stress of Reinforcement for Membrane Plus Bending ......75 Table 6.4-4 Allowable Stress of Concrete for Membrane Compression ......76 Table 7.3-1 Rebar and Concrete Stresses (Basemat and Slabs): Selected Load Combination CB-379 Table 7.3-2 Rebar and Concrete Stresses (Walls): Selected Load Combination CB-3 ......80 Table 7.3-3 Rebar and Concrete Stresses (Basemat and Slabs): Selected Load Combination CB-481 Table 7.3-4 Rebar and Concrete Stresses (Walls): Selected Load Combination CB-4 ......82 Table 7.3-5 Rebar and Concrete Stresses (Basemat and Slabs): Selected Load Combination CB-783 Table 7.3-6 Rebar and Concrete Stresses (Walls): Selected Load Combination CB-7......84 Table 7.3-7 Rebar and Concrete Stresses (Basemat and Slabs): Site-Specific Seismic Load Combination CB-9......85 Table 7.3-8 Rebar and Concrete Stresses (Walls): Site-Specific Seismic Load Combination CB-985 Table 7.3-9 Maximum Stress Ratios (Basemat and Slabs) for Flexure and Membrane Forces ....86 
 Table 7.3-10 Maximum Stress Ratios (Walls) for Flexure and Membrane Forces

 86

 Table 7.3-11 Maximum Stress Ratios for Membrane Compressive Forces
 87

 Table 7.3-12 Calculation Results for Maximum Transverse Shear
 88
 Table 7.3-14 Maximum Stress Ratio of Selected Columns at the rows CB and C2, X-direction .90 Table 7.3-15 Maximum Stress Ratio of Selected Columns at the rows CB and C2, Y-direction .92 Table 7.3-16 Maximum Stress Ratio of Selected Girders at the row CB......94 Table 7.3-17 Maximum Stress Ratio of Selected Girders at the row C2......96 Table 7.4-1 Dynamic Soil Pressures for Evaluating CB External Walls......100 Table 7.4-2 Rebar and Concrete Stresses of CB External Walls: Site-Specific Seismic Load Combination CB-9 ......100 Table 7.4-3 Maximum Transverse Shear of CB External Walls ......100



# LIST OF FIGURES

Figure 3.3-1 Concrete Outline Plan at EL -7.40	.101
Figure 3.3-2 Concrete Outline Plan at EL -2.00	.102
Figure 3.3-3 Concrete Outline Plan at EL 4.65	.103
Figure 3.3-4 Concrete Outline Plan at EL 9.06	.104
Figure 3.3-5 Concrete Outline Plan at EL 13.80	.105
Figure 3.3-6 Concrete Outline E-W Section	.106
Figure 5.2-1 Soil Pressure at Rest	.107
Figure 5.3-1 Normal Operation Temperatures	.108
Figure 5.3-2 DBA Temperatures	.109
Figure 5.3-3 Heat Transfer Analysis	.110
Figure 5.6-1 Dynamic Analysis Model	.111
Figure 5.6-2 Design Seismic Shear and Moments for CB	.112
Figure 5.6-3 Seismic Lateral Soil Pressure	.113
Figure 6.2-1 FE Model (Isometric View)	.114
Figure 6.2-2 FE Model, Basemat EL -7.40.	.115
Figure 6.2-3 FE Model, North Wall	.116
Figure 6.2-4 FE Model, Inner Wall	.117
Figure 6.2-5 FE Model, South Wall	.118
Figure 6.2-6 FE Model, East Wall	.119
Figure 6.2-7 FE Model, West Wall	.120
Figure 6.2-8 FE Model, B1F EL -2.00	.121
Figure 6.2-9 FE Model, 1F EL 4.65	.122
Figure 6.2-10 FE Model, 2F EL 9.06	.123
Figure 6.2-11 FE Model, Roof EL 13.80	.124
Figure 6.2-12 FE Model of Steel Plan, EL -2.00	.125
Figure 6.2-13 FE Model of Steel Plan, EL 4.65	.126
Figure 6.2-14 FE Model of Steel Plan, EL 9.06	.127
Figure 6.2-15 FE Model of Steel Plan, EL 13.80	.128
Figure 6.2-16 FE Model of CB Steel Frame	.129
Figure 6.2-17 FE Model of CC Steel Frame	.130
Figure 6.2-18 FE Model of C2 Steel Frame	.131
Figure 6.2-19 FE Model of C3 Steel Frame	.132
Figure 6.2-20 FE Model of C4 Steel Frame	.133
Figure 6.2-21 Calculation Method for Shear Forces and Overturning Moments	.134
Figure 6.2-22 Method of Applying Shear Forces	.135
Figure 6.2-23 Method of Applying Overturning Moments	.136
Figure 6.2-24 Method of Calculation Shear Forces due to Torsion	.137
Figure 6.2-25 Deformation due to Structure Load, GRAV	.138
Figure 6.2-26 Deformation due to Structure Load, DL	.139
Figure 6.2-27 Deformation due to Structure Load, EL	.140
Figure 6.2-28 Deformation due to Structure Load, LL.	.141
Figure 6.2-29 Deformation due to Structure Load, SP	.142



WG3-U73-ERD-S-0004	SH NO.	9
REV. 2	of 2	19

Figure 6.2-30 Deformation due to Structure Load, TLS0	143
Figure 6.2-31 Deformation due to Structure Load, TLW0	144
Figure 6.2-32 Deformation due to Structure Load, TLS1	145
Figure 6.2-33 Deformation due to Structure Load, TLW1	146
Figure 6.2-34 Deformation due to Structure Load, WON	147
Figure 6.2-35 Deformation due to Structure Load, WOS	148
Figure 6.2-36 Deformation due to Structure Load, WOE	149
Figure 6.2-37 Deformation due to Structure Load, WOW	150
Figure 6.2-38 Deformation due to Structure Load, WTN	151
Figure 6.2-39 Deformation due to Structure Load, WTS	152
Figure 6.2-40 Deformation due to Structure Load, WTE	153
Figure 6.2-41 Deformation due to Structure Load, WTW	154
Figure 6.2-42 Deformation due to Structure Load, WTD	155
Figure 6.2-43 Deformation due to Structure Load, XS	156
Figure 6.2-44 Deformation due to Structure Load, YS	157
Figure 6.2-45 Deformation due to Structure Load, VAS	158
Figure 6.2-46 Deformation due to Structure Load, TMS	159
Figure 6.2-47 Deformation due to Structure Load, SPNS	160
Figure 6.2-48 Deformation due to Structure Load, SPEW	161
Figure 6.2-49 Forces and Moments in Shell Element	162
Figure 6.4-1 Design Flow Chart of Reinforced Concrete Structures	163
Figure 6.4-2 Calculation of Shear Strength Provided by Concrete	164
Figure 6.4-3 Allowable Stress of W-shaped Members (Strong Axis Bending)	165
Figure 6.4-4 Allowable Stress of W-shaped Members (Weak Axis Bending)	166
Figure 6.4-5 Allowable Bending Stress of Box Members	167
Figure 7.1-1 Assumed Basemat Rebar Arrangement (unit: mm)	168
Figure 7.1-2 Assumed Floor Slabs Rebar Arrangement (unit: mm)	169
Figure 7.1-3 Assumed Walls Rebar Arrangement (unit: mm)	171
Figure 7.1-4 Structural Steel Member, Elevation on Col-Row CB	173
Figure 7.1-5 Structural Steel Member, Elevation on Col-Row C2	174
Figure 7.3-1 Elements Selected for Tabulation, Elevation on Col-Row CB	175
Figure 7.3-2 Elements Selected for Tabulation, Elevation on Col-Row C2	176
Figure 7.3-3 Stress Check of Members Subject to Two Direction Forces	177



Designation

# 1. SCOPE

The objective of this report is to document the North Anna Unit 3 (NA3) site-specific structural design evaluation of the Economic Simplified Boiling Water Reactor (ESBWR) Control Building (CB) for the site-specific seismic load demands that exceed the seismic loads used for the standard design of the CB structure in Reference 2.1.2-i. The scope of the evaluation is the analysis and stress checks of the structure for the site-specific seismic loads in combinations. The analysis is performed using the same NASTRAN model used for the standard design of the CB structure in Reference 2.1.2-i. The design loads applied to the model are the same as those considered in the standard design, except for the site-specific Safe Shutdown Earthquake (SSE) loads that are obtained from Reference 2.1.2-1. The NA3 site-specific SSE loads are combined with non-seismic standard plant loads following the same standard design analysis methodology and acceptance criteria.

### 2. APPLICABLE DOCUMENTS

#### 2.1 Supporting and Supplemental Documents

The following documents form a part of this document:

### 2.1.1 Supporting Documents

Supporting documents are those documents that complete the requirements of this document and are referred to herein.

		Designation
a.	Control Building Concrete Drawings, 105E4057	U73-2010

#### 2.1.2 Supplemental Documents

Supplemental documents are those documents that are to be used in conjunction with this document.

		Designation		
a.	Standard Review Plans and Regulatory Guides Design Specification,	SR3-1-A11-		
	TRD-5201, Revision 0	A11-5201		
b.	Industry Codes and Standards Design Specification, SR3-1-A11-TRI	s and Standards Design Specification, SR3-1-A11-TRD-5202,		
	Revision 0	A11-5202		
c.	Composite Design Specification, 26A6007, Revision 6	A11-5299		
d.	Seismic Design Input Design Specification, 26A6561	A25-4010		
e.	General Civil Design Criteria, 26A6558, Revision 4	A40-4010		
f.	Design Specification for Control Building, 26A6607, Revision 2	U73-4010		
g.	Stability Analysis of Control Building, 26A6654, Revision 4	U73-5020		
h.	Seismic Analysis of Control Building, 26A6648, Revision 4	U73-5030		
i.	Control Building Structural Design Report, 26A6653, Revision 5	U73-5010		
i.	North Anna 3 Control Building Stability Analysis Report, WG3-U73	-ERD-S-0003.		

J. North Anna 3 Control Building Stability Analysis Report, WG3-U73-ERD-S-0003 Revision 2



k. North Anna 3 Control Building Seismic Analysis Report, WG3-U73-ERD-S-0001, Revision 2

1. North Anna 3 Bounding Seismic Demands CB and FWSC Site-Specific Evaluations, SER-DMN-032, Revision 3

m. North Anna 3 Control Building and Reactor/Fuel Building Complex Seismic Soil-Structure Interaction Analysis Report, WG3-U73-ERD-S-0005, Revision 3

n. North Anna 3 Control Building and Firewater Service Complex Seismic Structure-Soil-Structure Interaction Analysis Report, WG3-U73-ERD-S-0002, Revision 6

o. WG3-U71-ERD-S-0004, "Reactor Building Structural Design Report", Revision 1

# 2.2 Industry Codes and Standards

The following industry codes and standards shall form a part of this document to the extent specified herein. Unless otherwise specified, the applicable revision of the industry codes and standards as indicated in the Industry Codes and Standards Design Specification (Reference 2.1.2-b) shall be used.

- a. ACI 349-01: "Code Requirements for Nuclear Safety-Related Concrete Structures (ACI 349-01) and Commentary (ACI 349R-01)"
- b. ASME-2004: Boiler and Pressure Vessel Code, Section III, Rules for Construction of Nuclear Power Plant Components, Division 2, Subsection CC, "Code for Concrete Reactor Vessels and Containments"
- c. AISC N690-1994: "Specification for the Design, Fabrication, and Erection of Steel Safety-Related Structures for Nuclear Facilities," with the Supplements No.1 (2002) and No.2 (2004)
- d. ASCE 7-02: "Minimum Design Loads for Buildings and other Structures," 2002
- e. ASCE 4-98: "Seismic Analysis of Safety-Related Nuclear Structures", 1998.
- f. ASTM A615: "Specification for Deformed and Plain Billet-Steel Bar for Concrete Reinforcement Steel"

# 2.3 Regulation and Regulatory Requirements

The following regulations and regulatory requirements shall form a part of this document to the extent specified herein. Unless otherwise specified, the applicable revision of the Standard Review Plans (SRP) and Regulatory Guides (RG) as indicated in the Standard Review Plans and Regulatory Guides Design Specification (Reference 2.1.2-a) shall be used.

a. NUREG-0800, "USNRC Standard Review Plan for Review of Safety Analysis Reports for Nuclear Power Plants Light Water Reactor Edition"

# 2.4 References

a. BC-TOP-3A: "Tornado and Extreme Wind Design Criteria for Nuclear Power Plants", Rev.3, Aug. 1974



- b. TM 5-855-1: "Fundamentals of Protective Design for Conventional Weapons", Department of the Army Technical Manual, Nov. 1986
- c. BC-TOP-9A: "Design of Structures for Missile Impact", Rev.2, Sep. 1974

# 3. STRUCTURAL DESCRIPTION AND GEOMETRY

### **3.1 Structural Geometry and Dimensions**

The CB houses the essential electrical, control and instrumentation equipment, the control room for the Reactor and Turbine Buildings, and the CB HVAC equipment. The CB is a Seismic Category I structure.

The CB has outside dimensions of 23.8 m x 30.3 m, 21.2 m high above the basemat. It consists of four floors, two of which are below-grade. It is embedded into the ground, such that the top of basemat is 11.9 m below the finished ground level grade.

### **3.2 Key Structural Elements and Descriptions**

The CB is a reinforced concrete box type shear wall structure consisting of walls and slabs and is supported by a foundation mat. Steel framing is composite with concrete slab and used to support the slabs for vertical loads.

### **3.3 Floor Layout and Elevations**

Floor layouts and sections of the CB are shown in Figures 3.3-1 through 3.3-6.

### **3.4 Conditions of Vicinity and Support**

The site-specific evaluation presented in this report considers supporting subgrade conditions shown in Table 3.4-1 that correspond to the generic Soft Site described in Reference 2.1.2-h. The applied site properties are identical to those used for the standard design. The consideration of generic Soft Site conditions for the NA3 rock site is conservative because a softer subgrade results in larger structural deformations and stress demands on the CB basemat and structure.

Ground temperature is considered to be 15.5 °C.

### 4. STRUCTURAL MATERIAL REQUIREMENTS

# 4.1 Concrete

Concrete for the CB structures has the following compressive strength, f'c:

- $f'_c = 27.6 \text{ MPa} = 4000 \text{ psi:}$  basemat
- $f'_c = 34.5 \text{ MPa} = 5000 \text{ psi:}$  other CB structures

#### 4.2 Reinforcement

Reinforcement is Grade 60 deformed billet steel that conforms to ASTM A615 (Reference 2.2-f). Minimum yield strength,  $f_y$  is 414 MPa = 60000 psi.



# 4.3 Structural Steel

- ASTM A572, Grade 50 (for steel frame members such as Columns, Girders, Beams, etc.)
- ASTM A36 (for miscellaneous steel such as Embedded plate, etc.)

# 5. STRUCTURAL LOADS

# 5.1 Dead Loads

The following types of dead loads are considered in the structural evaluation and are identical to those used for the standard design of the CB structure in Reference 2.1.2-i.

# 5.1.1 Structural Weight

The weights of modeled structural members, i.e., concrete slabs, walls and steel columns, are included in the model by specifying the unit weight density for each material, so that they are automatically accounted for in the analysis calculation.

The following unit weights are used for modeled members:

- Reinforced concrete: 23.5 kN/m<sup>3</sup>
- Steel: 77.0 kN/m<sup>3</sup>

# 5.1.2 Other Weight

The following weights are considered in the analysis:

1. Deck and steel beam  $\dots 3.0 \text{ kN/m}^2$ 

# 2. Finishing weight

	<ul> <li>Man-walking roof (cover concrete, waterproofing)</li> </ul>	1.8 kN/m <sup>2</sup>
	– Floor slab	1.0 kN/m <sup>2</sup>
	- Exterior wall below-grade (water proofing)	0.2 kN/m <sup>2</sup>
	- Exterior wall above-grade (architectural finishing concrete)	1.2 kN/m <sup>2</sup>
3.	Parapet weight	
	- Parapet on roof	9.0 kN/m

- 4. Reinforced-concrete-made partition walls
  - Weight of reinforced-concrete-made partition walls is calculated and applied as a uniform load to the specific area.
- 5. Piping load
  - Miscellaneous commodities and their supports...... 2.4 kN/m<sup>2</sup>



# 5.1.3 Equipment Weight

Table 5.1-1 shows the weights of major equipment located on floors. 20% design margin is added to the equipment weight in accordance with U73-4010, "Design Specification for Control Building" (Reference 2.1.2-f).

Equipment weights, which are identical to those used for the standard design of the CB structure in Reference 2.1.2-i, are calculated and applied as uniform loads to the floor slab elements by their tributary area.

### 5.2 Live Loads

The following three live loads are considered in the structural evaluation and are identical to those used for the standard design of the CB structure in Reference 2.1.2-i.

### 5.2.1 Floor Live Loads

Floor live loads are also shown in Table 5.2-1. Floor live loads are reduced to 1/4 of their values when used in the evaluation of seismic loads.

### 5.2.2 Static Soil Pressure

The static lateral soil pressure loads, which are shown in Table 5.2-2 and Figure 5.2-1, are applied to the external walls below grade. These loads envelope the generic site conditions considered for the standard design in Reference 2.1.2-i and the NA3 site-specific static lateral pressures as shown in Section 7 of Reference 2.1.2-j. Evaluations of lateral soil pressures are described in Appendix B of Reference 2.1.2-i.

### 5.2.3 Snow Loads

Snow loads considered for the site-specific evaluation of the CB structure are identical to those used for the standard design of CB structure in Reference 2.1.2-i and are shown in Table 5.2-1. Snow loads are taken as 2.4 kN/m<sup>2</sup> (50 psf). The magnitude of the snow loads applied to the area by staircases on roof slab is greater than 2.4 kN/m<sup>2</sup> to account for the effects of snow drift. One hundred percent of the snow load is used in the evaluation of seismic loads. The NA3 site-specific snow loads (1.2 kN/m<sup>2</sup> (25 psf)) are bounded by the above standard design loads.

# **5.3 Thermal Loads**

Figures 5.3-1 and 5.3-2 provide the temperatures during normal plant operation and Design Basis Accident (DBA), which are considered for both summer and winter seasons. These temperatures are identical to those used for the standard design of the CB structure in Reference 2.1.2-i.

The thermal loads for the CB are obtained by heat transfer analysis. Figure 5.3-3 shows the equations of heat transfer analysis. The room temperatures in winter and summer are provided in Tables 5.3-1 through 5.3-4 for both normal operation condition (To) and DBA condition (Ta). Average temperature (Td) and temperature difference (Tg) of walls and slabs are determined by equivalent linearization of the analysis results.



# 5.4 Wind Loads

Design conditions for calculating the basic wind load are as follows:

Basic wind speed (50 year recurrence interval), m/s (mph)	62.6 (140)
Importance Factors (Safety-Related structures)	1.15
Exposure Category	Exposure D

Wind load values at each floor level are shown in Table 5.4-1. The evaluation of these design wind loads, which are identical to those used for the standard design of the CB structure, is described in Appendix B of Reference 2.1.2-i. The NA3 site-specific wind loads (Basic wind speed is 40.2 m/s (90 mph)) are bounded by the above standard design loads.

# 5.5 Tornado Loads

Design conditions for calculating the tornado wind load are as follows:

Maximum Tornado wind speed, m/s (mph)	147.5 (330)
Maximum Rotational Speed, m/s (mph)	116.2 (260)
Maximum Translational Speed, m/s (mph)	31.3 (70)
Radius, m (ft)	45.7 (150)
Maximum Pressure Drop, kPa (psi)	16.6 (2.4)
Maximum Rate of Pressure Drop, kPa/s (psi/s)	11.7 (1.7)

Tornado load values at each floor level are shown in Table 5.5-1. The evaluation of design tornado loads, which are identical to those used for the standard design of the CB structure, is described in Appendix B in Reference 2.1.2-i. The NA3 site-specific tornado loads (for example, Maximum Tornado wind speed is 134.1 m/s (300 mph)) are bounded by the above standard design loads.

# 5.6 Seismic Loads

The seismic loads considered in the CB design are those generated by the site-specific SSE.

The design seismic loads are determined from the site-specific Soil-Structure Interaction (SSI) analysis results, described in the site-specific seismic analysis of the CB (Reference 2.1.2-k). Reference 2.1.2-l provides the site-specific seismic loads used for the evaluation presented in this report. These loads bound the effects of concrete cracking as described in Reference 2.1.2-k and the effects of Structure-Soil-Structure Interaction (SSSI) of the RB/FB and FWSC on the seismic response of CB as described in References 2.1.2-m and 2.1.2-n, respectively. The SSSI between the CB and FWSC, or the CB and RB/FB have a small effect on the site-specific seismic response of the CB at the NA3 site. The difference, which is only in vertical acceleration, is under 8%. Therefore, these effects are enveloped by design margin.



Four components - two horizontal, one vertical, and one torsional - of the seismic loads are evaluated following the methodology used for the standard design of the CB structure in Reference 2.1.2-i.

The site-specific seismic design loads applied to the CB structures are shown in the following tables and figures:

- Horizontal and torsional seismic loads: Table 5.6-1, Figure 5.6-2
- Vertical accelerations: Table 5.6-2

The node numbers in the tables are described in Figure 5.6-1. The following load is also regarded as a seismic load, and is considered in the CB design:

• Soil pressure due to an earthquake

The design soil pressure loads due to earthquakes are calculated from the envelope of SASSI (System for Analysis of Soil-Structure Interaction) results described in Reference 2.1.2-k. Reference 2.1.2-l provides the site-specific seismic lateral pressure loads used for the evaluation presented in this report and bound the effects of concrete cracking as described in Reference 2.1.2-k and the effects of SSSI of the RB/FB and FWSC on the seismic response of the CB as described in References 2.1.2-m and 2.1.2-n, respectively. The lateral pressure loads used for the site-specific evaluation are presented in Table 5.6-3 and Figure 5.6-3.

# 6. STRUCTURAL ANALYSIS AND DESIGN

# **6.1 General Description**

The structural analysis and design of the CB are performed consistently with the procedure used for the standard design in Reference 2.1.2-i, as follows:

- 1. Perform stress analyses for the site-specific seismic loads, described in Section 5.6, using the same Finite Element (FE) model as the one used for the standard design to calculate section forces due to SSE.
- 2. Combine the SSE section forces with the section forces due to non-seismic design loads, calculated in Reference 2.1.2-i, according to the site-specific seismic design load combination described later in Section 6.3.
- 3. Perform structural design calculations using the section forces from the site-specific seismic design load combination and compare them with the corresponding results for the non-seismic load combinations selected in Reference 2.1.2-i.

The design / evaluation is essentially performed using ASME, Section III, Division 2 (Reference 2.2-b) to use the same procedure as that in Reference 2.1.2-i.

The design of steel members in the CB is performed in accordance with AISC N690-1994.



# 6.2 Stress Analysis

# 6.2.1 Analysis Program

The computer program used for the stress analysis calculation is MSC/NASTRAN version 2013. It is a general-purpose stress analysis program, which is technically based on the FE method. Analysis calculations are executed on Red Hat Enterprise Linux Server release 5.7 OS.

# 6.2.2 Analysis Model

# 6.2.2.1 Outline of the Analysis Model

The stress analysis model is a three-dimensional FE model. Figure 6.2-1 illustrates the global stress analysis model, which is identical to the model used for the standard design in Reference 2.1.2-i.

# 6.2.2.2 Modeling Principles

The global FE model was developed for the standard design according to the following modeling principles:

- 1. Primary structure members, including basemat, walls, and roof slab are modeled so that their design section forces are adequately evaluated.
- 2. The global coordinate system of the analysis model is determined as follows:
  - Origin: The origin is at EL 0.0 m at the corner of the North and West wall.
  - X-axis: Positive X is the southward direction from the origin.
  - Y-axis: Positive Y is the eastward direction from the origin.
  - Z-axis: Positive Z is the vertically upward direction.
- 3. Local coordinate system (for application of element forces) of vertical shell elements, such as exterior walls, and inner walls, is determined as follows:
  - For East and West walls:
    - Z-axis: Positive Z is the westward direction.
    - X-axis: Positive X is same as the global X-axis.
    - Y-axis: Positive Y is the vertically upward direction.
  - For North and South walls:
    - Z-axis: Positive Z is the southward direction.
    - X-axis: Positive X is same as the global Y-axis.
    - Y-axis: Positive Y is the vertically upward direction.



- 4. Local coordinate system of horizontal shell elements, such as the basemat and roof slab, is determined as follows:
  - Z-axis: Positive Z is the vertically upward direction.
  - X-axis: Positive X is same as the global X-axis.
  - Y-axis: Positive Y is same as the global Y-axis.

### 6.2.2.3 Modeling of the Basemat and Ground

### 6.2.2.3.1 Basemat

The basemat is modeled with thick shell elements that have equal thickness of 3.0 m. The elements are placed horizontally at the center of basemat, EL -8.90 m. The horizontal region of the basemat model is limited by the center of the exterior walls.

Figure 6.2-2 shows the FE model of the basemat.

### 6.2.2.3.2 Ground

The ground is modeled with spring elements. Three independent spring elements, one vertical and two horizontals, are attached to each of the basemat grid points.

Spring constants are calculated using the generic soil properties described in Section 3.4. Table 6.2-1 shows the vertical and horizontal spring constants of the unit area of the CB. These values are multiplied by the tributary area of each grid point to estimate the spring constants of spring elements.

The constants are calculated based on soil spring constants of the Sway-Rocking model for standard plant SSI analyses (Reference 2.1.2-h).

# 6.2.2.4 Modeling of Shear Walls

The seismic walls, which are considered in the seismic analysis model, are included in the global analysis model.

The walls are modeled with shell elements. They are divided horizontally at the same locations as those of the basemat grid points, and vertically into three elements in each story. FE models of the walls are shown in Figures 6.2-3 through 6.2-7.

Openings in the seismic walls are modeled by eliminating corresponding elements, if their areas are  $3.0 \text{ m}^2$  or larger.

### 6.2.2.5 Modeling of Floor Slabs

Floor slabs are modeled with horizontal shell elements. Elements are positioned at the center of the slab thickness.

FE models of the slabs are shown in Figures 6.2-8 through 6.2-11.

### 6.2.2.6 Modeling of Frame Members

Frame members included in the global stress analysis model are steel columns and steel girders. They are modeled with bar elements.



Figures 6.2-12 through 6.2-20 show FE models of frame members.

# 6.2.2.7 Units and Material Constants

Stress analyses are executed with the following SI units:

- length: m
- force: MN
- moment: MN m
- pressure: MPa
- temperature: °C

Material constants shown in Table 6.2-2 are used for the stress analysis calculations.

Young's modulus used for concrete in the thermal load analysis is reduced, depending on the average temperature of each element as shown in Table 6.2-2.

# 6.2.3 Method of Applying Loads

Table 6.2-3 shows a list of the design basic load cases. A total of 22 load cases were considered in Reference 2.1.2-i for the standard design of the Reinforced Concrete (RC) shell elements, such as basemat, walls and slabs, and steel frame members, such as columns and girders. Table 6.2-4 shows a list of the analysis load cases considered for the standard design. In order to obtain the member stresses under site-specific seismic loads, the global FE model analyses are performed for the site-specific seismic load cases. A total of six site-specific seismic load cases are analyzed for the site-specific evaluation presented in this report.

# 6.2.3.1 Dead Loads

# 6.2.3.1.1 Structural Weight (GRAV)

The weights of reinforced concrete members included in the analysis model were evaluated in Reference 2.1.2-i using a GRAV feature that NASTRAN provides. It applies a downward gravity force to each element mass, which is calculated from the unit weight density and the volume of the element.

Evaluation of the structural weights using the GRAV feature has one drawback, which is double counting of weights at such regions as wall-to-wall and wall-to-slab corners and edges of girders and columns; however, this double counting is ignored in the analysis, for the following reasons: (1) duplicated weights of corners are negligibly small compared to the total weight of the analysis model and (2) the increased weights of girders lead to a design with larger margins.

# 6.2.3.1.2 Other Dead Weight (DL)

Dead weights, other than those included in the analysis model by using a GRAV feature, were evaluated in Reference 2.1.2-i as specified in Section 5.1.2 and applied to the analysis model as follows:



a. Decks and Steel Beams

The weights of decks and steel beams are applied to slabs as distributed surface loads.

b. Finishing

The weights of finishing for roof slabs, floor slabs, and exterior walls are applied as distributed loads.

c. Partition Walls

The weights of RC-made partition walls, which are not included in the model, are applied as uniformly distributed element loads.

d. Parapet

The uniform loads due to parapet weight are applied as concentrated forces at the intersection grids of parapets and roof slab. The applied force to each grid is calculated according to its tributary area.

e. Piping Loads

The weights of miscellaneous structures, piping and commodities are applied as distributed surface loads to the floor slab elements.

# 6.2.3.1.3 Equipment Loads (EL)

The unit loads due to equipment weight were calculated in Reference 2.1.2-i as specified in Section 5.1.3. They were applied to the slab elements as uniformly distributed surface loads.

# 6.2.3.2 Live Loads

In order to obtain the design live loads, the stress analyses were performed in Reference 2.1.2-i for the following load cases (LL1, LL2, SP).

# 6.2.3.2.1 Live Loads (LL1, LL2)

Floor live loads are applied to modeled slab elements as uniformly distributed surface loads.

The snow loads are applied to the roof slab. However, the snow loads on the roof by staircases at EL 13.80 m are larger than floor live loads, so the snow loads are applied instead of the floor live load.

The live load LL1 is the maximum value of floor live loads and snow loads for the condition of normal operation. And the live load LL2 is the maximum value of 25% floor live loads and 100% snow loads for calculating the vertical seismic forces.

# 6.2.3.2.2 Static Soil Pressure (SP)

The lateral soil pressure at rest is applied to the exterior walls below-grade. The average pressure for each element is calculated and applied as a uniformly distributed pressure load.



### 6.2.3.3 Thermal Loads

The average temperature Td, and the surface temperature difference, Tg, are obtained by heat transfer analyses as described in Section 5.3 and are applied to the corresponding shell elements.

# 6.2.3.4 Wind Loads

For the standard design analyses in Reference 2.1.2-i, the wind pressure loads acting on the walls and roof slab were applied to shell elements as uniform pressure loads. The average pressure for each element is calculated and applied to the element as a uniformly distributed pressure load.

Wind loads that act on exterior wall openings are applied to grid points around the openings as nodal forces. The nodal force applied to each grid point is determined according to its tributary area.

The description of the design wind loads (WON, WOS, WOE and WOW) are as follows. WON is a wind load from North to South. WOS is a wind load from South to North. WOE is a wind load from East to West. WOW is a wind load from West to East.

### 6.2.3.5 Tornado Loads

Analyses for the tornado wind loads were performed in Reference 2.1.2-i using the same method as the one used for design wind load.

A maximum pressure of 0.0165 MPa, shown in Table 5.5-1, is applied to roof slab and exterior walls above-grade as the tornado differential load.

The description of the design tornado wind loads (WTN, WTS, WTE and WTW), and tornado differential load (WTD) are as follows. WTN is a wind load from North to South. WTS is a wind load from South to North. WTE is a wind load from East to West. WTW is a wind load from West to East.

### 6.2.3.6 Site-Specific Seismic Loads

The site-specific seismic forces applied to the model for the site-specific stress analyses are determined from the design seismic loads presented in Section 5.6. Four components – two horizontal, one vertical, and one torsional – of the seismic loads are evaluated.

The methods of applying the site-specific seismic forces on the model are described below.

### 6.2.3.6.1 Shear Forces & Overturning Moment (XS, YS)

Calculation methods for the shear forces and the overturning moments are given in Figure 6.2-21. The horizontal force applied to each story is calculated by subtracting the design shear force for the story above from the design shear force for that story. The overturning moment applied to each story is determined in such a way that the sum of the applied moment and the one due to shear forces applied to the stories above is equal to or larger than the design moment of the story. The moment is adjusted considering the difference between the height where the design seismic loads are obtained and the height where the seismic forces are applied.



Tables 6.2-5 and 6.2-6 summarize the applied shear forces and overturning moments for the seismic walls for both earthquake directions. Columns "m+dMq" in these tables show the values of the applied moments.

### Shear Forces

Shear forces are applied as horizontal nodal forces to grid points as illustrated in Figure 6.2-22. The nodal forces are applied to grid points that are on the walls and at floor slab levels.

In addition to the design shear forces, the inertia forces of the basemat due to the earthquake are applied to the basemat grid points. Inertia forces are applied as horizontal nodal forces. The nodal force applied to each node is calculated as the tributary weight of the node multiplied by the specified acceleration.

### **Overturning Moments**

Overturning moments are applied as vertical nodal forces to grid points as illustrated in Figure 6.2-23. The magnitude of the vertical force is assumed to be proportional to the distance from the center of the building in each direction. The nodal force applied to each node is then calculated by multiplying it by the tributary wall area of the node. The nodal forces are applied to grid points that are on the walls at floor slab levels.

In addition to the design overturning moments mentioned above, an additional moment is applied to the basemat in order to adjust the total overturning moment imposed on the soil by the total shear force. The basemat is modeled at the center of its thickness, and the soil spring elements are directly attached to the basemat grid points. However, because the actual ground is underneath the basemat, an overturning moment,  $\Delta M$ , which is calculated by the following equation, needs to be added. Table 6.2-7 shows the calculated additional overturning moments to be applied to the basemat.

$$\Delta M = (Q + W_{mat} \cdot A)h$$

where,

Q: Shear force at EL-7.4 m

 $W_{mat}$ : Weight of Basemat (GRAV+DL+EL+LL2)

- *A*: Horizontal Acceleration of Basemat
- *h*: Half of Basemat thickness (1.5 m)

The additional overturning moment is applied as vertical nodal forces to the basemat grid points. The magnitude of the vertical force per unit area is assumed to be proportional to the distance from the center of the basemat. The nodal force applied to each node is then calculated by multiplying it by the tributary area of the node.

# 6.2.3.6.2 Vertical Acceleration (VAS)

The site-specific seismic vertical accelerations calculated for the lumped mass locations of the dynamic models used for the site-specific seismic response analyses are applied directly



to the seismic walls. On the other hand, the out-of-plane accelerations applied to the CB slabs are determined using the method described in Appendix D of Reference 2.1.2-k.

The average accelerations,  ${}_{S}A_{ave}$ , provided in Table 6.2-8, are obtained from Reference 2.1.2l and represent the out-of-plane site-specific seismic loads on the slabs. These loads bound effects of concrete cracking as described in Reference 2.1.2-k and the effects of SSSI of RB/FB and FWSC on the seismic response of the CB as described in References 2.1.2-m and 2.1.2-n, respectively. The site-specific out-of-plane acceleration loads in Table 6.2-8 are uniformly applied to all slab grid points following the methodology used for the standard design in Reference 2.1.2-i.

The vertical seismic forces are applied to all grid points as upward vertical nodal forces. Each nodal force is calculated by multiplying the tributary weight of the node by the vertical acceleration determined for the region containing the node. For the seismic walls, a design acceleration obtained at a given elevation is applied to a region that is limited by the centerlines of that elevation and the upper and lower elevations. The tributary weight of the node is obtained using the load combination for the vertical seismic loads, which consists of the dead load and a quarter of the floor live load.

### 6.2.3.6.3 Torsional Moment (TMS)

The torsional moment applied to each CB floor elevation is calculated by subtracting the design torsional moment for the story above from the design torsional moment for that story. The magnitudes of the site-specific torsional loads are summarized in Table 6.2-9. The torsional moments are applied to the seismic walls as in-plane shear forces following the methodology used for the standard design in Reference 2.1.2-i. The method of calculating the shear forces is described in Figure 6:2-24 and the results are summarized in Tables 6.2-10 through 6.2-13. Torsional moments in the clockwise (East to South) direction are considered to be positive.

The shear forces due to the torsional moments are applied as horizontal nodal forces to the grid points on floor slab levels. Their magnitudes are determined according to the tributary lengths of the nodes.

#### 6.2.3.6.4 Soil Pressure due to an Earthquake (SPNS, SPEW)

The soil pressure loads described in Section 5.6 are applied to the CB exterior walls located below grade, as active soil pressures. The method of applying the site-specific seismic lateral pressures is the same as the method used for the standard design in Reference 2.1.2-i and the method used to apply the static soil pressure described in Subsection 6.2.3.2.2.

#### 6.2.4 Analysis Results

Section deformations obtained from NASTRAN analyses for all the analysis cases are shown in Figures 6.2-25 through 6.2-48. Tables 6.2-14 through 6.2-18 tabulate section forces for the typical elements selected in Figures 6.2-2 through 6.2-11. The results presented in the tables for the non-seismic load cases are obtained from Reference 2.1.2-i.

Element forces and moments of shell elements are defined with relation to the element coordinate system shown in Figure 6.2-49.



### **6.3 Load Combinations**

### 6.3.1 Code Requirements

### **Reinforced Concrete Structures**

The load combinations, associated load factors, and acceptance criteria for reinforced concrete structures are summarized in Table 6.3-1, which is shown in Reference 2.1.2-f and in compliance with ACI 349-01 and SRP 3.8.4.

### **Steel Structures**

The load combinations and associated load factors and acceptance criteria for steel structures are summarized in Table 6.3-2, which is in compliance with AISC N690-1994 Code and SRP 3.8.4.

### 6.3.2 Selection of Design Load Combinations

The CB structural evaluation considers the same critical site-specific seismic load combinations as those used for the standard design in Reference 2.1.2-i. These combinations include DBA loads and seismic loads as shown in Tables 6.3-3 and 6.3-4. The acceptance criteria for the considered load combinations are also included in the same table. Tables 6.3-5 and 6.3-6 show the details regarding the load combinations used for the site-specific evaluation.

### 6.3.3 Result of Load Combinations

Identical to the approach used for the standard design in Reference 2.1.2-i, the site-specific seismic load combinations are based on the SRSS method for the four directions of seismic loads as follows. The site-specific seismic loads include the dynamic increment of soil pressure.

$$SEISMIC_{SRSS} = \sqrt{(|EQNS| + |SPNS|)^2 + (|EQEW| + |SPEW|)^2 + (EQZ)^2 + (EQT)^2}$$

 $E' = SEISMIC_{SRSS}$ , which E' refers to Table 6.3 - 3

- EQEW: Horizontal seismic loads in the EW direction
- EQNS: Horizontal seismic loads in the NS direction
- EQZ: Vertical seismic loads
- EQT: Torsional seismic loads
- SPEW: Dynamic soil pressure during a horizontal earthquake (East to West)
- SPNS: Dynamic soil pressure during a horizontal earthquake (North to South)

The basic concept for SRSS is shown below:

 Algebraic sum static component forces (dead, live, thermal, pressure, etc.): Retain sign for each force component. For example, N<sub>x</sub>(+), N<sub>y</sub>(-), and N<sub>xy</sub>(+) for axial forces in X and Y direction and in-plane shear force, respectively.



- 2) Seismic component forces (SRSS results of force due to each of 3 direction input): regardless of sign
- 3) Assign signs to total dynamic component force to be same as static force: refer to Step-1 example, N<sub>x</sub> (+), N<sub>y</sub> (-), and N<sub>xy</sub> (+)
- 4) Total component forces (add Step-1 and Step-3): refer to Step-1 example, N<sub>x</sub> (+), N<sub>y</sub> (-), and N<sub>xy</sub> (+)
- 5) The case to reverse the signs of section forces is evaluated for total dynamic components which are described in Step-3 (the signs of static component forces in Step-1 are not reversed).

Tables 6.3-7 through 6.3-10 show the combined forces and moments for the load combinations listed in Table 6.3-3.

Section forces due to the following loads are shown independently in the tables:

- OTHR: Loads other than temperature and seismic loads
- TEMP: Thermal loads
- SEIS: Seismic loads

# 6.4 Section Design Principles

# 6.4.1 Section Design of Reinforced Concrete Structures

Structural design is performed according to ACI 349-01. The design flow chart is shown in Figure 6.4-1.

Section design calculations are carried out for the following section forces and it is confirmed that the results satisfy code requirements:

- Flexure and Membrane Forces
- Membrane Compressive Forces
- Transverse Shear

All elements are examined by the evaluation method described in the following subsections.

# 6.4.1.1 Section Design for Flexure and Membrane Forces

The design calculations are carried out for flexure and axial forces, and for in-plane shear forces, separately.

Design calculations for flexure and membrane force are performed by a computer program SSDP-2D. The program has the following characteristics:

• It calculates concrete and rebar stresses under two-dimensional equilibrium conditions for six components of the section forces in a shell element – two axial forces, two bending moments, in-plane shear, and torsional moment. Transverse shear is generated in an element but is not considered in the equilibrium conditions.



- It takes concrete cracks into account in the stress calculation. Cracked concrete is assumed not to bear tensile forces.
- It considers the reduction of thermal stresses due to the decreased stiffness of a cracked concrete section.
- It assumes concrete and rebars to be perfectly elastic.

In calculations with SSDP-2D, all section forces including axial forces, bending moments and in-plane shear are considered simultaneously. In SSDP-2D, the compressive stress distribution of concrete is based on the linear distribution which is proportional to the strain distribution at the section. Moment capacity based on this condition is more conservative than the moment capacity specified in ACI 349-01 which is based on the stress block for the compressive stress distribution of concrete. As shown in Figure 6.4.1-3 of Reference 2.1.2-o, the ASME capacity with linear concrete compressive stress distribution (used in the SSDP program) is more conservative than ACI 349-01 except in the high axial force (compression) region. This is addressed in Appendix C by performing additional compression check per ACI 349-01. Additionally, in-plane shear check per ACI 349-01 is performed in Appendix B.

As for the thermal effects, section forces due to thermal loads, which are evaluated by NASTRAN analyses using uncracked concrete stiffness, are reduced considering the depth and direction of cracking in calculations with SSDP-2D. The cracked section properties are used in the calculation only for the cracked sections. Furthermore, compatibility between strain distribution in a section and internal forces, including reduced thermal stress, is examined under an assumed cracked condition in calculation with SSDP-2D. The calculations are continued until the compatibility of strain and internal forces are satisfied. During the iterative calculations, redistribution of internal forces and strains are considered adequate. Therefore, SSDP calculation satisfies the requirements of Appendix A.3.3 (a) and (b) in ACI 349-01.

Table 6.4-1 shows the material constants used for the stress calculation. Allowable stresses specified in CC-3420 of ASME-2004 are used in the design, since they are not specifically defined in ACI 349-01. Tables 6.4-2 and 6.4-3 show the allowable stresses of concrete and rebars.

As specified in Section 6.1 of Reference 2.1.2-f, strengths of concrete and rebars are reduced taking effects of elevated temperatures into consideration.

Reduction of concrete strength due to high temperature is determined based upon the average value of the following upper bound and lower bound equations:

• Lower bound reduction factor

 $-\phi = 1.0 - 0.0030 (T-21.1)$ 

 $- \phi = 0.70 - 0.00083 \text{ (T-121.1)}$ 

 $21.1^{\circ}C(70^{\circ}F) \le T \le 121.1^{\circ}C(250^{\circ}F)$  $121.1^{\circ}C(250^{\circ}F) \le T$ 

• Upper bound reduction factor

 $-\phi = 1.0$ 

T ≤ 260.0°C (500°F)



 $-\phi = 1.0 - 0.00081 (T-260.0)$   $260.0^{\circ}C (500^{\circ}F) \le T$ 

Reduction of reinforcing steel strength is based upon the following equation:

• Reduction Factor

 $-\phi = 1.0 - 0.000873 (T-21.1)$   $21.1^{\circ}C (70^{\circ}F) \le T \le 204.4^{\circ}C (400^{\circ}F)$ 

Average temperature "Td" in Section 5.3 is applied to the "T" of the above equation. Allowable stresses listed in Tables 6.4-2 and 6.4-3 are reduced using these factors in calculation for load combinations, including thermal loads.

# 6.4.1.2 Section Design for Membrane Compressive Forces

ASME-2004 specifies the allowable concrete stresses for membrane forces. It is necessary to confirm that the compressive stresses of the concrete due to membrane forces do not exceed the allowable stresses specified in CC-3420 of ASME-2004. Examinations for membrane compressive forces are also performed in the design in addition to examinations for flexure and membrane forces.

The principal membrane compressive stress  $\sigma_c$ , which is calculated by the following equation, is used for the evaluation.

$$\sigma_{c} = \frac{\sigma_{x} + \sigma_{y}}{2} + \sqrt{\left(\frac{\sigma_{x} - \sigma_{y}}{2}\right)^{2} + \tau^{2}_{xy}}$$
$$\sigma_{x} = \frac{N_{x}}{h}$$
$$\sigma_{y} = \frac{N_{y}}{h}$$
$$\tau_{xy} = \frac{N_{xy}}{h}$$

where,

 $N_x$ : x-direction axial force per unit length (Compression is positive.)

 $N_{y}$ : y-direction axial force per unit length (Compression is positive.)

 $N_{xy}$ : in-plane shear per unit length

*h*: element thickness

Reduction of thermal stresses is not considered in the calculation. Table 6.4-4 shows the allowable membrane compressive stresses of concrete. Reductions due to elevated temperature described in Subsection 6.4.1.1 are applicable to these allowables.



#### 6.4.1.3 Section Design for Transverse Shear

Section design calculations for transverse shear are performed according to ACI 349-01, Chapter 11. It requires that the shear force at a section and section strength satisfy the following equation:

 $V_u \le \phi \big( V_c + V_s \big)$ 

where,

 $V_{u}$ : factored shear force at section per unit length

 $V_c$ : nominal shear strength provided by concrete per unit length

 $V_{\rm s}$ : nominal shear strength provided by shear reinforcement per unit length

 $\phi$ : strength reduction factor (=0.85)

The nominal shear strength provided by concrete,  $V_c$ , is calculated according to Figure 6.4-2. The nominal shear strength provided by shear reinforcement,  $V_s$ , is calculated by the following equation:

$$V_s = \rho_w f_y d$$
,  $V_s \le 8\sqrt{f_c'} d$  (lb - in)

where,

 $\rho_w$ : shear reinforcement ratio

 $f_{y}$ : specified yield strength of rebar

d: distance from extreme compression fiber to centroid of tension reinforcement

 $f_c'$ : specified compressive strength of concrete

The transverse shear stress is evaluated in the direction of the maximum shear force, and the section forces for evaluation are calculated by the following equations:

$$V_{u} = \sqrt{Q_{x}^{2} + Q_{y}^{2}}$$

$$M_{u} = M_{x} \sin^{2} \theta + M_{y} \cos^{2} \theta + 2M_{xy} \sin \theta \cos \theta$$

$$N_{u} = N_{x} \sin^{2} \theta + N_{y} \cos^{2} \theta + 2N_{xy} \sin \theta \cos \theta$$

$$\theta = \tan^{-1} (Q_{x}/Q_{y})$$

#### 6.4.2 Section Design of Steel Structures

Section design of steel members is performed according to AISC N690-1994 (Reference 2.2c). Steel members, i.e., columns and girders, are examined by the evaluation method described in the following subsections.



The design flow of steel structures is almost the same as the flow of reinforced concrete structures, which is shown in Figure 6.4-1. However, reductions of thermal stresses are not considered for the steel design.

### 6.4.2.1 Section Design for Axial Compression and Bending

Steel members subjected to both axial compression and bending stresses shall be proportioned to satisfy the following requirements:

$$\frac{f_a}{F_a} + \frac{C_{mx}f_{bx}}{\left(1 - \frac{f_a}{F'_{ex}}\right)F_{bx}} + \frac{C_{my}f_{by}}{\left(1 - \frac{f_a}{F'_{ey}}\right)F_{by}} \le 1.0$$
(6.4.2-1)
$$- \frac{f_a}{f_{a}} + \frac{f_{bx}}{f_{bx}} + \frac{f_{by}}{f_{by}} \le 1.0$$
(6.4.2-2)

$$0.60F_y + F_{bx} + F_{by}$$
 (0.4.2.2)

When  $f_a/F_a \le 0.15$ , Equation (6.4.2-3) is permitted in lieu of Equations (6.4.2-1) and (6.4.2-2):

$$\frac{f_a}{F_a} + \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} \le 1.0$$
(6.4.2-3)

In Equations (6.4.2-1), (6.4.2-2) and (6.4.2-3), the subscripts x and y, combined with subscripts b, m and e, indicate the axis of bending about which a particular stress or design property applies, and

- $F_a$  = Axial compressive stress that would be permitted if axial force alone existed, ksi.
- $F_b$  = Compressive bending stress that would be permitted if bending moment alone existed, ksi.

$$F'_{e} = \frac{12\pi^{2}E}{23\left(Kl_{b}/r_{b}\right)^{2}}$$

= Euler stress divided by a factor of safety, ksi. (In the expression for  $F'_{e}$ ,  $L_{b}$  is the actual unbraced length in the plane of bending and  $r_{b}$  is the corresponding radius of gyration. K is the effective length factor in the plane of bending.)

- $f_a$  = Computed axial stress, ksi.
- $f_b$  = Computed compressive bending stress at the point under consideration, ksi.
- $C_m$  = Coefficient whose value shall be taken as follows:
  - a. For compression members in frames subject to joint translation (sideways),  $C_m = 0.85$ .
  - b. For rotationally restrained compression members in frames braced against joint translation and not subject to transverse loading between their supports in the



plane of bending,

 $C_m = 0.6 - 0.4 \ (M_I/M_2).$ 

where  $M_1/M_2$  is the ratio of the smaller to larger moments at the ends of that portion of the member unbraced in the plane of bending under consideration.  $M_1/M_2$  is positive when the member is bent in reverse curvature, negative when bent in single curvature.

- c. For compression members in frames braced against joint translation in the plane of loading and subjected to transverse loading between their supports, the value of  $C_m$  may be determined by an analysis. However, in lieu of such analysis, the following values are permitted:
  - i. For members whose ends are restrained against rotation in the plane of bending:  $C_m = 0.85$ .
  - ii. For members whose ends are unrestrained against rotation in the plane of bending:  $C_m = 1.0$ .

# 6.4.2.2 Section Design for Axial Tension and Bending

Steel members subjected to both axial tension and bending stresses shall be proportioned at all points along their length to satisfy the following requirement:

$$\frac{f_a}{F_t} + \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} \le 1.0$$
(6.4.2-4)

Where  $f_b$  is the computed bending tensile stress,  $f_a$  is the computed axial tensile stress,  $F_b$  is the allowable bending stress and  $F_i$  is the governing allowable tensile stress.

# 6.4.2.3 Section Design for Transverse Shear

Steel members subjected to transverse shear stress shall be proportioned to satisfy the following requirement:

$$\frac{f_{\nu}}{F_{\nu}} \le 1.0$$
 (6.4.2-5)

where  $f_{\nu}$  is the computed shear stress and  $F_{\nu}$  is the governing allowable shear stress.

# 6.4.2.4 Allowable Stresses

# 6.4.2.4.1 Allowable Axial Tensile Stress

On the gross section of axially loaded tension members, the allowable stress is:

 $F_{t} = 0.60F_{y} \tag{6.4.2-6}$ 

where  $F_y$  is the specified minimum yield stress of the type of steel being used, ksi.

# 6.4.2.4.2 Allowable Axial Compressive Stress

On the gross section of axially loaded compression members, when Kl/r, the largest effective slenderness ratio of any unbraced segment is less than  $C_c$ , the allowable stress is:



WG3-U73-ERD-S-0004	SH NO. 31
REV. 2	of 219

 $F_{a} = \frac{\left[1 - \frac{(Kl/r)^{2}}{2C_{c}^{2}}\right]F_{y}}{\frac{5}{3} + \frac{3(Kl/r)}{8C_{c}} - \frac{(Kl/r)^{3}}{8C_{c}^{3}}}$ 

(6.4.2-7)

where,

$$C_c = \sqrt{\frac{2\pi^2 E}{F_y}}$$

E = Modulus of elasticity of steel, ksi

On the gross section of axially loaded compression members, when Kl/r exceeds  $C_c$ , the allowable stress is:

$$F_a = \frac{12\pi^2 E}{23(Kl/r)^2}$$
(6.4.2-8)

### 6.4.2.4.3 Allowable Bending Stress of W-shaped Members (Strong Axis Bending)

The allowable stress for the strong axis bending of W-shaped members is given according to the procedure shown in Figure 6.4-3.

### 6.4.2.4.4 Allowable Bending Stress of W-shaped Members (Weak Axis bending)

The allowable stress for the weak axis bending of W-shaped members is given according to the procedure shown in Figure 6.4-4.

# 6.4.2.4.5 Allowable Bending Stress of Box Members

The allowable bending stress of box members is given according to the procedure shown in Figure 6.4-5.

# 6.4.2.4.6 Allowable Shear Stress

For  $h/t_w \leq 380/\sqrt{F_y}$ , on the overall depth times the web thickness, the allowable shear stress is:

$$F_{v} = 0.40F_{v} \tag{6.4.2-9}$$

For  $h/t_w > 380/\sqrt{F_y}$ , the allowable shear stress on the clear distance between flanges times the web thickness is:

$$F_{\nu} = \frac{F_{\nu}}{2.89} (C_{\nu}) \le 0.40 F_{\nu}$$
(6.4.2-10)



where,

$$C_{v} = \frac{45000k_{v}}{F_{y}(h/t_{w})^{2}} \text{ when } C_{v} \text{ is less than } 0.8.$$

$$= \frac{190}{h/t_{w}} \sqrt{\frac{k_{v}}{F_{y}}} \text{ when } C_{v} \text{ is more than } 0.8.$$

$$k_{v} = 4.00 + \frac{5.34}{(a/h)^{2}} \text{ when } a/h \text{ is less than } 1.0.$$

$$= 5.34 + \frac{4.00}{(a/h)^{2}} \text{ when } a/h \text{ is more than } 1.0.$$

- $t_w$  = thickness of web, in.
- a = clear distance between transverse stiffener, in.
- h = clear distance between flanges at the section under investigation, in.

# 7. SUMMARY OF RESULTS

# 7.1 Required Sections

The basemat has a uniform thickness of 3.0 m. Figure 7.1-1 shows the typical sections of the basemat. #11 bars are used for the primary reinforcement. Bottom and top rebars are arranged orthogonally in NS- and EW- directions. Standard bar pitches are 200 mm.

Figure 7.1-2 shows the typical sections of the slabs. #11 bars are used for the primary reinforcement. Bottom and top rebars are arranged orthogonally in NS- and EW- directions. Standard bar pitches are 200 mm.

Figure 7.1-3 shows the typical sections of the wall. #11 bars are used for the primary reinforcement. Inside and outside rebars are arranged orthogonally in Horizontal- and Vertical- directions. Standard bar pitches are 200 mm.

The NA3 site-specific design rebar arrangement is the same as the standard design one.

The sections of the steel members are shown in Figures 7.1-4 and 7.1-5. Steel beam "SG23" at EL 4.65 m on Col-Row CB shown in Figure 7.1-4 is revised from the standard design.

# 7.2 Provided Sections

The sections of the CB which have been provided are identical to the required sections described in Section 7.1. Table 7.2-1 shows the sectional thickness and rebar ratios used in the evaluation.



#### 7.3 Tabulation of Allowable Stresses versus Calculated Stresses

#### 7.3.1 Reinforced Concrete Structures

#### 7.3.1.1 Calculations for Flexure and Membrane Forces

The calculations are performed for all elements for the load combinations described in Section 6.3, and it is confirmed that all values are less than their allowable stresses.

Tables 7.3-1 through 7.3-8 show the rebar and concrete stresses at these sections for the typical elements selected in Figures 6.2-2 through 6.2-11. Tables 7.3-9 and 7.3-10 give a summary of the maximum stress ratios, which are ratios of the maximum stresses to the allowable stresses.

The maximum rebar stress in shear walls is found to be 254.8 MPa (36.96 ksi) against allowable stress 372.2 MPa (53.98 ksi) in the vertical rebar in the wall at EL 9.06 m due to the load combination CB-9 as shown in Table 7.3-8. The maximum horizontal rebar stress in shear walls is found to be 239.0 MPa (34.66 ksi) against allowable stress 372.2 MPa (53.98 ksi) in the vertical rebar in the wall at EL 9.06 m due to the load combination CB-9 as shown in Table 7.3-8.

The maximum rebar stress in floor slabs is found to be 198.3 MPa (28.76 ksi) against allowable stress 372.2 MPa (53.98 ksi) in the roof at EL 13.8 m slab due to the load combination CB-9 as shown in Table 7.3-7.

The maximum rebar stress in foundation mat is found to be 159.9 MPa (23.19 ksi) against allowable stress 372.2 MPa (53.98 ksi) due to the load combination CB-9 as shown in Table 7.3-7.

#### 7.3.1.2 Calculations for Membrane Compressive Forces

The compressive stress of concrete is calculated for membrane forces. The calculations are performed for all elements for the selected design load combinations, and it is confirmed that all values are less than the allowable stress.

Table 7.3-11 gives a summary of the maximum compressive stresses for the typical elements selected in Figures 6.2-2 through 6.2-11.

The maximum concrete stress in shear walls is found to be 5.4 MPa (0.78 ksi) against allowable stress 20.7 MPa (3.0 ksi) in the wall at EL -2.0 m as shown in Table 7.3-11.

The maximum concrete stress in floor slabs is found to be 14.8 MPa (2.15 ksi) against allowable stress 20.7 MPa (3.0 ksi) at EL 9.06 m slab as shown in Table 7.3-11.

The maximum concrete stress in foundation mat is found to be 2.0 MPa (0.29 ksi) against allowable stress 16.6 MPa (2.41 ksi) as shown in Table 7.3-11.

#### 7.3.1.3 Calculations for Transverse Shear

The transverse shear strength is calculated and compared with shear forces generated by design loads. All elements are examined, and it is confirmed section forces are less than the shear strength of sections.



Table 7.3-12 gives a summary of the examinations for the typical elements shown in Figures 6.2-2 through 6.2-11. Table 7.3-13 shows calculation results for transverse shear by the selected load combination listed in Table 6.3-3.

The maximum transverse shear force in shear walls is found to be 1.481 MN/m (8.46 kips/in) against the shear strength of 1.881 MN/m (10.74 kips/in) in the wall at EL -7.4 m as shown in Table 7.3-13.

The maximum transverse shear force in floor slabs is found to be 0.340 MN/m (1.94 kips/in) against the shear strength of 0.353 MN/m (2.02 kips/in) at EL 4.65 m slab as shown in Table 7.3-13.

The maximum transverse shear force in foundation mat is found to be 1.974 MN/m (11.27 kips/in) against the shear strength of 4.682 MN/m (26.73 kips/in) as shown in Table 7.3-13.

# 7.3.2 Steel Structure

The stresses of the steel members are combined in accordance with Table 6.3-6, and it is confirmed that all values are less than the allowable stresses in accordance with the procedure in Subsection 6.4.2.

Tables 7.3-14 through 7.3-17 list the calculation results of the selected sections included in Figures 7.3-1 and 7.3-2. The calculation results for "CBAR ID 21016", shown in Table 7.3-16 is revised from the standard design. "CBAR ID 21016" is included in the steel beam "SG23" at EL 4.65 m on Col-Row CB as shown in Figure 7.1-4. The stress ratios of the design stresses against their allowable stresses shown in the tables are the maximum ratios among all the load combinations.

Please note the columns are subject to two direction forces. The procedure for their stress check is shown in Figure 7.3-3.

Column members are subjected to forces in the NS (X) and EW (Y) directions and five kinds of forces (N,  $M_x$ ,  $M_y$ ,  $V_x$ ,  $V_y$ ) are induced. For the combination of axial force and bending moments, column stresses are checked by using the full section area of the column as follows. Calculation results are shown in Table 7.3-18.

$$R_{NS} + R_{EW} - R_a \le 1.0$$

(6.4.2-11)

- where,  $R_{NS}$ : maximum stress ratio of design stresses to allowable stresses for NS direction considering N and  $M_x$ 
  - $R_{\rm EW}$ : maximum stress ratio of design stresses to allowable stresses for EW direction considering N and M<sub>y</sub>
  - $R_a$ : minimum ratio of axial stress ratios for NS and EW direction

# 7.4 External Wall Capacity Evaluation

Sliding of the CB during the SSE input is evaluated against the building stability requirement. As shown in Section 7 of Reference 2.1.2-j, the site-specific passive lateral pressure loads required for the sliding stability of the CB at the NA3 site are almost enveloped by the corresponding lateral pressure loads used for the standard design wall



WG3-U73-ERD-S-0004 SH NO. 35 REV. 2 of 219

capacity check. This check was performed for the standard design in Reference 2.1.2-i for the embedded exterior walls under SSE loading in combination with other applicable loads. Design load is shown in Table 7.4-1 based on the sliding analysis shown in Table 5-1 in Reference 2.1.2-j. The stress check results are shown in Tables 7.4-2 and 7.4-3.

# 7.5 Missile Impact Evaluations

Appendix A in Reference 2.1.2-i describes the design methodology and results of the evaluation for exterior walls and roof slab of the CB against the tornado missile impact.

Appendix C in Reference 2.1.2-i describes the design methodology and evaluation for the effect of the impact of an automobile tornado missile on the CB structures including exterior walls and roof slabs.

# 8. CONCLUSIONS

Site-specific stress check calculations for the CB are performed to evaluate the structural integrity of the CB at the NA3 site per specifications of ACI 349-01 and AISC N690-1994, following the same methodology as that used for the standard design in Reference 2.1.2-i. The stress checks are based on the results of the CB global model analyses for the site-specific seismic loads combined together with the non-seismic load results from Reference 2.1.2-i according to the site-specific seismic load combinations. The conclusions from the site-specific stress checks are summarized as follows:

- Reinforced concrete structures
  - The stresses of the concrete and rebar are less than the allowable stresses specified in the code.
  - The areas of the primary and shear reinforcement, which have been provided, satisfy the required values.
- Steel structures
  - The stresses of steel members are less than the allowable stresses specified in the code.

Therefore, it can be concluded that the standard design of the CB structures is adequate to resist the NA3 site-specific SSE loads in combination with non-seismic standard plant loads.

And, it is confirmed that the standard design of the CB is verified to be acceptable for NA3 site-specific loads, with minor design change for one structural steel beam as described in Section 7.1.


#### Table 3.4-1 Conditions of Applied Site Properties (Reproduced from Reference 2.1.2-i)

	/				
Site Condition	Soft Site				
Shear Wave Velocity (m/s)	300				
Mass Density (kN/m <sup>3</sup> )	19.6				
Passion's Ratio	0.478				
Material Damping (%)	5				

Notes: The values are in accordance with the Seismic Analysis of Control Building. (Reference 2.1.2-h) The maximum standard design ground water table is 0.61 m below the design plant grade.

EL		Room	Weight	*
(m)	ID No.	Description	(kN)	
	3401	HVAC Room A and B	1	
	3402	HVAC Room C and D		
0.06	3403	HVAC Chilled Water Storage Room A	Total	
9.00	3404	HVAC Chilled Water Storage Room B	1489	
	3406	Control Room EFU Room A		
	3407	Control Room EFU Room B		
4 65	3301	Non 1E DCIS Room A	490	
4.00	3302	Non 1E DCIS Room B	490	
-2.00	3275	Main Control Room	230	
	3110	Division I DCIS Electrical Room	216	
74	3120	Division II DCIS Electrical Room	216	
-7.4	3130	Division III DCIS Electrical Room	216	
	3140	Division IV DCIS Electrical Room	216	

### Table 5.1-1 Equipment Load (Reproduced from Reference 2.1.2-i)

Note: \* Design margin (20%) shall be added to this weight for future change.

WG3-U73-ERD-S-0004	SH NO. 37
REV. 2	of 219

( F													
EL	Live Load	Snow Load	LL1	LL2									
(m)	(MN/m <sup>2</sup> )	(MN/m <sup>2</sup> )	(MN/m <sup>2</sup> )	(MN/m <sup>2</sup> )									
13.80	0.00290	0.00240	0.00290	0.00240									
		0.00576	0.00576	0.00576									
9.06	0.00480	-	0.00480	0.00120									
4.65	0.00480		0.00480	0.00120									
-2.00	0.00480		0.00480	0.00120									
-7.40	0.00480		0.00480	0.00120									

#### **Table 5.2-1 Floor Live Loads** (Reproduced from Reference 2.1.2-i)

Notes: LL1 = Max (Live Load, Snow Load) used for analysis and design LL2 = Max (Live Load/4, Snow Load) used for evaluation of seismic loads Snow loads distributing on EL 13.80 m are distinguished as follows: 0.00240 MN/m<sup>2</sup>: snow load is distributed on roof without snow drift 0.00576 MN/m<sup>2</sup>: snow load is distributed on roof by staircase with snow drift

#### **Table 5.2-2 Calculation of At-Rest Pressure** (Reproduced from Reference 2.1.2-i)

	· · · · · · · · · · · · · · · · · · ·					
EL				Total		
(m)	Корь	к <sub>оŶb</sub> H	γwHw	k₀q	Total	(MN/m²)
4.65		0.00	0.00	1.12	1.12	0.0110
4.04	1.831	1.12	0.00	1.12	2.23	0.0219
-2.00	1.140	8.00	6.04	1.12	15.16	0.1487
-7.40	1.140	14.16	11.44	1.12	26.72	0.2620
-10.40	1.140	17.58	14.44	1.12	33.14	0.3250

on CA, CD and C1 col-row

#### on C5 col-row

EL			Soil Press	sure (t/m²)		Total
(m)	Коуъ	k <sub>oγь</sub> H	γ <sub>w</sub> H <sub>w</sub>	k₀q	Total	(MN/m <sup>2</sup> )
4.65		0.00	0.00	17.88	17.88	0.1754
4.04	1.831	1.12	0.00	17.88	19.00	0.1863
-2.00	1.140	8.00	6.04	17.88	31.93	0.3131
-7.40	1.140	14.16	11.44	17.88	43.49	0.4265
-10.40	1.140	17.58	14.44	17.88	49.91	0.4894

Notes:

1

Ground water level is at EL 4.04 m.

Surcharge, q, is assumed to be 19.53 tf/m<sup>2</sup> on col-row C5 and 1.22 tf/m<sup>2</sup> on the others.



I NO.38
of 219

# Table 5.3-1 Result of Heat Transfer Analysis, Normal Operation: Summer (Reproduced from Reference 2.1.2-i)

EL (m)	Location	ID	Thick. (m)		Atom. (°	Temp C)		Thin F (kcal/i	Thin Film Coef. (kcal/m <sup>2</sup> h °C)         Resistance of Heat Conduction (m <sup>2</sup> h °C /kcal)					Surface Temperature (°C)		Linearized Temperature (°C)		Tg/t
(,			t		T1		T2	h1	h2	rc	г <b>1</b>	r2	R	Та	ТЪ	Td	Тg	(°C /m)
SLAB			_															
13.80	Roof	S_RF	0.70	Т	46.1	в	30.0	30.0	6.0	0.50	0.03	0.17	0.70	45.3	33.8	39.6	11.5	16.4
9.06	Slab	S_2F	0.50	Т	30.0	В	21.0	6.0	6.0	0.36	0.17	0.17	0.69	27.8	23.2	25.5	4.7	9.3
4.65	Slab	S_1F	0.50	Т	21.0	В	21.0	6.0	6.0	0.36	0.17	0.17	0.69	21.0	21.0	21.0	0.0	0.0
-2.00	Slab	S_B1F	0.50	т	21.0	в	21.0	6.0	6.0	0.36	0.17	0.17	0,69	21.0	21.0	21.0	0.0	0.0
-7.40	Mat	S_MAT	3.00	Т	21.0	в	15.5	6.0	1E+09	2.14	0.17	0.00	2.31	20.6	15.5	18.1	5.1	1.7
WALL			•															
	C1	Wall-N	0.70	s	30.0	N	46.1	6.0	30.0	0.50	0.17	0,03	0.70	33.8	45.3	39.6	-11.5	-16.4
13.80 -	C5	Wall-S	0.70	s	46.1	N	30.0	30.0	6.0	0.50	0.03	0.17	0.70	45.3	33.8	39.6	11.5	16.4
9.06	CA	Wall-E	0.70	w	30.0	E	46.1	6.0	30.0	0.50	0.17	0.03	0.70	33.8	45.3	39.6	-11.5	-16.4
	CD	Wall-W	0.70	w	46.1	Е	30.0	30.0	6.0	0.50	0.03	0.17	0.70	45.3	33.8	39.6	11.5	16.4
	C1	Wall-N	0.90	s	21.0	N	46.1	6.0	30.0	0.64	0.17	0.03	0.84	26.0	45.1	35.5	-19.1	-21.3
9.06 -	C5	Wall-S	0.90	S	46.1	N	21.0	30.0	6.0	0.64	0.03	0.17	0.84	45.1	26.0	35.5	19.1	21.3
4.65	CA	Wall-E	0.90	w	21.0	E	46.1	6.0	30.0	0.64	0.17	0.03	0.84	26.0	45.1	35.5	-19.1	-21.3
	CD	Wall-W	0.90	w	46.1	Ę	21.0	30.0	6.0	0.64	0.03	0.17	0.84	45.1	26.0	35.5	19.1	21.3
	C1	Wall-N	0.90	s	21.0	N	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	19.9	15.5	17.7	4.4	4.9
4.65 -	C5	Wall-S	0.90	S	15.5	N	21.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	19.9	17.7	-4.4	-4.9
-2.00	CA	Wall-E	0.90	w	21.0	Е	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	19.9	15.5	17.7	4.4	4.9
1	CD	Wali-W	0.90	w	15.5	E	21.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	19.9	17.7	-4.4	-4.9
	C1	Wall-N	0.90	s	21.0	N	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	19.9	15.5	17.7	4.4	4.9
-2.00 -	C3	Wall-NS	1.00	s	21.0	N	21.0	6.0	6.0	0.71	0.17	0.17	1.05	21.0	21.0	21.0	0.0	0.0
-7.40	C5	Wall-S	0.90	s	15.5	N	21.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	19.9	17.7	-4.4	-4.9
	CA	Wall-E	0.90	w	21.0	E	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	19.9	15.5	17.7	4.4	4.9
	CD	Wall-W	0.90	W	15.5	E	21.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	19.9	17.7	-4.4	-4.9

Notes: T: Top of Roof, Slab or Mat, B: Bottom of Roof, Slab or Mat, N: North side of Wall, S: South side of Wall, E: East side of Wall,

W: West side of Wall



WG3-U73-ERD-S-0004	SH NO.39
REV. 2	of 219

## Table 5.3-2 Result of Heat Transfer Analysis, Normal Operation: Winter (Reproduced from Reference 2.1.2-i)

EL Location ID (m)					Atom. °۱	Temp C)	I	Thin F (kcal/t	ilm Coef. n² h °C)	Resis	tance of He (m² h °C	eat Cond C /kcal)	uction	Surface Temperature (°C)		Linearized Temperature (°C)		Tg/t
()			t		T1		T2	h1	h2	rc	r1	r2	R	Та	Тb	Td	Тg	(°C /m)
SLAB																		
13.80	Roof	S_RF	0.70	Т	-40.0	в	10.0	35.0	6.0	0.50	0.03	0.17	0.70	-37. <del>9</del>	-2.0	-20.0	-36.0	-51.4
9.06	Slab	S_2F	0.50	Т	10.0	в	21.0	6.0	6.0	0.36	0.17	0.17	0.69	12.7	18.3	15.5	-5.7	-11.4
4.65	Slab	S_1F	0.50	Т	21.0	в	21.0	6.0	6.0	0.36	0.17	0.17	0.69	21.0	21.0	21.0	0.0	0.0
-2.00	Slab	S_B1F	0.50	Т	21.0	В	21.0	6.0	6.0	0.36	0.17	0.17	0.69	21.0	21.0	21.0	0.0	0.0
-7.40	Mat	S_MAT	3.00	т	21.0	В	15.5	6.0	1E+09	2.14	0.17	0.00	2.31	20.6	15.5	18.1	5.1	1.7
WALL																		
	<b>C</b> 1	Wall-N	0.70	s	10.0	N	-40.0	6.0	35.0	0.50	0.17	0.03	0.70	-2.0	-37.9	-20.0	36.0	51.4
13.80 -	C5	Wall-S	0.70	S	-40.0	И	10.0	35.0	6.0	0.50	0.03	0.17	0.70	-37.9	-2.0	-20.0	-36.0	-51.4
9.06	CA	Wall-E	0.70	Ŵ	10.0	Е	-40.0	6.0	35.0	0.50	0.17	0.03	0.70	-2.0	-37.9	-20.0	36.0	51.4
	CD	Wail-W	0.70	w	-40.0	Е	10.0	35.0	6.0	0.50	0.03	0.17	0.70	-37.9	-2.0	-20.0	-36.0	-51.4
	C1	Wall-N	0.90	S	21.0	N	-40.0	6.0	35.0	0.64	0.17	0.03	0.84	8.9	-37.9	-14.5	46.8	52.0
9.06 -	C5	Wall-S	0.90	Ş	-40.0	Z	21.0	35.0	6.0	0.64	0.03	0.17	0.84	-37.9	8.9	-14.5	-46.8`	-52.0
4.65	CA	Wall-E	0.90	Ŵ	21.0	Е	-40.0	6.0	35.0	0.64	0.17	0.03	0.84	8.9	-37.9	-14.5	46.8	52.0
	CD	Wall-W	0.90	W	-40.0	Е	21.0	35.0	6.0	0.64	0.03	0.17	0.84	-37.9	8.9	-14.5	-46.8	-52.0
	C1	Wall-N	0.90	s	21.0	N	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	19.9	15.5	17.7	4.4	4.9
4.65 -	C5	Wall-S	0.90	s	15.5	N	21.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	19.9	17.7	-4.4	-4.9
-2.00	CA	Wall-E	0.90	Ŵ	21.0	Е	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	19.9	15.5	<sup>•</sup> 17.7	4.4	4.9
	CD	Wall-W	0.90	w	15.5	Е	21.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	19.9	17.7	-4.4	-4.9
	C1	Wall-N	0.90	s	21.0	N	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	19.9	15.5	17.7	4.4	4.9
-2.00 -	C3	Wail-NS	<u>`</u> 1.00	s	21.0	Ν	21.0	6.0	6.0	0.71	0.17	0.17	1.05	21.0	21.0	21.0	0.0	0.0
-7.40	C5	Wall-S	0.90	s	15.5	Ν	21.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	19.9	17.7	-4.4	-4.9
	CA	Wall-E	0.90	w	21.0	Е	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	19.9	15.5	17.7	4.4	4.9
	CD	Wall-W	0.90	w	15.5	Е	21.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	19.9	17.7	-4.4	-4.9

Notes: T: Top of Roof, Slab or Mat, B: Bottom of Roof, Slab or Mat, N: North side of Wall, S: South side of Wall, E: East side of Wall,

W: West side of Wall



WG3-U73-ERD-S-0004	SH NO.40
REV. 2	of 219

## Table 5.3-3 Result of Heat Transfer Analysis, DBA: Summer (Reproduced from Reference 2.1.2-i)

EL (m)	Location	ID	Thick. (m)		Atom. (°	Temp C)	•	Thin F (kcal/i	Thin Film Coef. (kcal/m <sup>2</sup> h °C)     Resistance of Heat Conduction (m <sup>2</sup> h °C /kcal)					Surface Temperature (°C)		Linearized Temperature (°C)		Tg/t
(,			t		T1		T2	h1 .	h2	rc	r1	r2	R	Та	Тb	Td	Tg	(°C /m)
SLAB								_										
13.80	Roof	S_RF	0.70	Т	46.1	В	50.0	30.0	6.0	0.50	0.03	0.17	0.70	46.3	49.1	47.7	-2.8	-4.0
9.06	Slab	S_2F	0.50	Т	50.0	В	50.0	6.0	6.0	0.36	0.17	0.17	0.69	50.0	50.0	50.0	0.0	0.0
4.65	Slab	S_1F	0.50	т	50.0	В	30.0	6.0	6.0	0.36	0.17	0.17	0.69	45.2	34.8	40.0	10.3	20.7
-2.00	Slab	S_B1F	0.50	Т	30.0	В	50.0	6.0	6.0	0.36	0.17	0.17	0.69	34.8	45.2	40.0	-10.3	-20.7
-7.40	Mat	S_MAT	3.00	Т	50.0	В	15.5	6.0	1E+09	2.14	0.17	0.00	2.31	47.5	15.5	31.5	32.0	10.7
WALL					_									_				
	C1	Wall-N	0.70	S	50.0	N	46.1	6.0	30.0	0.50	0.17	0.03	0.70	49.1	46.3	47.7	2.8	4.0
13.80 -	C5	Wall-S	0.70	S	46.1	N	50.0	30.0	6.0	0.50	0.03	0.17	0.70	46.3	49.1	47.7	-2.8	· -4.0
9.06	CA	Wall-E	0.70	w	50.0	Е	46.1	6.0	30.0	0.50	0.17	0.03	0.70	49.1	46.3	47.7	2.8	4.0
	CD	Wali-W	0.70	w	46.1	Ē	50.0	30.0	6.0	0.50	0.03	0.17	0.70	46.3	49.1	47.7	-2.8	-4.0
	C1	Wall-N	0.90	S	50.0	N	46.1	6.0	30.0	0.64	0.17	0.03	0.84	49.2	46.3	47.7	3.0	3.3
9.06 -	C5	Wall-S	0.90	s	46.1	N	50.0	30.0	6.0	0.64	0.03	0.17	0.84	46.3	49.2	47.7	-3.0	-3.3
4.65	CA	Wall-E	0.90	w	50.0	E	46.1	6.0	30.0	0.64	0.17	0.03	0.84	49.2	46.3	47.7	3.0	3.3
	CD	Wall-W	0.90	w	46.1	Е	50.0	30.0	6.0	0.64	0.03	0.17	0.84	46.3	49.2	47.7	-3.0	-3.3
	C1	Wall-N	0.90	S	30.0	N	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	27.0	15.5	21.3	11.5	12.8
4.65 -	C5	Wall-S	0.90	S	15,5	N	30.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	27.0	21.3	-11.5	-12.8
-2.00	CA	Wall-E	0.90	w	30.0	Е	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	27.0	15.5	21.3	11.5	12.8
	CD	Wall-W	0.90	w	15.5	Е	30.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	27.0	21.3	-11.5	-12.8
	C1	Wali-N	0.90	s	50.0	N	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	42.9	15.5	29.2	27.4	30.4
-2.00 -	C3	Wall-NS	1.00	s	50.0	N	50.0	6.0	6.0	0.71	0.17	0.17	1.05	50.0	50.0	50.0	0.0	0.0
-7.40	C5	Wall-S	0.90	S	15.5	Ν	50.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	42.9	29.2	-27.4	-30.4
	CA	Wall-E	0.90	W	50.0	Е	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	42.9	15.5	29.2	27.4	30.4
	CD	Wail-W	0.90	W	15.5	Е	50.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	42.9	29.2	-27.4	-30.4

Notes: T: Top of Roof, Slab or Mat, B: Bottom of Roof, Slab or Mat, N: North side of Wall, S: South side of Wall, E: East side of Wall,

W: West side of Wall



WG3-U73-ERD-S-0004	SH NO.41
REV. 2	of 219

#### Table 5.3-4 Result of Heat Transfer Analysis, DBA: Winter (Reproduced from Reference 2.1.2-i)

EL (m)	Location	ID	Thick. (m)		Atom.	Temp C)	1	Thin Film Coef. (kcal/m <sup>2</sup> h °C)         Resistance of Heat Conduction (m <sup>2</sup> h °C /kcal)		Surface Lineariz Temperature (°C) (°C)		earized perature °C)	Tg/t					
(,			t		T1		T2	h1	h2	rc	r1	r2	R	Та	Tb	Td	. Tg	(°C /m)
SLAB	_					_												
13.80	Roof	S_RF	0.70	Т	-40.0	В	40.0	35.0	6.0	0.50	0.03	0.17	0.70	-36.7	20.8	-7.9	-57.5	-82.2
9.06	Slab	S_2F	0.50	Т	40.0	В	50.0	6.0	6.0	0.36	0.17	0.17	0.69	42.4	47.6	45.0	-5.2	-10.3
4.65	Slab	S_1F	0.50	Т	50.0	в	30.0	6.0	6.0	0.36	0.17	0.17	0.69	45.2	34.8	40.0	10.3	20.7
-2.00	Slab	S_B1F	0.50	Т	30.0	В	50.0	6.0	6.0	0.36	0.17	0.17	0.69	34.8	45.2	40.0	-10.3	-20.7
-7.40	Mat	S_MAT	3.00	Т	50.0	В	15.5	6.0	1E+09	2.14	0.17	0.00	2.31	47.5	15.5	31.5	32.0	10.7
WALL					_		-				_							
	C1	Wall-N	0.70	s	40.0	N	-40.0	6.0	35.0	0.50	0.17	0.03	0.70	20.8	-36.7	-7.9	57.5	82.2
13.80 <b>-</b>	C5	Wail-S	0.70	S	-40.0	N	40.0	35.0	6.0	0.50	0.03	0.17	0.70	-36.7	20.8	-7.9	-57.5	82.2
9.06	CA	Wall-E	0.70	w	40.0	Е	-40.0	6.0	35.0	0.50	0.17	0.03	0.70	20.8	-36.7	-7.9	57.5	82.2
	CD	Wall-W	0.70	w	-40.0	Е	40.0	35.0	6.0	0.50	0.03	0.17	0.70	-36.7	20.8	-7.9	-57.5	-82.2
	C1	Wall-N	0.90	S	50.0	N	-40.0	6.0	35.0	0.64	0.17	0.03	0.84	32.1	-36.9	-2.4	69.0	76.7
9.06 -	C5	Wall-S	0.90	s	-40.0	N	50.0	35.0	6.0	0.64	0.03	0.17	0.84	-36.9	32.1	-2.4	-69.0	-76.7
4.65	CA	Wall-E	0.90	w	50.0	ш	-40.0	6.0	35.0	0.64	0.17 ·	0.03	0.84	32.1	-36.9	-2.4	69.0	76.7
	CD	Wall-W	0.90	w	-40.0	Е	50.0	35.0	6.0	0.64	0.03	0.17	0.84	-36.9	32.1	-2.4	-69.0	-76.7
	C1	Wall-N	0.90	s	30.0	N	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	27.0	15.5	21.3	11.5	12.8
4.65 -	C5	Wall-S	0.90	S	15.5	N	30.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	27.0	21.3	-11.5	-12.8
-2.00	CA	Wall-E	0.90	w	30.0	Е	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	27.0	15.5	21.3	11.5	12.8
	CD	Wall-W	0.90	w	15.5	Е	30.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	27.0	21.3	-11.5	-12.8
	C1	Wall-N	0.90	s	50.0	N	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	42.9	15.5	29.2	27.4	30.4
-2.00 -	C3	Wall-NS	1.00	S	50.0	N	50.0	6.0	6.0	0.71	0.17	0.17	1.05	50.0	50.0	50.0	0.0	0.0
-7.40	C5	Wall-S	0,90	s	15.5	N	50.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	42.9	29.2	-27.4	-30.4
	CA	Wall-E	0.90	w	50.0	E	15.5	6.0	1E+09	0.64	0.17	0.00	0.81	42.9	15.5	29.2	27.4	30.4
	CD	Wall-W	0.90	W	15.5	Е	50.0	1E+09	6.0	0.64	0.00	0.17	0.81	15.5	42.9	29.2	-27.4	-30.4

Notes: T: Top of Roof, Slab or Mat, B: Bottom of Roof, Slab or Mat, N: North side of Wall, S: South side of Wall, E: East side of Wall,

W: West side of Wall



Basic wind speed

Wind directionality factor Kd 0.85

WG3-U73-ERD-S-0004	SH NO. 42
REV. 2	of 219

Heig	ht (m)	Design Wind Load (kN/m <sup>2</sup> )							
EL	Z	Windward Wall			Leewar	d Wall	Side Wall	R	oof
13.80	9.15	2.35		2.35 -1.65		55	-2.11	-2	2.90
9.22	4.57	2.14		2.14		65	-2.11	-2	2.90
9.06	4.41	2.14		-1.65		-2.11	-2	2.90	
4.65	0.00	2.14		2.14		35	-2.11	-2	2.90
		zg	700	ft	Coef.		Wali		Roof
			11.5			Windward	Leeward	Side	
Importance fac	ctor	Ι	1.15		G	0.85			

# Table 5.4-1 Design Wind Pressure Loads by Floor Level(Reproduced from Reference 2.1.2-i)

Table 5.5-1 Design Pressure of Tornado Wind Load	
(Reproduced from Reference 2.1.2-i)	

Ср

GCpi

0.8

-0.18

-0.5

0.18

-0.7

0.18

-1.04

0.18

V 62.59 m/s

	p (kN/m²)									
Wind Direction		Roof								
	Windward	Leeward	Side							
All	7.1	-4.4	-6.2	-9.2						
Differential	16.5	16.5	16.5	16.5						



WG3-U73-ERD-S-0004	SH NO.43
REV. 2	of 219

FI	Node No.	NS-direction <sup>*)</sup>		EW-d	irection*)	Calculated	Accidental	Design
		Shear	Moment	Shear	Moment	Torsion	Torsion	Torsion
(m)		(MN)	(MN-m)	(MN)	(MN-m)	(MN-m)	(MN-m)	(MN-m)
13.80	6	42.68	109.76	40.16	86.07	27.53	64.67	92.20
9.06	5	42.68	276.32	40.16	226.02	27.53	64.67	92.20
9.06	5	77.90	359.79	70.07	292.54	57.73	118.02	175.75
4.65	4	77.90	684.74	70.07	561.86	57.73	118.02	175.75
4.65	4	101.02	381.88	91.19	204.46	51.22	153.04	204.26
-2.00	3	101.02	1053.35	91.19	736.10	51.22	153.04	204.26
-2.00	3	40.98	566.89	44.77	510.74	26.91	67.83	94.74
-7.40	2	40.98	770.80	44.77	693.16	26.91	67.83	94.74
-7.40	2	26.86	338.05	20.86	198.89	0.00	40.70	40.70
-10.40	1	26.86	257.43	20.86	136.22	0.00	40.70	40.70

## Table 5.6-1 Design Seismic Loads for Horizontal

Note: Obtained from Reference 2.1.2-l based on site-specific Seismic Analysis of Control Building in Reference 2.1.2-k The node numbers in this table are described in Figure 5.6-1.

\*) NS and EW represent moments for bending in the NS and EW direction, respectively.



WG3-U73-ERD-S-0004	SH NO. 44
REV. 2	of 219

EL (m)	Node No.	V (g)					
13.80	6	1.05					
9.06	5	0.95					
4.65	4	0.82					
-2.00	3	0.60					
-7.40	2	0.64					
-10.40	1	0.63					
13.80	9001	2.20					
	9002	2.09					
	9003	2.00					
	9004	2.08					
9.06	9101	2.08					
	9102	1.62					
	9103	2.00					
	9104	1.93					
4.65	9201	1.53					
	9202	1.73					
	9203	1.75					
-2.00	9301	1.32					
	9302	1.28					

## Table 5.6-2 Vertical Acceleration

Note: Obtained from Reference 2.1.2-l based on site-specific Seismic Analysis of Control Building in Reference 2.1.2-k

The node numbers in this table are described in Figure 5.6-1.



WG3-U73-ERD-S-0004	SH NO. 45
REV. 2	of 219

EL	н	C1 and C5 Walls σ	CA and CD Walls σ
(m)	(m)	(MN/m*)	(MN/m²)
4.650	0.350		
4.300	0.350		
3.950	1.830		
2.120	2.190	0.12	0.12
-0.070	1.930		
-2.000	0.250		
-2.250	0.250		
-2.500	1.465		
-3.965	1.400	0.28	0.23
-5.685	1.720		
-7.400	1.715		
-9.900	2.500	0.31	0.28
-10.400	0.500		

## Table 5.6-3 Dynamic Soil Pressures

Note: Obtained from Reference 2.1.2-l, based on site-specific Seismic Analysis of Control Building in Reference 2.1.2-k

		Soil Spring Constants (MN/m/m <sup>2</sup> )						
Lo	ads	Horiz	Mantiaal					
		NS-direction	EW-direction	vertical				
for All Loads except for Se	eismic Loads	19.650	20.378	29.177				
	Horizontal, NS motion *	19.650	20.378	79.174				
for Seismic Loads	Horizontal, EW motion *	19.650	20.378	79.174				
	Vertical	19.650	20.378	29.177				
	Torsional	19.650	20.378	79.174				

# Table 6.2-1 Soil Spring Constants(Reproduced from Reference 2.1.2-i)

Note: \* Vertical springs for horizontal seismic loads are calculated based on the rotational spring constants.

(Reproduced from Reference 2.1.2-1)								
			Reinforce	d Concrete	Steel			
			Basemat	Others				
,		Temperature	f' <sub>c</sub> =4000psi	f' <sub>c</sub> =5000psi	Structural Steel			
		(°C) <sup>(*)</sup>	27.6MPa	34.5MPa	Oleen			
Young's	Temperature	< 21	2.49×10 <sup>4</sup>	2.78×10 <sup>4</sup>				
Modulus	Loads	93	1.81×10⁴	2.03×10⁴	2.00x10⁵			
(MPa)		204	1.62×10⁴	1.81×10 <sup>4</sup>				
	Other	Loads	2.49×10 <sup>4</sup>	2.78×10 <sup>4</sup>	2.00×10⁵			
Poisson's Ratio			0.17		0.3			
Thermal Expansion (m/m°C)			9.90	1.17×10 <sup>-5</sup>				
1	Unit Weight (MI	N/m³)	0.0	0.0770				

#### Table 6.2-2 Properties of Structural Material (Reproduced from Reference 2.1.2-i)

Note:(\*) Linear interpolation of material properties should be used for temperatures between the specified values.



WG3-U73-ERD-S-0004	SH NO. 47
REV. 2	of 219

# Table 6.2-3 Design Basic Load Case List

	Label	Combination of		
				Analysis Cases
Dead Loads			DLO	=GRAV+DL+EL
Live Loads	Floor Live Loads		LLO	=LL1
	Static Soil Pressure		SPO	=SP
Thermal Loads	Normal Summer		TLS0	=TLS0
	Normal Winter		TLWO	=TLW0
	DBA Summer		TLS1	=TLS1
	DBA Winter		TLW1	=TLW1
Wind Loads	Wind Loads	North to South	WON	=WON
		South to North	WOS	=WOS
		East to West	WOE	=WOE
		West to East	WOW	=WOW
	Tornado Loads	North to South	WTN	=WTN
		South to North	WTS	=WTS
		East to West	WTE	=WTE
		West to East	WTW	I=WTW
·	Tornado Differential Pressure Loads	Outward	WTD	=WTD
NA3 Seismic	X (NS) direction V & M	North to South	KXS	=XS
Loads (SSE)	Y (EW) direction V & M	West to East	KYS	=YS
	Vertical Acceleration	Upward	KZS	=VAS
	Torsional Moment	Clockwise	KTS	=TMS
	Dynamic Soil Pressure	North and South (with KXS and/or -KXS)	SKNS	=SPNS
		East and West (with -KYS and/or KYS)	SKEW	=SPEW

Note: Non-Seismic load combinations, shown in the red case, are from the standard design in Reference 2.1.2-i.



WG3-U73-ERD-S-0004	SH NO. 48
REV. 2	of 219

Analysis Load Cases			Load	Case
	Applied load	Direction	ID No.	Label
Dead Loads	Structural Weight		1000	GRAV
	Other Weight		1100	DL
	Equipment Loads		1200	EL
Live Loads	Floor Live Loads		2000	LL1
	Floor Live Loads (25% Live Load)		2100	LL2
	Static Soil Pressure		2200	SP
Thermal Loads	Normal Summer		3101	TLS0
	Normal Winter		3102	TLW0
	DBA Summer		3201	TLS1
	DBA Winter		3202	TLW1
Wind Loads	Severe Environmental	North to South	4101	WON
		South to North	4102	wos
		East to West	4103	WOE
		West to East	4104	wow
	Extreme Environmental	North to South	4201	WTN
,		South to North	4202	WTS
		East to West	4203	WTE
		West to East	4204	WTW
	Tornado Differential Pressure Loads	Outward	4205	WTD
NA3 Seismic Loads	X (NS) direction Shear & Moment	North to South	5110	XS
(SSE)	Y (EW) direction Shear & Moment	West to East	5120	YS
	Vertical Acceleration	Upward	5130	VAS
	Torsional Moment	Clockwise	5140	TMS
	Dynamic Soil Pressure	North and South (with XS and/or -XS)	5150	SPNS
		East and West (with-YS and/or YS)	5160	SPEW

# Table 6.2-4 Analysis Load Case List

Note: Non-Seismic load combinations, shown in the red case, are from the standard design in Reference 2.1.2-i.

.



WG3-U73-ERD-S-0004	SH NO.49
REV. 2	of 219

Elevation	Height	Shear			Moment								
EL (m)	DH (m)	Q (MN)	q (MN)	M (MNm)	Mq (MNm)	M-Mq (MNm)	dM (MNm)	m (MNm)	Mq+dM (MNm)	Input Level (m)	Difference (m)	dMq (MNn)	Total m + dMq (MNm)
13.80		42.68	42.68	109.76	0.00	109.76	109.76	109.76	109.76	13.45	0.35	14.94	124.70
9.06	4.74			276.32	202.32	74.00			312.08				
9.06		77.90	35.22	359.79	202.32	157.47	157.47	47.71	359.79	8.81	0.25	8.80	56.51
4.65	4.41			684.74	545.85	138.89			703.32				
4.65		101.02	23.12	381.88	545.85	-163.98	-163.98	-321.45	381.88	4.40	0.25	5.78	-315.67
-2.00	6.65			1053.35	1217.61	-164.26			1053.63				
-2.00		40.98	-60.03	566.89	1217.61	-650.72	-650.72	-486.74	566.89	-2.25	0.25	-15.01	-501.75
-7.40	5.40			770.80	1438.93	-668.13			788.21				
Notes :	Q : D	esign Shear Fo	rce dM	: Additional Mo	oment								

# Table 6.2-5 Applied Shear and Moment for Walls, NS Input

: Q : Design Shear Force q : Input Shear Force

m : Input Moment

M : Design Moment dMq : Moment Modification Considering

Mq : Moment due to Shear

the Difference of Input Level



1

WG3-U73-ERD-S-0004	SH NO.50
REV. 2	of 219

Elevation	Height	Sh	ear		Moment								
EL (m)	DH (m)	Q (MN)	q (MN)	M (MNm)	Mq (MNm)	M-Mq (MNm)	dM (MNm)	m (MNm)	Mq+dM (MNm)	Input Level (m)	Difference (m)	dMq (MNn)	Total m + dMq (MNm)
13.80		40.16	40.16	86.07	0.00	86.07	86.07	86.07	86.07	13.45	0.35	14.06	100.13
9.06	4.74			226.02	190.36	35.66			276.43				
9.06		70.07	29.90	292.54	190.36	102.18	102.18	16.11	292.54	8.81	0.25	7.48	23.58
4.65	4.41			561.86	499.35	62.51			601.53				
4.65		91.19	21.13	204.46	499.35	-294.90	-294.90	-397.07	204.46	4.40	0.25	5.28	-391.79
-2.00	6.65			736.10	1105.79	-369.69			810.90				
-2.00		44.77	-46.42	510.74	1105.79	-595.06	-595.06	-300.16	510.74	-2.25	0.25	-11.60	-311.77
-7.40	5.40			693.16	1347.58	-654.42			752.52				
Notes :	Q : Des	ign Shear Force	e dM:	Additional Morr	ient								

# Table 6.2-6 Applied Shear and Moment for Walls, EW Input

Q : Design Shear Force q: Input Shear Force

M : Design Moment

m : Input Moment

dMq : Moment Modification Considering

Mq : Moment due to Shear

the Difference of Input Level



WG3-U73-ERD-S-0004	SH NO. 51
REV. 2	of 219

#### Table 6.2-7 Additional Overturning Moments for Basemat

	NS direc	tion	EW direction			
Q	A	ΔМ	Q	A	ΔM	
(MN)	(g)	(MN-m)	(MN)	(g)	(MN-m)	
40.98	0.48	102.57	44.77	0.43	104.33	

Note: Additional moment for basemat is calculated by the following equation:

 $\Delta M = (Q + W_{mat} A) h$ 

where,

Q: Shear force at EL -7.40 m

 $W_{mat}$ : Weight of Basemat (GRAV+DL +EL+ LL2) = 57.55MN

A: Horizontal Acceleration of Basemat

h: Half of Basemat thickness (1.50 m)

#### Table 6.2-8 Slab Vertical Acceleration

EL (m)	Slab Equivalent Out-of-Plane Acceleration Load ( <sub>s</sub> A <sub>ave</sub> ) (g)
13.80	1.53
9.06	1.21
4.65	1.03
-2.00	0.69

Note: Obtained from Reference 2.1.2-1, based on site-specific Seismic Analysis of Control Building in Reference 2.1.2-k

EL (m)	Torsion Mt (MN-m)	Applied Torsion dMt (MN-m)
13.80	92.20	92.20
9.06	92.20	
9.06	175.75	83.55
4.65	175.75	
4.65	204.26	28.52
-2.00	204.26	
-2.00	94.74	-109.52
-7.40	94.74	

#### **Table 6.2-9 Applied Torsional Moment**



WG3-U73-ERD-S-0004	SH NO.52
REV. 2	of 219

Wali iD	Xi,Yi (m)	Thick- ness (m)	Height (m)	Length (m)	A (m²)	l (m⁴)	K (MN/m)	Lxi,Lyi (m)	Kt (MNm)	dMt (MNm)	Q (MN)	input Load (MN)	Applied dir.	Applied grid No.
X 1	-0.10	0.70	4.74	29.60	20.72	1513	51370	-11.55			1.756	0.13510	- X	
X2	23.00	0.70	4.74	29.60	20.72	1513	51370	11.55	3.11E+07	92.20	1.756	0.13510	+ X	6631~6643, Interval=1
Y1	-0.10	0,70	4.74	23.10	16.17	719	39812	-14.80			1.744	0.15856	+ Y	6501~6631, Interval≕13
Y2	29.50	0.70	4.74	23.10	16.17	719	39812	14.80			1.744	0.15856	- Y	6513~6643, Interval=13

 Table 6.2-10 Applied Force due to Torsional Moment, EL 9.06 to 13.80

 $Ec = 27800 \text{ MN/m}^2$ 

n = 0.17

 $G = 11880 \text{ MN/m}^2$ 

Xcr = 14.70 m

Ycr = 11.45 m

dMt = Mt (EL 9.06 ~ EL 13.80)



WG3-U73-ERD-S-0004	SH NO.53
REV. 2	of 219

Wall ID	Xi,Yi (m)	Thick- ness (m)	Height (m)	Length (m)	A (m²)	l (m⁴)	K (MN/m)	Lxi,Lyi (m)	Kt (MNm)	dMt (MNm)	Q (MN)	Input Load (MN)	Applied dir.	Applied grid No.
X1a	0.00	0.90	4.41	12.20	10.98	136	28015	-11.45			0.699	0.11658	-X	5001~5006, Interval≍1
X1b	0.00	0.90	4.41	12.20	10.98	136	28015	-11.45			0.699	0.11658	-X	5008~5013, Interval=1
X2a	22.90	0.90	4.41	12.20	10.98	136	28015	11.45	3.83E+07	83.55	0.699	0.11658	+X	5131~5136, Interval≍1
X2b	22.90	0.90	4.41	12.20	10.98	136	28015	11.45			0.699	0.11658	+X	5138~5143, Interval≕1
Y1	0.00	0.90	4.41	22.90	20.61	901	54656	-14.70			1.752	0.15928	+Y	5001~5131, Interval=13
Y2	29.40	0.90	4.41	22.90	20.61	901	54656	14.70			1.752	0.15928	-Y	5013~5143, Interval=13

## Table 6.2-11 Applied Force due to Torsional Moment, EL 4.65 to 9.06

 $Ec = 27800 \text{ MN/m}^2$ 

n = 0.17

 $G = 11880 \text{ MN/m}^2$ 

Xcr = 14.70 m

Ycr = 11.45 m

dMt = Mt (EL 4.65 ~ EL 9.06)



WG3-U73-ERD-S-0004	SH NO.54
REV. 2	of 219

Wall ID	Xi,Yi (m)	Thick- ness (m)	Height (m)	Length (m)	A (m²)	l (m⁴)	K (MN/m)	Lxi,Lyi (m)	Kt (MNm)	dMt (MNm)	Q (MN)	Input Load (MN)	Applied dir.	Applied grid No.
X1	0.00	0.90	6.65	29.40	26.46	1906	46260	-11.45			0.549	0.04227	-X	3501~3513, Interval=1
X2	22.90	0.90	6.65	29.40	26.46	1906	46260	11.45	2.75E+07	28.52	0.549	0.04227	+X	3631~3643, Interval=1
Y1	0.00	0.90	6.65	22.90	20.61	901	35539	-14.70			0.542	0.04927	+Y	3501~3631, Interval=13
Y2	29.40	0.90	6.65	22.90	20.61	901	35539	14.70			0.542	0.04927	-Y	3513~3643, Interval=13

 Table 6.2-12 Applied Force due to Torsional Moment, EL -2.00 to 4.65

 $Ec = 27800 \text{ MN/m}^2$ 

n = 0.17

 $G = 11880 \text{ MN/m}^2$ 

Xcr = 14.70 m

Ycr = 11.45 m

dMt = Mt (EL -2.00 ~ EL 4.65)



WG3-U73-ERD-S-0004	SH NO.55
REV. 2	of 219

.

Wall ID	Xi,Yi (m)	Thick- ness (m)	Height (m)	Length (m)	A (m²)	l (m⁴)	K (MN/m)	Lxi,Lyi (m)	Kt (MNm)	dMt (MNm)	Q (MN)	input Load (MN)	Applied dir.	Applied grid No.
X1	0.00	0.90	5.40	29.40	26.46	1906	57386	-11.45			2.105	0.16191	+X	2001~2013, Interval=1
X2	22.90	0.90	5.40	29.40	26.46	1906	57386	11.45			2.105	0.16191	-X	2131~2143, Intervai=1
Y1	0.00	0.90	5.40	22.90	20.61	901	44291	-14.70	3.42E+07	-109.52	2.086	0.18960	-Y	2001~2131, Interval=13
Y2a	14.70	1.00	5.40	9.95	9.95	82	19443	0.00			0.000	0.00000	-Y	2007~2059, interval=13
Y2b	14.70	1.00	5.40	9.95	9.95	82	19443	0.00			0.000	0.00000	-Y	2085~2137, interval=13
Y3	29.40	0.90	5.40	22.90	20.61	901	44291	14.70			2.086	0.18960	+Y	2013~2143, Interval≕13

 Table 6.2-13 Applied Force due to Torsional Moment, EL -7.40 to -2.00

 $Ec = 27800 \text{ MN/m}^2$ 

n = 0.17

 $G = 11880 \text{ MN/m}^2$ 

Xcr = 14.70 m

Ycr = 11.45 m

dMt = Mt (EL -7.40 ~ EL -2.00)



WG3-U73-ERD-S-0004	SH NO. 56
REV.2	of 219

		(~	<b>P</b> - <b>o</b> -  -  -  -  -  -  -  -  -  -  -  -  -						
Location	Element ID	N <sub>x</sub> (MN/m)	N <sub>y</sub> (MN/m)	N <sub>xy</sub> (MN/m)	M <sub>x</sub> (MNm/m)	M <sub>y</sub> (MNm/m)	M <sub>xy</sub> (MNm/m)	Q <sub>x</sub> (MN/m)	Q <sub>y</sub> (MN/m)
Basemat	67	0.026	-0.709	0.027	-0.987	-1.078	0.088	0,195	-0.160
EL-7.4m	72	-0.050	0.071	0.010	-0.469	-0.218	-0.025	-0.623	0.037
	115	-0.729	-0,274	0.309	-0.219	-0.213	-0.371	-0.027	-0.660
	120	-0.058	-0.027	-0.157	-0.110	-0.173	0.675	-0.033	-0.021
Slab B1F	567	-0.004	0.729	-0.044	-0.049	-0.023	-0.009	-0.077	0.022
EL-2.0m	572	0.080	0.122	-0.012	-0.021	-0.017	0.008	0.100	-0.006
	615	0.167	0.128	-0.255	-0.034	-0.006	0.026	-0.042	0.004
	620	0.040	0.042	0.056	-0.024	-0.024	-0.029	0.034	0.039
Slab 1F	1067	0.071	0.031	-0.002	0.168	0.058	-0.011	Qx           (MN/m)           0.195           -0.623           -0.027           -0.033           -0.077           0.100           -0.042           0.034           0.035           -0.010           -0.042           0.034           0.030           0.073           -0.001           0.016           0.007           0.017           0.023           0.057           -0.004           0.057           -0.004           0.057           -0.004           0.057           -0.002           -0.059           -0.034           0.044           -0.002           0.019           0.004           0.019           0.000           -0.002           0.006           0.005           -0.002	0.025
EL4.65m Slab 2F	1072	-0.013	0.032	0.002	-0.028	-0.009	0.000	0.073	0.005
	1115	0.110	0.008	0.010	-0.016	-0.152	-0.009	-0.001	0.144
	1120	0.020	0.015	0.055	-0.016	-0.015	-0.015	0.019	0.025
Slab 2F EL9.06m	1567	0.012	0.061	-0.002	0.081	0.002	-0.004	0.016	0.010
	1572	0.018	-0.006	0.001	-0.030	-0.012	0.000	0.061	0.001
	1615	0.136	0.114	-0.025	-0.007	-0.117	-0.007	0.007	0.128
	1620	0.015	0.009	0.018	-0.015	-0.015	-0.014	0.017	0.022
Slab RF	1867	-0.081	-0.055	0.003	0.152	0.050	-0.007	0.023	0.004
EL13.8m	1872	-0.033	-0.104	0.003	-0.029	-0.015	0.006	0.057	0.001
Slab 2F EL9.06m Slab RF EL13.8m Wall	1915	-0.074	-0.105	-0.001	-0.004	-0.122	-0.008	-0.004	0.136
	1920	-0.010	-0.043	0.012	-0.017	10 $-0.173$ $0.675$ $-0$ 149 $-0.023$ $-0.009$ $-0$ 134 $-0.006$ $0.026$ $-0$ 134 $-0.006$ $0.026$ $-0$ 121 $-0.024$ $-0.029$ $0.0$ 134 $-0.024$ $-0.029$ $0.0$ 124 $-0.024$ $-0.029$ $0.0$ 128 $-0.009$ $0.000$ $0.0$ 128 $-0.009$ $0.000$ $0.0$ 128 $-0.015$ $-0.015$ $0.001$ 128 $-0.015$ $-0.015$ $0.001$ 16 $-0.015$ $-0.015$ $0.001$ 130 $-0.012$ $0.000$ $0.0$ 130 $-0.015$ $-0.014$ $0.0$ 15 $-0.015$ $-0.007$ $0.0$ 14 $0.097$ $-0.006$ $-0.007$ 14 $0.025$ $0.008$ $0.0$ 14 $0.025$ $0.007$ $0.0$ <	0.016	0.021	
Wall	6007	-0.263	-0.753	-0.224	-0.014	0.097	-0.006	-0.059	0.070
EL-7.4m	4006	0.028	-0.925	0.015	-0.035	-0.188	0.001	-0.002	-0.045
~EL-2.001	4010	0.070	-0.211	-0.113	0.016	-0.073	-0.007	-0.034	-0.042
Wall	6043	0.172	-1.275	-0.295	0.041	0.025	0.008	0.044	0.002
EL-2.0m	4036	0.070	-0.620	-0.007	0.021	0.116	-0.002	-0.002	0.036
~EL4.05m	4040	-0.018	-0.362	0.045	-0.005	0.028	0.014	0.019	0.021
Wall	6081	0.006	-0.592	-0.031	-0.014	-0.116	-0.007	0.000	-0.062
=L-7.4m ~EL-2.0m EL-2.0m ~EL4.65m Wall EL4.65m ~EL9.06m	4066	-0.012	-0.338	0.004	0.005	0.022	-0.002	-0.002	0.018
	4070	-0.016	-0.263	0.095	-0.003	0.007	0.001	0.006	0.007
Wall	6117	-0.003	-0.330	-0.053	-0.009	-0.060	0.005	0.005	-0.077
~EL 13.8m	4096	-0.067	-0.164	0.001	0.006	0.033	0.000	-0.002	0.038
	4100	-0.009	-0.113	0.083	0.003	0.009	-0.001	-0.001	0.010

### Table 6.2-14 Results of NASTRAN Analysis: Dead Load (Reproduced from Reference 2.1.2-i)



WG3-U73-ERD-S-0004	SH NO. 57
REV. 2	of 219

		(					,		
Location	Element	N <sub>x</sub>	Ny	N <sub>xy</sub>	M <sub>×</sub>	My	M <sub>xy</sub>	Qx	Qy
Decement		<u>(MN/m)</u>	( <u>MN/m</u> )	(MN/m)	(MNm/m)	( <u>MNm/m</u> )	( <u>MNm/m</u> )	(MN/m)	( <u>MN/m</u> )
Basemat	67	-0.409	-1.291	0.169	6.783	6.419	-0.132	0.291	-0.113
CL-7.44111	72	-0.189	-0.279	0.059	1.916	5.868	-0.007	0.290	0.127
	115	-0.198	-0.082	0.185	6.662	2.336	-0.255	0.533	0.941
_	_ 120 _	-0.949	-1.034	-0.271	3.316	3.332	1.777	1.350	1.269
Slab B1F	567	-0.720	0.380	0.045	-0.078	-0.091	0.002	-0.003	0.006
EL-2.0m	572	0.331	-0.756	-0.056	-0.030	-0.063	0.003	-0.023	0.000
	615	-0.858	0.641	-0.723	-0.078	-0.033	0.006	-0.032	-0.073
	620	-0.970	-0.965	-1.402	-0.066	-0.065	0.009	0.007	0.005
Slab 1F	1067	-1.315	-0.447	-0.012	0.062	0.026	0.001	0.003	-0.003
EL4.65m	1072	-0.170	-1.780	-0.097	0.184	0.081	0.007	-0.061	-0.001
	1115	-1.419	0.046	0.018	0.065	0.113	0.002	-0.008	-0.017
	1120	-1.987	-1.963	-2.417	0.130	0.129	-0.007	-0.033	-0.031
Slab 2F	1567	-2.552	-1.076	0.015	-0.027	-0.087	0.002	0.004	0.000
EL9.06m	1572	-0.679	-3.420	-0.099	0.070	-0.022	0.008	-0.099	0.006
	1615	-2.425	0.082	-0.110	0.043	0.193	-0.031	0.036	-0.087
	1620	-3.153	-3.133	-4.149	-0.051	-0.057	0.025	0.020	0.029
Roof	1867	1.500	1.282	-0.012	-0.783	-1.023	0.001	0.015	-0.006
EL13.8m	1872	1.774	1.355	0.412	-0.232	-0.745	0.032	-0.330	0.023
	1915	1.949	1.114	0.485	-0.695	-0.400	0.008	0.017	-0.146
	1920	-0.003	-0.164	0.493	-0.634	-0.644	-0.022	-0.011	0.005
Wall	6007	0.521	1.371	-0.057	0.642	0.904	0.004	-0.032	0.165
EL-7.4m	4006	0.756	-0.069	0.091	-0.688	-1.068	-0.002	-0.001	-0.194
~EL-2.0m	4010	1.043	1.253	-0.324	-0.531	-0.881	-0.042	-0.156	-0.334
Wall	6043	2.535	-1.168	-0.671	0.378	0.483	-0.026	0.127	0.061
EL-2.0m	4036	2.463	-0.411	-0.013	-0.289	-0.300	0.001	0.031	0.070
~EL4.65m	4040	1.381	1.392	-0.606	-0.080	-0.300	-0.047	-0.217	-0.181
Wall	6081	5.519	-0.786	0.338	1.391	1.000	0.007	-0.048	-0.161
EL4.65m	4066	6.358	-0.464	-0.042	-1.488	-1.021	0.000	-0.021	0.188
~EL9.06m	4070	3.596	1.323	-1.489	-1.232	-1.167	-0.021	-0.332	-0.163
Wall	6117	3.560	-0.619	-1.500	0.908	1.500	-0.022	-0.038	0.385
EL9.06m	4096	3.980	-0.285	-0.182	-0.936	-1.566	-0.001	0.034	-0.463
~EL13.8m	4100	2.844	1.752	-1.526	-0.681	-1.227	-0.002	-0.347	-0.594

Table 6.2-15 Results of NASTRAN Analysis: Temperature Load (DBA: Winter)
(Reproduced from Reference 2.1.2-i)

HITACHI

WG3-U73-ERD-S-0004	SH NO. 58
REV. 2	of 219

to South Direction)									
Location	Element	Nx	Ny	N <sub>xy</sub>	M <sub>×</sub>	My	M <sub>×y</sub>	Qx	Qy
LUCATION	ID	(MN/m)	(MN/m)	(MN/m)	(MNm/m)	(MNm/m)	(MNm/m)	(MN/m)	(MN/m)
Basemat	67	-0.075	-0.060	0.054	-0.245	-0.160	-0.095	0.339	-0.008
EL-7.4m	72	-0.201	-1.943	-0.047	-0.427	-0.587	0.040	-0.663	-0.042
	115	-0.095	-0.041	0.946	0.024	0.021	-1.012	0.510	-0.071
	120	0.093	-0.370	-0.057	-0.249	-0.110	0.320	0.028	-0.458
Slab B1F	567	0.063	0.068	-0.052	0.019	-0.001	-0.005	0.008	-0.005
EL-2.0M	572	-0.299	-0.162	0.093	-0.007	-0.004	-0.001	0.002	0.001
	615	0.091	0.006	0.442	0.013	0.001	0.002	0.013	0.002
	620	-0.144	0.014	0.409	-0.010	0.010	-0.001	0.011	-0.013
Slab 1F	1067	0.020	-0.007	0.010	-0.003	-0.004	-0.002	0.006	-0.002
EL4.65M	1072	0.157	0.138	-0.042	-0.036	-0.008	-0.002	0.016	0.001
	1115	0.007	-0.010	-0.234	-0.009	-0.001	0.000	0.005	0.001
	1120	0.148	0.049	-0.072	-0.019	0.010	0.002	0.019	-0.018
Slab 2F	1567	0.042	-0.048	0.007	-0.003	-0.003	-0.002	0.006	-0.001
EL9.06m	1572	0.280	0.336	-0.061	-0.015	-0.005	-0.001	0.009	0.000
	1615	-0.481	-0.090	0.003	-0.017	-0.003	0.002	0.010	0.003
	1620	0.166	0.082	-0.235	-0.014	0.009	0.000	0.014	-0.015
Roof	1867	0.052	0.026	-0.014	-0.006	-0.005	-0.003	0.009	-0.001
EL13.8M	1872	0.412	0.848	0.014	0.003	-0.010	0.001	-0.008	0.001
	1915	0.152	0.025	-0.481	-0.012	-0.001	-0.004	0.007	0.002
	1920	0.182	0.189	-0.003	-0.011	0.008	-0.002	0.012	-0.014
Wall	6007	0.026	-0.070	1.074	-0.033	0.019	-0.003	-0.040	0.019
~EL-7.4m ~EL-2.0m	4006	-0.616	-0.860	-0.079	-0.016	-0.133	0.001	-0.001	-0.083
	4010	-0.111	-0.495	-0.534	0.008	-0.035	0.011	-0.006	-0.022
Wall	6043	-0.030	0.060	2.181	-0.013	-0.009	-0.001	-0.003	-0.004
~EL-2.0m ~EL4.65m	4036	-0.360	-0.871	-0.029	0.039	0.168	-0.002	0.006	0.050
	4040	-0.184	-1.318	-0.723	-0.005	0.090	-0.012	0.056	0.062
Wall	6081	0.551	-0.330	1.576	0.005	0.022	-0.004	0.001	0.015
~EL9.06m	4066	0.197	-0.677	-0.054	-0.013	-0.044	-0.003	-0.005	0.008
	4070	0.029	-0.697	-0.891	0.002	-0.006	-0.025	-0.019	-0.016
Wall	6117	-0.358	0.126	0.778	-0.002	-0.003	0.000	-0.002	0.004
~EL9.06m	4096	0.551	-0.298	-0.069	-0.011	-0.039	0.001	-0.006	-0.014
	4100	0.132	-0.208	-0.674	-0.001	-0.019	-0.004	-0.021	-0.020

Table 6.2-16 Results of NASTRAN Analysis: Site-Specific Seismic Load (Horizontal: North



l

WG3-U73-ERD-S-0004	SH NO. 59
REV. 2	of 219

# Table 6.2-17 Results of NASTRAN Analysis: Site-Specific Seismic Load (Horizontal: East to West Direction)

Lacation	Element	N <sub>x</sub>	Ny	N <sub>xy</sub>	M <sub>×</sub>	My	M <sub>×y</sub>	Q <sub>x</sub>	Qy
Location	ID	(MN/m)	(MN/m)	(MN/m)	(MNm/m)	(MNm/m)	(MNm/m)	(MN/m)	(MN/m)
Basemat	67	-0.134	0.064	-0.105	-0.265	-0.782	-0.049	-0.253	1.034
EL-7.400	72	-0.020	0.046	1.236	-0.037	-0.090	-1.297	-0.076	0.457
	115	-3.134	-0.280	-0.025	-0.343	-0.272	-0.109	0.017	-0.412
	120	-0.548	0.263	0.001	-0.132	-0.344	0.111	-0.759	0.117
Slab B1F	567	-0.012	-0.087	0.374	-0.011	-0.032	-0.008	-0.007	0.050
EL-2.0m	572	0.004	-0.005	0.600	0.001	0.000	0.000	-0.001	-0.001
	615	-0.354	-0.068	0.227	-0.007	-0.025	-0.002	0.002	0.017
	620	0.019	-0.091	0.511	0.013	-0.017	-0.002	-0.019	0.018
Slab 1F	1067	0.001	0.015	-0.016	-0.003	0.000	-0.003	-0.001	-0.001
EL4.65m	1072	0.001	0.004	-0.193	0.000	0.000	-0.001	-0.001	-0.002
	1115	0.244	0.109	0.003	-0.016	-0.051	0.001	-0.001	0.019
	1120	0.051	0.104	-0.108	0.012	-0.024	0.000	-0.022	0.023
Slab 2F	1567	0.017	0.043	-0.044	-0.001	0.001	-0.001	0.000	-0.001
EL9.06m	1572	0.005	0.005	-0.424	0.000	0.000	-0.001	0.000	-0.001
	1615	0.737	0.254	0.032	-0.004	-0.023	0.001	0.004	0.009
	1620	0.092	0.147	-0.207	0.010	-0.018	-0.001	-0.017	0.018
Roof	1867	0.063	0.036	-0.070	-0.003	0.000	-0.003	0.000	0.001
EL13.8m	1872	0.006	0.004	-0.635	0.000	0.000	-0.005	0.000	-0.003
	1915	1.315	0.362	-0.015	-0.013	-0.042	0.002	0.001	0.013
	1920	0.251	0.141	-0.099	0.006	-0.022	-0.007	-0.020	0.015
Wall	6007	-1.101	-0.560	-0.141	-0.012	0.034	0.002	-0.003	0.043
EL-7.4m ~EL-2.0m	4006	0.038	-0.087	1.175	-0.005	-0.015	0.011	0.005	-0.006
	4010	0.155	-0.683	0.526	-0.039	-0.086	-0.001	-0.026	-0.038
Wall	6043	-0.612	-0.583	-0.136	-0.074	-0.250	0.000	-0.014	-0.087
EL-2.0m ~EL4.65m	4036	0.001	-0.058	2.069	-0.001	0.000	-0.003	-0.004	0.000
	4040	-0.156	-1.151	1.627	-0.042	0.006	0.019	0.027	0.021
Wall	6081	0.189	-0.741	-0.330	0.015	0.075	0.018	0.007	0.005
~EL4.65m ~EL9.06m	4066	-0.002	-0.051	1.692	0.000	-0.001	0.005	0.000	-0.001
	4070	0.016	-0.601	1.263	0.016	-0.007	0.015	-0.004	-0.010
Wall	6117	0.707	-0.375	-0.393	0.006	0.002	0.002	0.004	-0.016
~EL9.06m ~EL13.8m	4096	-0.004	-0.027	0.980	0.001	0.001	0.002	0.000	0.000
	4100	0.012	-0.254	0.691	0.014	-0.004	0.007	-0.002	-0.016



I

.

WG3-U73-ERD-S-0004	SH NO. 60
REV. 2	of 219

# Table 6.2-18 Results of NASTRAN Analysis: Site-Specific Seismic Load (Vertical: Upward Direction)

Location	Element	N <sub>x</sub>	Ny	N <sub>xy</sub>	Mx	My	M <sub>×y</sub>	Q <sub>x</sub>	Qy	
Location	ID	(MN/m)	(MN/m)	(MN/m)	(MNm/m)	(MNm/m)	(MNm/m)	(MN/m)	(MN/m)	
Basemat	67	-0.027	0.640	-0.022	1.152	0.943	-0.093	-0.111	0.130	
EL-7.4m	72	0.041	-0.092	-0.013	0.432	0.127	0.044	0.535	-0.031	
	115	0.676	0.259	-0.284	0.242	0.214	0.325	0.029	0.639	
	120	0.053	0.027	0.137	0.099	0.174	-0.587	0.043	0.044	
Slab B1F	567	-0.005	-0.662	0.039	0.048	0.018	0.006	0.060	-0.017	
EL-2.0m	572	-0.073	-0.114	0.011	0.023	0.012	-0.006	-0.077	0.004	
	615	-0.164	-0.128	0.231	0.027	0.003	-0.020	0.033	0.003	
	620	-0.041	-0.041	-0.056	0.017	0.017	0.021	-0.024	-0.028	
Slab 1F	1067	-0.086	-0.047	0.004	-0.178	-0.066	0.011	-0.032	-0.026	
EL4.65M	1072	0.001	-0.044	-0.001	0.041	0.011	0.001	-0.085	-0.005	
	1115	-0.123	-0.034	-0.014	0.019	0.171	0.009	0.000	-0.158	
	1120	-0.024	-0.019	-0.056	0.019	0.017	0.017	-0.020	-0.026	
Slab 2F	1567	-0.039	-0.079	0.004	-0.103	-0.008	0.005	-0.020	-0.013	
EL9.06m	1572	-0.028	-0.008	0.000	0.050	0.016	0.001	-0.088	0.000	
	1615	-0.156	-0.137	0.022	0.011	0.159	0.008	-0.008	-0.167	
	1620	-0.021	-0.017	-0.008	0.021	0.020	0.017	-0.022	-0.028	
Roof	1867	0.125	0.099	-0.004	-0.254	-0.083	0.012	-0.038	-0.007	
EL 13.0(1)	1872	0.051	0.125	-0.005	0.047	0.026	-0.009	-0.097	-0.001	
	1915	0.135	0.166	0.002	0.008	0.200	0.013	0.007	-0.226	
	1920	0.026	0.059	-0.017	0.029	0.025	0.062	-0.027	-0.032	
Wall	6007	0.236	0.736	0.210	0.012	-0.088	0.004	0.054	-0.066	
~EL-2.0m	4006	-0.014	0.829	-0.019	0.029	0.158	-0.001	0.002	0.039	
	4010	-0.062	0.221	0.102	-0.013	0.066	0.005	0.029	0.038	
Wall	6043	-0.160	1.287	0.274	-0.037	-0.024	-0.006	-0.039	0.002	
~EL4.65m	4036	-0.059	0.636	0.002	-0.018	-0.097	0.001	0.002	-0.033	
	4040	0.017	0.390	-0.046	0.004	-0.023	-0.010	-0.016	-0.018	
Wall	6081	-0.004	0.713	-0.006	0.021	0.133	0.005	0.001	0.073	
~EL9.06m	4066	0.007	0.408	-0.007	-0.008	-0.041	0.003	0.003	-0.029	
	4070	0.017	0.297	-0.096	0.003	-0.009	-0.002	-0.007	-0.010	
Wall	6117	0.018	0.434	0.043	0.013	0.089	-0.006	-0.006	0.125	
~EL13.8m	4096	0.069	0.222	0.000	-0.009	-0.048	0.001	0.003	-0.062	
	4100	0.002	0.125	-0.090	-0.005	-0.012	0.003	0.003	-0.016	



WG3-U73-ERD-S-0004	SH NO.61
REV. 2	of 219

Table 6.3-1 Load Combinations and A	cceptance Criteria for Safe	y-Related Reinforced Concrete Structures
		N Contraction of the second seco

Category	Combination		Load*								Acceptance
	No.	D	F	L	н	То	Та	E'	w	Wt	Criteria**
Normal	CB-1	1.4	1.4	1.7	1.7						U
	CB-2	1.05	1.05	1.3	1.3	1.3					U
Severe	CB-3	1.4	1.4	1.7	1.7				1.7		υ
Environmental	CB-4	1.05	1.05	1.3	1.3	1.3			1.3		υ
	CB-5	1.2	1.2						1.7		U
Extreme	CB-6	1.0	1.0	1.0	1.0	1.0		1.0			Ņ
Environmental	CB-7	1.0	1.0	1.0	1.0	1.0				1.0	υ
Abnormal	CB-8	1.0	1.0	1.0	1.0		1.0				U
Abnormal/Extreme	CB-9	1.0	1.0	1.0	1.0		1.0	1.0			υ
Environmental											

Note \*: D = Dead loads

F = Hydrostatic pressure loads

L = Live loads (For the roof, Roof Live loads or Snow loads or Rain loads each act independently.)

H = Lateral soil pressure loads

To = Thermal loads during the normal operation

Ta = Thermal loads during design basis accident

E' = Seismic loads (SSE)

W = Wind loads (basic wind)

Wt = Wind loads (tornado wind)

Note \*\*: U = Required section strength based on the strength design method per ACI 349-01.

Note: Non-Seismic load combinations, shown in the red combination No., are analyzed as part of the standard design in Reference 2.1.2-i.



WG3-U73-ERD-S-0004	SH NO.62
REV. 2	of 219

Category	Combination		-	Acceptance					
	No.	D	L	То	Та	E'	w	Wt	Criteria**
Normal	CB-S1	1.0	1.0						S
	CB-S2	1.0	1.0	1.0					S(a)
Severe	CB-S3	1.0	1.0				1.0		S
Environmental	CB-S4	1.0	1.0	1.0			1.0		S(a)
Extreme	CB-S5	1.0	1.0	1.0		1.0			1.6S(b)(c)
Environmental	CB-S6	1.0	1.0	1.0				1.0	1.6S(b)(c)
Abnormal	CB-S7	1.0	1.0		1.0				1.6S(b)(c)
Abnormal/Extreme	CB-S8	1.0	1.0		1.0	1.0			1.7S(b)(c)
Environmental									

#### Table 6.3-2 Load Combinations and Acceptance Criteria for Safety-Related Steel Structures

Note \*: D = Dead loads

L = Live loads (For the roof, Roof Live loads or Snow loads or Rain loads each act independently.)

To = Thermal loads during the normal operation

Ta = Thermal loads during design basis accident

E' = Seismic loads (SSE)

W = Wind loads (basic wind)

Wt = Wind loads (tornado wind)

Note \*\*: Allowable elastic working stress (S) is the allowable stress limit specified in Part 1 of AISC N690-1994-s2 (2004).

- (a) For primary plus secondary stress, the allowable limits are increased by a factor of 1.5.
- (b) Stress limit coefficient in shear shall not exceed 1.4 in members and bolts.
- (c) Stress limit coefficient where axial compression exceeds 20% of nominal allowable, shall be 1.5 for load combination 5, 6, 7, and 1.6 for load combination 8.
- Note: Non-Seismic load combinations, shown in the red combination No., are analyzed as part of the standard design in Reference 2.1.2-i.



WG3-U73-ERD-S-0004	SH NO. 63
REV. 2	of 219

Catagony		Load Combination													
Calegory	No.	D	L	То	Та	E'	W	Wt	Criteria*						
Severe Environmental	CB-3	1.4	1.7	-			1.7		U						
	CB-4	1.05	1.3	1.3			1.3		U						
Tornado	CB-7	1.0	1.0	1.0				1.0	υ						
DBA + SSE	CB-9	1.0	1.0		1.0	1.0			U						

#### Table 6.3-3 Selected Load Combinations for Reinforced Concrete Structures

Note \*: U = Required section strength based on the strength design method per ACI 349-01

Note: Non-Seismic load combinations, shown in the red combination No., are analyzed as part of the standard design in Reference 2.1.2-i.

Catagoni		Load Combination													
Category	No.	No. D L				E'	E' W		Criteria*						
Severe Environmental	CB-S3	1.0	1.0				1.0		S						
	CB-S4	1.0	1.0	1.0			1.0		S (a)						
SSE	CB-S5	1.0	1.0	1.0		1.0			1.6S (b)(c)						
Tornado	CB-S6	1.0	1.0	1.0				1.0	1.6S (b)(c)						
DBA	CB-S7	1.0	1.0		1.0				1.6S (b)(c)						
DBA + SSE	CB-S8	1.0	1.0		1.0	1.0			1.7S (b)(c)						

#### Table 6.3-4 Selected Load Combination for Steel Structures

Note \*: See note in Table 6.3-2.

Note: Non-Seismic load combinations, shown in the red combination No., are analyzed as part of the standard design in Reference 2.1.2-i.



WG3-U73-ERD-S-0004	SH NO. 64
REV. 2	of 219

				Live	Load	<u> </u>	herm	al Loa	d			wina	Load			ОП	<u>1ado L</u>	oad		i i	ō		
			Dead Load	mal Operation ressure (Static)		mal Operation ressure (Static)		Normal Operation		DBA		Seismic Load	N to S	S to N	E to W	W to E	N to S	S to N	E to W	W to E	o Differential Load	tance Criteria	ombination for Tables orces and Moments
				Nor	Soil F	Summer	Winter	Summer	Winter										Tornad	Accept	ed Load Co ombined Fo		
			рго	LLO	SPO	TLS0	דורעיס	TLS1	1LW1	KSO	NON	NOS	WOE	NON	WTΝ	WTS	WTE	WTW	WTD		Select		
CB-3	1 4D+1 7I +1 7W (Normal (	(neration)				<u>†                                    </u>	<u> </u>	<u> </u>			-							<u> </u>					
00-0	1.4011.7211.744 (Horman C	N to S Wind 3001	1 40	1 70	1 70						1 70	— ·								hu t	J		
		S to N Wind 3007	1 40	1.70	1 70	-					1.70	1 70						<u> </u>		нñ			
		E to W Wind 3002	1 40	1 70	1 70	+						1.70	1 70					'	F	нт			
		W to E Wind 3004	1.40	1.70	1.70									1.70						Ū			
CB-4	1.05D+1.3L+1.3To+1.3W ()	formal Operation)										-											
[ ·	Summer	N to S Wind 4011	1.05	1.30	1.30	1.30					1.30									U			
		S to N Wind 4012	1.05	1.30	1.30	1.30						1.30								Ū			
		E to W Wind 4013	1.05	1.30	1.30	1.30							1.30							U			
		W to E Wind 4014	1.05	1.30	1.30	1.30								1.30						U			
E	Winter	N to S Wind 4021	1.05	1.30	1.30		1.30				1.30								Г — Т	U	$\checkmark$		
		S to N Wind 4022	1.05	1.30	1.30		1.30					1.30								U			
		E to W Wind 4023	1.05	1.30	1.30		1.30						1.30				_			U			
		W to E Wind4024	1.05	1,30	1.30		1.30							1.30						U			
CB-7	Tornado (Normal Operatio	n)																					
	w/o Temp	N to S Wind 5001	1.00	1.00	1.00										1.00				L	U			
		S to N Wind 5002	1.00	1.00	1.00											1.00				U			
1		E to W Wind 5003	1.00	1.00	1.00	1				<u>ا</u>					I		1.00	1		101			
		W to E Wind 5004	1.00	1.00	1.00								_					1.00		U			
		N to S Wind+DP/2 5005	i 1.00	1.00	1.00										1.00				0.50				
		S to N Wind+DP/2 5008	1.00	1.00	1.00											1.00			0.50	U			
		E to W Wind+DP/2 5007	1.00	1.00	1.00												1.00		0.50	U			
		W to E Wind+DP/2 5008	1.00	1.00	1.00													1.00	0.50	U			
	<u> </u>	Differential 5009	1.00	1.00	1.00				L									<u> </u>	1.00	U			
	Summer	N to S Wind 5011	1.00	1.00	1.00	1.00									1.00					U			
		S to N Wind 5012	1.00	1.00	1.00	1.00									-	1.00	1.00	<u> </u>	1	U			
		E to W Wind 5013	11.00	1.00	1.00	1.00		<u> </u>									1.00	4 00		문			
		VV to E Wind 5014	1.00	1.00	1.00	1.00						<u> </u>			1.00		<u> </u>	1.00	0.50		-		
		N to S Wind+DP/2 5015	1.00	1.00	1.00	1.00									1.00	1.00	<u> </u>		0.50				
		5 to N Wind+DP/2 5016	1.00	1.00	1.00	1.00	-			<b> </b>	<u> </u>				-	1.00	1 00	<u>                                     </u>	0.50	나라	—		
		W to E Wind+DP/2 5017	1.00	1.00	1.00	1.00				<u> </u>	· · ·	-					1.00	1 00	0.50	HH			
		Differential 5019	1 00	1 00	1.00	1.00									-		<del> </del>	1.00	1.00	Ŭ			
	Winter	N to S Wind 5021	1 00	1 00	1 00	1.00	1 00	<u> </u>							1 00		t	<u> </u>	1.00	Ŭ	V		
		S to N Wind 5022	1.00	1.00	1.00		1.00							<u> </u>	1	1.00		<u> </u>		ū			
1		E to W Wind 5023	1.00	1.00	1.00		1.00			<u> </u>						1	1.00			Ū			
		W to E Wind 5024	1.00	1.00	1.00	+	1.00	<u> </u>			1			1			1	1.00		Ū			
		N to S Wind+DP/2 5025	1.00	1.00	1.00		1.00								1.00				0.50	Ū			
		S to N Wind+DP/2 5026	1.00	1.00	1.00		1.00									1.00	<u> </u>		0.50	U			
		E to W Wind+DP/2 5027	1.00	1.00	1.00		1.00										1.00	<b>—</b>	0.50	U			
1		W to E Wind+DP/2 5028	1.00	1.00	1.00		1.00											1.00	0.50	U			
		Differential 5029	1.00	1.00	1.00		1.00		1										1.00	U			
CB-9	LOCA (DBA+SSE)																						
1	Max." w/o Temp	7001	1.00	1.00	1.00					1.00										U			
1	Summer	7011	1.00	1.00	1.00			1.00		1.00										U			
1	Winter	7021	1.00	1.00	1.00				1.00	1.00		1								U	√_		
1	Min.") w/o Temp	7501	1.00	1.00	1.00					-1.00										U			
1	Summer	7511	1.00	1.00	1.00			1.00		-1.00										U			
1	Winter	7521	1.00	1.00	1.00				1.00	-1.00	1	1	1				1		1	U			

# Table 6.3-5 Detailed Load Combinations for Reinforced Concrete Structures

 vvrnuer
 /52111.00 | 1.00 | 1.00 | 1.00 |
 | 1.00 | -1.00 |
 0

 Notes: Non-Seismic load combinations, shown in the red box, are analyzed as part of the standard design in Reference 2.1.2-i.
 \*) Max. = Seismic Load is applied to positive direction.

 \*\*') Min. = Seismic Load is applied to negative direction.



WG3-U73-ERD-S-0004	SH NO. 65
REV. 2	of 219

					Live	Load		Inerm	al Loa	d			VVING	Load			101				ACI	ceptai Scitori	100	
				Dead Load	mal Operation	Pressure (Static)	0	- Normal Operation	ă		Seismic Load	N to S	S to N	E to W	W to E	N to S	S to N	E to W	W to E	o Differential Load			•	
					Nor	Soil F	Summer	Winter	Summer	Winter										Tornad				
				DLO	ΓΓΟ	SPO	TLSO	TLWD	TLS1	TLW1	KSO	NON	sow	WOE	wow	WTN	WTS	WTE	WTW	WTD	tens.	comp.	shear	
CB-S3	1.0D+1.0L+1.0W (	Normal Operation)										1												
		N to S Wind	3001	1.00	1.00	1.00						1.00										_		
		S to N Wind	3002	1.00	1.00	1.00	— ·		<u> </u>				1.00	1 00				<u> </u>			S	S	S	
		E to w wind	3003	1.00	1.00	1.00								1.00	1.00									
CB-S4	1 0D+1 0I +1 0To+	1 0W (Normal Operation	on)	1.00	1.00	1.00		<u> </u>			t –				1.00									
	Summer	N to S Wind	4011	1.00	1.00	1.00	1.00					1.00												
		S to N Wind	4012	1.00	1.00	1.00	1.00						1.00											
		E to W Wind	4013	1.00	1.00	1.00	1.00				<u> </u>			1.00							4 50		4.40	
		W to E Wind	4014	1.00	1.00	1.00	1.00	1.00		<u> </u>		1.00			1.00					-	1.55	1.35	1.45	
	winter	S to N Mind	4021	1.00	1.00	1.00		1.00				1.00	1.00	-										
		E to W Wind	4022	1.00	1.00	1.00		1 00					1.00	1.00										
_		W to E Wind	4024	1.00	1,00	1,00		1.00				L			1.00					_				
CB-S5	(Normal Operation	n+SSE)																						
	Max."	w/o Temp	5001	1.00	1.00	1.00					1.00													
		Summer	5101	1.00	1.00	1.00	1.00		1		1.00							-			1.6S 1.4		4.0	
		Winter	5201	1.00	1.00	1.00		1.00			1.00	<u> </u>	ļ									1.6S	S 1.4S 1.4S	1.45
	Min.	w/o Temp	5501	1.00	1.00	1.00	1.00	1.00			-1.00		ļ											
		Summer	5601	1.00	1.00	1.00		1.00			-1.00													
CB-S6	Tornado (Normal	Operation)	5701	1.00	1.00	1.00	<u></u>			-	-1.00													
00-30	w/o Tem	D N to S Wind	6001	1.00	1.00	1.00			-			ł	1-			1.00								
		S to N Wind	6002	1.00	1.00	1.00					1	<u> </u>	1				1.00				1			
		E to W Wind	6003	1.00	1.00	1.00												1.00						
		W to E Wind	6004	1.00	1.00	1.00			1										1.00					
		N to S Wind+DP/2	6005	1.00	1.00	1.00								<u> </u>		1.00	1.00	<u> </u>		0.50				
		S to N Wind+DP/2	6007	1.00	1.00	1.00											1.00	1 00		0.50				
		W to E Wind+DP/2	6008	1.00	1.00	1.00												1.00	1.00	0.50				
		Differential	6009	1.00	1.00	1.00		····					1	1			<u> </u>			1.00	1			
	Summer	N to S Wind	6011	1.00	1.00	1.00	1,00									1.00								
		S to N Wind	6012	1.00	1.00	1.00	1.00			<u> </u>			<u> </u>	<u> </u>			1.00	1.00						
		E to W Wind	6013	1.00	1.00	1.00	1.00											1.00	1 00					
		N to S Wind+DP/2	6015	1.00	1.00	1.00	1.00	-		-		<u> </u>	1	1		1.00		├──	1.00	0.50	1.6S	1. <b>4</b> S	1.4S	
1		S to N Wind+DP/2	6016	1.00	1.00	1.00	1.00	1					1			1	1.00		· ·	0.50	1		i	
		E to W Wind+DP/2	6017	1.00	1.00	1.00	1.00											1.00		0.50				
1		W to E Wind+DP/2	6018	1.00	1.00	1.00	1.00												1.00	0.50			1	
1		Differential	6019	1.00	1.00	1.00	1.00	1.00				I	1			1.00		<u> </u>		1.00				
	winter	Sto N Wind	6021	1.00	1.00	1.00	<u> </u>	1.00				<del> </del>				1.00	1.00		<u> </u>					
1		E to W Wind	6023	1.00	1.00	1.00	<del> </del>	1.00		+			1				1.00	1.00					i	
		W to E Wind	6024	1.00	1.00	1.00		1.00				· · ·	t						1.00		1			
1		N to S Wind+DP/2	6025	1.00	1.00	1.00		1.00								1.00				0.50			i l	
		S to N Wind+DP/2	6026	1.00	1.00	1.00		1.00									1.00	1.00		0.50				
		E to W Wind+DP/2	6027	1.00	1.00	1.00	<u> </u>	1.00	·	<u> </u>	<u> </u>	<u> </u>						1.00	1.00	0.50				
1		Note wind+DP/2	6020	1.00	1.00	1.00	<del> </del>	1.00				<u> </u>							1.00	1.00			1	
CB-97		Direfertual	0029	1.00	1.00	1.00		1.00	i —			-	1							1.00				
1 <sup>00-3</sup>	Summer		7011	1.00	1.00	1.00		1	1.00				†								1.6S	1.45	1.4S	
	Winter		7021	1.00	1.00	1.00		1		1.00	· · ·													
CB-S8	LOCA (DBA+SSE)	)						_												_			7	
	Max."	Summer	8101	1.00	1.00	1.00			1.00	L	1.00	ļ	L											
		Winter	8201	1.00	1.00	1.00			1.00	1.00	1.00										1.7S	1.65	1.4S	
	Min.	Summer	8601	1.00	1.00	1.00	<b> </b>		11.00	1.00	-1.00		<u> </u>								1		1	
		VVIDEE	0/01			• I.U.I.I		1		1 1 111	1 = 1 UU		1	1								1		

## Table 6.3-6 Detailed Load Combinations for Steel Structures

Notes: Non-Seismic load combinations, shown in the red box, are analyzed as part of the standard design in Reference 2.1.2-i. \*) Max. = Seismic Load is applied to positive direction. \*\*) Min. = Seismic Load is applied to negative direction.



WG3-U73-ERD-S-0004	SH NO. 66
REV. 2	of 219

	Element		N <sub>y</sub>	N <sub>v</sub>	N <sub>xv</sub>	M,	M <sub>v</sub>	M <sub>xv</sub>	Q,	Q,
Location	ID		(MN/m)	(MN/m)	(MN/m)	(MNm/m)	(MNm/m)	(MNm/m)	(MN/m)	(MN/m)
Basemat	67	OTHR	-3.076	-3.299	-0.064	-1.214	-0.445	0.171	-0.029	-0.209
EL-7.4m		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	72	OTHR	-3.988	-0.998	-0.061	3.228	1.110	-0.064	-0.756	-0.033
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1	115	OTHR	-3.867	-2.269	-0.933	-0.231	0.426	0.867	-0.626	-0.886
Į – – – – – – – – – – – – – – – – – – –		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	120	OTHR	-3.044	-1.664	-0.173	1.430	0.607	-0.028	-0.555	-0.039
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Slab B1F	567	OTHR	-1.677	-0.332	0.009	-0.116	-0.035	-0.006	-0.138	0.041
EL-2.0m		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	572	OTHR	-2.586	-1.024	0.182	-0.014	-0.020	0.013	0.156	-0.010
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	615	OTHR	-0.867	-0.783	0.118	-0.069	-0.014	0.032	-0.078	0.010
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	620	OTHR	-1.208	-0.600	1.568	-0.031	-0.054	-0.048	0.041	0.077
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Slab 1F	1067	OTHR	-0.567	-0.133	-0.024	0.271	0.103	-0.017	0.045	0.035
EL4.65m		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	1072	OTHR	-1.227	-0.485	0.096	-0.190	-0.034	-0.004	0.189	0.007
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	1115	OTHR	-0.354	-0.296	0.327	-0.034	-0.298	-0.010	0.001	0.261
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	1120	OTHR	-0.445	-0.114	0.614	-0.059	-0.029	-0.010	0.054	0.031
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Slab 2F	1567	_OTHR	0.017	0.092	0.028	0.140	0.010	-0.006	0.026	0.016
EL9.06m		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	1572	OTHR	0.140	-0.070	-0.022	-0.085	-0.023	-0.002	0.134	0.000
	<u></u>	TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	1615	_OTHR	0.022	0.199	-0.056	-0.016	-0.208	-0.010	0.011	0.224
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	1620	OTHR	0.054	0.027	-0.135	-0.030	-0.028	-0.027	0.030	0.037
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Roof	1867	OTHR	-0.111	-0.087	-0.006	0.220	0.103	-0.009	0.024	0.006
EL13.8m	1_	TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	1872	OTHR	-0.062	-0.136	-0.009	-0.084	-0.020	0.003	0.120	-0.002
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	1915	OTHR	-0.110	-0.168	-0.028	-0.014	-0.205	-0.005	-0.004	0.207
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	1920	OTHR	-0.010	-0.059	0.038	-0.028	-0.028	-0.062	0.019	0.026
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Table 6.3-7 Combined Forces and Moments: Selected Load Combination CB-3 (Standard design analysis results reproduced from Reference 2.1.2-i)

Notes:

OTHR: Loads other than thermal loads

TEMP: Thermal loads



WG3-U73-ERD-S-0004	SH NO. 67
REV. 2	of 219

Londian	Element		Nx	Ny	N <sub>xy</sub>	Mx	M <sub>y</sub>	M <sub>×y</sub>	Q <sub>x</sub>	Qy
Location	D		(MN/m)	(MN/m)	(MN/m)	(MNm/m)	(MNm/m)	(MNm/m)	(MN/m)	(MN/m)
Wall	6007	OTHR	-1.370	-1.029	-1.442	0.093	0.134	0.050	0.104	0.321
EL-7.4m		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
~EL-2.0m	4006	OTHR	-0.630	-0.851	-0.047	-0.103	-0.605	0.002	-0.007	-1.197
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	4010	OTHR	-0.498	-0.704	-0.037	-0.112	-0.242	0.133	0.136	-0.504
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Wali	6043	OTHR	-0.954	-1.472	-0.807	0.061	0.054	-0.019	0.064	0.359
EL-2.0m		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
~EL4.65m	4036	OTHR	-1.175	-0.429	0.058	0.043	0.103	-0.007	0.037	-0.967
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	4040	OTHR	-0.680	-1.387	0.649	-0.180	-0.008	0.168	0.356	-0.283
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Wall	6081	OTHR	-0.538	-0.813	0.197	0.005	0.007	0.001	-0.001	-0.057
EL4.65m		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
~EL9.06m	4066	OTHR	-0.674	-0.365	0.092	-0.073	-0.509	-0.013	0.015	-0.096
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	4070	OTHR	-0.153	-0.624	0.418	-0.041	-0.153	-0.125	0.005	-0.081
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Wall	6117	OTHR	-0.097	-0.482	0.023	-0.020	-0.128	0.004	0.007	-0.141
EL9.06m		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
~EL13.8m	4096	OTHR	-0.220	-0.261	0.031	0.009	0.057	-0.002	-0.009	0.082
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	4100	OTHR	0.000	-0.080	0.083	0.008	0.006	-0.001	-0.011	0.011
		TEMP	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

# Table 6.3-7 Combined Forces and Moments: Selected Load Combination CB-3 (Continued)

Notes:

OTHR: Loads other than thermal loads TEMP: Thermal loads



WG3-U73-ERD-S-0004	SH NO. 68
REV. 2	of 219

· · · · · · · · · · · · · · · · · · ·		a acoig								
Location	Element		Nx	Ny	N <sub>xy</sub>	M <sub>x</sub>	My	M <sub>xy</sub>	Q <sub>x</sub>	Qy
	ID		(MN/m)	(MN/m)	(MN/m)	(MNm/m)	(MNm/m)	(MNm/m)	<u>(MN/m)</u>	_(MN/m)
Basemat	67	OTHR	-2.353	-2.508	-0.049	-0.908	-0.318	0.129	-0.026	-0.156
EL-7.4m		TEMP	0.245	0.128	0.024	1.598	1.437	-0.003	-0.013	0.008
	72	OTHR	-3.049	-0.765	-0.047	2.478	0.853	-0.048	-0.565	-0.026
		TEMP	0.067	0.300	0.066	0.289	1.406	-0.040	0.110	0.095
	115	OTHR	-2.942	-1.729	-0.720	-0.172	0.330	0.671	-0.478	-0.664
		TEMP	1.046	0.058	0.132	1.780	0.464	-0.083	0.263	0.175
	120	OTHR	-2.327	-1.272	-0.129	1.096	0.468	-0.035	-0.424	-0.029
		TEMP	-0.179	-0.321	0.371	0.667	0.679	-0.063	0.490	0.334
Slab B1F	567	OTHR	-1.282	-0.269	0.008	-0.087	-0.027	-0.004	-0.104	0.031
EL-2.0m		TEMP	-0.230	0.032	0.005	-0.007	-0.004	0.000	-0.004	0.002
	572	OTHR	-1.980	-0.786	0.139	-0.010	-0.015	0.009	0.117	-0.008
		TEMP	0.093	-0.254	-0.026	-0.017	0.001	0.000	0.007	0.000
	615	OTHR	-0.666	-0.601	0.095	-0.052	-0.010	0.024	-0.059	0.007
		TEMP	-0.428	0.121	-0.119	-0.001	0.000	0.001	-0.007	-0.012
	620	OTHR	-0.924	-0.460	1.198	-0.023	-0.041	-0.036	0.031	0.058
		TEMP	-0.347	-0.334	-0.506	-0.010	-0.007	0.006	0.006	0.001
Slab 1F	1067	OTHR	-0.435	-0.102	-0.018	0.204	0.077	-0.013	0.034	0.026
EL4.65m		TEMP	-1.179	-0.492	-0.005	0.003	-0.015	0.000	0.002	-0.001
	1072	OTHR	-0.938	-0.372	0.073	-0.145	-0.026	-0.003	0.143	0.005
ļ.		TEMP	-0.153	-1.626	-0.081	0.100	0.016	0.005	-0.045	-0.002
(	1115	OTHR	-0.273	-0.226	0.250	-0.026	-0.225	-0.008	0.001	0.197
		TEMP	-1.366	0.033	-0.042	-0.004	0.028	0.003	-0.010	-0.005
	1120	OTHR	-0.340	-0.087	0.468	-0.045	-0.022	-0.008	0.041	0.023
		TEMP	-1.745	-1.712	-2.181	0.088	0.086	-0.008	-0.041	-0.038
Slab 2F	1567	OTHR	0.013	0.069	-0.021	0.105	0.008	-0.005	0.019	0.012
EL9.06m		TEMP	-2.057	-0.795	0.007	-0.039	-0.083	0.001	0.003	0.000
	1572	OTHR	0.107	-0.054	-0.017	-0.064	-0.017	-0.002	0.101	0.000
		TEMP	-0.490	-2.745	-0.073	0.027	-0.039	0.005	-0.070	0.005
	1615	OTHR	0.014	0.150	-0.042	-0.012	-0.157	-0.008	0.008	0.169
		TEMP	-1.573	0.168	-0.018	0.019	0.137	-0.025	0.031	-0.069
	1620	OTHR	0.041	0.021	-0.104	-0.023	-0.021	-0.020	0.023	0.028
		TEMP	-2.781	-2.761	-3.520	-0.067	-0.073	0.022	0.020	0.029
Roof	1867	OTHR	-0.084	-0.065	-0.005	0.165	0.078	-0.006	0.018	0.004
EL13.8m		TEMP	1.083	0.974	-0.007	-0.620	-0.784	0.001	0.011	-0.004
	1872	OTHR	-0.047	-0.102	-0.007	-0.064	-0.015	0.002	0.090	-0.001
}		TEMP	1.288	0.870	0.299	-0.226	-0.592	0.022	-0.235	0.017
4	1915	OTHR	-0.083	-0.126	-0.021	-0.010	-0.154	-0.004	-0.003	0.156
		TEMP	1.560	0.814	0.362	-0.557	-0.354	0.007	0.014	-0.103
	1920	OTHR	-0.007	-0.045	0.029	-0.021	-0.021	-0.047	0.014	0.020
		TEMP	-0.018	-0.182	0.316	-0.520	-0.530	-0.022	-0.009	0.007
	I		0.010	0.102	0.010	0.04.0	0.000	0.022	0.000	0.001

Table 6.3-8 Combined	Forces and Moments: Selected Load Combination CB-4
(Standard design	analysis results reproduced from Reference 2.1.2-i)

Notes:

OTHR: Loads other than thermal loads TEMP: Thermal loads



WG3-U73-ERD-S-0004	SH NO. 69
REV. 2	of 219

Leastian	Element		N <sub>x</sub>	Ny	N <sub>xy</sub>	Mx	My	M <sub>xy</sub>	Q <sub>x</sub>	Qy
Location	ם		(MN/m)	(MN/m)	(MN/m)	(MNm/m)	(MNm/m)	(MNm/m)	(MN/m)	(MN/m)
Wall	6007	OTHR	-1.042	-0.772	-1.098	0.071	0.100	0.038	0.081	0.244
EL-7.4m		TEMP	0.343	0.087	0.124	0.139	0.187	0.000	-0.006	0.045
~EL-2.0m	4006	OTHR	-0.482	-0.632	-0.036	-0.078	-0.459	0.001	-0.005	-0.914
		TEMP	0.359	-0.212	0.108	-0.134	-0.142	0.000	-0.001	-0.023
	4010	OTHR	-0.382	-0.534	-0.026	-0.086	-0.183	0.102	0.105	-0.384
		TEMP	0.173	0.673	0.175	-0.115	-0.131	-0.010	-0.005	-0.031
Wall	6043	OTHR	-0.733	-1.099	-0.611	0.046	0.040	-0.015	0.048	0.275
EL-2.0m		TEMP	-0.258	-0.852	-0.163	0.134	0.145	-0.008	0.011	-0.063
~EL4.65m	4036	OTHR	-0.900	-0.315	0.045	0.033	0.076	-0.005	0.028	-0.740
		TEMP	0.077	-0.838	0.043	-0.138	-0.138	0.000	0.002	0.114
	4040	OTHR	-0.519	-1.053	0.496	-0.137	-0.007	0.128	0.272	-0.217
		TEMP	0.340	2.135	0.158	-0.047	-0.159	-0.042	-0.097	-0.035
Wall	6081	OTHR	-0.412	-0.610	0.151	0.004	0.008	0.001	-0.001	-0.042
EL4.65m		TEMP	6.548	-1.010	0.131	1.243	0.955	0.018	-0.056	-0.077
~EL9.06m	4066	OTHR	-0.515	-0.272	0.070	-0.056	-0.389	-0.010	0.011	-0.074
		TEMP	7.531	-0.836	-0.102	-1.322	-0.952	-0.001	0.000	0.110
	4070	OTHR	-0.116	-0.471	0.317	-0.031	-0.117	-0.096	0.004	-0.062
		TEMP	4.742	1.668	-2.190	-1.087	-0.988	-0.027	-0.303	-0.234
Wall	6117	OTHR	-0.074	-0.362	0.019	-0.015	-0.097	0.003	0.005	-0.106
EL9.06m		TEMP	3.689	-0.604	-1.506	0.729	1.178	-0.018	-0.029	0.288
~EL13.8m	4096	OTHR	-0.167	-0.196	0.024	0.007	0.043	-0.002	-0.007	0.062
	1	TEMP	4.099	-0.340	-0.173	-0.751	-1.226	0.000	0.023	-0.344
	4100	OTHR	0.000	-0.059	0.062	0.006	0.005	-0.001	-0.008	0.008
	1	TEMP	2.630	1.287	-1.234	-0.554	-0.993	-0.004	-0.282	-0.506

# Table 6.3-8 Combined Forces and Moments: Selected Load Combination CB-4 (Continued)

Notes:

OTHR: Loads other than thermal loads TEMP: Thermal loads



WG3-U73-ERD-S-0004	SH NO. 70
REV. 2	of 219

Location	Element		N <sub>x</sub>	Ny	N <sub>xy</sub>	Mx	My	M <sub>xy</sub>	Q <sub>x</sub>	Qy
Location	ID		(MN/m)	( <u>MN/m</u> )	(MN/m)	(MNm/m)	(MNm/m)	(MNm/m)	(MN/m)	(MN/m)
Basemat	67	OTHR	-1.808	-2.051	-0.030	-0.844	-0.436	0.109	0.033	-0.149
EL-7.4m		TEMP	0.189	0.099	0.018	1.230	1.105	-0.002	-0.010	0.006
	72	OTHR	-2.357	-0.633	-0.035	1.804	0.589	-0.038	-0.565	-0.014
		TEMP	0.052	0.231	0.051	0.223	1.082	-0.031	0.085	0.073
	115	OTHR	-2.387	-1.376	-0.471	-0.164	0.221	0.417	-0.356	-0.619
		TEMP	0.804	0.045	0.101	1.369	0.357	-0.064	0.202	0.135
	120	OTHR	-1.798	-0.994	-0.125	0.815	0.329	0.097	-0.328	-0.035
		TEMP	-0.138	-0.247	0.285	0.513	0.522	-0.049	0.377	0.257
Slab B1F	567	OTHR	-0.986	-0.084	-0.001	-0.074	-0.025	-0.005	-0.094	0.028
EL-2.0m		TEMP	-0.177	0.025	0.004	-0.005	-0.003	0.000	-0.003	0.002
	572	OTHR	-1.509	-0.582	0.106	-0.011	-0.015	0.009	0.109	-0.007
		TEMP	0.071	-0.195	-0.020	-0.013	0.001	0.000	0.005	0.000
	615	OTHR	-0.485	-0.442	0.032	-0.046	-0.010	0.024	-0.053	0.007
		TEMP	-0.329	0.093	-0.091	-0.001	0.000	0.001	-0.005	-0.009
	620	OTHR	-0.704	-0.346	0.932	-0.022	-0.036	-0.033	0.031	0.052
		TEMP	-0.267	-0.257	-0.389	-0.008	-0.005	0.004	0.005	0.001
Slab 1F	1067	OTHR	-0.325	-0.066	-0.014	0.189	0,070	-0.012	0.032	0.025
EL4.65m	'	TEMP	-0.907	-0.378	-0.004	0.003	-0.012	0.000	0.002	-0.001
	1072	OTHR	-0.720	-0.271	0.055	-0.115	-0.022	-0.002	0.123	0.005
		TEMP	-0.118	-1.251	-0.062	0.077	0.013	0.004	-0.035	-0.001
	1115	OTHR	-0.193	-0.164	0.188	-0.023	-0.202	-0.008	0.001	0.179
		TEMP	-1.051	0.025	-0.032	-0.003	0.021	0.002	-0.008	-0.004
	1120	OTHR	-0.256	-0.060	0.361	-0.038	-0.019	-0.008	0.035	0.023
		TEMP	-1.342	-1.317	-1.678	0.068	0.066	-0.006	MNm/m)         (MN/m)           0.109         0.033           -0.002         -0.010           -0.038         -0.565           -0.031         0.085           0.417         -0.356           -0.044         0.202           0.097         -0.328           -0.049         0.377           -0.005         -0.094           0.009         0.109           0.000         -0.003           0.001         -0.005           0.024         -0.053           0.001         -0.005           -0.012         0.032           0.004         0.005           -0.012         0.032           0.004         -0.035           -0.002         0.123           0.004         -0.035           -0.008         0.001           0.004         -0.035           -0.008         0.001           0.004         -0.032           -0.004         0.018           0.001         0.002           -0.003         0.001           0.004         -0.034           -0.005         0.013           0.001         0.024	-0.030
Slab 2F	1567	OTHR	-0.001	0.069	-0.016	0.097	0.005	-0.004	0.018	0.011
EL9.06m		TEMP	-1.582	-0.611	0.005	-0.030	-0.064	0.001	0.002	0.000
	1572	OTHR	0.092	-0.030	-0.015	-0.051	-0.016	-0.001	0.086	0.000
		TEMP	-0.377	-2.111	-0.056	0.021	-0.030	0.004	-0.054	0.003
	1615	OTHR	0.020	0.138	-0.044	-0.011	-0.139	-0.008	0.007	0.153
		TEMP	-1.210	0.130	-0.014	0.015	0.105	-0.019	0.024	-0.053
	1620	OTHR	0.037	0.025	-0.088	-0.020	-0.019	-0.018	0.021	0.025
	•	TEMP	-2.139	-2.124	-2.708	-0.051	-0.056	0.017	0.015	0.022
Roof	1867	OTHR	-0.071	-0.041	-0.003	0.120	0.060	-0.005	0.013	0.003
EL13.8m	1	TEMP	0.833	0.750	-0.005	-0.477	-0.603	0.001	0.008	-0.003
	1872	OTHR	-0.032	-0.070	-0.004	-0.050	-0.010	0.001	0.070	-0.001
		TEMP	0.990	0.669	0.230	-0.174	-0.455	0.017	-0.181	0.013
	1915 .	OTHR	-0.063	-0.094	-0.024	-0.008	-0.117	-0.002	-0.002	0.115
		TEMP	1.200	0.626	0.278	-0.429	-0.272	0.005	0.011	-0.079
	1920	OTHR	-0.002	-0.030	0.022	-0.015	-0.016	-0.036	0.011	0.015
		TEMP	-0.014	-0.140	0.243	-0.400	-0.408	-0.017	-0.007	0.005

#### Table 6.3-9 Combined Forces and Moments: Selected Load Combination CB-7 (Standard design analysis results reproduced from Reference 2.1.2-i)

Notes:

OTHR: Loads other than thermal loads TEMP: Thermal loads



WG3-U73-ERD-S-0004	SH NO. 71
REV. 2	of 219

۰.

Location	Element		N <sub>x</sub>	Ny	N <sub>xy</sub>	Mx	My	M <sub>xy</sub>	Qx	Qy
Location	ID		(MN/m)	(MN/m)	(MN/m)	(MNm/m)	(MNm/m)	(MNm/m)	(MN/m)	(MN/m)
Wall	6007	OTHR	-0.845	-0.717	-0.846	0.051	0.094	0.028	0.051	0.200
EL-7.4m		TEMP	0.264	0.067	0.095	0.107	0.144	0.000	-0.005	0.034
~EL-2.0m	4006	OTHR	-0.378	-0.673	-0.027	-0.067	-0.387	0.001	-0.004	-0.711
		TEMP	0.276	-0.163	0.083	-0.103	-0.109	0.000	-0.001	-0.018
	4010	OTHR	-0.285	-0.453	-0.052	-0.062	-0.153	0.077	0.075	-0.303
		TEMP	0.133	0.518	0.135	-0.088	-0.101	-0.007	-0.004	-0.024
Wall	6043	OTHR	-0.536	-1.046	-0.483	0.042	0.034	-0.010	0.044	0.212
EL-2.0m		TEMP	-0.199	-0.655	-0.125	0.103	0.111	-0.006	0.009	-0.048
~EL4.65m	4036	OTHR	-0.677	-0.360	0.032	0.029	0.080	-0.004	0.021	-0.563
	1	TEMP	0.059	-0.645	0.033	-0.106	-0.106	0.000	0.001	0.088
	4040	OTHR	-0.403	-0.877	0.373	-0.107	0.000	0.101	0.212	-0.163
		TEMP	0.262	1.642	0.122	-0.036	-0.123	-0.033	-0.075	-0.027
Wall	6081	OTHR	-0.305	-0.544	0.126	0.001	-0.013	0.000	0.000	-0.052
EL4.65m		TEMP	5.037	-0.777	0.101	0.957	0.735	0.014	-0.043	-0.060
~EL9.06m	4066	OTHR	-0.381	-0.262	0.053	-0.043	-0.298	-0.008	0.008	-0.050
		TEMP	5.793	-0.643	-0.079	-1.017	-0.732	-0.001	0.000	0.085
	4070	OTHR	-0.085	-0.401	0.246	-0.023	-0.089	-0.074	0.002	-0.045
		TEMP	3.647	1.283	-1.685	-0.836	-0.760	-0.021	-0.233	-0.180
Wali	6117	OTHR	-0.058	-0.297	0.011	-0.013	-0.083	0.002	0.005	-0.089
EL9.06m		TEMP	2.838	-0.465	-1.159	0.560	0.906	-0.014	-0.022	0.222
~EL13.8m	4096	OTHR	-0.118	-0.166	0.017	0.006	0.037	-0.001	-0.005	0.053
		TEMP	3.153	-0.262	-0.133	-0.578	-0.943	0.000	0.018	-0.265
	4100	OTHR	0.005	-0.056	0.047	0.005	0.005	0.000	-0.007	0.008
		TEMP	2.023	0.990	-0.949	-0.426	-0.764	-0.003	-0.217	-0.390

# Table 6.3-9 Combined Forces and Moments: Selected Load Combination CB-7 (Continued)

Notes:

OTHR: Loads other than thermal loads TEMP: Thermal loads


WG3-U73-ERD-S-0004	SH NO. 72
REV. 2	of 219

# Table 6.3-10 Combined Forces and Moments: Site-Specific Seismic Load Combination CB-9

					<u>CD-7</u>					
Location	Element ID		N <sub>x</sub> (MN/m)	N <sub>y</sub> (MN/m)	N <sub>xy</sub> (MN/m)	M <sub>x</sub> (MNm/m)	M <sub>y</sub> (MNm/m)	M <sub>xy</sub> (MNm/m)	Q <sub>x</sub> (MN/m)	Q <sub>y</sub> (MN/m)
Basemat	67	OTHR	-1 803	-2 073	-0.034	-0.908	-0 459	0 120	0.010	-0 152
EL-7.4m		TEMP	-0.409	-1.291	0.169	6.783	6.419	-0.132	0.291	-0.113
		SEIS	0.156	0.646	0.129	1.363	1.690	0.181	0.565	1.102
	72	OTHR	-2.353	-0.545	-0.033	1.822	0.627	-0.044	-0.549	-0.012
		TEMP	-0.189	-0.279	0.059	1.916	5.868	-0.007	0.290	0.127
		SEIS	0.206	1.945	1.239	1.936	0.924	1.306	1.012	0.479
	115	OTHR	-2.411	-1.386	-0.507	-0.180	0.209	0.459	-0.382	-0.646
		TEMP	-0.198	-0.082	0.185	6.662	2.336	-0.255	0.533	0.941
		SEIS	3.207	0.383	0.992	0.532	0.814	1.151	0.527	0.774
	120	OTHR	-1.802	-0.979	-0.132	0.826	0.326	0.105	-0.334	-0.022
		TEMP	-0.949	-1.034	-0.271	3.316	3.332	1.777	1.350	1.269
		SEIS	0.559	0.455	0.148	0.839	0.819	0.916	0.852	0.576
Slab B1F	567	OTHR	-0.988	-0.058	-0.003	-0.078	-0.025	-0.005	-0.095	0.028
EL-2.0m		TEMP	-0.720	0.380	0.045	-0.078	-0.091	0.002	-0.003	0.006
		SEIS	0.065	0.671	0.379	0.054	0.036	0.012	0.061	0.057
	572	OTHR	-1.507	-0.581	0.105	-0.012	-0.015	0.009	0.110	-0.007
		TEMP	0.331	-0.756	-0.056	-0.030	-0.063	0.003	-0.023	0.000
		SEIS	0.308	0.199	0.607	0.028	0.013	0.006	0.077	0.005
	615	OTHR	-0.478	-0.436	0.021	-0.047	-0.009	0.024	-0.054	0.006
		TEMP	-0.858	0.641	-0.723	-0.078	-0.033	0.006	-0.032	-0.073
		SEIS	0.400	0.145	0.548	0.031	0.034	0.020	0.037	0.029
	620	OTHR	-0.703	-0.345	0.932	-0.022	-0.036	-0.034	0.030	0.052
		TEMP	-0.970	-0.965	-1.402	-0.066	-0.065	0.009	0.007	0.005
		SEIS	0.151	0.101	0.657	0.027	0.028	0.021	0.035	0.038
Slab 1F	1067	OTHR	-0.319	-0.076	-0.015	0.189	0.071	-0.012	0.032	0.025
EL4.65M		TEMP	-1.315	-0.447	-0.012	0.062	0.026	0.001	0.003	-0.003
		SEIS	0.088	0.050	0.020	0.178	0.067	0.012	0.032	0.026
	1072	OTHR	-0.727	-0.284	0.058	-0.117	-0.022	-0.002	0.124	0.005
		TEMP	-0.170	-1.780	-0.097	0.184	0.081	0.007	-0.061	-0.001
		SEIS	0.157	0.145	0.198	0.084	0.017	0.003	0.091	0.005
	1115	OTHR	-0.187	-0.177	0.197	-0.023	-0.202	-0.008	0.001	0.179
		TEMP	-1.419	0.046	0.018	0.065	0.113	0.002	-0.008	-0.017
		SEIS	0.274	0.115	0.235	0.031	0.190	0.009	0.006	0.161
	1120	OTHR	-0.260	-0.067	0.376	-0.038	-0.020	-0.009	0.035	0.023
		TEMP	-1.987	-1.963	-2.417	0.130	0.129	-0.007	-0.033	-0.031
	1	SEIS	0.159	0.116	0.141	0.038	0.040	0.018	0.045	0.049

Notes:

OTHR: Loads other than thermal and seismic loads. TEMP: Thermal loads. SEIS: Seismic loads.

Load Combination IDs in Table 6.3-5 = 7021 and 7521 T



WG3-U73-ERD-S-0004	SH NO. 73
REV. 2	of 219

#### Table 6.3-10 Combined Forces and Moments: Site-Specific Seismic Load Combination CB-9 (Continued)

	Element		N <sub>x</sub>	Ny	N <sub>xy</sub>	M <sub>×</sub>	My	M <sub>xy</sub>	Qx	Qy
Location	ID		(MN/m)	(MN/m)	(MN/m)	(MNm/m)	(MNm/m)	(MNm/m)	(MN/m)	(MN/m)
Slab 2F	1567	OTHR	0.018	0.062	-0.017	0.097	0.007	-0.004	0.018	0.011
EL9.00III		TEMP	-2.552	-1.076	0.015	-0.027	-0.087	0.002	0.004	0.000
		SEIS	0.059	0.102	0.046	0.104	0.009	0.006	0.021	0.013
	1572	OTHR	0.081	-0.049	-0.011	-0.057	-0.016	-0.001	0.091	0.000
		TEMP	-0.679	-3.420	-0.099	0.070	-0.022	0.008	-0.099	0.006
		SEIS	0.281	0.336	0.429	0.054	0.017	0.002	0.089	0.001
	1615	OTHR	0.045	0.136	-0.034	-0.011	-0.145	-0.007	0.008	0.155
		TEMP	-2.425	0.082	-0.110	0.043	0.193	-0.031	0.036	-0.087
		SEIS	0.895	0.302	0.041	0.022	0.161	0.009	0.014	0.167
	1620	OTHR	0.033	0.014	-0.070	-0.021	-0.020	-0.018	0.021	0.026
		TEMP	-3.153	-3.133	-4.149	-0.051	-0.057	0.025	0.020	0.029
		SEIS	0.191	0.169	0.314	0.028	0.029	0.018	0.032	0.037
Roof	1867	OTHR	-0.084	-0.071	-0.003	0.173	0.074	-0.007	0.021	0.005
EL IS.ON		TEMP	1.500	1.282	-0.012	-0.783	-1.023	0.001	0.015	-0.006
		SEIS	0.149	0.109	0.072	0.255	0.084	0.013	0.039	0.007
	1872	OTHR	-0.047	-0.113	-0.005	-0.057	-0.016	0.003	0.086	-0.001
		TEMP	1.774	1.355	0.412	-0.232	-0.745	0.032	-0.330	0.023
		SEIS	0.415	0.857	0.635	0.048	0.028	0.010	0.097	0.004
	1915	OTHR	-0.085	-0.129	-0.012	-0.009	-0.154	-0.005	-0.004	0.160
		TEMP	1.949	1.114	0.485	-0.695	-0.400	0.008	0.017	-0.146
		SEIS	1.331	0.399	0.482	0.022	0.206	0.014	0.010	0.227
	1920	OTHR	-0.011	-0.049	0.026	-0.022	-0.021	-0.046	0.015	0.021
		TEMP	-0.003	-0.164	0.493	-0.634	-0.644	-0.022	-0.011	0.005
		SEIS	0.312	0.243	0.101	0.032	0.034	0.063	0.035	0.039

Notes:

OTHR: Loads other than thermal and seismic loads.

TEMP: Thermal loads. SEIS: Seismic loads.

Load Combination IDs in Table 6.3-5 = 7021 and 7521 |



WG3-U73-ERD-S-0004	SH NO. 74
REV. 2	of 219

#### Table 6.3-10 Combined Forces and Moments: Site-Specific Seismic Load Combination CB-9 (Continued)

1	Element		N <sub>x</sub>	Ny	N <sub>×y</sub>	Mx	My	M <sub>×y</sub>	Qx	Qy
Location	ID		(MN/m)	(MN/m)	(MN/m)	(MNm/m)	(MNm/m)	(MNm/m)	(MIN/m)	(MN/m)
Wall	6007	OTHR	-0.856	-0.748	-0.908	0.052	0.097	0.029	0.051	0.202
~EL-7.400		TEMP	0.521	1.371	-0.057	0.642	0.904	0.004	-0.032	0.165
		SEIS	1.228	0.934	1.128	0.076	0.119	0.037	0.115	0.208
	4006	OTHR	-0.359	-0.658	-0.024	-0.067	-0.390	0.001	-0.004	-0.712
		TEMP	0.756	-0.069	0.091	-0.688	-1.068	-0.002	-0.001	-0.194
		SEIS	0.855	1.301	1.186	0.051	0.327	0.012	0.006	0.592
	4010	OTHR	-0.278	-0.450	-0.037	-0.063	-0.156	0.077	0.074	-0.304
		TEMP	1.043	1.253	-0.324	-0.531	-0.881	-0.042	-0.156	-0.334
		SEIS	0.496	0.999	0.888	0.096	0.144	0.079	0.101	0.237
Wall	6043	OTHR	-0.529	-1.111	-0.549	0.044	0.037	-0.010	0.046	0.212
~EL-2.0m ~EL4.65m		TEMP	2.535	-1.168	-0.671	0.378	0.483	-0.026	0.127	0.061
		SEIS	0.877	1.448	2.282	0.101	0.277	0.023	0.058	0.362
	4036	OTHR	-0.679	-0.361	0.034	0.029	0.082	-0.004	0.021	-0.562
		TEMP	2.463	-0.411	-0.013	-0.289	-0.300	0.001	0.031	0.070
		SEIS	0.662	1.151	2.087	0.053	0.273	0.006	0.022	0.345
	4040	OTHR	-0.403	-0.880	0.399	-0.107	0.000	0.101	0.213	-0.163
1		TEMP	1.381	1.392	-0.606	-0.080	-0.300	-0.047	-0.217	-0.181
		SEIS	0.465	1.967	1.906	0.112	0.133	0.046	0.144	0.171
Wall	6081	OTHR	-0.321	-0.600	0.102	0.000	-0.018	-0.001	-0.001	-0.041
~EL9.06m		ТЕМР	5.519	-0.786	0.338	1.391	1.000	0.007	-0.048	-0.161
		SEIS	0.795	1.112	1.694	0.046	0.276	0.029	0.013	0.089
	4066	OTHR	-0.407	-0.280	0.056	-0.042	-0.294	-0.008	0.008	-0.055
		TEMP	6.358	-0.464	-0.042	-1.488	-1.021	0.000	-0.021	0.188
		SEIS	0.308	0.832	1.708	0.042	0.214	0.009	0.011	0.058
	4070	OTHR	-0.097	-0.419	0.271	-0.025	-0.089	-0.073	0.005	-0.047
		TEMP	3.596	1.323	-1.489	-1.232	-1.167	-0.021	-0.332	-0.163
		SEIS	0.065	0.976	1.663	0.026	0.060	0.072	0.026	0.049
Wall	6117	OTHR	-0.057	-0.362	0.001	-0.013	-0.087	0.004	0.005	-0.100
~EL9.0611 ~EL13.8m		ТЕМР	3.560	-0.619	-1.500	0.908	1.500	-0.022	-0.038	0.385
		SEIS	0.829	0.599	0.911	0.015	0.090	0.006	0.007	0.127
	4096	OTHR	-0.154	-0.190	0.020	0.007	0.041	-0.001	-0.005	0.055
		TEMP	3.980	-0.285	-0.182	-0.936	-1.566	-0.001	0.034	-0.463
		SEIS	0.591	0.391	0.986	0.016	0.065	0.002	0.008	0.064
	4100	OTHR	-0.005	-0.072	0.071	0.005	0.006	-0.001	-0.006	0.008
		TEMP	2.844	1.752	-1.526	-0.681	-1.227	-0.002	-0.347	-0.594
		SEIS	0.146	0.391	1.010	0.016	0.025	0.009	0.024	0.031

Notes:

1

¢

OTHR: Loads other than thermal and seismic loads. TEMP: Thermal loads.

SEIS: Seismic loads.

Load Combination IDs in Table 6.3-5 = 7021 and 7521

WG3-U73-ERD-S-0004	SH NO. 75
REV. 2	of 219

Material	Property		Value	
Concrete Compressive strength, f <sub>c</sub> '		Basemat 27.6 MPa		
<i>e</i>		Others	34.5 MPa	
	Young's modulus	Basemat	2.49×10 <sup>4</sup> MPa	
		Others	2.78×10 <sup>4</sup> MPa	
	Poisson's ratio	0.17		
Reinforcement	Yield stress, $f_{y}$	413.6 MPa		
	Young's modulus	2.00×10 <sup>5</sup> MPa		

Table 6.4-1 Material Constants	for Stress Calculations
--------------------------------	-------------------------

Table 6.4-2 Allowable Stress of Concrete for Membrane Plus Bending

Load Condition	Allowable Compressive Stress (MPa)			
Primary	Basemat	20.7	(0.75 f <sub>c</sub> ')	
	Others	25.9		
Primary plus secondary	Basemat	23.5	(0.85 f <sub>c</sub> ')	
	Others	29.3		

Note: Concrete allowable stress for load condition of "Primary plus secondary" is applied to the load combinations that include thermal loads.

Table 6.4-3 Allowable Stress of Reinforcement for Membrane Plus Bending

	Allowable Stress (MPa)					
Tension	372.2	(0.90 f <sub>y</sub> )				
Compression	372.2	(0.90 f <sub>y</sub> )				



WG3-U73-ERD-S-0004	SH NO. 76
REV. 2	of 219

## Table 6.4-4 Allowable Stress of Concrete for Membrane Compression

r

Load Condition	Allowable Compressive Stress (MPa)		
Primary	Basemat	16.6	(0.60 f <sub>c</sub> ')
	Others	20.7	
Primary plus secondary	Basemat	20.7	(0.75 f <sub>c</sub> ')
	Others	25.9	



WG3-U73-ERD-S-0004	SH NO. 77
REV. 2	of 219

			Primary Reinforcement					Shear Tie		
Location	ion Element Thickness Direction 1 <sup>*1</sup> Dire		Direction 2 <sup>*1</sup>							
	ID	(m)	Position	Arrangement	Ratio (%)	Arrangement	Ratio (%)	Arrangement	Ratio (%)	
Basemat EL-7.4m	67		Тор	2-#11@200	0.335	2-#11@200	0.335	#6@400 × 400	0.177	
	72	3.0	Bottom	2-#11@200	0.335	2-#11@200	0.335	#001001100	0.177	
	115	0.0	Тор	2-#11@200	0.335	2-#11@200	0.335	#6@400 x 400	0 177	
	120		Bottom	2-#11@200	0.335	2-#11@200 ``	0.335		0.177	
SlabB1F EL-2.0m	567		Тор	1-#11@200	1.006	1-#11@200	1.006	_	_	
	507	0.5	Bottom	1-#11@200	1.006	1-#11@200	1.006			
	572 615	0.5	Тор	1-#11@200	1.006	1-#11@200	1.006	_		
	620		Bottom	1-#11@200	1.006	1-#11@200	1.006			
Slab 1F EL4.65m	1067 1072	0.5	Тор	1-#11@200	1.006	1-#11@200	1.006	-	_	
	1115 1120	0.5	Bottom	1-#11@200	1.006	1-#11@200	1.006			
Slab 2F EL9.06m	1567		Тор	1-#11@200	1.006	1-#11@200	1.006	_	_	
	1620	0.5	Bottom	1-#11@200	1.006	1-#11@200	1.006	_		
	1615	0.5	Тор	1-#11@200	1.006	1-#11@200	1.006	#4@400 × 400	0.081	
	1013		Bottom	1-#11@200	1.006	1-#11@200	1.006		0.001	
Slab RF EL13.8m	1867		Тор	1-#11@200 + 1-#11@400	1.078	1-#11@200 + 1-#11@400	1.078			
1872	1920	0.7	Bottom	1-#11@200 + 1-#11@400	1.078	1-#11@200 + 1-#11@400	1.078		-	
	1015	0.7	Тор	1-#11@200 + 1-#11@400	1.078	1-#11@200 + 1-#11@400	1.078	#4@400 x 400	0.081	
	1915	1915		Bottom	1-#11@200 + 1-#11@400	1.078	1-#11@200 + 1-#11@400	1.078	<del>,,,</del> ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	

#### Table 7.2-1 Sectional Thicknesses and Rebar Ratios Used in the Evaluation

Note \*1: Wall

Direction 1: Horizontal,

Basemat, Slab, Roof

.

Direction 1: N-S,

Direction 2: Vertical Direction 2: E-W



WG3-U73-ERD-S-0004	SH NO. 78
REV. 2	of 219

# Table 7.2-1 Sectional Thicknesses and Rebar Ratios Used in the Evaluation(Continued)

				Primary Reinforcement					Shoar Tio	
Location	Element	Thickness		Direction	1 <sup>*1</sup>	Direction 2 <sup>1</sup>				
	ID	(m)	Position	Arrangement	Ratio (%)	Arrangement	Ratio (%)	Arrangement	Ratio (%)	
Wall EL-7.4m	6007		Inside	2-#11@200	1.118	2-#11@200	1.118	#6@200 x 400	0 365	
~EL-2.0m	0007	0.0	Outside	2-#11@200	1.118	2-#11@200	1.118	#0@2000100	0.000	
	4006	0.9	Inside	2-#11@200	1.118	2-#11@200	1.118	#0@200 × 400	0.355	
	4010		Outside	2-#11@200	1.118	2-#11@200	1.118	#0@200 ^ 400		
Wall EL-2.0m	6043		Inside	2-#11@200	1.118	2-#11@200	1.118	#6@200 x 400	0 355	
~EL4.65m 4040	0.9	Outside	2-#11@200	1.118	2-#11@200	1.118	#6@200++60	0.000		
		Inside	2-#11@200	1.118	2-#11@200	1.118	#6@200 x 200	0.710		
	4000		Outside	2-#11@200	1.118	2-#11@200	1.118	#0@200 ~ 200		
Wali EL4.65m	6081	0.9	Inside	2-#11@200	1.118	2-#11@200	1.118	_		
~EL9.06m	4070	0.9	Outside	2-#11@200	1.118	2-#11@200	1.118	-	_	
Wall EL9.06m	6117		Inside	1-#11@200	0.719	1-#11@200	0.719			
~EL13.8m	~EL13.8m	0.7	Outside	1-#11@200 + 1-#11@400	1.078	1-#11@200 + 1-#11@400	1.078	-		
	4096	0.7	Inside	1-#11@200	0.719	1-#11@200	0.719	_	_	
	4100		Outside	1-#11@200 + 1-#11@400	1.078	1-#11@200 + 1-#11@400	1.078	-		

Note \*1: Wall

Basemat, Slab, Roof

Direction 1: Horizontal, Direction 1: N-S, Direction 2: Vertical Direction 2: E-W

(



WG3-U73-ERD-S-0004	SH NO. 79
REV. 2	of 219

		Concrete Stress (MPa)		Primary Reinforcement Stress (MPa)					
Location	Element				Calculated				
		Calculated	Allowable	NS di	rection	EW di	rection	Allowable	
				Тор	Bottom	Тор	Bottom		
Basemat	67	-1.7	-20.7	-1.7	-10.9	-6.0	-8.2	372.2	
IEL-7.4m	72	-3.4		-23.3	5.2	-4.7	6.2		
	115	-1.9		-7.6	-10.1	-6.1	-2.3		
	120	-1.8		-12.5	-1.9	-4.6	-1.4		
Slab B1F	567	-5.5	-25.9	-12.7	-28.1	0.8	-2.7	372.2	
EL-2.0m	572	-5.0		-29.7	-31.3	-6.3	-9.7		
	615	-3.6		-4.7	-14.1	-7.9	-8.5		
	620	-8.4		110.2	19.1	141.0	20.1		
Slab 1F	1067	-13.9	-25.9	-10.8	112.6	-2.4	46.4	372.2	
EL4.65m	1072	-7.6		10.8	-27.5	-1.4	-4.3		
	1115	-11.9		37.1	8.4	155.5	-28.0		
	1120	-4.4		64.2	6.2	70.1	14.6		
Slab 2F	1567	-7.4	-25.9	4.1	90.5	7.2	24.8	372.2	
1EL9.06m	1572	-4.4		67.9	8.1	7.4	-0.7		
	1615	-7.5		14.0	6.0	133.3	-11.6		
	1620	-3.3		22.9	14.1	17.7	16.2		
Roof	1867	-5.6	-25.9	0.2	56.3	-2.2	20.9	372.2	
EL13.8m	1872	-2.1		20.8	-0.9	-0.2	-1.3		
	1915	-4.1		-0.5	0.0	45.0	-9.8		
	1920	-2.9		25.2	5.9	23.5	1.1		

#### Table 7.3-1 Rebar and Concrete Stresses (Basemat and Slabs): Selected Load Combination CB-3 (Standard design analysis results reproduced from Reference 2.1.2-i)

Notes: Negative value means compression.

\* For denominations of table columns, see the definition of local coordinate in Figure 6.2-49. Load Combination ID in Table 6.3-5 = 3001



WG3-U73-ERD-S-0004	SH NO. 80
REV. 2	of 219

		- <u>B</u>		reprou				
		Concrete S	tress (MPa)	Primary Reinforcement Stress (MPa)				
Location	Element				Calcu	lated		
1		Calculated	Allowable	Horizonta	direction	Vertical	direction	Allowable
				Inside	Outside	Inside	Outside	
Wall	6007	-4.0	-25.9	0.7	19.6	-2.9	31.6	372.2
EL-7.4m	4006	-7.9		-3.6	-1.7	-16.1	58.8	
~====	4010	-5.0		-3.8	17.0	-8.3	23.0	
Wall	6043	-2.4	-25.9	-6.6	-2.5	-10.2	-7.2	372.2
EL-2.0m	4036	-1.5		-6.9	-8.4	1.3	-4.1	
~EL4.65m	4040	-3.7		-8.1	1.7	-5.1	-9.5	
Wall	6081	-1.0	-25.9	-3.0	-2.8	-5.2	-4.9	372.2
EL4.65m	4066	-6.9		-3.7	-1.1	-8.2	67.7	
~EL9.00m	4070	-4.3		5.0	35.6	-2.8	36.0	
Wali	6117	-2.7	-25.9	-0.1	-0.2	10.0	-7.7	372.2
EL9.06m	4096	-1.2		-1.6	-1.6	2.5	-3.8	
~===13.011	4100	-0.3		9.1	2.0	4.8	1.0	

#### Table 7.3-2 Rebar and Concrete Stresses (Walls): Selected Load Combination CB-3 (Standard design analysis results reproduced from Reference 2.1.2-i)

Notes: Negative value means compression.



WG3-U73-ERD-S-0004	SH NO. 81
REV. 2	of 219

		Concrete S	tress (MPa)	Primary Reinforcement Stress (MPa)				
Location	Element							
		Calculated	Allowable	NS di	rection	EW di	rection	Allowable
				Тор	Bottom	Тор	Bottom	
Basemat	67	-1.5	-23.5	-6.5	-2.4	-9.4	-1.1	372.2
[EL-7.4m	72	-2.7		-17.9	4.5	-5.4	14.1	
	115	-1.8		-8.6	0.0	-6.0	-1.0	
	120	-1.8	. –	-11.8	0.2	-6.4	0.4	
Slab B1F	567	-4.8	-29.3	-12.2	-24.8	1.5	-1.5	372.2
EL-2.0m	572	-4.1		-19.9	-23.4	-8.6	-10.4	
	615	-3.3		-9.2	-16.4	-3.7	-4.2	
	620	-5.4		67.1	. 7.1	88.9	7.0	
Slab 1F	1067	-8.4	-29.3	-28.9	13.8	-8.9	4.5	372.2
EL4.65m	1072	-3.8		-6.7	-12.8	-22.8	-23.3	
	1115	-8.0		-13.9	-18.9	102.7	-18.2	
	1120	-6.9		-21.2	-23.0	-22.2	-14.5	
Slab 2F	1567	-5.1	-29.3	-29.6	-18.9	2.8	-13.3	372.2
EL9.06m	1572	-6.3		33.7	4.2	-30.0	-39.1	
	1615	-4.2		-18.9	-19.6	82.2	1.3	
	1620	-14.2		74.8	38.5	75.9	37.3	
Roof	1867	-0.6	-29.3	-8.6	39.6	47.9	-15.9	372.2
EL13.8m	1872	-4.4		65.8	15.4	79.2	-0.3	
	1915	-4.4		53.0	15.0	66.7	-4.6	
	1920	-10.6		104.4	13.3	111.8	-6.9	

#### Table 7.3-3 Rebar and Concrete Stresses (Basemat and Slabs): Selected Load Combination CB-4 (Standard design analysis results reproduced from Reference 2.1.2-i)

Notes: Negative value means compression.



WG3-U73-ERD-S-0004	SH NO. 82
REV. 2	of 219

		Concrete S	tress (MPa)	Primary Reinforcement Stress (MPa)					
Location	Element				Calcu	ulated			
	טו	Calculated	Allowable	Horizonta	d direction	Vertical	direction	Allowable	
				Inside	Outside	Inside	Outside		
Wall	6007	-3.8	-29.3	-0.8	32.8	-0.7	40.4	372.2	
EL-7.4m ~EL-2.0m	4006	-6.8		-1.2	1.8	-14.3	49.2		
	4010	-4.4		-4.6	19.7	-1.9	29.0		
Wall	6043	-3.5	-29.3	-7.4	0.3	-15.9	-6.2	372.2	
EL-2.0m	4036	-1.6		-7.1	-1.9	-8.2	-6.0	1	
~EL4.0011	4040	-2.7		9.3	16.8	24.8	-2.7	_	
Wall	6081	-6.9	-29.3	20.4	76.6	-21.7	24.4	372.2	
EL4.65m	4066	-11.6		34.6	99.3	-27.1	72.0		
	4070	-7.8		32.3	112.8	-4.5	91.6		
Wall	6117	-11.5	-29.3	33.6	97.5	-21.4	86.8	372.2	
EL9.06m	4096	-7.6		15.7	57.8	-16.3	57.0		
~ 13.8m	4100	-6.9		27.2	78.7	-0.3	95.5		

# Table 7.3-4 Rebar and Concrete Stresses (Walls):Selected Load Combination CB-4(Standard design analysis results reproduced from Reference 2.1.2-i)

Notes: Negative value means compression.



WG3-U73-ERD-S-0004	SH NO. 83
REV. 2	of 219

		Concrete S	tress (MPa)	Primary Reinforcement Stress (MPa)					
Location	Element								
		Calculated	Allowable	NS di	rection	EW direction		Allowable	
	_			Тор	Bottom	Тор	Bottom		
Basemat	67	-1.0	-23.5	-4.5	-2.2	-6.9	-1.9	372.2	
EL-7.4m	72	-2.0		-13.2	2.4	-3.7	7.6		
	115	-1.3		-7.1	-0.1	-4.5	-1.1		
	120	-1.4		-9.1	0.3	-5.0	0.4		
Slab B1F	567	-3.9	-29.3	-9.0	-19.7	7.6	-0.1	372.2	
EL-2.0m	572	-3.2		-15.0	-18.1	-6.1	-8.0		
	615	-2.6		-6.4	-12.7	-2.6	-3.1		
	620	-4.4		58.6	6.6	75.8	6.0		
Slab 1F	1067	-8.4	-29.3	-21.2	32.8	-6.8	8.9	372.2	
EL4.65m	1072	-2.9		-4.9	-10.1	-17.2	-17.8		
	1115	-7.3		-9.7	-14.1	95.9	-16.0		
	1120	-5.4		-16.0	-17.8	-16.8	-11.3	_	
Slab 2F	1567	-4.3	-29.3	-24.0	-13.6	2.8	-10.4	372.2	
EL9.06m	1572	-4.9		28.6	3.7	-22.7	-30.1		
	1615	-3.8		-14.4	-14.9	75.8	0.1		
	1620	-11.1		58.9	31.0	59.7	30.4		
Roof	1867	-0.2	-29.3	-6.5	27.2	37.9	-13.7	372.2	
EL13.8m	1872	-3.4		43.1	10.5	49.6	-1.1		
	1915	-3.4		42.2	11.5	53.3	-3.3		
	1920	-8.2		80.3	10.3	86.1	-5.3		

#### Table 7.3-5 Rebar and Concrete Stresses (Basemat and Slabs): Selected Load Combination CB-7 (Standard design analysis results reproduced from Reference 2.1.2-i)

Notes: Negative value means compression.



WG3-U73-ERD-S-0004	SH NO. 84
REV. 2	of 219

		8						
		Concrete Stress (MPa) Primary Reinforcement Stress (M						/IPa)
Location	Element				Calcu	lated		
	- טו	Calculated	Allowable	Horizonta	l direction	Vertical	direction	Allowable
				Inside	Outside	Inside	Outside	
Wall	6007	-3.1	-29.3	-1.5	21.7	-3.0	27.8	372.2
EL-7.4m ~EL-2.0m	4006	-5.5		-0.8	1.8	-13.8	34.5	
	4010	-3.6		-2.9	17.8	-1.7	25.9	
Wall	6043	-2.9	-29.3	-5.6	1.0	-13.9	-6.5	372.2
EL-2.0m	4036	-1.2		-5.2	-1.3	-6.6	-5.9	
~EL4.00III	4040	-2.0		5.3	13.3	18.0	-3.9	
Wall	6081	-5.2	-29.3	16.0	59.4	-17.2	16.4	372.2
EL4.65m	4066	-8.6		24.7	76.4	-20.6	53.0	
~EL9.0011	4070	-7.2		15.4	88.2	24.9	60.7	
Wall	6117	-8.8	-29.3	25.8	74.9	-16.7	65.1	372.2
EL9.06m	4096	-5.8		12.2	45.2	-12.8	42.1	
~EL13.8m	4100	-5.3		20.3	61.3	-0.2	72.8	

#### Table 7.3-6 Rebar and Concrete Stresses (Walls): Selected Load Combination CB-7 (Standard design analysis results reproduced from Reference 2.1.2-i)

Notes: Negative value means compression.



WG3-U73-ERD-S-0004	SH NO. 85
REV. 2	of 219

.

		Concrete S	tress (MPa)	Primary Reinforcement Stress (MPa)					
Location	Element				Calcu	lated			
Location	ID	Calculated	Allowable	NS d	lirection	EW d	lirection	Allowable	
				Тор	Bottom	Тор	Bottom		
Basemat	67	-5.0	-23.5	-20.3	35.1	-30.7	28.8	372.2	
EL-7.4m	72	-8.4		-30.9	136.4	24.9	159.9		
	115	-4.9		-25.2	107.8	-11.3	12.8		
	120	-5.7		-22.8	28.9	-17.8	35.5		
Slab B1F	567	-9.7	-29.3	14.9	-33.1	136.8	35.7	372.2	
EL-2.0m	572	-6.2		-11.7	-19.7	-9.0	-23.9		
	615	-9.8		61.5	-15.9	76.4	6.7		
	620	-9.0		-13.2	-26.4	-6.4	-25.6		
Slab 1F	1067	-21.0	-29.3	-27.7	143.4	-8.2	57.0	372.2	
EL4.65m	1072	-6.4		-18.9	8.0	-30.7	-20.5		
	1115	-13.2		-16.5	-17.0	180.1	-31.0		
	1120	-9.5		-19.1	24.1	-26.4	38.3		
Slab 2F	1567	-8.4	-29.3	-43.4	-31.0	1.8	-20.0	372.2	
EL9.06m	1572	-7.9		-9.1	1.3	-39.9	-52.2		
Í í	1615	-8.8		-43.2	-37.3	183.9	38.9		
	1620	-18.2		98.4	61.9	100.4	61.0		
Roof	1867	-13.6	-29.3	80.0	137.3	79.3	-33.9	372.2	
EL13.8m	1872	-4.1		159.4	64.6	196.7	54.9		
	1915	-8.6		198.3	86.2	196.6	6.8		
	1920	-15.3		138.8	20.7	153.7	-8.6		

Table 7.3-7 Rebar and Concrete Stre	esses (Basemat and Slabs):
Site-Specific Seismic Load C	Combination CB-9

Notes: Negative value means compression.

Load Combination ID in Table 6.3-5 = 7021 or 7521, whichever is greater.

Tab	ole 7.3-8 Rebar and Co	oncrete Stresses (Walls):
Si	te-Specific Seismic Lo	ad Combination CB-9
	Concrete Stress (MPa)	Primary Reinforcement Stre

		Concrete S	Primary Reinforcement Stress (MPa)					
	Flomont			Calculated				
Location	ID	Calculated	Allowable	Horizontal direction		Vertical direction		Allowable
				Inside	Outside	Inside	Outside	
Wall	6007	-9.8	-29.3	13.2	116.5	21.0	136.7	372.2
EL-7.4m ~EL-2.0m	4006	-14.3		68.6	121.3	-27.7	168.0	
	4010	-10.7		29.2	176.7	36.6	224.9	1
Wall	6043	-9.2	-29.3	97.1	210.5	-25.4	150.6	372.2
EL-2.0m	4036	-5.8		103.5	113.2	130.0	102.4	
~EL4.05m	4040	-6.5		77.0	123.9	189.7	148.4	
Wall	6081	-7.8	-29.3	76.6	198.1	32.8	101.9	372.2
EL4.65m	4066	-15.8		87.4	200.8	-12.5	189.2	
ALTS:00III	4070	-7.6		119.2	188.0	77.8	227.3	
Wali	6117	-17.6	-29.3	89.1	239.0	-33.2	147.1	372.2
EL9.06m	4096	-15.2		73.6	182.1	-11.5	181.0	
CL 13.0m	4100	-12.8		99.8	180.4	17.4	254.8	

Notes: Negative value means compression.

Load Combination ID in Table 6.3-5 = 7021 or 7521, whichever is greater.



WG3-U73-ERD-S-0004	SH NO. 86
REV. 2	of 219

# Table 7.3-9 Maximum Stress Ratios (Basemat and Slabs) for Flexure and Membrane Forces

		Co	ncrete	Primary			rimary Rei	y Reinforcement				
Location	Element				NS dir	rection		EW direction				
				-	Гор	Bottom		Тор		Bottom		
	ID	σ/σ <sub>a</sub>	Load ID	σ/σ <sub>a</sub>	Load ID	σ/σa	Load ID	σ/σa	Load ID	σ/σa	Load ID	
Basemat	67	0.228	7011	0.058	7011	0.095	7021	0.087	7011	0.078	7021	
EL-7.4M	72	0.367	7011	0.084	7011	0.370	7021	0.207	7501	0.434	7521	
	115	0.234	7011	0.129	7501	0.292	7521	0.063	7501	0.041	7501	
	120	0.254	7011	0.062	7021	0.078	7021	0.048	7021	0.096	7021	
SlabB1F	567	0.340	7021	0.041	7021	0.091	7011	0.374	7011	0.221	7501	
EL-2.0m	572	0.217	7021	0.080	3004	0.084	3002	0.025	7021	0.067	7011	
	615	0.345	7021	0.185	7011	0.075	7501	0.216	7011	0.100	7501	
	620	0.337	7001	0.418	7001	0.089	7001	0.480	7001	0.082	7001	
Slab 1F	1067	0.751	7001	0.078	4022	0.527	7011	0.024	4024	0.185	7011	
EL4.050	1072	0.361	7001	0.131	7001	0.074	3002	0.084	7021	0.063	4022	
	1115	0.606	7001	0.155	4014	0.052	4014	0.581	7001	0.092	7011	
	1120	0.335	7021 `	0.211	4013	0.071	7501	0.224	4012	0.113	7501	
Slab 2F	1567	0.417	7001	0.119	7021	0.368	7001	0.037	4012	0.130	4014	
EL9.00m	1572	0.278	7021	0.371	7001	0.083	7501	0.160	7501	0.166	7501	
	1615	0.413	7001	0.325	7001	0.179	7001	0.572	7001	0.107	7521	
	1620	0.643	7021	0.270	7021	0.170	7021	0.276	7021	0.167	7021	
Slab RF	1867	0.465	7021	0.215	7521	0.369	7021	0.213	7021	0.091	7021	
EL 13.011	1872	0.154	4023	0.428	7021	0.174	7021	0.529	7021	0.238	7011	
	1915	0.336	7011	0.533	7021	0.311	7501	0.528	7021	0.188	7501	
	1920	0.523	7021	0.373	7021	0.087	7511	0.413	7021	0.076	7511	

#### Table 7.3-10 Maximum Stress Ratios (Walls) for Flexure and Membrane Forces

	( )	Cor	ncrete	Primary Reinforcement										
Location	Element				Horizontal	directio	วท		Vertical	direction	ו			
	1 1		'	In	iside	Οι	utside	ln In	iside	Οι	utside			
	ID	σ/σ <sub>a</sub>	Load ID	σ/σ <sub>a</sub>	Load ID	σ/σa	Load ID	σ/σ <sub>a</sub>	Load ID	σ/σ <sub>a</sub>	Load ID			
Wall	6007	0.339	7021	0.092	7501	0.315	7521	0.075	7501	0.370	7021			
EL-7.4m ~EL-2.0m	4006	0.506	7011	0.213	7501	0.348	7511	0.189	7501	0.457	7511			
	4010	0.402	7011	0.170	7501	0.478	7021	0.166	7501	0.609	7021			
Wall	6043	0.315	7021	0.290	7501	0.590	7011	0.421	7501	0.445	7011			
~EL-2.000 ~EL4.65m	4036	0.282	7001	0.286	7501	0.408	7011	0.484	7511	0.462	7501			
	4040	0.317	7011	0.239	7511	0.380	7011	0.510	7521	0.399	7521			
Wall	6081	0.267	7021	0.295	7501	0.532	7021	0.385	7511	0.421	7501			
~EL9.06m	4066	0.538	7021	0.235	7521	0.540	7021	0.221	7501	0.508	7521			
	4070	0.320	4023	0.320	7021	0.505	7021	0.233	7501	0.611	7021			
Wall	6117	0.600	7021	0.366	7501	0.642	7021	0.345	7511	0.395	7021			
~EL13.8m	4096	0.517	7021	0.322	7501	0.489	7021	0.331	7511	0.486	7021			
	4100	0.436	7021	0.281	7011	0.485	7021	0.278	7011	0.685	7021			

~



WG3-U73-ERD-S-0004	SH NO. 87
REV. 2	of 219

,

1				Section Forces (MN/m) 7		Thickness	Calcula	ited Concre	s (MPa)	Allowable			
1	Location	Element	Load	N <sub>x</sub>	Ny	N <sub>xy</sub>	h	σχ	σy	τ <sub>xy</sub>	σc	Stress	σ₀/σа
1		ID	D				(m)					σ <sub>a</sub> (MPa)	
j	Basemat EL-7.4m	67	3004	3.077	3,293	-0.076	3.0	1.0	1.1	0.0	1.1	16.6	0.07
		72	3001	3.988	0.998	-0.061	3.0	1.3	0,3	0.0	1.3	16.6	0.08
		115	7001	5.618	1.769	-1.498	3.0	1.9	0.6	-0.5	2.0	16.6	0.12
		120	3004	3.061	1.649	-0.173	3.0	1.0	0.5	-0.1	1.0	16.6	0.06
	SlabB1F	567	3002	1.679	0.333	0.009	0.5	3.4	0.7	0.0	3.4	20.7	0.16
	LL-2.011	572	3004	2.587	1.026	0.190	0.5	5.2	2.1	0.4	5.2	20.7	0.25
		615	7021	1.737	0.565	-1.108	0.5	3.5	1.1	-2.2	4.8	25.9	0.19
		620	3004	1.207	0.599	1.574	0.5	2.4	1.2	3.1	5.0	20.7	0.24
	Slab 1F	1067	4022	1.292	0.550	-0.025	0.5	2.6	1.1	0.0	2.6	25.9	0.10
	CL4,00111	1072	7021	1.035	2.210	-0.237	0.5	2.1	4.4	-0.5	4.5	25.9	0.17
		1115	7021	1.880	0.251	0.450	0.5	3.8	0.5	0.9	4.0	25.9	0.15
		1120	7021	2.406	2.146	-2.027	0.5	4.8	4.3	-4.1	8.6	25.9	0.33
	Slab 2F	1567	7021	2.594	1.116	-0.048	0.5	5.2	2.2	-0.1	5.2	25.9	0.20
	EL9.00III	1572	7021	0.879	3.805	-0.539	0.5	1.8	7.6	-1.1	7.8	25.9	0.30
		1615	7021	3.276	-0.520	-0.184	0.5	6.6	-1.0	-0.4	6.6	25.9	0.25
		1620	7021	3.311	3.288	-4.116	0.5	6.6	6.6	-8.2	14.8	25.9	0.57
	Slab RF	1867	7001	0.234	0.179	-0.075	0.7	0.3	0.3	-0.1	0.4	20.7	0.02
	EL 13.011	1872	7001	0.462	0.970	-0.640	0.7	0.7	1.4	-0.9	2.0	20.7	0,10
		1915	7001	1.415	0.528	-0.494	0.7	2.0	0.8	-0.7	2.3	20.7	0.11
		1920	7021	0.325	0.456	0.480	0.7	0.5	0.7	0.7	1.3	25.9	0.05
	Wall	6007	7001	2.084	1.682	-2.036	0.9	2.3	1.9	-2.3	4.4	20.7	0.21
	~EL-2.0m	4006	7001	1.215	1.960	-1.209	0.9	1.3	2.2	-1.3	3.2	20.7	0.15
		4010	7001	0.775	1.448	-0.924	0.9	0.9	1.6	-1.0	2.3	20.7	0.11
	Wall	6043	7001	1.406	2.559	-2.831	0.9	1.6	2.8	-3.1	5.4	20.7	0.26
	~EL4.65m	4036	7001	1.341	1.512	2.120	0.9	1.5	1.7	2.4	3.9	20.7	0.19
		4040	7001	0.868	2.847	2.305	0.9	1.0	3.2	2.6	4.9	20.7	0.23
	Wall	6081	7011	2.814	1.478	1.918	0.9	3.1	1.6	2.1	4.6	25.9	0.18
	~EL9.06m	4066	7011	2.626	0.910	1.828	0.9	2.9	1.0	2.0	4.2	25.9	0.16
		4070	7011	1.719	1.605	2.851	0.9	1.9	1.8	3.2	5.0	25.9	0.19
	Wall	6117	7001	0,886	0.961	0.912	0.7	1.3	1.4	1.3	2.6	20.7	0.13
	~EL13.8m	4096	7001	0.745	0.581	1.005	0.7	1.1	0.8	1.4	2.4	20.7	0.12
1		4100	7001	0.151	0.464	1.081	0.7	0.2	0.7	1.5	2.0	20.7	0.10

## Table 7.3-11 Maximum Stress Ratios for Membrane Compressive Forces

Note: Compressive forces are positive.



WG3-U73-ERD-S-0004	SH NO.88
REV. 2	of 219

Table 7.3-12 Calculation Results for Maximum Transverse Sn
--

	Element	Load		Sec	tion Force	es and Mo	ments (M	N/m, MN-r	n/m)		d	ρω	ρν	Shear Forces (MN/m)				
Location	ID	ID	N <sub>x</sub>	Ny	N <sub>xy</sub>	M <sub>x</sub>	My	M <sub>xy</sub>	Qx	Qy	(m)	(%)	(%)	Vu	V <sub>c</sub>	V <sub>s</sub>	φVn	V <sub>u</sub> /φV <sub>n</sub>
Basemat	67	7011	-2.501	-4.050	0.232	3.503	4.701	-0.214	0.820	-1.366	2.744	0.366	0.177	1.594	4.868	2.011	5.847	0.273
EL-7.4m	72	7011	-2.714	-2.735	-1.278	4.321	2.874	-1.327	-1.441	0.481	2.719	0.370	0.177	1.520	2.499	1.992	3.818	0.398
	115	7521	0.666	-1.057	0.606	1.963	0.423	-0.818	0.495	0.757	2.743	0.366	0.177	0.905	2.370	2.010	3.723	0.243
	120	7021	-3.010	-2.082	-0.367	3.097	2.502	1.335	1.440	1.350	2.734	0.368	0.177	1.974	3.505	2.003	4.682	0.422
Slab B1F	567	7001	-1.052	-0.730	-0.382	-0.131	-0.061	-0.017	-0.156	0.086	0.372	1.359	0.000	0.179	0.746	0.000	0.634	0.282
EL-2.0m	572	7001	-1.815	-0.779	0.712	-0.040	-0.028	0.015	0.187	-0.012	0.360	1.402	0.000	0.187	0.891	0.000	0.757	0.247
	615	7011	-1.600	-0.576	-1.102	-0.123	-0.043	0.044	-0.124	0.034	0.363	1.390	0.000	0.128	0.764	0.000	0.649	0,197
	620	7001	-0.854	-0.446	1.589	-0.049	-0.065	-0.055	0.065	0.090	0.393	1.286	0.000	0.111	0.178	0.000	0.151	0.735
Slab 1F	1067	7011	-0.521	-0.130	-0.039	0.396	0.151	-0.024	0.065	0.051	0.379	1,332	0.000	0.082	0.360	0.000	0.306	0.269
EL4.65m	1072	7001	-0.884	-0.429	0.256	-0.202	-0.039	-0.005	0.215	0.010	0.360	1.402	0.000	0.216	0.593	0.000	0.504	0.428
	1115	7011	-0.683	-0.292	0.470	0.062	-0.355	-0.017	0.007	0.340	0.410	1.232	0.000	0.340	0.415	0.000	0.353	0.965
ľ	1120	7001	-0.418	-0.183	0.517	-0.076	-0.060	-0.027	0.080	0.071	0.382	1.322	0.000	0.107	0.330	0.000	0.280	0.383
Slab 2F	1567	7011	-0.160	-0.119	-0.062	0.200	-0.023	-0.010	0.040	0.024	0.373	1.352	0.000	0.046	0.355	0.000	0.302	0.153
EL9.06m	1572	7001	0.363	-0.385	-0.440	-0.111	-0.033	-0.003	0.180	-0.002	0.360	1.403	0.000	0.180	0.276	0.000	0.234	0.769
	1615	7011	-1.546	0.433	-0.122	-0.033	-0.292	-0.016	0.025	0.320	0.410	1.233	0.081	0.321	0.300	0.137	0.372	0.865
	1620	7001	0.224	0.183	-0.384	-0.048	-0.049	-0.036	0.053	0.063	0.389	1.298	0.000	0.082	0.418	0.000	0.355	0.231
Slab RF	1867	7021	0.460	0.406	-0.085	0.284	-0.262	-0.020	0.064	0.010	0.511	1.479	0.000	0.064	0.409	0.000	0.347	0.185
EL13.8m	1872	7021	0.975	1.255	0.688	-0.130	-0.235	0.025	-0.125	0.012	0.500	1.511	0.000	0.125	0.318	0.000	0.270	0.463
	1915	7021	1.802	0.632	0.506	-0.116	-0.406	0.017	0.011	0.339	0.550	1.375	0.081	0.339	0.388	0.184	0.486	0.698
	1920	7011	-0.323	-0.292	0.250	-0.056	-0.057	-0.101	0.051	0.060	0.529	1.428	0.000	0.078	0.519	0.000	0.441	0.177
Wali	6007	7021	-1.680	-1.003	-2.036	0.559	0.622	0.069	0.141	0.492	0.676	1.491	0.355	0.512	1.489	0.994	2.110	0.242
EL-7.4m	4006	7021	-0.895	-2.022	1.186	-0.242	-1.019	0.013	-0.011	-1.481	0.672	1.500	0.355	1.481	1.225	0.988	1.881	0.787
EE-2.011	4010	7021	0.768	1.120	-0.924	-0.406	-0.591	0.115	-0.110	-0.693	0.673	1.498	0.355	0.702	0.479	0.989	1.247	0.563
Wal!	6043	7011	1.146	-3.056	-3.113	0.180	0.719	-0.032	0.135	0.733	0.674	1.495	0.355	0.745	1.744	0.991	2.324	0.321
EL-2.0m	4036	4013	-0.241	0.009	-0.006	-0.045	-0.003	-0.005	0.031	-0.790	0.672	1.500	0.710	0.791	0.654	1.975	2.235	0.354
-EE4.00m	4040	7011	0.555	-3.663	-1.971	-0.218	-0.365	0.147	0.296	-0.514	0.682	1.478	0.355	0.593	1.202	1.002	1.874	0.317
Wall	6081	7021	1.735	-2.499	1.907	0.263	0.754	-0.030	-0.025	-0.290	0.673	1.497	0.000	0.291	1.494	0.000	1.270	0.229
EL4.65m	4066	7021	1.600	-1.575	1.763	-0.248	-0.858	-0.017	0.014	0.190	0.672	1.500	0.000	0.191	0.681	0.000	0.579	0.330
CL9.00III	4070	7521	1.112	-0.741	1.456	-0.283	-0.386	-0.019	-0.087	-0.078	0.694	1.452	0.000	0.117	0.300	0.000	0.255	0.458
Wal!	6117	7021	1.448	-1.580	-1.426	0.162	0.690	0.010	-0.009	0.412	0.493	1.533	0.000	0.412	0.562	0.000	0.478	0.863
EL9.06m ~EL13.8m	4096	7021	1.206	-0.865	1.004	-0.120	-0.443	-0.004	0.009	-0.472	0.493	1.533	0.000	0.472	0.623	0.000	0.530	0.892
LE10.011	4100	7521	0.600	-0.043	0.898	-0.081	-0.267	0.006	-0.074	-0.103	0.507	1.492	0.000	0.127	0.284	0.000	0.242	0.526



WG3-U73-ERD-S-0004	SH NO.89
REV. 2	of 219

	Element	Load	d	ρ <sub>w</sub>	ρ	Shear Forces (MN/m)				
Location	ID	ID	(m)	(%)	(%)	Vu	Vc	Vs	φV <sub>n</sub>	Vu∕∳Vn
Basemat	67	CB-9	2.745	0.366	0.177	1.537	4.798	2.011	5.788	0.266
EL-7.4m	72	CB-9	2.720	0.370	0.177	1.477	2.483	1.993	3.805	0.388
	115	CB-9	2.743	0.366	0.177	0.905	2.370	2.010	3.723	0.243
	120	CB-9	2.734	0.368	0.177	1.974	3.505	2.003	4.682	0.422
Slab B1F	567	CB-9	0.372	1.359	0.000	0.183	0.859	0.000	0.730	0.250
EL-2.0m	572	CB-9	0.360	1.402	0.000	0.165	0.838	0.000	0.713	0.231
	615	CB-9	0.363	1.390	0.000	0.127	0.783	0.000	0.665	0.190
	620	CB-3	0.399	1.266	0.000	0.087	0.260	0.000	0.221	0.395
Slab 1F	1067	CB-9	0.378	1.336	0.000	0.082	0.370	0.000	0.314	0.262
EL4.65m	1072	CB-3	0.360	1.403	0.000	0.189	0.803	0.000	0.682	0.276
	1115	CB-9	0.410	1.232	0.000	0.325	0.415	0.000	0.352	0.923
	1120	CB-3	0.372	1.356	0.000	0.062	0.327	0.000	0.278	0.225
Slab 2F	1567	CB-3	0.374	1.350	0.000	0.030	0.362	0.000	0.308	0.098
EL9.06m	1572	CB-3	0.360	1.403	0.000	0.134	0.323	0.000	0.274	0.490
	1615	CB-9	0.407	1.240	0.081	0.243	0.339	0.136	0.404	0.600
	1620	CB-3	0.390	1.295	0.000	0.048	0.406	0.000	0.345	0.139
Slab RF	1867	CB-9	0.511	1.479	0.000	0.064	0.409	0.000	0.347	0.185
EL13.8m	1872	CB-9	0.500	1.511	0.000	0.125	0.318	0.000	0.270	0.463
	1915	CB-9	0.550	1.375	0.081	0.339	0.388	0.184	0.487	0.697
	1920	CB-9	0.537	1.408	0.000	0.076	0.524	0.000	0.445	0.171
Wall	6007	CB-9	0.676	1.491	0.355	0.512	1.489	0.994	2.110	0.242
EL-7.4m	4006	CB-9	0.672	1.500	0.355	1.481	1.225	0.988	1.881	0.787
~EL-2.001	4010	CB-9	0.673	1.498	0.355	0.702	0.479	0.989	1.247	0.563
Wall	6043	CB-9	0.675	1.494	0.355	0.649	1.847	0.992	2.413	0.269
EL-2.0m	4036	CB-3	0.673	1.498	0.710	0.967	1.227	1.978	2.724	0.355
~EL4.00III	4040	CB-3	0.696	1.447	0.355	0.454	1.461	1.023	2.111	0.215
Wall	6081	CB-9	0.673	1.497	0.000	0.291	1.494	0.000	1.270	0.229
EL4.65m	4066	CB-9	0.672	1.500	0.000	0.191	0.681	0.000	0.579	0.330
~EL9.00M	4070	CB-9	0.694	1.452	0.000	0.117	0.300	0.000	0.255	0.458
Wall	6117	CB-9	0.493	1.533	0.000	0.412	0.562	0.000	0.478	0.863
EL9.06m	4096	CB-9	0.493	1.533	0.000	0.472	0.623	0.000	0.530	0.892
	4100	CB-9	0.507	1.492	0.000	0.127	0.284	0.000	0.242	0.526

#### Table 7.3-13 Calculation Results for Transverse Shear by Selected Load Combination

Note: Load Combination ID of CB-9 in Table 6.3-5 = 7021 or 7521, whichever is greater.



#### Table 7.3-14 Maximum Stress Ratio of Selected Columns at the rows CB and C2, Xdirection

	Member Nan	ne:	C2-	CB-Columr	n-B2F (top)								
	Section	ID : 5002				Section		CBA	50006				
	Flange Pl	L:800 x 7	<b>'</b> 0			Web			j- edge				
	Maximum		Load	D	esign Load			Stress		Allowable Stress			
	Ratio	ID	(MN, MNm)				(MPa)		(MPa)				
			L	Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	$F_{bc}, F_{bt}$	Fv	
ĺ	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.513	8201	-20.42	-0.54		-99.9	-11.8		315.4	386.8		
	$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.013	5601	0.16	0.18		0.8	4.0		330.9	364.0		
	f <sub>v</sub> /F <sub>v</sub>	0.006	8101			0.12			1.1			193.1	

	Member Nam	ie :	C2-0	CB-Columr	I-B2F (bot)							
	Section	ID : 5002				Section	CBA	50006				
	Flange PL	. : 800 x 7	0			Web			i- edge			
	Maximum	Load	D	esign Load			Stress		Allowable Stress			
	Ratio	ID	(MN, MNm)				(MPa)		(MPa)			
				P	М	<	$f_{ac}, f_{at}$	$f_{bc}, f_{bt}$	fv	Fac,Fat	$F_{bc}, F_{bt}$	Fv
	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.483	8201	-20.42	0.00		-99.9	0.0		315.4	386.8	
	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.002	5601	0.16	0.00		0.8	0.0		330.9	364.0	
Į	f <sub>v</sub> /F <sub>v</sub>	0.006	8101			0.12			1.1			193.1

Member Nan	ne:	C2-	CB-Column	I-B1F (top)								
Section	ID: 6002				Section		CBA	60003				
Flange P	L:800 x 7	0			Web			j- edge				
Maximum	L	Load	D	esign Load	I		Stress		Allowable Stress			
Ratio	Ratio			(MN, MNm)			(MPa)			(MPa)		
			Р	М	V	$f_{ac}, f_{at}$	f <sub>bc</sub> ,f <sub>bt</sub>	fv	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	Fv	
$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.501	8201	-17.37	1.60		-85.0	34.8		309.6	386.8		
$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.021	5601	1.03	0.10		5.0	2.1		330.9	364.0		
f₀/F₀	0.017	5001			-0.37			-3.3			193.1	

[	Member Nam	e:	C2-0	B-Columr	n-B1F (bot)	-						
ĺ	Section I	D:6002	_			Section	on Type : Bo	XC		CBA	60003	
	Flange PL	: 800 x 7	70			Web	PL:660 x				i- edge	
	Maximum	D	esign Load			Stress		Allowable Stress				
1	Ratio	ID	(	MN, MNm)			(MPa)			(MPa)		
1				Р	М	<	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
1	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.444	8201	-17.37	0.59		-85.0	12.8		309.6	386.8	
L	$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.038	5601	1.03	0.39		5.0	8.4		330.9	364.0	
	f <sub>v</sub> /F <sub>v</sub>	0.017	5001			-0.37			-3.3			193.1



WG3-U73-ERD-S-0004	SH NO. 91
REV. 2	of 219

#### Table 7.3-14 Maximum Stress Ratio of Selected Columns at the rows CB and C2, Xdirection (Continued)

1	Member Nam	ie :	C2-	CB-Colum	n-1F (top)								
	Section	ID : 7002				Section	on Type : B	ох		CBA	70004		
	Flange PL	. : 800 x 6	60			Web	PL:680 x	60			_	j- edge	
	Maximum		Load	Design Load Stress						Allowable Stress			
	Ratio		ID	(	MN, MNm)		(MPa)				(MPa)		
[				Р	М	V	$f_{ac}, f_{at}$	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	F <sub>v</sub>	
	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.475	8201	-11.90	2.38		-67.0	58.4		318.2	386.8		
I	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.024	5601	1.18	-0.06		6.7	-1.5		330.9	364.0		
[	f <sub>v</sub> /F <sub>v</sub>	0.061	8101			-1.13			-11.7			193.1	

1	Member Nam	е:	C2-	CB-Colum	n-1F (bot)							-
	Section I	ID : 7002				Section	on Type : Bo	ох		CBA	R ID :	70004
	Flange PL	:800 x 6	60	_		Web	PL:680 x 6	60				i- edge
	Maximum		Load	D	esign Load			Stress		Allowable Stress		
	Ratio		ID	(	MN, MNm)		(MPa)			(MPa)		
				Р	M	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.485	8201	-11.90	-2.54		-67.0	-62.3		318.2	386.8	
	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.034	5601	1.18	-0.21		6.7	-5.1		330.9	364.0	
	f₀/F₀	0.061	8101			-1.13			-11.7			193.1

Member Nam	e:	C2-	CB-Colum	in-2F (top)							
Section	ID: 8002				Section	on Type : B	XC		CBA	R ID :	80004
Flange PL	:800 x 6	50			Web	PL:680 x 0	60				j- edge
Maximum	Maximum Load Design Loa Ratio ID (MN, MNm						Stress		Allo	owable Stre	ess
Ratio		ID	(	MN, MNm)		(MPa)			(MPa)		
			Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> , f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.340	5101	-4.49	3.24		-25.3	79.3		277.7	364.0	
fat/Fat+fbt/Fbt	0.042	5601	1.14	0.33		6.4	8.1		330.9	364.0	
f <sub>v</sub> /F <sub>v</sub>	0.070	5101			-1.29			-13.5			193.1

[	Member Nam	e:	C2-	CB-Colum	n-2F (bot)							
	Section I	D:8002				Secti	on Type :BC	X		CBA	80004	
	Flange PL	:800 x 6	60			Web	PL :680 x 6	60				i- edge
	Maximum	num Load Design Load					Stress Allow					ess
	Ratio		ID	(MN, MNm)			(MPa)				(MPa)	
l				Р	М	<	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.282	5101	-4.49	-2.37		-25.3	-58.2		277.7	364.0	
	$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.030	5601	1.14	-0.16		6.4	-4.0		330.9	364.0	
	f <sub>v</sub> /F <sub>v</sub>	0.070	5101			-1.29			-13.5			193.1



WG3-U73-ERD-S-0004	SH NO. 92
REV. 2	of 219

#### Table 7.3-15 Maximum Stress Ratio of Selected Columns at the rows CB and C2, Y-direction

	Member Nam	ie :	C2-0	CB-Colum	n-B2F (top)						_	
ſ	Section	ID : 5002				Section	on Type : B	OX		CBA	R ID :	50006
	Flange PL	. : 800 x 7	0			Web	PL:660 x	70				j- edge
ſ	Maximum		Load		esign Load		-	Stress		All	owable Str	ess
	Ratio ID			(	MN, MNm)			(MPa)		(MPa)		
				Р	M	<ul> <li></li> </ul>	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	F <sub>v</sub>
	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.528	8201	-20.42	0.80		-99.9	17.5		315.4	386.8	
	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.028	5601	0.16	0.42		0.8	9.2		330.9	364.0	
ł	f <sub>v</sub> /F <sub>v</sub>	0.008	8101			-0.17			-1.5			193.1

Member Nam	ie :	 C2-0	CB-Colum	n-B2F (bot)							
Section	ID : 5002				Secti	on Type : B	DX XC		CBA	RID:	50006
Flange PL	Flange PL : 800 x 70 Maximum Load				Web PL : 660 x 70						i- edge
Maximum	Maximum Load Ratio ID					I	Stress		All	owable Str	ess
Ratio	Ratio ID			MN, MNm)		(MPa)				(MPa)	
			Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> , f <sub>bt</sub>	fv	Fac,Fat	F <sub>bc</sub> ,F <sub>bt</sub>	F <sub>v</sub>
f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.483	8201	-20.42	0.00		-99.9	0.0		315.4	386.8	
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.002	5601	0.16	0.00		0.8	0.0		330.9	364.0	
f <sub>v</sub> /F <sub>v</sub>	0.008	8101			-0.17			-1.5			193.1

Member Nam	ne :	C2-0	CB-Colum	n-B1F (top)						-	
Section	ID : 6002				Section	on Type : B	ox		CBA	R ID :	60003
Flange PL	: 800 x 7	70			Web	PL:660 x	70				j- edge
Maximum		Load		esign Load			Stress		All	owable Str	ess
Ratio	Ratio ID			MN, MNm)		(MPa)				(MPa)	
			Р	М	V	$f_{ac}, f_{at}$	f <sub>bc</sub> , f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	F,
$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.499	8201	-17.37	1.57		-85.0	34.2		309.6	386.8	
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.016	5601	1.03	0.01		5.0	0.3		330.9	364.0	
f <sub>v</sub> /F <sub>v</sub>	0.023	8201			-0.49			-4.4			193.1

Member Nam	e:	C2-0	CB-Colum	n-B1F (bot)							
Section	ID : 6002				Secti	on Type : B	XC		СВА	R ID :	60003
Flange PL	: 800 x 7	70			Web	PL:660 x 7	70			_	i- edge
Maximum		Load		esign Load			Stress		Alle	wable Str	ess
Ratio	Ratio ID			MN, MNm)		(MPa)				(MPa)	
			P	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> , f <sub>bt</sub>	f <sub>v</sub>	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	F <sub>v</sub>
$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.506	8201	-17.37	-1.68		-85.0	-36.6		309.6	386.8	
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.020	5601	1.03	-0.09		5.0	-1.9		330.9	364.0	
f <sub>v</sub> /F <sub>v</sub>	0.023	8201			-0.49			-4.4			193.1



WG3-U73-ERD-S-0004	SH NO. 93
REV. 2	of 219

# Table 7.3-15 Maximum Stress Ratio of Selected Columns at the rows CB and C2, Y direction (Continued)

Member Nam	е:	C2-	CB-Colum	in-1F (top)							
Section I	ID : 7002				Section	on Type : Bo	ох		CBA	R ID :	70004
Flange PL	:800 x 6	50			Web	PL:680 x 6	60				j- edge
Maximum		Load	Design Load Stress					Alle	owable Stre	ess	
Ratio ID			(MN, MNm)				(MPa)		(MPa)		
			Р	М	<ul> <li></li> </ul>	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.402	8201	-11.90	1.24		-67.0	30.3		318.2	386.8	
$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.023	5601	1.18	-0.04		6.7	-0.9		330.9	364.0	
f <sub>v</sub> /F <sub>v</sub>	0.032	8201			-0.60			-6.3			193.1

	Member Nam	e :	C2-	CB-Colum	n-1F (bot)							
	Section I	ID : 7002				Secti	on Type : B	DX XC		СВА	RID:	70004
	Flange PL	:800 x 6	50			Web	PL:680 x	60				i- edge
	Maximum		Load		esign Load			Stress		Alle	owable Stre	əss
	Ratio		ID	(	MN, MNm)			(MPa)			(MPa)	
				Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.414	8201	-11.90	-1.42		-67.0	-34.8		318.2	386.8	
	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.022	5601	1.18	-0.03	}	6.7	-0.8		330.9	364.0	
	f <sub>v</sub> /F <sub>v</sub>	0.032	8201			-0.60			-6.3			193.1

[	Member Nam	e :	C2-	CB-Colum	n-2F (top)							
	Section	ID : 8002	!			Section	on Type : Bo	ХС		CBA	R ID :	80004
	Flange PL	: 800 x 6	50			Web	PL:680 x 6	60				j- edge
	Maximum		Load	D	esign Load			Stress		Allo	wable Stre	ess
I	Ratio		ID	(	MN, MNm)			(MPa)			(MPa)	
				Р	М	<ul> <li></li> </ul>	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> , f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	$F_{bc}, F_{bt}$	Fv
[	fac/Fac+fbc/Fbc	0.368	8201	-7.08	2.77		-39.9	67.9		317.4	386.8	
	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.038	8601	0.16	0.56		0.9	13.7	}	351.6	386.8	
	f <sub>v</sub> /F <sub>v</sub>	0.057	8201			-1.05			-11.0			193.1

!	Member Nam	e:	C2-	CB-Colum	n-2F (bot)		- ,					×	
	Section I	D : 8002				Secti	on Type : B	XC		CBA	R ID :	80004	
	Flange PL			Web	PL:680 x 6	50				i- edge			
	Maximum	Maximum Load				Design Load Stress					Allowable Stress		
1	Ratio	Ratio			MN, MNm)			(MPa)			(MPa)		
				Р	М	V	$f_{ac}, f_{at}$	f <sub>bc</sub> , f <sub>bt</sub>	fv	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	Fv	
	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.307	8201	-7.08	-1.80		-39.9	-44.1		317.4	386.8		
	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.024	8601	0.16	-0.34		0.9	-8.3		<b>3</b> 51.6	386.8		
	f <sub>v</sub> /F <sub>v</sub>	0.057	8201			-1.05			-11.0			193.1	



WG3-U73	3-ERD-S-0004	SH NO.	94
REV. 2		of 2	219

#### Table 7.3-16 Maximum Stress Ratio of Selected Girders at the row CB

1	Member Nam	e :	. CB-E	B1F-Girder	-23 (2eṅd)							
	Section	ID : 1002				Sec	tion Type : I	H		CBA	RID:	11016
	Flange PL	: 300 x 2	28			Web	PL:644 x	19	_			i- edge
	Maximum		Load	D	esign Load			Stress		Allo	owable Stre	ess
1	Ratio		ID	(	MN, MNm)			(MPa)			(MPa)	
				Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	Fv
	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.555	8101	-1.64	-0.43		-56.6	-64.7		328.7	229.6	
1	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.142	5501	0.36	-0.23		12.4	-34.6		330.9	330.9	
1	f <sub>v</sub> /F <sub>v</sub>	0.107	3002			-0.20			-14.8			137.9

Member Nam	e:	CB-E	31F-Girde	r-45 (4end)							
Section	ID : 1002				Sec	tion Type : I	4		CBA	R ID :	11022
Flange PL	: 300 x 2	28			Web	PL : 644 x 1	19				i- edge
Maximum		Load		esign Load			Stress		Allowable Stress		
Ratio		ID	(	MN, MNm)			(MPa)			(MPa)	
			Р	M	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.775	8101	-1.96	-0.68		-67.6	-103.0		328.7	229.6	
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.155	5501	0.06	-0.33		2.2	-49.2		330.9	330.9	
f <sub>v</sub> /F <sub>v</sub>	0.143	3004			-0.26			-19.7			137.9

Member Nam	ne:	CB-	1F-Girder	-23 (2end)							
Section	ID : 2004				Sec	tion Type : I	Н		CBA	R ID :	21016
Flange Pl	Flange PL : 400 x 40 Maximum Load				Web	PL:920 x	28				i- edge
Maximum	Maximum Load						Stress		Allo	owable Stre	ess
Ratio	(	MN, MNm)			(MPa)			(MPa)			
			Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.842	5201	-0.80	-4.11		-13.9	-223.2		288.1	288.2	
$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.701	5101	0.52	-4.10		9.4	-223.1		330.9	330.9	
f₀/F₀	0.242	8201			-1.31			-46.8			193.1

Member Nam	e:	CB-	1F-Girder-	45 (4end)		-						
Section I	ID : 1002				Sec	tion Type : I	Н		CBA	R ID :	21022	
Flange PL	Flange PL : 300 x 28           Maximum         Load				Web	PL:644 x	19				i- edge	
Maximum		Load	Load Design Load				Stress		Allowable Stress			
Ratio	Ratio			MN, MNm)			(MPa)			(MPa)		
			Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	Fbc,Fbt	Fv	
$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.607	5201	-0.73	-0.69		-25.3	-104.7		287.6	216.1		
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.348	8101	0.36	-0.73		12.3	-110.0		351.6	351.6		
f <sub>v</sub> /F <sub>v</sub>	0.140	8201			-0.36			-27.1			193.1	



WG3-U73-ERD-S-0004	SH NO. 95
REV. 2	of 219

## Table 7.3-16 Maximum Stress Ratio of Selected Girders at the rows CB (Continued)

Member Nam	e:	CB-	-2F-Girder	-23 (2end)							
Section	ID : 3003				Sec	tion Type :	H		CBA	AR ID :	31016
Flange PL	. : 400 x 4	40			Web	PL : 1220 x	28				i- edge
Maximum		Load	C	esign Load			Stress		All	owable Stre	ess
Ratio	ID	(	MN, MNm)			(MPa)		(MPa)			
			Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> , f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.726	8201	-3.40	-4.38		-51.4	-168.0		329.1	351.6	
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt/</sub> F <sub>bt</sub>	0.552	5101	1.07	-4.34		16.2	-166.6		330.9	330.9	
f <sub>v</sub> /F <sub>v</sub>	0.200	8201			-1.41			-38.6			193.1 <sup>-</sup>

	Member Nam	e:	CB-	2F-Girder	45 (4end)					-		
	Section I	ID : 3001				Sec	tion Type : i	+		CBA	R ID :	31022
	Flange PL	: 300 x 3	36			Web	PL:928 x 3	28				i- edge
	Maximum		Load	C	esign Load			Stress		Alle	ess	
Ι	Ratio		ID	(	MN, MNm)			(MPa)			(MPa)	
				P	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	$F_{ac}, F_{at}$	$F_{bc}, F_{bt}$	Fv
	fad/Fac+fbc/Fbc	0.686	8201	-2.23	-1.31	ĺ	-46.8	-95.0		328.4	206.7	
	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.163	5101	0.73	-0.53		15.4	-38.6		330.9	330.9	
	f <sub>v</sub> /F <sub>v</sub>	0.092	8201			-0.50			-17.8			193.1

	Member Nam	e:	CB-	RF-Girder	-23 (2end)							
	Section	ID : 4003				Sec	tion Type : I	4		CBA	RID:	41016
	Flange PL	. : 500 x 4	10			Web	PL : 1220 x	28				i- edge
	Maximum		Load		esign Load			Stress		Allo	owable Stre	ess
	Ratio		ID	(	MN, MNm)			(MPa)			(MPa)	
				P	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	F <sub>v</sub>
	fad/Fac+fbc/Fbc	0.841	8201	-7.13	-4.10		-96.2	-132.3		329.6	351.6	
	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.331	5101	0.58	-3.46		7.8	-111.9		330.9	364.0	
	f <sub>v</sub> /F <sub>v</sub>	0.192	8201			-1.35			-37.0			193.1

-

ſ	Member Nam	e:	CB-	RF-Girder	-45 (4end)	•				_			
Ī	Section	ID : 4001			Section Type : H						CBAR ID :		
	Flange PL	: 400 x 4	0			Web	PL:920 x	28		\ \		i- edge	
ľ	Maximum		Load		esign Load			Stress		Alle	wable Stre	ess	
	Ratio		ID		MN, MNm)		(MPa)				(MPa)		
		l		Р	М	V	$f_{ac}, f_{at}$	f <sub>bc</sub> ,f <sub>bt</sub>	fv	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	Fv	
Ī	fac/Fac+fbc/Fbc	0.876	8201	-5.59	-2.30		-96.7	-125.1		329.3	306.2		
	$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.195	5101	0.87	-0.91		15.0	-49.5		330.9	330.9		
	f <sub>v</sub> /F <sub>v</sub>	0.137	8201			-0.74			-26.4			193.1	



WG3-U73-ERD-S-0004	SH NO. 96
REV. 2	of 219

## Table 7.3-17 Maximum Stress Ratio of Selected Girders at the row C2

Member Nam	ie:	C2-E	B1F-Girder	-CB (Cend)							
Section	ID: 1002				Sec	tion Type :	Н		CBAR ID :		10005
Flange Pl	. : 300 x 2	28			Web	PL : 644 x	19				i- edge
Maximum	Ē	esign Load			Stress		Allowable Stress				
Ratio	ID	(MN, MNm)			(MPa)			(MPa)			
			Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.375	8101	-1.56	-0.30		-53.9	-44.5		328.7	386.8	
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.042	5501	0.39	0.00		13.5	-0.4		330.9	364.0	
f <sub>v</sub> /F <sub>v</sub>	0.037	8101	_		-0.10			-7.2			193.1

Member Nam	ne :	C2-E	B1F-Girder	-BA (Bend)							
Section	ID : 1001				Sec	tion Type : I	H		CBA	R ID :	10007
Flange PL	: 400 x 3	36			Web	PL : 628 x 2	28				i- edge
Maximum		Load		Design Load		1	Stress		Allowable Stress		
Ratio		ID	(	(MN, MNm)			(MPa)			(MPa)	
			P	M	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> , f <sub>bt</sub>	fv	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.638	8101	-2.21	-1.69		-47.6	-157.8		329.4	386.8	
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.290	5601	0.47	-1.01		10.2	-94.5		330.9	364.0	
f <sub>v</sub> /F <sub>v</sub>	0.207	3003			-0.56			-28.6		_	137.9

M	ember Nam	e:	C2-	1F-Girder-	CB (Cend)								
	Section	ID : 2002				Sec	tion Type :	H		CBA	20005		
	Flange PL	: 300 x 2	28			Web	PL : 644 x				i- edge		
	Maximum		Load	C	)esign Load			Stress		Allowable Stress			
	Ratio		ID	(MN, MNm)			(MPa)				(MPa)		
				Р	M	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> , f <sub>bt</sub>	f <sub>v</sub>	Fac,Fat	F <sub>bc</sub> ,F <sub>bt</sub>	F <sub>v</sub>	
f <sub>ac</sub> /F <sub>a</sub>	<sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.229	5201	-0.56	-0.33		-19.3	-49.2		287.6	364.0		
f <sub>at</sub> /F	at+f <sub>bt</sub> /F <sub>bt</sub>	0.186	8101	0.56	-0.34		19.2	-50.7		351.6	386.8		
1 1	f <sub>v</sub> /F <sub>v</sub>	0.059	8201			-0.15			-11.3			193.1	

	Member Nam	e :	C2-′	IF-Girder-	BA (Bend)							
Ī	Section	ID : 2001				Sec	tion Type :	н		CBA	R ID :	20007
	Flange PL	: 400 x 4	10			Web	PL:720 x	28				i- edge
	Maximum		Load		esign Load			Stress		Alle	wable Stre	ess
	Ratio		ID	(	MN, MNm)		(MPa)				(MPa)	
				Р	M	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	$F_{ac}, F_{at}$	Fbc,Fbt	Fv
	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.453	5201	-0.82	-1.89		-15.6	-137.4		288.2	364.0	
	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.415	8101	0.91	-1.94	:	17.4	-141.5		351.6	386.8	
	f <sub>v</sub> /F <sub>v</sub>	0.202	8201			-0.87			-39.1		_	193.1



WG3-U73-ERD-S-0004	SH NO. 97
REV. 2	of 219

## Table 7.3-17 Maximum Stress Ratio of Selected Girders at the rows CB (Continued)

r

	Member Nam	ie :	C2-:	 2F-Girder-	CB (Cend)							
	Section	ID : 3002				Sec	tion Type :	н		CBAR ID : 30		
	Flange PL	: 300 x 2	28			Web	PL : 944 x	19				i- edge
	Maximum		Load	C	esign Load			Stress		Allo	ess	
	Ratio		ID	(	MN, MNm)		(MPa)					
1		1		Р	M	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	F <sub>v</sub>
1	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.400	8201	-2.02	-0.44		-58.1	-41.8		328.5	351.6	
1	fat/Fat+fbt/Fbt	0.157	5101	0.46	-0.45		13.2	-42.8	ĺ	330.9	364.0	
1	f <sub>v</sub> /F <sub>v</sub>	0.049	8201			-0.18			-9.5			193.1

ſ	Member Nam	ne :	C2-:	2F-Girder-	BA (Bend)					_		
	Section	ID : 3001				Sec	tion Type :	Н		CBA	30007	
	Flange Pl	. : 300 x 3	36			Web	PL : 928 x	28				i- edge
ſ	Maximum		Load		esign Load			Stress		All	owable Stre	ess
	Ratio		ID	(	MN, MNm)			(MPa)		(MPa)		
				Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> , f <sub>bt</sub>	fv	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.607	8201	-2.23	-2.02		-46.9	-147.0		328.4	386.8	
	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.346	5101	0.67	-1.52		14.0	-110.6		330.9	364.0	
	f <sub>v</sub> /F <sub>v</sub>	0.156	8201			-0.84			-30.1			193.1

Member Nam	e:	C2-F	RF-Girder-	CB (Cend)							
Section	D:4002				Sec	tion Type : I	Н		CBA	RID:	40005
Flange PL	: 300 x 2	28			Web	PL:944 x	19				i- edge
Maximum		Load	C	esign Load			Stress		Allowable Stress		
Ratio		ID	(	MN, MNm)		(MPa)				(MPa)	
			Р	M	∠ \	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.684	8201	-3.36	-0.81		-96.7	-76.2		328.5	351.6	
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.190	5101	0.75	-0.48		21.7	-45.4		330.9	364.0	
f <sub>v</sub> /F <sub>v</sub>	0.046	8201			-0.17			-8.9			193.1

Member Nam	e:	C2-F	RF-Girder-	BA (Bend)							
Section	ID : 4001				Sec	tion Type : I			CBA	R ID :	40007
Flange PL	:400 x 4	10			Web	PL:920 x 2	28				i- edge
Maximum		Load	E	esign Load			Stress		Allowable Stress		
Ratio		ID	(	MN, MNm)		(MPa)				(MPa)	
			Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	Fv
f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.777	8201	-5.56	-2.22		-96.2	-120.6		329.3	386.8	
$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.226	5101	0.77	-1.25		13.3	-67.8		330.9	364.0	
f <sub>v</sub> /F <sub>v</sub>	0.180	8201			-0.97			-34.7			193.1



1

WG3-U73-ERD-S-0004	SH NO. 98
REV. 2	of 219

Member Name :	C2-CB-Co	umn-B2F	(top)	_							
Section ID : 5	002		Se	ction Type :		CBAR ID	: 50006				
Flange PL : 800	Flange PL : 800 x 70					Web PL : 660 x 70					
	X-d	irection			Y-direction	Ratio					
	Load	R <sub>NS</sub>	R <sub>fa/Fa</sub>	Load	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> + R <sub>EW</sub> -	Max.(R <sub>tv/Fv</sub> )			
	0204	0.542	0.247	0004	0.500	0.047	IVIIII.[Rfa/Fa)				
lac/Fac+lbc/Fbc	8201	0.513	0.317	8201	0.528	0.317	0.725				
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	5601	0.013	0.002	5601	0.028	0.002	0.039				
f <sub>v</sub> /F <sub>v</sub>	8101	0.006		8101	0.008			0.010			

#### Table 7.3-18 Column Stress Check Results

	Member Name :	C2-CB-Co	lumn-B2F	(bot)						
	Section ID : 5	002		Se	ction Type	: BOX		CBAR ID	: 50006	
	Flange PL : 800		W	eb PL : 660	) x 70			i- edge		
		lirection	ection Y-direction					Ratio		
		Load ID	R <sub>NS</sub>	R <sub>fa/Fa</sub>	Load ID	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>fv/Fv</sub> )	
į	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	8201	0.483	0.317	8201	0.483	0.317	0.649		
	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	5601	0.002	0.002	5601	0.002	0.002	0.002		
1	f./F.	8101	0.006		8101	0.008			0.010	

Member Name :	C2-CB-Col	umn-B1F	(top)						
Section ID : 60	Section ID: 6002			ction Type :	CBAR ID	: 60003			
Flange PL : 800		W	eb PL : 660		j- edge				
	X-directio				Y-direction		Ratio		
	Load		Rus	Load	Rau	R. c	R <sub>NS</sub> + R <sub>EW</sub> -	Max (R, r, )	
	ID	11/05	r sta/r-a	ID	NEW	r (a/Fa	Min.(R <sub>fa∕Fa</sub> )	Max.(NW/W	
$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	8201	0.501	0.275	8201	0.499	0.275	0.726		
$f_{at}/F_{at}+f_{bt}/F_{bt}$	5601	0.021	0.015	5601	0.016	0.015	0.022		
f <sub>v</sub> /F <sub>v</sub>	5001	0.017		8201	0.023			0.028	

Member Name ;	C2-CB-Col	umn-B1F								
Section ID : 6	Section ID : 6002			ction Type :	CBAR ID	: 60003				
Flange PL : 800	Flange PL : 800 x 70				Web PL : 660 x 70					
	X-d	rection			Y-direction		Ratio			
	Load ID		R <sub>fa/Fa</sub>	Load ID	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>fv/Fv</sub> )		
$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	8201	0.444	0.275	8201	0.506	0.275	0.675			
$f_{at}/F_{at}+f_{bt}/F_{bt}$	5601	0.038	0.015	5601	0.020	0.015	0.044			
f <sub>v</sub> /F <sub>v</sub>	5001	0.017		8201	0.023			0.028		



WG3-U73-ERD-S-0004	SH NO. 99
REV. 2	of 219

Member Name :	C2-CB-C	olumn-1F	(top)					
Section ID : 7	002		Se	ction Type	: BOX		CBAR ID	: 70004
Flange PL : 800	Flange PL : 800 x 60				) x 60		j- edge	
	X-0			Y-direction	Ratio			
	Load ID R <sub>N</sub>		R <sub>fa/Fa</sub>	Load ID	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>fv/Fv</sub> )
f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	8201	0.475	0.211	8201	0.402	0.211	0.667	-
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	5601	0.024	0.020	5601	0.023	0.020	0.027	
f <sub>v</sub> /F <sub>v</sub>	8101	0.061		8201	0.032			0.069

## Table 7.3-18 Column Stress Check Results (Continued)

Member Name :	C2-CB-C	olumn-1F	(bot)						
Section ID : 7	Section ID: 7002			ction Type	CBAR ID	: 70004			
Flange PL : 80	0 x 60		W	eb PL : 680		i- edge			
	X-0	lirection			Y-direction		Ratio		
	Load ID R <sub>NS</sub> R <sub>fe</sub>			Load ID	R <sub>EW</sub> R <sub>fa/Fa</sub>		R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>fv/Fv</sub> )	
f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	8201	0.485	0.211	8201	0.414	0.211	0.688		
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	5601	0.034	0.020	5601	0.022	0.020	0.036		
f <sub>v</sub> /F <sub>v</sub>	8101	0.061		8201	0.032		ļ	0.069	

Member Nar	ne :	C2-C	C2-CB-Column-2F (top)									
Section	ID : 8002			S	ection Typ	e : BOX			CBAR ID :		80004	
Flange Pl	_ : 800 x 60	)		V	Veb PL : 6	80 x 60					j- edge	
			X-direction						Y-direction			
Maximum Ra	Maximum Ratio			R <sub>EW</sub> ·	R <sub>fa/Fa</sub>	R <sub>NS</sub> +R <sub>EW</sub> - R <sub>fa/Fa</sub>	Load ID	R <sub>NS</sub>	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> +R <sub>EW</sub> ≁ R <sub>fa∕Fa</sub>	
fad/Fac+fbd/Fbc	0.541	5101	0.340	0.213	0.091	0.462	8201	0.298	0.368	0.126	0.541	
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.066	5601	0.042	0.020	0.019	0.042	8601	0.031	0.038	0.003	0.066	
f <sub>v</sub> /F <sub>v</sub>	0.076	5101	0.070	0.029	-	0.076	8201	0.036	0.057	-	0.067	

Member Nar	ne :	C2-C	C2-CB-Column-2F (bot)								•
Section	ID : 8002			S	ection Typ	e : BOX			CBA	R ID :	80004
Flange PL	.: 800 x 60	כ		V	Veb PL : 6	60 x 60				i- edge	
				X-direc		Y-direction					
Maximum Ra	Maximum Ratio			R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> +R <sub>EW</sub> - R <sub>fa/Fa</sub>	Load ID	R <sub>NS</sub>	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> +R <sub>EW</sub> - R <sub>fa/Fa</sub>
fac/Fac+fbc/Fbc	0.452	5101	0.282	0.189	0.091	0.380	8201	0.271	0.307	0.126	0.452
f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.051	5601	0.030	0.020	0.019	0.031	8601	0.030	0.024	0.003	0.051
f <sub>v</sub> /F <sub>v</sub>	0.076	5101	0.070	0.029	-	0.076	8201	0.036	0.057		0.067



WG3-U73-ERD-S-0004	SH NO.100
REV. 2	of 219

#### Table 7.4-1 Dynamic Soil Pressures for Evaluating CB External Walls

١

EL _ (m)	H (m)	C1 and C5 Walls σ (MN/m²)	CA and CD Walls σ (MN/m <sup>2</sup> )
4.650			
-3.120	7.770	-	-
2.065	0.845	0.060	0.068
-3.905	1.720	0.244	0.274
-5.685	1.715	0.489	0.550
-10.400	3.000	-	-

# Table 7.4-2 Rebar and Concrete Stresses of CB External Walls: Site-Specific Seismic Load Combination CB-9

		Concrete S	tress (MPa)	Primary Reinforcement Stress (MPa)						
Location	Element ID	-			Calcul	ated				
		Calculated	Allowable	Horizonta	I direction	Vertica	I direction	Allowable		
				Inside	Outside	Inside	Outside			
Wall Fil -7.4m	6007	-9.5	-29.3	32.7	138.0	25.5	149.9	372.2		
~EL-2.0m	4006	-10.4		33.1	122.2	<b>-2</b> 3.7	132.8			
	4010	-3.3		62.4	96.4	22.0	173.7			
Wall FL-2.0m	6043	-9.8	-29.3	93.7	194.2	<b>-2</b> 7.7	127.4	372.2		
~EL4.65m	4036	-6.0		112.7	128.8	142.4	108.1			
	4040	-5.1		122.5	141.6	144.1	213.3			

Notes: Negative value means compression.

1

Load Combination ID in Table 6.3-5 = 7021 or 7521, whichever is greater.

Location	Element	Load	d	ρ"	ρ,	Shear Forces (MN/m)				
	ID	ID	(m)	(%)	(%)	Vu	V <sub>c</sub>	Vs	φV <sub>n</sub>	<b>V</b> <sub>u</sub> /∳V <sub>n</sub>
Wall	6007	7021	0.679	1.485	0.355	0.553	0.638	0.998	1.391	0.397
~EL-7.4///	4006	7021	0.672	1.500	0.355	1.160	1.488	0.988	2.104	0.551
	4010	7021	0.675	1.493	0.355	0.559	0.539	0.992	1.301	0.430
Wali	6043	7511	0.674	1.495	0.355	0.164	0.608	0.991	1.359	0.121
~EL4.65m	4036	7511	0.673	1.498	0.710	0.135	0.523	1.978	2.126	0.063
	4040	7021	0.677	1.489	0.355	0.279	0.532	0.995	1.298	0.215

#### Table 7.4-3 Maximum Transverse Shear of CB External Walls



WG3-U73-ERD-S-0004	SH NO.101
REV. 2	of 219

Figure 3.3-1 Concrete Outline Plan at EL -7.40



WG3-U73-ERD-S-0004	SH NO.102
REV. 2	of 219

Figure 3.3-2 Concrete Outline Plan at EL -2.00



WG3-U73-ERD-S-0004	SH NO.103
REV. 2	of 219

Figure 3.3-3 Concrete Outline Plan at EL 4.65



WG3-U73-ERD-S-0004	SH NO.104
REV. 2	of 219

Figure 3.3-4 Concrete Outline Plan at EL 9.06



WG3-U73-ERD-S-0004	SH NO.105
REV. 2	of 219

Figure 3.3-5 Concrete Outline Plan at EL 13.80



Figure 3.3-6 Concrete Outline E-W Section



WG3-U73-ERD-S-0004	SH NO.107
REV. 2	of 219








Figure 5.3-1 Normal Operation Temperatures















WG3-U73-ERD-S-0004	SH NO.111
REV. 2	of 219



Figure 5.6-1 Dynamic Analysis Model



WG3-U73-ERD-S-0004	SH NO.112
REV. 2	of 219



Note: Obtained from Reference 2.1.2-l, based on site-specific Seismic Analysis of Control Building in Reference 2.1.2-k. Figure 5.6-2 Design Seismic Shear and Moments for CB



WG3-U73-ERD-S-0004	SH NO.113
REV. 2	of 219



Figure 5.6-3 Seismic Lateral Soil Pressure



Cut View

Figure 6.2-1 FE Model (Isometric View)



•	+	•	Ť	•	2.4	5@12	1.00	•	Ť			ŤĹ,	►X(S)
131	132	l 133	134	135	136	137	138	l 139	140	141	142	143	
109	110	111	112	113	114	115	116	117	118	119	120		CA
118	119	120	121	122	123	124	125	126	127	128	129	130 Ni	
97	98	99	100	101	102	103	104	105	106	107	108	485	
105	106	107	108	109	110	111	112	113	114	115	116	117	
85	86	87	88	89	90	91	92	93	94	95	96	2.485	
92	93	94	95	96	97	98	99	100	101	102	103	104	
73	74	75	76	77	78	79	80	81	82	83	84	2.49	
79 61	80 62	81 63	82 64	83 65	84 66	85 67	86 68	87 69	88 70	89 71	90 72	91	СВ
66	67	68	69	70	71	72	73	74	75	76	77	78 - 00	
53	54	55	56	57	58	59	60	61	62	63	64	65 -	
37	38	39	40	41	42	43	44	45	46	47	48	2.49	$\bigcirc$
40	41	42	43	44	45	46	47	48	49	50	51	- 52	
25	26	27	28	29	30	31	32	33	34	35	36	2.485	
27	28	29	30	31	32	33	34	35	36	37	38	- 39 - 66	
13	14	15	16	17	18	19	20	21	22	23	24	2.485	
14	15	16	17	18	19	20	21	22	23	24	25	26	
1	2	3	4	5	6	7	8	9	10	11	12	5.49	$\sim$
Ľ		3	4	5	0		d	9	10	111	12	•	-(CD)

Figure 6.2-2 FE Model, Basemat EL -7.40



WG3-U73-ERD-S-0004	SH NO.116
REV. 2	of 219

») •	. 9	.95	(e	3.		в) ————————————————————————————————————	9,	95	(e		Ā
2.49	2.485	2.485	2.49	1.50	1.50	2.49	2.485	2.485	2,49	+	► Y(E)
6501	6514	6527	6540	6553	6566	6579	6592	6605	6618	6631	EL 13800
2111 6001	2112 6014	2113 6027	2114 6040	2115 6053	2116 6066	2117 6079	2118 6092	2119 6105	2120 6118	<u>ب</u> 6131 ₩	
2101 5501	2102 5514	2103 5527	2104 5540	2105 5553	2106 5566	2107 5579	2108 5592	2109 5605	2110 5618	5631 <u></u>	
2091 5001	2092 5014	2093 5027	2094 5040	2095 5053	2096 5066	2097 5079	2098 5092	2099 5105	2100 5118	5131 <sup>-</sup>	EL 9060
2081 4501	2082 4514	2083 4527	2084 4540	2085 4553	2086 4566	2087 4579	2088 4592	2089 4605	2090 4618	4631	
2071 4001	2072 4014	2073 4027	2074 4040	2075 4053	2076 4066	2077 4079	2078 4092	2079 4105	2080 4118	4131 +	
2061 3501	2062 3514	2063 3527	2054 3540	2065 3553	2066 3566	2067 3579	3692	2069 3605	2070 3618	3631 4	EL 4650
2051 3001	2052 3014	2053 3027	2054 3040	2055 3053	2056 3066	2057 3079	2058 3092	2059 3105	2060 3118	3131	
2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2.21	•
2501	2514	2527	2540	2553	2566	2579	2592	2605	2618	2631	
2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	22	
2001	2014	2027	2040	2053	2066	2079	2092	2105	2118	2131 0	EL -2000
1501	1514	1527	1540	1553	1566	1579	1592	1605	1618	1631	
2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	12	•
1001	1014	1027	1040	1053	1066	1079	1092	1105	1118	1131	•
2001 501	2002 514	2003 527	2004 540	2005 553	2006 566	2007 579	2008 592	2009 605	2010 618	631 412	EL-7400
ELEM-ID GRID-ID	(Unit: m)										

Figure 6.2-3 FE Model, North Wall





.







WG3-U73-ERD-S-0004	SH NO.118
REV. 2	of 219

Ÿ		9.	.95	6	3.	00 0		9	.95	6	7	
+	2.49	2.485	2.485	2.49	1.50	1.50	2.49	2.485	2.485	2.49	+	→ Y(E)
651	13	6526	6539	6552	6565	6578	6591	6604	l 6617	6630	6643	EL 13800
	4111	4112	4113	4114	4115	4116	4117	4118	4119	4120	]	
601	13	6026	6039	6052	6065	6078	6091	6104	6117	6130	6143 🕂	
	4101	4102	4103	4104	4105	4106	4107	4108	4109	4110	8	
551	13	5526	2039	5552	5565	5578	5591	5604	5617	5630	5643 **	•
501	4091 13	4092 5026	4093 5039	4094 5052	4095 5065	4096 5078	4097 5091	4098 5104	4099 5117	4100 5130	نې 5143 ۲	EL 9060
	4081	4082	4083	4084	4085	4086	4087	4088	4089	4090	.47	
451	13	4526	4539	4552	4565	4578	4591	4604	4617	4630	4643	•
401	4071 13	4072	4073	4074	4075	4076	4077	4078	4079	4080	4143	
351	4061 13	4062 3526	4063 3539	4064 3552	4065 3565	4066 3578	4067 3591	4068 3604	4069 3617	4070 3630	3643 4.	EL 4650
	4051	4052	4053	4054	4055	4056	4057	4058	4059	4060	8	
301	13	3026	3039	3052	3065	3078	3091	3104	3117	3130	3143	
	4041	4042	4043	4044	4045	4046	4047	4048	4049	4050	1 -	•
											2.21	
251	3	2526	2539	2552	2565	2578	2591	2604	2617	2630	2643	,
	4031	4032	4033	4034	4035	4036	4037	4038	4039	4040	8	
201	13	2026	2039	2052	2065	2078	2091	2104	2117	2130	2143	EL -2000
·   ·	4021	4022	4023	4024	4025	4026	4027	4028	4029	4030	715	
151	3	1526	1539	1552	1565	1578	1591	1604	1617	1630	1643 -	,
	4011	4012	4013	4014	4015	4016	4017	4018	4019	4020	1.7	
101	3	1026	1039	1052	1055	1078	1091	1104	111/	1130	1143	
513	4001	4002	4003	4004	4005	4006 578	4007	4008	4009	4010	643	F1 .7400
		0.0				0,0			1011	000		
EU	EM-ID											
GRI	ID-ID	(Unit: m)						Eleme	it selected i	orevaluation	1	

Figure 6.2-5 FE Model, South Wall



<u> </u>	7.35	0	┥	7.35		<u> </u>	7.35	(	$\checkmark$	7.35	C	Ý	<b>≜</b>
	•	ŧ	<b>↓</b>	•	2.45	@12	•	¶	┼───	•	<u>†</u>	ł	└ <b>→</b> X(S)
6624	1	1	1	1	0000	6697	0028	1	I	6644	6640	6642	EI 13800
6133	6134	6135	6136	6137	6138	6139	6140	6141	6142	6143	6144	1 6043	EL 13000
6131	6132	6133	6134	6135	6136	6137	6138	6139	6140	6141	6142	6143	
6121 5631	6122 5632	6123 5633	6124 5634	6125 5635	6126 5636	6127 5637	6128 5638	6129 5639	6130 5640	6131 5641	6132 5642	5643	
6109 5131	6110 5132	6111 5133	6112 5134	6113 5135	6114 5136	6115 5137	6116 5138	6117 5139	6118 5140	6119 5141	6120 5142	5143 S	EL 9060
6097 4631	6098 4632	6099 4633	6100 4634	6101 4635	4636		6104 4638	6105 4639	6106 4640	6107 4641	6108 4642	4643	
6085 4131	6086 4132	6087 4133	6088 4134	6089 4135	4136	4137	6092 4138	6093 4139	6094 4140	6095 4141	6096 4142	4143	
6073 3631	6074 3632	6075 3633	6076 3634	6077 3635	6078 3636	6079 3637	6080 3638	6081 3639	6082 3640	6083 3641	6084 3642	3643	EL 4650
6061	6062	6063	6064	6065	6066	6067	6068	6069	6070	6071	6072	8	
3131	3132	3133	3134	3135	3136	3137	3138	3139	3140	3141	3142	3143	'
6049	6050	6051	6052	6053	6054	6055	6056	6057	6058	6059	6060	5	I
2631	2632	2633	2634	2635	2636	2637	2638	2639	2640	2641	2642	2643	
6037	6038	6039	6040	6041	6042	6043	6044	6045	6046	6047	6048	8	
2131	2132	2133	2134	2135	2136	2137	2138	2139	2140	2141	2142	2143	EL -2000
6025	6026	6027	6028	6029	6030	6031	6032	6033	6034	6035	6036	715	
1631	1632	1633	1634	1635	1636	1637	1638	1639	1640	1641	1642	1643	+
6013	6014	6015	6016	6017	6018	6019	6020	6021	6022	6023	6024	1142	
6001	6002	6003	6004	6005	6006	6007	6008	6009	6010	6011	6012	- <sup>(143</sup>	,†
631	632	633	634	635	636	637	638	639	640	641	642	643	EL -7400
												_	

Figure 6.2-6 FE Model, East Wall



WG3-U73-ERD-S-0004	SH NO.120
REV. 2	of 219

<b>c1</b> )	7.35	(	22)	7.35	(	3)	7.35	(	24)	7.35	(	c5)	Z
Ī	7.00		Ī		2.45	@12			Ī			Ī	
Ī	1	1	Ī	Ι.	T	1	I	T	T	I	T	T	^(3)
6501	6502	6503	6504	6505_	6506	6507	6508	6509	6510	6511	6512	6513	EL 13800
5133	5134	5135	5136	5137	5138	5139	5140	5141	5142	5143	5144	3	
6001	6002	6003	6004	6005	6006	6007	6008	6009	6010	6011	6012	6013	-
5121	5122	5123	5124	5125	5126	5127	5128 5508	5129 5509	5130 5510	5131	5132 5512	5513	2
5100	5002	5000	5110	5112	5114	5115	5110	6117	5119	5110	512D		-
5001	5002	5003	5004	5005	5006	5007	5008	5009	5010	5011	5012	5013	EL 9060
5097	5098	5099	5100	5101	$\overline{)}$		5104	5105	5106	5107	5108	5	
4501	4502	4503	4504	4505	4506	<	4508	4509	4510	4511	4512	4513	•
5085 4001	5086 4002	5087 4003	5088 4004	5089 4005	4006	4007	5092 4008	5093 4009	5094 4010	5095 4011	5096 4012	4013	
5073 3501	5074 3502	5075 3503	5076 3504	5077 3505	5078 3506	5079 3507	5080 3508	5081 3509	5082 3510	5083 3511	5084 3512	3513	EL 4650
5061	5062	5063	5064	5065	5066	5067	5068	5069	5070	5071	5072	1	
3001	3002	3003	3004	3005	3006	3007	3008	3009	3010	3011	3012	3013	
5049	5050	5051	5052	5053	5054	5055	5056	5057	5058	5059	5060	5	
2501	2502	2503	2504	2505	2506	2507	2508	2509	2510	2511	2512	2513	i   •
5037	5038	5039	5040	5041	5042	5043	5044	5045	5046	5047	5048	5	
2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	EL -2000
5025	5026	5027	5028	5029	5030	5031	5032	5033	5034	5035	5036	4	2
1501	1502	1503	1504	1505	1506	1507	1508	1509	1510	1511	1512	1513	
5013	5014	5015	5016	5017	5018	5019	5020	5021	5022	5023	5024	3	
1001	1002	1003	1004	1005	1006	1007	1008	1009	1010	1011	1012	1013	·
5001	5002	5003	5004	5005	5006	5007	5008	5009	5010	5011	5012	14	
501	502	503	504	505	506	507	508	509	510	511	512	513	EL -7400
ELEM-ID	ו												
GRID-ID	(Unit: m)												

Figure 6.2-7 FE Model, West Wall



WG3-U73-ERD-S-0004	SH NO.121
REV. 2	of 219

<u>(1</u>	7.35	(	<u>2</u> 2)	7.35	(9	<b>3</b> 3)	7.35	(	<b>C</b> 4)	7.35	(	( <u>C5</u> ) Y(	E)
ļ	1	•	•	•	2.4	5@12	f	•	ļ	•	•	1 L	-► X(S)
	I	I	l	l	I	I	I		I		I	ł	• •
2131	2132	2133	2134	2135	2136	2137	2138	2139	2140	2141	2142	<b>2</b> <sup>2143</sup>	+(CA)
609	610	611	612	613	614	615	616	617	618	619	620	49	
2118	2119	2120	2121	2122	2123	2124	2125	2126	2127	2128	2129	2130	
597	598	599	600	601	602	603	604	605	606	607	608	485	
2105	2106	2107	2108	2109	2110	2111	2112	2113	2114	2115	2116	2117y	3
585	586	587	588	589	590	591	592	593	594	595	596	58	i
2092	2093	2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	
672	674	676	670	677	£79	670	590	E94	692	593	594		
2070	2080	2091	2002	2092	2084	2095	2096	2097	2089	202	2000	3001	
561	562	563	564	565	566	567	568	569	570	571	572		СВ
2066	2067	2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078 7	
549 2053	550 2054	551 2055	552 2056	553 2057	554 2058	555 2059	556 2060	557 2061	558 2062	559 2063	560 2064	2065	
537	538	539	540	541	542	543	544	545	546	547	548		
2040	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	
525	526	527	528	520	530	531	532	533	534	535	536		
2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	
-021	2020	2023	2030			12000	12004	2000	2000	2007	2000		i i
513	514	515	516		>	<		521	522	523	524	2,48	
2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	
501	502	503	504	505	506	507	508	509	510	511	512	2.49	
2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	CD
ELEM-ID	ר							<u> </u>					$\bigcirc$

Figure 6.2-8 FE Model, B1F EL -2.00



WG3-U73-ERD-S-0004	SH NO.122
REV. 2	of 219

	7.35	(	C2)	7.35	(	3) 1	7.35	(	C4) ∳	7.35		>5) Y(E) ∓ ≜	
•	•			•	2.4	5@12	ţ	1	+	ł	•	┥╴└╾┆	X(S)
, 3631	3632	3633	3634	3635	3636	3637	3638	3639	3640	3641	3642	3643	$\overline{}$
1100			4440	4440							4400		
3618	3619	3620	3621	3622	3623	3624	3625	3626	3627	3628	3629	3630	
3010	3013	3020	3021	3022	3023	3024	3023	3020			3025	3030	
1097	1098	1099	1100	1101	1102	1103	1104	1105	1106	1107	1108	2.485	
3605	3606	3607	3608	3609	3610	3611	3612	3613	3614	3615	3616	3617ູ່ເຊິ່ ຫຼື	
1085	1086	1087	1088	1089	1090	1091	1092	1093	1094	1095	1096	2.485	
3592	3593	3594	3595	3596	3597	3598	3599	3600	3601	3602	3603	3604	
1073	1074	1075	1076	1077	1078	1079	1080	1081	1082	1083	1084	649	
3579	3580	3581	3582	3583	3584	3585	3586	3587	3588	3589	3590	3591	<b>B</b> )
1061 3566	1062 3567	1063 3568	1064 3569	1065 3570	1066 3571	1067 3572	1068 3573	1069 3574	1070 3575	1071 3576	1072 3577	3578 - 0	
1049	1050	1051	1052	1053	1054	1055	1056	1057	1058	1059	1060	3.0	
3553	3554	3555	3556	3557	3558	3559	3560	3561	3562	3563	3564	3565	
1037	1038	1039	1040	1041	1042	1043	1044	1045	1046	1047	1048	2.49	
3540	3541	3542	3543	3544	3545	3546	3547	3548	3549	3550	3551	3552	
1025	1026	1027	1028	1029	1030	1031	1032	1033	1034	1035	1036	0.485	
3527	3528	3529	3530	3531	3532	3533	3534	3535	3536	3537	3538	3539 6	
1013	1014	1015	1016			<		1021	1022	1023	1024	485	
3514	3515	3516	3517	3518	3519	3520	3521	3522	3523	3524	3525	3526	
1001	1002	1003	1004	1005	1006	1007	1008	1009	1010	1011	1012	6	
3501	3502	3503	3504	3505	3506	3507	3508	3509	3510	3511	3512	3513	
	 1		1			I			1		· .	·+(c	

Figure 6.2-9 FE Model, 1F EL 4.65



21) 7.35 C		2)	7.35	(	3	7.35	(	7.35	(C5) Y(E)					
	•	•		•	¢ 2.45	@12	•	•	•	•	•	ļĪ	- <b>⊳</b> X(	
		l				I	ł				1			
5131	5132	5133	5134	5135	5136	5137	5138	5139	5140	5141	5142	<b>1</b> <sup>5143</sup>		
1609	1610	1611	1612	1613	1614	1615	1616	1617	1618	1619	1620	.48		
5118	5119	5120	5121	5122	5123	5124	5125	5126	5127	5128	5129	5130		
1597	1598	1599	1600	1601	1602	1603	1604	1605	1606	1607	1608	485		
5105	5106	5107	5108	5109	5110	5111	5112	5113	5114	5115	5116	5117 N	S	
1585	1586	1587	1588	1589	1590	1591	1592	1593	1594	1595	1596	85	തി	
5092	5093	5094	5095	5096	5097	5098	5099	5100	5101	5102	5103	5104		
1572	1674	1575	1576	1577	1579	1570	1590	1591	1592	1582	1594			
5079	5080	5081	5082	5083	5084	5085	5086	5087	5088	5089	5090	5091		
1561	1562	1563	1564	1565	1566	1567	1568	1569	1570	1571	1572	8	-+(CB)	
5066	5067	5068	5069	5070	5071	5072	5073	5074	5075	5076	5077	5078 -	8.0	
5053	5054	5055	5056	5057	5058	5059	5060	5061	5062	5063	5064	5065 <u>6</u>		
1537	1538	1539	1540	1541	1542	1543	1544	1545	1546	1547	1548	6		
5040	5041	5042	5043	5044	5045	5046	5047	5048	5049	5050	5051	ີ. 5052		
1525	1526	1527	1529	1520	1620	1521	1522	1522	1524	1525	1526			
5027	5028	5029	5030	5031	5032	5033	5034	5035	5036	15037	5038	4 N 5039		
5027	3020	5025	3030			0000	10004	0000		0001	0000		6	
1513	1514	1515	1516	-	<u> </u>	~		1521	1522	1523	1524	2.48		
5014	5015	5016	5017	5018	5019	5020	5021	5022	5023	5024	5025	5026		
1501	1502	1503	1504	1505	1506	1507	1508	1509	1510	1511	1512	2.49		
5001	5002	5003	5004	5005	5006	5007	5008	5009	5010	5011	5012	5013	(CD)	

Figure 6.2-10 FE Model, 2F EL 9.06



WG3-U73-ERD-S-0004	SH NO.124
REV. 2	of 219

C1	7.35	(	22)	7.35	(	3	7.35	(	C4)	7.35		C5 Y	E)
<b>—</b>	•	Ť	<b>I</b>	Ŧ	2.45	@12	<del> </del> ·	•	<b>I</b>	t	· · · · · ·	I L	
I	I	1	1	1	1	l 	1	1	1	1	1	1	_
6631	6632	6633	6634	6635	6636	6637	6638	6639	6640	6641	6642		†CA
1909	1910	1911	1912	1913	1914 ·	1915	1916	1917	1918	1919	1920	2.49	
6618	6619	6620	6621	6622	6623	6624	6625	6626	6627	6628	6629	6630	
1897	1898	1899	1900	1901	1902	1903	1904	1905	1906	1907	1908	2.485	
6605	6606	6607	6608	6609	6610	6611	6612	6613	6614	6615	6616	6617	3
1885	1886	1887	1888	1889	1890	1891	1892	1893	1894	1895	1896	198	2
6592	6593	6594	6595	6596	6597	6598	6599	6600	6601	6602	6603	ہٰ 6604	
1873	1874	1875	1876	1877	1878	. 1879	1880	1881	1882	1883	1884		
6579	6580	6581	6582	6583	6584	6585	6586	6587	6588	6589	6590	ب 6591	
1861	1862	1863	1864	1865	1866	1867	1868	1869	1870	1871	1872		
6566	6567	6568	6569	6570	6571	6572	6573	6574	6575	6576	6577	6578 - 8	8
1849 6553	1850 6554	1851 6555	1852 6556	6557	.6558	6559	1856 6560	6561	6562	6563	6564	6565 F	
1837	1838	1839	1840	1841	1842	1843	1844	1845	1846	1847	1848	49	
6540	6541	6542	6543	6544	6545	6546	6547	6548	6549	6565	6551	6552	
1825	1826	1827	1828	1829	1830	1831	1832	1833	1834	1835	1836	8	
6527	6528	6529	6530	6531	6532	6533	6534	6535	6536	6537	6538	6539	
												ין <u>ה</u> ן	5
1813	1814	1815	1816	1817	1818	1819	1820	1821	1822	1823	1824	2.48	
6514	6515	6516	6517	6518	6519	6520	6521	6522	6523	6524	6525	6526	
1801	1802	1803	1804	1805	1806	1807	1808	1809	1810	1811	1812	2.49	
6501	6502	6503	6504	6505	6506	6507	6508	6509	6510	6511	6512	6513	
ELEM-ID GRID-ID	(Unit: m)								Elemer	nt selected fo	or evaluation	n	$\bigcirc$

Figure 6.2-11 FE Model, Roof EL 13.80

.



WG3-U73-ERD-S-0004	SH NO.125
REV. 2	of 219



Figure 6.2-12 FE Model of Steel Plan, EL -2.00



WG3-U73-ERD-S-0004	SH NO.126
REV. 2	of 219



Figure 6.2-13 FE Model of Steel Plan, EL 4.65



WG3-U73-ERD-S-0004	SH NO.127
REV. 2	of 219



Figure 6.2-14 FE Model of Steel Plan, EL 9.06



WG3-U73-ERD-S-0004	SH NO.128
REV. 2	of 219



Figure 6.2-15 FE Model of Steel Plan, EL 13.80



WG3-U73-ERD-S-0004	SH NO.129
REV. 2	of 219

<u>ч</u>	7.35	C		7.35	(0		7.35		4	7.35	(	ц Ц	Ā	
<b> </b>	•	•	ļ		2.45	@12	•	•		•	•	-	L	- <b>&gt;</b> X(S)
6579	6580	6581	6582	6583	6584	6585	6586	6587	6588	6589	6590	 6591	E	EL 13800
41013	41014	41015	41016	41017	41018	41019	41020	41021	41022	41023	41024	-0	5	
			80004						80006				1.54	
5079	5080	5081	5082	5083	5084	5085	5086	5087	5088	5089	5090	5091	Ë E	L 9060
31013	31014	31015	31016	31017	31018	31019	31020	31021	31022	31023	31024		1.47	
			70004						70000				4	
			70004						70006					
3579	3580	3581	3582	3583	3584	3585	3586	3587	3588	3589	3590	3591	1.47	EL 4650
21013	21014	21015	21016	21017	21018	21019	21020	21021	21022	21023	21024	-0		
													22	
			60003						60004				2.21	
													-	
													2.22	
2079	2080	2081	11016	2083	2084	2085	2086	2087	2088	2089	2090	2091	E	EL -2000
1013	,1014	1,015	1,010	1.017	50009	1585	11020	11021	11022	11023	11024		1.71	
						50008							2	
ELEM-ID	9 9		50006			1085			50010				<u> </u>	
ELEM-ID						50007							.715	
GRID-ID	(Unit: m)		582			585			588				E	L -7400

Figure 6.2-16 FE Model of CB Steel Frame



WG3-U73-ERD-S-0004	SH NO.130
REV. 2	of 219

C1)	7.35	(	C2)	7.35	(	3	7.35	(	C4)	7.35	(	<b>c</b> 5) 2	Z
			1		2.45	@12	•		<u> </u>	•	•	Ī	
I	I	I	]	Ţ	I	I	I	I	I	I	Ī	I	- 7(0)
6553	6554	6555	6556 9	6557	6558	6559	6560	6561	6562	6563	6564	6565	EL 13800
41001	41002	41003	41004	41005	41006	41007	41008	41009	41010	41011	41012	1.55	
													•
			80001						80003			, S	]
												55	I
5053	5054	5055	5056	5057	5058	5059	5060	5061	5062	5063	5064	_ <sup>5065</sup> _	EL 9060
31001	31002	31003	31004	31005	31006	31007	31008	31009	31010	31011	31012	1.47	
												2	†
			70001						70003				4
3553	3554	3555	3556	3557	3558	3559	3560	3561	3562	3563	3564	3565	EL 4650
21001	21002	21003	21004	21005	21006	21007	21008	21009	21010	21011	21012		EL 4030
21001	11002	21000	21001	11000	21000	21007	11000	21000	21010	21071	21012	222	
													4
												2	
			60001						60002			2	
													1
				0057	0050							222	_
2053	-0-2054	2055	2056	2057		2059	2050	e 2061	2062	2063	2064	-2055	EL -2000
11001	11002	11003	11004	11005	50004	1559	11008	1009	1010		11012	1.715	
					50004	60002							•
GRID-ID	GRID-ID		50001			1059			50005			1.7	
						50002						15	1
GRID-ID	(Unit: m)		556			559			562			1.7	EL -7400

Figure 6.2-17 FE Model of CC Steel Frame



WG3-U73-ERD-S-0004	SH NO.131
REV. 2	of 219



Figure 6.2-18 FE Model of C2 Steel Frame



WG3-U73-ERD-S-0004	SH NO.132
REV. 2	of 219



Figure 6.2-19 FE Model of C3 Steel Frame



WG3-U73-ERD-S-0004	SH NO.133
REV. 2	of 219



Figure 6.2-20 FE Model of C4 Steel Frame





Figure 6.2-21 Calculation Method for Shear Forces and Overturning Moments



Figure 6.2-22 Method of Applying Shear Forces





Figure 6.2-23 Method of Applying Overturning Moments





Figure 6.2-24 Method of Calculation Shear Forces due to Torsion



WG3-U73-ERD-S-0004	SH NO.138
REV. 2	of 219







Figure 6.2-26 Deformation due to Structure Load, DL



WG3-U73-ERD-S-0004	SH NO.140
REV. 2	of 219



Figure 6.2-27 Deformation due to Structure Load, EL



WG3-U73-ERD-S-0004	SH NO.141
REV. 2	of 219



Figure 6.2-28 Deformation due to Structure Load, LL



WG3-U73-ERD-S-0004	SH NO.142
REV. 2	of 219







Figure 6.2-30 Deformation due to Structure Load, TLS0


----

WG3-U73-ERD-S-0004	SH NO.144
REV. 2	of 219

----



Figure 6.2-31 Deformation due to Structure Load, TLW0



 WG3-U73-ERD-S-0004
 SH NO.145

 REV. 2
 of 219



Figure 6.2-32 Deformation due to Structure Load, TLS1



WG3-U73-ERD-S-0004	SH NO.146
REV. 2	of 219



Figure 6.2-33 Deformation due to Structure Load, TLW1



WG3-U73-ERD-S-0004	SH NO.147
REV. 2	of 219



Figure 6.2-34 Deformation due to Structure Load, WON

	<b>86</b> )	HITACHI
--	-------------	---------

WG3-U73-ERD-S-0004	SH NO.148
REV. 2	of 219



Figure 6.2-35 Deformation due to Structure Load, WOS



WG3-U73-ERD-S-0004 SH NO.149 REV. 2 of 219



Figure 6.2-36 Deformation due to Structure Load, WOE



WG3-U73-ERD-S-0004	SH NO.150
REV. 2	of 219



Figure 6.2-37 Deformation due to Structure Load, WOW





Figure 6.2-38 Deformation due to Structure Load, WTN



WG3-U73-ERD-S-0004	SH NO.152
REV. 2	of 219



Figure 6.2-39 Deformation due to Structure Load, WTS



WG3-U73-ERD-S-0004	SH NO.153
REV. 2	of 219



Figure 6.2-40 Deformation due to Structure Load, WTE



WG3-U73-ERD-S-0004	SH NO.154
REV. 2	of 219



Figure 6.2-41 Deformation due to Structure Load, WTW



WG3-U73-ERD-S-0004	SH NO.155
REV. 2	of 219



Figure 6.2-42 Deformation due to Structure Load, WTD

.



WG3-U73-ERD-S	-0004	SH NO.156
REV. 2		of 219



Figure 6.2-43 Deformation due to Structure Load, XS



.



Figure 6.2-44 Deformation due to Structure Load, YS



WG3-U73-ERD-	S-0004	SH NO.158
REV. 2	•	of 219



Figure 6.2-45 Deformation due to Structure Load, VAS



WG3-U73-ERD-S-0004	SH NO.159
REV. 2	of 219



Figure 6.2-46 Deformation due to Structure Load, TMS



WG3-U73-ERD-S-0004	SH NO.160
REV. 2	of 219



Figure 6.2-47 Deformation due to Structure Load, SPNS



WG3-U73-ERD-S-0004	SH NO.161
REV. 2	of 219



Figure 6.2-48 Deformation due to Structure Load, SPEW



WG3-U73-ERD-S-0004	SH NO.162
REV. 2	of 219



Figure 6.2-49 Forces and Moments in Shell Element





Figure 6.4-1 Design Flow Chart of Reinforced Concrete Structures





Figure 6.4-2 Calculation of Shear Strength Provided by Concrete





where,

- d = full depth of steel member, in.
- $b_f =$  flange width, in.
- $t_f$  = flange thickness, in.
- $t_w$  = web thickness, in.
- $A_f$  = area of compression flange, in.2
- $r_t$  = radius of gyration of a section comprising the compression flange plus 1/3 of the compression web area, taken about an axis in the plane of the web, in.
- $C_b = 1.0$  (conservatively taken)

Figure 6.4-3 Allowable Stress of W-shaped Members (Strong Axis Bending)





Figure 6.4-4 Allowable Stress of W-shaped Members (Weak Axis Bending)





Figure 6.4-5 Allowable Bending Stress of Box Members



 WG3-U73-ERD-S-0004
 SH NO.168

 REV. 2
 of 219



Figure 7.1-1 Assumed Basemat Rebar Arrangement (unit: mm)





Figure 7.1-2 Assumed Floor Slabs Rebar Arrangement (unit: mm)





Figure 7.1-2 Assumed Floor Slabs Rebar Arrangement (Continued)



Figure 7.1-3 Assumed Walls Rebar Arrangement (unit: mm)

. .



WG3-U73-ERD-S-0004	SH NO.172
REV. 2	of 219



Figure 7.1-3 Assumed Walls Rebar Arrangement (Continued)



WG3-U73-ERD-S-0004	SH NO.173
REV. 2	of 219



Figure 7.1-4 Structural Steel Member, Elevation on Col-Row CB

.



WG3-U73-ERD-S-0004	SH NO.174
REV. 2	of 219



Figure 7.1-5 Structural Steel Member, Elevation on Col-Row C2



WG3-U73-ERD-S-0004	SH NO.175
REV. 2	of 219



Figure 7.3-1 Elements Selected for Tabulation, Elevation on Col-Row CB



WG3-U73-ERD-S-0004	SH NO.176
REV. 2	of 219



Figure 7.3-2 Elements Selected for Tabulation, Elevation on Col-Row C2





Figure 7.3-3 Stress Check of Members Subject to Two Direction Forces



 WG3-U73-ERD-S-0004
 SH NO.178

 REV. 2
 of 219

ډ

## **APPENDIX A COMPARISON WITH DCD DATA**



## LIST OF TABLES

Table A-1 Design Seismic Shear Loads for Horizontal	180
Table A-2 Design Seismic Moment Loads for Horizontal	180
Table A-3 Design Seismic Torsion Loads for Horizontal	181
Table A-4 Vertical Acceleration	182
Table A-5 Dynamic Soil Pressures	183
Table A-6 Maximum Stress Ratios (Basemat and Slabs) for Flexure and Membrane Fo	orces184
Table A-7 Maximum Stress Ratios (Walls) for Flexure and Membrane Forces	186
Table A-8 Maximum Stress Ratios for Membrane Compressive Forces	187
Table A-9 Calculation Results for Maximum Transverse Shear	189
Table A-10 Maximum Stress Ratio of Selected Columns at the rows CB and C2, X-di	rection .191
Table A-11 Maximum Stress Ratio of Selected Columns at the rows CB and C2, Y-di	rection .194
Table A-12 Maximum Stress Ratio of Selected Girders at the row CB	197
Table A-13 Maximum Stress Ratio of Selected Girders at the row C2	200
Table A-14 Column Stress Check Results	203
Table A-15 Transverse Shear of CB External Walls	206

## LIST OF FIGURES

· .

## NONE


WG3-U73-ERD-S-0004	SH NO.180
REV. 2	of 219

	El NS-direction			EW-direction			
сс (m)	Node No.	NA3 (MN)	DCD (MN)	Ratio (NA3/DCD)	NA3 (MN)	DCD (MN)	Ratio (NA3/DCD)
13.80	6	42.68	33.10	1.29	40.16	29.14	1.38
9.06	5	42.68	33.10	1.29	40.16	29.14	1.38
9.06	5	77.90	53.35	1.46	70.07	54.75	1.28
4.65	4	77.90	53.35	1.46	70.07	54.75	1.28
4.65	4	101.02	75.57	1.34	91.19	80.11	1.14
-2.00	3	101.02	75.57	1.34	91.19	80.11	1.14
-2.00	3	40.98	124.35	0.33	44.77	99.44	0.45
-7.40	2	40.98	124.35	0.33	44.77	99.44	0.45
-7.40	2	26.86	111.89	0.24	20.86	112.78	0.18
-10.40	1	26.86	111.89	0.24	20.86	112.78	0.18

#### Table A-1 Design Seismic Shear Loads for Horizontal

Note: Obtained from Reference 2.1.2-1, based on site-specific Seismic Analysis of Control Building in Reference 2.1.2-k

EI		NS-direction			EW-direction		
сс (m)	Node No.	NA3 (MN-m)	DCD (MN-m)	Ratio (NA3/DCD)	NA3 (MN-m)	DCD (MN-m)	Ratio (NA3/DCD)
13.80	6	109.76	160.05	0.69	86.07	124.05	0.69
9.06	5	276.32	250.07	1.10	226.02	196.72	1.15
9.06	5	359.79	359.61	1.00	292.54	274.88	1.06
4.65	4	684.74	572.61	1.20	561.86	443.07	1.27
4.65	4	381.88	723.05	0.53	204.46	540.35	0.38
-2.00	3	1053.35	1135.62	0.93	736.10	987.53	0.75
-2.00	3	566.89	1231.72	0.46	510.74	1035.59	0.49
-7.40	2	770.80	1570.05	0.49	693.16	1524.94	0.45
-7.40	2	338.05	1601.43	0.21	198.89	1560.25	0.13
-10.40	1	257.43	1839.74	0.14	136.22	1855.43	0.07

Table A-2 Design Seismic Moment Loads for Horizontal

Note: Obtained from Reference 2.1.2-1, based on site-specific Seismic Analysis of Control Building in Reference 2.1.2-k



WG3-U73-ERD-S-0004	SH NO.181
REV. 2	of 219

=		Calculated Torsion		Accidental Torsion		Design Torsion				
(m)	Node No.	NA3 (MN-m)	DCD (MN-m)	Ratio (NA3/DCD)	NA3 (MN-m)	DCD (MN-m)	Ratio (NA3/DCD)	NA3 (MN-m)	DCD (MN-m)	Ratio (NA3/DCD)
13.80	6	27.53	23.09	1.19	64.67	50.14	1.29	92.20	73.24	1.26
9.06	5	27.53	23.09	1.19	64.67	50.14	1.29	92.20	73.24	1.26
9.06	5	57.73	44.86	1.29	118.02	82.95	1.42	175.75	127.80	1.38
4.65	4	57.73	44.86	1.29	118.02	82.95	1.42	175.75	127.80	1.38
4.65	4	51.22	56.88	0.90	153.04	121.37	1.26	204.26	178.25	1.15
-2.00	3	51.22	56.88	0.90	153.04	121.37	1.26	204.26	178.25	1.15
-2.00	3	26.91	59.85	0.45	67.83	188.39	0.36	94.74	248.24	0.38
-7.40	2	26.91	59.85	0.45	67.83	188.39	0.36	94.74	248.24	0.38
-7.40	2	0.00	54.79	0.00	40.70	170.86	0.24	40.70	225.65	0.18
-10.40	1	0.00	54.79	0.00	40.70	170.86	0.24	40.70	225.65	0.18

# Table A-3 Design Seismic Torsion Loads

Note: Obtained from Reference 2.1.2-l, based on site-specific Seismic Analysis of Control Building in Reference 2.1.2-k



I

.

WG3-U73-ERD-S-0004	SH NO.182
REV. 2	of 219

Table A-4 Ver tical Acceler ation						
EL	Node	NA3	DCD	Ratio		
(m)	No.	(g)	(g)	(NA3/DCD)		
13.80	6	1.05	1.00	1.05		
9.06	5	0.95	0.86	1.11		
4.65	4	0.82	0.74	1.10		
-2.00	3	0.60	0.56	1.06		
-7.40	2	0.64	0.51	1.26		
-10.40	1	0.63	0.51	1.25		
13.80	9001	2.20	2.19	1.00		
	9002	2.09	1.34	1.56		
	9003	2.00	1.43	1.40		
	9004	2.08		_		
9.06	9101	2.08	2.00	1.04		
	9102	1.62	1.26	, 1.28		
	9103	2.00	1.43	1.40		
	9104	1.93		-		
4.65	9201	1.53	1.30	1.18		
	9202	1.73	1.43	1.21		
	9203	1.75	—	-		
-2.00	9301	1.32	1.39	0.95		
	9302	1.28	_	-		

#### **Table A-4 Vertical Acceleration**

Note: Obtained from Reference 2.1.2-l, based on site-specific Seismic Analysis of Control Building in Reference 2.1.2-k The node numbers in this table are described in Figure 5.6-1.

;

A.



WG3-U73-ERD-S-0004	SH NO.183
REV. 2	of 219

Table A-5	Dynamic	Soil	Pressures
-----------	---------	------	-----------

.

Pressure on C1 and C5 Walls

EL (m)	H (m)	NA3 (MN/m²)	DCD (MN/m²)	Ratio (NA3/DCD)
4.650 4.300	0.350			
3.950	0.350 1.830			
2.120	2.190	0.12	0.22	0.54
-2.000	1.930			
-2.250	0.250			
-2.500 -3.965	1.465			
-5.685	1.720 1.715	0.28	0.18	1.51
-7.400 -9.900	2.500	0.31	0.19	1.63
-10.400	0.500			

Pressures on CA and CD Walls

EL. (m)	H (m)	NA3 (MN/m²)	DCD (MN/m²)	Ratio (NA3/DCD)
4.650 4.300 3.950 2.120 -0.070 -2.000	0.350 0.350 1.830 2.190 1.930	0.12	0.22	0.52
-2.250	0.250			
-2.500 -3.965 -5.685	0.250 1.465 1.720 1.715	0.23	0.18	1.24
-7.400 -9.900 -10.400	2.500 0.500	0.28	0.19	1.48

Note: Obtained from Reference 2.1.2-1, based on site-specific Seismic Analysis of Control Building in Reference 2.1.2-k



WG3-U73-ERD-S-0004	SH NO.184
REV. 2	of 219

		Concrete										
Location	Element	NA3		C	CD	Ratio						
	ID	$\sigma/\sigma_a$ Load ID		σ/σa	Load ID							
Basemat	67	0.228	7011	0.281	7011	0.81						
EL-7.4(1)	72	0.367	7011	0.512	7011	0.72						
	115	0.234	7011	0.310	7011	0.76						
	120	0.254	7011	0.250	7011	1.02						
SlabB1F	567	0.340	7021	0.493	7011	0.69						
LL-2.011	572	0.217	7021	0.265	7001	0.82						
	615	0.345	7021	0.356	7011	0.97						
	620	0.337	7001	0.355	7021	0.95						
Slab 1F	1067	0.751	7001	0.635	7001	1.18						
EL4.05/11	1072	0.361	7001	0.325	7001	1.11						
	1115	0.606	7001	0.587	7001	1.03						
	1120	0.335	7021	0.364	7021	0.92						
Slab 2F	1567	0.417	7001	0.396	7001	1.05						
EL9.00III	1572	0.278	7021	0.266	7021	1.05						
	1615	0.413	7001	0.439	7001	0.94						
	1620	0.643	7021	0.611	7021	1.05						
Slab RF	1867	0.465	7021	0.550	7021	0.84						
EL 13.0III	1872	0.154	4023	0.154	4023	1.00						
	1915	0.336	7011	0.305	7011	1.10						
	1920	0.523	7021	0.512	7021	1.02						



WG3-U73-ERD-S-0004	SH NO.185
REV. 2	of 219

#### Table A-6 Maximum Stress Ratios (Basemat and Slabs) for Flexure and Membrane Forces (Continued)

		-	Primary Reinforcement																		
Location	Element		NS direction									EW direction									
				Тор					Botto	m		Top Bottom									
		NA	\3	DC	D	Ratio	NA	\3	DC	D	Ratio	NA	\3	DC	D.	Ratio	N/	13	DC	D	Ratio
_	D	σ/σa	Load ID	σ/σ <sub>a</sub>	Load ID	(NA3/DCD)	σ/σ <sub>a</sub>	Load ID	σ/σ <sub>a</sub>	Load ID	(NA3/DCD)	σ/σ <sub>a</sub>	Load ID	σ/σ <sub>a</sub>	Load ID	(NA3/DCD)	σ/σa	Load ID	σ/σa	Load ID	(NA3/DCD)
Basemat	67	0.058	7011	0.060	7011	0.98	0.095	7021	0.088	7501	1.08	0.087	7011	0.111	7011	0.78	0.078	7021	0.256	7501	0.30
CL-7,400	72	0.084	7011	0.106	7011	0.79 .	0.370	7021	0.568	7521	0.65	0.207	7501	0.575	7501	0.36	0.434	7521	0.795	7521	0.55
	115	0.129	7501	0.549	7501	0.24	0.292	7521	0.398	7521	0.74	0.063	7501	0.655	7501	0.10	0.041	7501	0.047	7501	0.87
	120	0.062	7021	0.072	7501	0.86	0.078	7021	0.053	7011	1.48	0.048	7021	0.195	7501	0.25	0.096	7021	0.053	7021	1.83
SlabB1F	567	0.041	7021	0.109	7501	0.38	0.091	7011	0.282	7501	0.32	0.374	7011	0.669	7011	0.56	0.221	7501	0.599	7501	0.37
EL-2,0/()	572	0.080	3004	0.092	7521	0.87	0.084	3002	0.119	7511	0.70	0.025	7021	0.054	7501	0.45	0.067	7011	0.080	7501	0.84
	615	0,185	7011	0.282	7501	0.66	0.075	7501	0.292	7501	0.26	0.216	7011	0.310	7501	0.70	0.100	7501	0.488	7501	0.20
	620	0.418	7001	0.303	7001	1.38	0.089	7001	0.091	7021	0.98	0.480	7001	0.382	3004	1.26	0.082	7001	0.105	7501	0.78
Slab 1F	1067	0.078	4022	0.113	7021	0.69	0.527	7011	0.332	7011	1.59	0.024	4024	0.155	7501	0.16	0.185	7011	0.221	7511	0.84
EL4.65M	1072	0.131	7001	0,192	7501	0.68	0.074	3002	0.238	7511	0.31	0,084	7021	0.142	7501	0.59	0.063	4022	0.120	7511	0.52
	1115	0.155	4014	0.155	4014	1.00	0.052	4014	0.145	7501	0.36	0.581	7001	0.421	3002	1.38	0.092	7011	0.212	7521	0.44
	1120	0.211	4013	0.211	4013	1.00	0.071	7501	0.125	7511	0.57	0.224	4012	0.224	4012	1.00	0.113	7501	0.132	7501	0.85
Slab 2F	1567	0.119	7021	0.114	7021	1.04	0.368	7001	0.350	7001	1.05	0.037	4012	0.039	7511	0.95	0.130	4014	0.130	4014	1.00
EL9.06m	1572	0.371	7001	0.331	7001	1.12	0.083	7501	0.073	7501	1.14	0.160	7501	0.156	7501	1.02	0.166	7501	0.156	7501	1.06
	1615	0.325	7001	0.330	7001	0.99	0.179	7001	0.165	7001	1.08	0.572	7001	0.539	7001	1.06	0.107	7521	0.076	7521	1.40
	1620	0.270	7021	0.259	7021	1.04	0.170	7021	0.171	7021	0.99	0.276	7021	0.263	7021	1.05	0.167	7021	0.165	7021	1.02
Slab RF	1867	0.215	7521	0.201	7521	1.07	0.369	7021	0.348	7021	1.06	0.213	7021	0.204	7021	1.05	0.091	7021	0.082	4012	1.11
EL13.8m	1872	0.428	7021	0.390	7021	1.10	0.174	7021	0.134	7021	1.30	0.529	7021	0.490	7021	1.08	0.238	7011	0.204	7011	1.17
	1915	0.533	7021	0.474	7021	1.12	0.311	7501	0.257	7501	1.21	0.528	7021	0.458	7021	1.15	0.188	7501	0.146	7501	1.29
	1920	0.373	7021	0.370	7021	1.01	0.087	7511	0.079	7511	1.11	0.413	7021	0.407	7021	1.02	0.076	7511	0.073	4014	1.04



WG3-U73-ERD-S-0004	SH NO.186
REV. 2	of 219

		Concrete										
Location	Element		NA3	ſ	DCD	Ratio (NA3/DCD)						
	ID	σ/σ <sub>a</sub>	Load ID	σ/σa	Load ID							
Wall	6007	0.339	7021	0.397	7021	0.85						
EL-7.4m	4006	0,506	7011	0.512	7011	0.99						
- <u>EL-2.011</u>	4010	0.402	7011	0.423	7011	0.95						
Wall	6043	0.315	7021	0.429	7011	0.73						
EL-2.0m	4036	0.282	7001	0.227	7001	1.24						
	4040	0.317	7011	0.320	7011	0.99						
Wall	6081	0.267	7021	0.395	7021	0.68						
EL4.65m	4066	0.538	7021	0.581	7021	0.93						
CL9.00III	4070	0.320	4023	0.320	4023	1.00						
Wall	6117	0.600	7021	0.605	7021	0.99						
EL9.06m	4096	0.517	7021	0.484	7021	1.07						
2210.00	4100	0.436	7021	0.376	7021	1.16						

#### Table A-7 Maximum Stress Ratios (Walls) for Flexure and Membrane Forces

#### Table A-7 Maximum Stress Ratios (Walls) for Flexure and Membrane Forces (Continued)

			Primary Reinforcement																		
Location	Element					Horizontal	direction	1								Vertical	direction	1			•
				Inside	;				Outsi	de				Insid	е		Outside				
		N	A3	DC	D	Ratio	N/	43	DC	D	Ratio	N/	43	DC	D	Ratio	N/	43	DC	D:	Ratio
	ID	σ/σ <sub>a</sub>	Load	σ/σa	Load ID	(NA3/DCD)	σ/σa	Load ID	σίσα	Load ID	(NA3/DCD)	σ/σa	Load ID	σ/σa	Load ID	(NA3/DCD)	σ/σa	Load ID	σ/σa	Load ID	(NA3/DCD)
Wall	6007	0.092	7501	0.327	7501	0.28	0.315	7521	0.585	7521	0.54	0.075	7501	0.372	7501	0.20	0.370	7021	0.664	7521	0.56
~EL-2.0m	4006	0.213	7501	0.399	7501	0.53	0.348	7511	0.551	7511	0.63	0.189	7501	0.425	7501	0.44	0.457	7511	0.783	7511	0.58
	4010	0.170	7501	0.226	7501	0.75	0.478	7021	0.540	7021	0.89	0.166	7501	0.286	7501	0.58	0.609	7021	0.728	7021	0.84
Wall FL-2.0m	6043	0.290	7501	0.256	7501	1.13	0.590	7011	0.538	7011	1.10	0.421	7501	0.337	7501	1.25	0.445	7011	0.342	7011	1.30
~EL4.65m	4036	0.286	7501	0.304	7501	0.94	0.408	7011	0.348	7011	1.17	0.484	7511	0.486	7511	1.00	0.462	7501	0.452	7501	1.02
	4040	0.239	7511	0.266	7521	0.90	0.380	7011	0.405	7011	0.94	0.510	7521	0.411	7521	1.24	0.399	7521	0.307	7521	1.30
Wall EL4.65m	6081	0.295	7501	0.249	7501	1.18	0.532	7021	0.486	7021	1.10	0.385	7511	0.372	7511	1.03	0.421	7501	0.423	7501	1.00
~EL9.06m	4066	0.235	7521	0.202	7501	1.16	0.540	7021	0.530	7021	1.02	0.221	7501	0.274	7501	0.81	0.508	7521	0.494	7021	1.03
	4070	0.320	7021	0.302	7021	1.06	0.505	7021	0.493	7021	1.02	0.233	7501	0.204	7501	1.14	0.611	7021	0.569	7021	1.07
Wali EL9.06m	6117	0.366	7501	0.328	7501	1.12	0.642	7021	0.591	7021	1.09	0.345	7511	0.295	7511	1.17	0.395	7021	0.377	7521	1.05
~EL13.8m	4096	0.322	7501	0.246	7501	1.31	0.489	7021	0.435	7021	1.13	0.331	7511	0.250	7511	1.32	0.486	7021	0.385	7021	1.26
	4100	0.281	7011	0.234	7011	1.20	0.485	7021	0.450	7021	1.08	0.278	7011	0.248	7011	1.12	0.685	7021	0.630	7021	1.09



WG3-U73-ERD-S-0004	SH NO.187
REV. 2	of 219

		Thickness			NA3					DCD		Ratio					
Location	Element			Cal	culated Co (M	oncrete St Pa)	ress		Calcu	lated Co (M	oncrete Pa)	Stress	(NA3/DCD)				
	ID	h	Load	σχ	σγ	τ <sub>xy</sub>	σ	Load	σχ	σγ	τ <sub>xy</sub>	σc	σχ	σγ	τχγ	σc	
		(m)	ID					ID					,				
Basemat	67	3,0	3004	1.0	1.1	0.0	1.1	7011	0.9	1.4	0.2	1.5	1.20	0.81	-0.11	0.76	
CC-7.401	72	3.0	3001	1.3	0.3	0.0	1.3	7001	0.8	1.4	-0.7	1.9	1.57	0.23	0.03	0.70	
	115	3.0	7001	1.9	0.6	-0.5	2.0	7001	1.9	0.6	-1.0	2.5	0.97	0.97	0.51	0.83	
	120	3.0	3004	1.0	0.5	-0.1	1.0	3004	1.0	0.5	-0.1	1.0	1.00	1.00	1.00	1.00	
SlabB1F EL-2.0m	567	0.5	3002	3.4	0.7	0.0	3.4	3002	3.4	0.7	0.0	3.4	1.00	1.00	1.00	1.00	
L,L-2,011	572	0.5	3004	5.2	2.1	0.4	5.2	3004	5.2	2.1	0.4	5.2	1.00	1.00	1.00	1.00	
	615	0.5	7021	3.5	1.1	-2.2	4.8	7021	3.3	1.4	-2.2	4.8	1.07	0.78	0.99	1.01	
	620	0.5	3004	2.4	1.2	3.1	5,0	3004	2.4	1.2	3.1	5.0	1.00	1.00	1.00	1.00	
Slab 1F EL4 65m	1067	0.5	4022	2.6	1.1	0.0	2.6	4022	2.6	1.1	0.0	2.6	1.00	1.00	1.00	1.00	
EE4.0011	1072	0.5	7021	2.1	4.4	-0.5	4.5	7021	2.2	4.7	-0.6	4.8	0.94	0.94	0.73	0.93	
	1115	0.5	7021	3.8	0.5	0.9	4.0	7021	3.9	0.6	1.0	4.2	0.96	0.84	0.94	0.96	
	1120	0.5	7021	4.8	4.3	-4.1	8.6	7021	4.8	4.3	-4.1	8.7	1.00	0.99	0.98	0.99	
Slab 2F Fl 9 06m	1567	0.5	7021	5.2	2.2	-0.1	5.2	7021	5.2	2.2	-0.1	5.2	1.00	1.01	1.03	1.00	
	1572	0.5	7021	1.8	7.6	-1.1	7.8	7021	1.5	7.6	-1.0	7.7	1.16	1.00	1.12	1.01	
	1615	0.5	7021	6.6	-1.0	-0.4	6.6	7021	6.4	-1.0	-0.4	6.4	1.03	1.08	0.97	1.03	
	1620	0.5	7021	6.6	6.6	-8.2	14.8	7021	6.5	6.5	-8.0	14.5	1.02	1.01	1.03	1.02	
Slab RF EL 13 8m	1867	0.7	7001	0.3	0.3	-0.1	0.4	7001	0.3	0.2	-0.1	0.4	1.08	1.08	1.23	1.12	
	1872	0.7	7001	0.7	1.4	-0.9	2.0	7001	0.6	1.2	-0.7	1.7	1.19	1.12	1.32	1.21	
	1915	0.7	7001	2.0	0.8	-0.7	2.3	7001	1.8	0.6	-0.5	2.0	1.14	1.20	1.35	1.18	
	1920	0.7	7021	0.5	0.7	0.7	1.3	7021	0.4	0.6	0.6	1.1	1.25	1.13	1.14	1.15	
Wall EL-7.4m	6007	0.9	7001	2.3	1.9	-2.3	4.4	7001	2.6	2.6	-4.0	6.6	0.91	0.72	0.56	0.66	
~EL-2.0m	4006	0.9	7001	1.3	2.2	-1.3	3.2	7001	1.6	3.6	-2.4	5.3	0.83	0.60	0.55	0.60	
	4010	0,9	7001	0.9	1.6	-1.0	2.3	7001	0.9	2.1	-1.4	3.0	1.00	0.78	0.73	0.78	
Wall E12.0m	6043	0.9	7001	1.6	2.8	-3.1	5.4	7001	1.6	3.1	-2.8	5.2	0.98	0.91	1.14	1.04	
~EL4.65m	4036	0.9	7001	1.5	1.7	2.4	3.9	7001	1.5	2.5	2.2	4.3	1.01	0.66	1.06	0.92	
	4040	0.9	7001	1.0	3.2	2.6	4.9	7001	0.9	2.5	2.5	4.3	1.08	1.24	1.04	1.13	
Wall EL4.65m	6081	0.9	7011	3.1	1.6	2.1	4.6	7011	3.2	1.6	1.6	4.2	0.99	1.01	1.34	1.11	
~EL9.06m	4066	0.9	7011	2.9	1.0	2.0	4.2	7011	3.3	1.1	1.6	4.1	0.89	0.93	1.26	1.02	
	4070	0.9	7011	1.9	1.8	3.2	5.0	7011	2.0	1.4	3.0	4.7	0,95	1.24	1.06	1.06	
Wall EL9,06m	6117	0.7	7001	1.3	1.4	1.3	2.6	7001	1.2	1.4	1.1	2.4	1.10	0.99	1.19	1.11	
~EL13.8m	4096	0.7	7001	1.1	0.8	1.4	2.4	4012	2.7	0.1	0.1	2.7	0.39	6.03	10.89	0.87	
1	4100	0.7	7001	0.2	0.7	1.5	2.0	7001	0.2	0.6	1.3	1.7	1.29	1.03	1.18	1.15	

#### Table A-8 Maximum Stress Ratios for Membrane Compressive Forces

Note: Compressive forces are positive.



I

WG3-U73-ERD-S-0004	SH NO.188
REV. 2	of 219

Logition	Element		NA3			DCD		σ <sub>c</sub> /σ <sub>a</sub>				
Location	D	Load	σ	σa	Load			NA2	DCD	Ratio		
	_	ID	(MPa)	(MPa)	ID	(MPa)	(MPa)	NAJ		(NA3/DCD)		
Basemat	67	3004	1.1	16.6	7011	1.5	20.7	0.07	0.07	0.95		
	72	3001	1.3	16.6	7001	1.9	16.6	0.08	0.11	0.70		
	115	7001	2.0	16.6	7001	2.5	16.6	0.12	0.15	0.83		
	120	3004	1.0	16.6	3004	1.0	16.6	0.06	0.06	1.00		
SlabB1F	567	3002	3.4	20.7	3002	3.4	20.7	0.16	0.16	1.00		
LL-2.011	572	3004	5.2	20.7	3004	5.2	20.7	0.25	0.25	1.00		
	615	7021	4.8	25.9	7021	4.8	25.9	0.19	0.18	1.01		
	620	3004	5.0	20.7	3004	5.0	20.7	0.24	0.24	1.00		
Slab 1F	1067	4022	2.6	25.9	4022	2.6	25.9	0.10	0.10	1.00		
EL4.00m	1072	7021	4.5	25.9	7021	4.8	25.9	0.17	0.19	0.93		
	1115	7021	4.0	25.9	7021	4.2	25.9	0.15	0.16	0.96		
	1120	7021	8.6	25.9	7021	8.7	25.9	0.33	0.34	0.99		
Slab 2F	1567	7021	5.2	25.9	7021	5.2	25.9	0.20	0.20	1.00		
EL9.00m	1572	7021	7.8	25.9	7021	7.7	25.9	0.30	0.30	1.01		
	1615	7021	6.6	25.9	7021	6.4	25.9	0.25	0.25	1.03		
	1620	7021	14.8	25.9	7021	14.5	25.9	0.57	0.56	1.02		
Slab RF	1867	7001	0.4	20.7	7001	0.4	20.7	0.02	0.02	1.12		
	1872	7001	2.0	20.7	7001	1.7	20.7	0.10	0.08	1.21		
	1915	7001	2.3	20.7	7001	2.0	20.7	0.11	0.10	1.18		
	1920	7021	1.3	25.9	7021	1.1	25.9	0.05	0.04	1.15		
Wall	6007	7001	4.4	20.7	7001	6.6	20.7	0.21	0.32	0.66		
~EL-2.0m	4006	7001	3.2	20.7	7001	5.3	20.7	0.15	0.25	0.60		
	4010	7001	2.3	20.7	7001	3.0	20.7	0.11	0.14	0.78		
Wall	6043	7001	5.4	20.7	7001	5.2	20.7	0.26	0.25	1.04		
~EL4.65m	4036	7001	3.9	20.7	7001	4.3	20.7	0.19	0.21	0.92		
	4040	7001	4.9	20.7	7001	4.3	20.7	0.23	0.21	1.13		
Wall	6081	7011	4.6	25.9	7011	4.2	25.9	0.18	0.16	1.11		
~EL9.06m	4066	7011	4.2	25.9	7011	4.1	25.9	0.16	0.16	1.02		
	4070	7011	5.0	25.9	7011	4.7	25.9	0.19	0.18	1.06		
Wall	6117	7001	2.6	20.7	7001	2.4	20.7	0.13	0.11	1.11		
~EL13.8m	4096	7001	2.4	20.7	4012	2.7	25.9	0.12	0.11	1.09		
	4100	7001	2.0	20.7	7001	1.7	20.7	0.10	0.08	1.15		

# Table A-8 Maximum Stress Ratios for Membrane Compressive Forces (Continued)

Note: Compressive forces are positive.



WG3-U73-ERD-S-0004	SH NO.189
REV. 2	of 219

	Flomont		N	A3			D	CD	
Location	Ciement	Load	d	ρw	ρν	Load	d	ρw	ρv
	ID	ID	(m)	(%)	(%)	ID	(m)	(%)	(%)
Basemat	67	7011	2.744	0.366	0.177	7001	2.818	0.357	0.177
EL-7.4m	72	7011	2.719	0.370	0.000	7011	2.721	0.369	0.177
	115	7521	2.743	0.366	0.177	7521	2.799	0.359	0.177
	120	7021	2.734	0.368	0.177	7021	2.734	0.368	0.177
Slab B1F	567	7001	0.372	1.359	0.000	7501	0.407	1.242	0.000
EL-2.0m	572	7001	0.360	1.402	0.000	7001	0.360	1.402	0.000
	615	7011	0.363	1.390	0.000	7011	0.368	1.373	0.000
	620	7001	0.393	1.286	0.000	7001	0.392	1.288	0.000
Slab 1F	1067	7011	0.379	1.332	0.000	7011	0.379	1.333	0.000
EL4.65m	1072	7001	0.360	1.402	0.000	7001	0.360	1.402	0.000
	1115	7011	0.410	1.232	0.000	7011	0.410	1.232	0.000
	1120	7001	0.382	1.322	0.000	7001	0.382	1.321	0.000
Slab 2F	1567	7011	0.373	1.352	0.000	7011	0.373	1.356	0.000
EL9.06m	1572	7001	0.360	1.403	0.000	7001	0.360	1.403	0.000
	1615	7011	0.410	1.233	0.081	7011	0.410	1,232	0.081
	1620	7001	0.389	1.298	0.000	7001	0.389	1.297	0.000
Slab RF	1867	7021	0.511	1.479	0.000	7021	0.511	1.479	0.000
EL13.8m	1872	7021	0.500	1.511	0.000	7021	0.501	1.510	0.000
	1915	7021	0.550	1.375	0.323	7021	0.550	1.375	0.000
	1920	7011	0.529	1.428	0.000	7011	0.529	1.429	0.000
Wall	6007	7021	0.676	1.491	0.355	7021	0.677	1.489	0.355
~EL-7.4m	4006	7021	0.672	1.500	0.355	7521	0.672	1.500	0.355
	4010	7021	0.673	1.498	0.355	7021	0.673	1.497	0.355
Wall	6043	7011	0.674	1.495	0.355	7501	0.673	1.499	0.355
~EL-2.0m	4036	4013	0.672	1.500	0.710	4013	0.672	1.500	0.710
	4040	7011	0.682	1.478	0.355	7011	0.683	1.476	0.355
Wall	6081	7021	0.673	1.497	0.000	7021	0.673	1.497	0.000
~EL4.65m	4066	7021	0.672	1.500	0.000	7021	0.672	1.499	0.000
	4070	7521	0.694	1.452	0.000	7521	0.699	1.442	0.000
Wall	6117	7021	0.493	1.533	0.000	7021	0.493	1.533	0.000
~EL9.06m	4096	7021	0.493	1.533	0.000	7021	0.493	1.533	0.000
	4100	7521	0.507	1.492	0.000	7521	0.507	1.490	0.000

Table A-9 Calculation Results for Maximum Transverse Shear



I

WG3-U73-ERD-S-0004	SH NO.190
REV. 2	of 219

•

	Flomont				NA3			DCD Load Shoar Earoos (MN/m)								Ratio	;D)					
Location	Clement	Load		Shear Fo	rces (MN	/m)		Load Shear Forces (MN/m)							I	(NA3/DC	D)					
	D	ID	Vu	Vc	Vs	φVn	Vu/φVn	ID	Vu	V <sub>c</sub>	V <sub>s</sub>	φVn	Vu∕∳Vn	Vu	Vc	Vs	φVn	V <sub>u</sub> /φV <sub>n</sub>				
Basemat	67	7011	1.594	4.868	2.011	5.847	0.273	7001	3.159	3.751	2.065	4.943	0.639	0.50	1.30	0.97	1.18	0.43				
EL-7.4m	72	7011	1.520	2.499	1.992	3.818	0.398	7011	2.419	2.460	1.994	3.786	0.639	0.63	1.02	1.00	1.01	0.62				
	115	7521	0.905	2.370	2.010	3.723	0.243	7521	1.654	1.917	2.051	3.373	0.490	0.55	1.24	0.98	1.10	0,50				
	120	7021	1.974	3.505	2.003	4.682	0.422	7021	2.441	4.552	2.003	5.572	0.438	0.81	0.77	1.00	0.84	0.96				
Slab B1F	567	7001	0.179	0.746	0.000	0.634	0.282	7501	0.118	0.236	0.000	0.200	0.587	1.52	3.17	-	3.17	0.48				
EL-2.0m	572	7001	0.187	0.891	0.000	0.757	0.247	7001	0.185	0.884	0.000	0.752	0.246	1.01	1.01	-	1.01	1.00				
	615	7011	0.128	0,764	0.000	0.649	0.197	7011	0.152	0.438	0.000	0.372	0.409	0.84	1.74	-	1.74	0.48				
	620	7001	0.111	0.178	0.000	0.151	0.735	7001	0.125	0.262	0.000	0.223	0.559	0.89	0.68	-	0.68	1.31				
Slab 1F	1067	7011	0.082	0.360	0.000	0.306	0.269	7011	0.077	0.360	0.000	0.306	0.250	1.07	1.00	-	1.00	1.08				
EL4.65m	1072	7001	0.216	0.593	0.000	0.504	0.428	7001	0.207	0.688	0.000	0.584	0.355	1.04	0.86	-	0.86	1.21				
	1115	7011	0.340	0.415	0.000	0.353	0.965	7011	0.318	0.416	0.000	0.353	0.899	1.07	1.00	-	1.00	1.07				
	1120	7001	0.107	0.330	0.000	0.280	0.383	7001	0.108	0.323	0.000	0.275	0.394	0.99	1.02	-	1.02	0.97				
Slab 2F	1567	7011	0.046	0.355	0.000	0.302	0.153	7011	0.045	0.354	0.000	0.301	0.150	1.02	1.00	-	1.00	1.02				
EL9.06m	1572	7001	0.180	0.276	0.000	0,234	0.769	7001	0.172	0.300	0.000	0.255	0.676	1.05	0.92	-	0.92	1.14				
	1615	7011	0.321	0.300	0.137	0.372	0.865	7011	0.303	0.308	0.137	0.379	0.799	1.06	0.97	1.00	0.98	1.08				
	1620	7001	0.082	0.418	0.000	0.355	0.231	7001	0.076	0.405	0.000	0.345	0.220	1.08	1.03	-	1.03	1.05				
Slab RF	1867	7021	0.064	0.409	0.000	0.347	0.185	7021	0.065	0.411	0.000	0.350	0.186	0.99	0.99	-	0.99	1.00				
EL13.8m	1872	7021	0.125	0.318	0.000	0.270	0.463	7021	0.121	0.329	0.000	0.280	0.433	1.03	0.96	-	0.96	1.07				
	1915	7021	0.339	0.388	0.184	0.486	0.698	7021	0.317	0.411	0.000	0.350	0.908	1.07	0.94	-	1.39	0.77				
	1920	7011	0.078	0.519	0.000	0.441	0.177	7011	0.072	0.518	0.000	0.441	0.164	1.08	1.00	-	1.00	1.08				
Wali	6007	7021	0.512	1.489	0.994	2.110	0.242	7021	0.464	1.722	0.995	2.309	0.201	1.10	0.87	1.00	0.91	1.21				
EL-7.4m ~El-2.0m	4006	7021	1.481	1.225	0,988	1,881	0.787	7521	0.546	0.247	0.988	1.050	0.520	2.71	4.95	1.00	1.79	1.51				
	4010	7021	0.702	0.479	0.989	1.247	0.563	7021	0.629	0.427	0.989	1.203	0.523	1.12	1.12	1.00	1.04	1.08				
Wall	6043	7011	0.745	1.744	0.991	2.324	0.321	7501	0.407	0.461	0.989	1.233	0.330	1.83	3.78	1.00	1.89	0.97				
~EL-2.0m ~EL4.65m	4036	4013	0.791	0.654	1.975	2.235	0.354	4013	0.791	0.654	1.975	2.235	0.354	1.00	1.00	1.00	1.00	1.00				
	4040	7011	0.593	1.202	1.002	1.874	0.317	7011	0.635	0.873	1.004	1.595	0.398	0.94	1.38	1.00	1.17	0.80				
Wall	6081	7021	0.291	1.494	0.000	1.270	0.229	7021	0.316	1.047	0.000	0.890	0.355	0.92	1.43	-	1.43	0.65				
~EL9.06m	4066	7021	0.191	0.681	0.000	0.579	0.330	7021	0.222	0.679	0.000	0,577	0.384	0.86	1.00	-	1.00	0,86				
	4070	7521	0.117	0.300	0.000	0.255	0.458	7521	0.111	0.294	0.000	0.250	0.445	1.05	1.02	-	1.02	1.03				
Wall	6117	7021	0.412	0.562	0.000	0.478	0.863	7021	0.401	0.564	0.000	0.480	0.835	1.03	1.00	-	1.00	1.03				
~EL13.8m	4096	7021	0.472	0.623	0.000	0.530	0.892	7021	0.470	0.626	0.000	0.532	0.883	1.01	1.00	-	1.00	1.01				
	4100	7521	0.127	0.284	0.000	0.242	0.526	7521	0.139	0.309	0.000	0.262	0.529	0.92	0.92	-	0.92	0,99				

#### Table A-9 Calculation Results for Maximum Transverse Shear (Continued)



WG3-U73-ERD-S-0004	SH NO.191
REV. 2	of 219

#### Table A-10 Maximum Stress Ratio of Selected Columns at the rows CB and C2, X-direction

Member	Name :C2	-CB-Colu	imn-B2F (	(top)											
Section II	D :5002		Sec	tion Type	:BOX										CBAR ID :50006
Flange P	L :800 x 7	0	We	b PL :660	x 70										j- edge
						NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress		Allo	wable Stre	ss	Load		_	Load			
(N	/IN, MNm)	)		(MPa)			(MPa)		ID ID	Maximum R	latio	ID	Maximum Ra	atio	Maximum Ratio
Р	М		f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub> _	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	Fv							
-20.42	-0.54		-99.9	-11.8		315.4	386.8		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.513	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.517	0.99
0.16	0.18		0.8	4.0		330.9	364.0		5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.013		f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>		
L	Į _	0.12			1.1	_		193.1	8101	f <sub>v</sub> /F <sub>v</sub>	0.006	8101	f <sub>v</sub> /F <sub>v</sub>	0.009	0.63

Member	Name :C2	-CB-Colu	ımn-B2F (	(bot)											
Section II	D :5002		Sec	tion Type	:BOX										CBAR ID :50006
Flange P	L :800 x 7	0	We	b PL :660	x 70										i- edge
						NA3							DCD	-	Ratio(NA3/DCD)
De	esign Load	ł		Stress		Allo	owable Stre	ess	Load			Load			
(1	۸N, MNm)	)		(MPa)			(MPa)		ID	Maximum R	Ratio	ID	Maximum R	atio	Maximum Ratio
Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	F,							
-20.42	0.00		-99.9	0.0		315.4	386.8		8201	-fac/Fac+fbc/Fbc	0.483	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.465	1.04
0.16	0.00		0.8	0.0		330.9	364.0		5601	f <sub>at/</sub> F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.002		f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>		
		0.12			1.1			193.1	8101	f₀/F₀	0.006	8101	f <sub>v</sub> /F <sub>v</sub>	0.009	0.63

Member	Name :C2	2-CB-Colu	ımn-B1F i	(top)				-							
Section II	D :6002		Sec	tion Type	:BOX										CBAR ID :60003
Flange P	L :800 x 7	'0	We	b PL :660	x 70										j- edge
						NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress		Allo	owable Stre	ess	Load			Load			
۸)	/N, MNm	)		(MPa)			(MPa)		ID	Maximum F	Ratio	ID	Maximum R	atio	Maximum Ratio
Р	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	F <sub>v</sub>	]						
-17.37	1.60		-85.0	34.8		309.6	386.8		8201	fa/Fac+fbc/Fbc	0.501	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.472	1.06
1.03	0.10	}	5.0	2.1		330.9	364.0		5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.021	5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.022	0.97
		-0.37			-3.3	1		193.1	5001	f <sub>v</sub> /F <sub>v</sub>	0.017	5001	f <sub>v</sub> /F <sub>v</sub>	0.014	1.25



WG3-U73-ERD-S-0004	SH NO.192
REV. 2	of 219

#### Table A-10 Maximum Stress Ratio of Selected Columns at the rows CB and C2, X-direction (Continued)

Member N	Name :C2	2-CB-Colu	ımn-B1F	(bot)											
Section II	) :6002		Sec	tion Type	:BOX										CBAR ID :60003
Flange Pl	L :800 x 7	0	We	b PL :660	x 70										i- edge
						NA3							DCD	-	Ratio(NA3/DCD)
De	sign Loa	ď		Stress		Allc	wable Stre	SS	Load			Load			
(N	N, MNm	)		(MPa)			(MPa)		ID	Maximum R	Ratio	ID	Maximum Ra	atio	Maximum Ratio
P	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	_ F <sub>v</sub>							
-17.37	0.59		-85.0	12.8		309.6	386.8		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.444	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.405	1.10
1.03	0.39		5.0	8.4	}	330.9	364.0		5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.038	5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.005	7.76
		-0.37			-3,3			193.1	5001	f₀/F₀	0.017	5001	f <sub>v</sub> /F <sub>v</sub>	0.014	1.25

Member I	Name :C2	2-CB-Colu	ımn-1F (to	op)								_			
Section I	7002 :7		Sec	tion Type	:BOX										CBAR ID :70004
Flange Pl	_ :800 x 6	60	Wei	DPL :680	x 60										j- edge
						NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress		Allo	owable Stre	ess	Load			Load			
(N	IN, MNm	)		(MPa)			(MPa)		ID	Maximum F	Ratio	ID	Maximum Ra	atio	Maximum Ratio
Р	М	v	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv							
-11.90	2.38		-67.0	58.4		318.2	386.8		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.475	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.454	1.05
1.18	-0.06		6.7	-1.5		330.9	364.0		5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.024	5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.019	1.27
		-1.13			-11.7			193.1	8101	f <sub>v</sub> /F <sub>v</sub>	0.061	8101	f <sub>v</sub> /F <sub>v</sub>	0.057	1.07

Member	Name :C2	2-CB-Colu	mn-1F (b	ot)											
Section II	D :7002		Sec	tion Type	:BOX										CBAR ID :70004
Flange P	L :800 x 6	0	Wel	b PL :680	x 60										i- edge
						NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	ď		Stress		Allo	owable Stre	ess	Load			Load			
(N	/N, MNm	)		(MPa)			(MPa)		ID	Maximum F	Ratio	ID	Maximum R	atio	Maximum Ratio
P	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	$F_{bc}, F_{bt}$	Fv							
-11.90	-2.54		-67.0	-62.3		318.2	386.8		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.485	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.464	1.05
1.18	-0.21		6.7	-5.1		330.9	364.0		5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.034	5601	$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.038	0.90
		-1.13			-11.7			193.1	8101	f₀/F₀	0.061	8101	f₀/F₀	0.057	1.07



WG3-U73-ERD-S-0004	SH NO.193
REV. 2	of 219

#### Table A-10 Maximum Stress Ratio of Selected Columns at the rows CB and C2, X-direction (Continued)

Member	Name :C2	2-CB-Colu	mn-2F (to	vp)											
Section I	D :8002		Sec	tion Type	:BOX										CBAR ID :80004
Flange P	L :800 x 6	60	Wei	9 PL :680	x 60										j- edge
						NA3							DCD	_	Ratio(NA3/DCD)
D	esign Loa	d		Stress		Allo	wable Stre	SS	Load			Load		_	
()	VN, MNm	)		(MPa)			(MPa)		ID	Maximum R	Ratio	ID	Maximum Ra	atio	Maximum Ratio
Р	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	$F_{ac},F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	۴v							
-4.49	3.24		-25.3	79.3		277.7	364.0		5101	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.340	5101	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.325	1.05
1.14	0.33		6.4	8.1		330.9	364.0		5601	f <sub>at/</sub> F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.042	5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.047	0.88
		-1.29			-13.5			193.1	5101	f₀/F₀	0.070	5101	f₀/F₀	0.067	1.04

Member	Name :C2	-CB-Colu	mn-2F (b	ot)											
Section I	D :8002		Sec	tion Type	:BOX										CBAR ID :80004
Flange P	L :800 x 6	0	Web	0 PL :680	x 60										i- edge
						NA3							DCD		Ratio(NA3/DCD)
D	esign Loa	đ		Stress		All	owable Stre	ess	Load			Load			
1)	MN, MNm	)		(MPa)			(MPa)		D	Maximum R	tatio	ID	Maximum Ra	atio	Maximum Ratio
Р	м	v	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	$F_{ac}, F_{at}$	F <sub>bc</sub> , F <sub>bt</sub>	Fv				l			
-4.49	-2.37		-25.3	-58.2		277.7	364.0		5101	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.282	5101	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.270	1.05
1.14	-0.16		6.4	-4.0		330.9	364.0		5601	$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.030	5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.033	0.91
		-1.29			-13.5			193.1	5101	f <sub>v</sub> /F <sub>v</sub>	0.070	5101	f <sub>v</sub> /F <sub>v</sub>	0.067	1.04



WG3-U73-ERD-S-0004 SH NO.194 REV. 2 of 219

#### Table A-11 Maximum Stress Ratio of Selected Columns at the rows CB and C2, Y-direction

Member	Name :C2	2-CB-Colu	ımn-B2F (	(top)											
Section	D :5002		Sec	tion Type	:BOX										CBAR ID :50006
Flange F	PL :800 x 7	0	We	b PL :660	x 70										j- edge
						NA3							DCD		Ratio(NA3/DCD)
D	esign Loa	d		Stress		All	owable Stre	SS	Load			Load			
(1	MN, MNm	)		(MPa)			(MPa)		D	Maximum R	Ratio	ID	Maximum Ra	atio	Maximum Ratio
Р	M	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	$F_{bc}, F_{bt}$	Fv							
-20.42	0.80		-99.9	17.5		315.4	386.8		8201	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.528	8201	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.521	1.01
0.16	0.16 0.42 0.8 9.2 330.9 364.0								5601	$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.028		f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>		
		-0.17			-1.5			193.1	8101	f <sub>v</sub> /F <sub>v</sub>	0.008	8101	f <sub>v</sub> /F <sub>v</sub>	0.009	0.82

Member I	Name :C2	2-CB-Colu	ımn-B2F (	(bot)											
Section II	) :5002		Sec	tion Type	:BOX										CBAR ID :50006
Flange Pl	_ :800 x 7	0	We	b PL :660	x 70										i- edge
						NA3							DCD		Ratio(NA3/DCD)
De	sign Loa	d		Stress		Alle	owable Stre	SS	Load			Load			
(N	IN, MNm	)		(MPa)			(MPa)		ID	Maximum F	Ratio	D	Maximum Ra	atio	Maximum Ratio
Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	$F_{bc}, F_{bt}$	Fv							
-20.42	0.00		-99.9	0.0		315.4	386.8		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.483	8201	fad/Fac+fbd/Fbc	0.465	1.04
0.16	0.00		0.8	0.0		330.9	364.0		5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.002		f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>		
•		-0.17			-1.5			193.1	8101	f <sub>v</sub> /F <sub>v</sub>	0.008	8101	f <sub>v</sub> /F <sub>v</sub>	0.009	0.82

Member I	Name :C2	-CB-Colu	Imn-B1F	(top)											
Section II	6002 :		Sec	tion Type	:BOX										CBAR ID :60003
Flange Pl	. :800 x 7	0	We	b PL :660	x 70										j- edge
						NA3							DCD		Ratio(NA3/DCD)
De	sign Loa	d		Stress		Alle	owable Stre	ss	Load			Load			
(N	IN, MNm)	)		(MPa)			(MPa)		DI ID	Maximum F	Ratio	ID	Maximum Ra	atio	Maximum Ratio
Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	F,							
-17.37	1.57		-85.0	34.2		309.6	386.8		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.499	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.479	1.04
1.03	0.01		5.0	0.3		330.9	364.0		5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.016	5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.007	2.40
		-0.49			-4.4			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.023	8201	f <sub>v</sub> /F <sub>v</sub>	0.022	1.04



T

WG3-U73-ERD-S-0004 SH NO.195 REV. 2 of 219

٠.,

.

#### Table A-11 Maximum Stress Ratio of Selected Columns at the rows CB and C2, Y-direction (Continued)

Member	Name :C2	2-CB-Colu	Imn-B1F	(bot)									_		
Section I	D :6002		Sec	tion Type	:BOX										CBAR ID :60003
Flange P	L :800 x 7	0	We	b PL :660	x 70										i- edge
					_	NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress	_	Allo	wable Stre	ss	Load			Load			=
(N	/N, MNm	)		(MPa)			(MPa)		ID	Maximum R	atio	ID	Maximum Ra	atio	Maximum Ratio
P	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	Fac, Fat	$F_{bc}, F_{bt}$	Fv						1	
-17.37	-1.68		-85.0	-36.6		309.6	386.8		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.506	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.483	1.05
1.03	-0.09		5.0	-1.9		330.9	364.0		5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.020	5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.014	1.41
		-0.49			-4.4			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.023	8201	f <sub>v</sub> /F <sub>v</sub>	0.022	1.04
Member I	Name :C2	-CB-Colu	mn-1F (to								- '			<u>`</u>	<u>.</u>
Section II	D :7002		Sec	tion Type	:BOX						<u> </u>				CBAR ID :70004
Flange Pl	L :800 x 6	0	Wel	o PL :680	x 60										j- edge
						NA3		DCD							Ratio(NA3/DCD)
De	esign Loa	d		Stress		Alle	owable Stre	SS	Load			Load			
(N	/N, MNm	)	1	(MPa)			(MPa)		ID	Maximum F	tio	ID	Maximum Ra	atio	Maximum Ratio
P	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	Fac, Fat	Fbc,Fbt	Fv							
-11.90	1.24		-67.0	30.3		318.2	386.8		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.402	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.388	1.04
1.18	-0.04		6.7	-0.9		330.9	364.0		5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.023	5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.013	1.72
		-0.60			-6.3			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.032	8201	f <sub>v</sub> /F <sub>v</sub>	0.032	1.03
Member I	Name :C2	-CB-Colu	mn-1F (b	ot)								_			
Section II	D :7002		S	ection Typ	e :BOX										CBAR ID :70004
Flange Pl	L :800 x 6	0	Wel	o PL :680	x 60										i- edae
						NA3						1	DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress Allowable Stress Load Load							, ,				
(N	- /N. MNm	)		(MPa)		(MPa) ID Maximum Ratio ID					Maximum Ra	atio	Maximum Ratio		
P	M	v	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	fv Fac,Fat Fbc,Fbt Fv									
-11.90	-1.42		-67.0	-34.8		318.2	386.8		8201	fac/Fac+fbc/Fbc	0.414	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.400	1.03
1.18	-0.03		6.7	-0.8		330.9	364.0		5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.022	5601	fat/Fat+fbt/Fbt	0.018	1.27
	i	-0.60			-6.3			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.032	8201	f <sub>v</sub> /F <sub>v</sub>	0.032	1.03



WG3-U73-ERD-S-0004	SH NO.196
REV. 2	of 219

# Table A-11 Maximum Stress Ratio of Selected Columns at the rows CB and C2, Y-direction (Continued)

Member	Name :C2	2-CB-Colu	mn-2F (to	op)											
Section I	D :8002	_	Sec	tion Type	:BOX										CBAR ID :80004
Flange P	L :800 x 6	60	Wel	b PL :680	x 60										j- edge
	_					NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	d –		Stress		Alle	owable Stre	ISS	Load			Load			
()	MN, MNm	)		(MPa)			(MPa)		ID	Maximum F	Ratio	ID	Maximum Ra	atio	Maximum Ratio
Р	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> , f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	Fv							
-7.08	2.77		-39.9	67.9		317.4	386.8		8201	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.368	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.359	1.02
0.16	0.16 0.56 0.9 13.7 351.6 386.8 8601 $f_{at}/F_{at}+f_{bt}/F_{bt}$ 0.038 5501 $f_{at}/F_{at}+f_{bt}/F_{bt}$ 0.024									1.62					
		-1.05			-11.0			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.057	8201	f₀/F₀	0.056	1.02

Wemper	Name :02	-08-0014	mn-2F (D	σι)											
Section II	D :8002		Sec	tion Type	:BOX										CBAR ID :80004
Flange P	L :800 x 6	0	Wel	o PL :680	x 60										i- edge
						NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress		All	owable Stre	ess	Load			Load			
(1	/N, MNm	)		(MPa)			(MPa)		D	Maximum F	Ratio	ID	Maximum Ra	atio	Maximum Ratio
P	M	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> , f <sub>bt</sub>	fv	$F_{ac},F_{at}$	F <sub>bc</sub> , F <sub>bt</sub>	Fv							
-7.08	-1.80		-39.9	-44.1		317.4	386.8		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.307	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	.0.300	1.02
0.16	-0.34		0.9	-8.3		351.6	386.8		8601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.024	5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.017	1.46
		-1.05			-11.0			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.057	8201	f <sub>v</sub> /F <sub>v</sub>	0.056	1.02



 WG3-U73-ERD-S-0004
 SH NO.197

 REV. 2
 of 219

Member	Name : C	B-B1F-Gi	rder-23 (2	2end)											
Section I	D :1002		Se	ection Type	ə : H										CBAR ID :11016
Flange P	'L :300 x2	8	v	/eb PL :64	4 x 19										i- edge
						NA3							DCD		Ratio(NA3/DCD)
D	esign Loa	d		Stress	-	Allo	wable Stres	s	Load			Load			
()	MN, MNm	)		(MPa)			(MPa)		ID	Maximum R	atio	D ID	Maximum R	atio	Maximum Ratio
Р	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv							
-1.64	-0.43		-56.6	-64.7		328.7	229.6		8101	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.555	8101	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.637	0.87
0.36	-0.23		12.4	-34.6		330.9	330.9		5501	$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.142	5501	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.103	1.38
		-0.20			-14.8			137.9	3002	f <sub>v</sub> /F <sub>v</sub>	0.107	3002	f <sub>v</sub> /F <sub>v</sub>	0.107	1.00
Member	Name : C	B-B1F-Gi	rder-45 (4	lend)						<u> </u>				-	
Section I	D :1002		S	ection Type	ə : H										CBAR ID : 11022
Flange P	L :300 x2	8	Ŵ	/eb PL :64	4 x 19										i- edge
						NA3						DCD			Ratio(NA3/DCD)
D	esign Loa	d		Stress		Allo	wable Stre	ss	Load			Load			
(1	MN, MNm	)		(MPa)			(MPa)		D	Maximum R	atio	D ID	Maximum R	atio	Maximum Ratio
P	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	Fv							
-1.96	-0.68		-67.6	-103.0		328.7	229.6		8101	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.775	8101	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.788	0.98
0.06	-0.33		2.2	-49.2		330.9	330.9		5501	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.155	5601	f <sub>at/</sub> F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.167	0.93
		-0.26			-19.7			137.9	3004	f <sub>v</sub> /F <sub>v</sub>	0.143	3004	f <sub>v</sub> /F <sub>v</sub>	0.143	1.00
Member	Name : Cl	B-1E-Gird	er-23 (2e	nd)											
Section II			01 20 (20	Section Tv	ne · H										CBAR ID : 21016
Elange Pl	1 · 400 x 4	10		Web Pl	920 x 28										i- edge
	<u></u>					NA3						T	DCD		Ratio(NA3/DCD)
De	sign Load	4		Stress		Alle	wable Stre	55	Load			load			
()	AN MNm)	-		(MPa)		, ure	(MPa)			Maximum F	Ratio		Maximum R	atio	Maximum Ratio
(	м	v	factor	fba.fbt	f.,	Fac.Fat	Eho, Eho	F <sub>v</sub>		in a Airi airi i	1200				
-0.80	-4 11		-13.9	-223 2		288 1	288.2	+-··	5201	faa/Faa+fua/Fu	0.842	5201	fau/Fau+fhu/Fh	0.966	0.87
0.52	-4 10		9.0	-223 1		330.9	330.9		5101	for/For+fbr/Fbr	0 701	5101	fat/Fat+fat/Fat	0.726	0.97
		-1.31			-46.8			193 1	8201	f./F	0.242	8201	f./F.	0.229	1.06

#### Table A-12 Maximum Stress Ratio of Selected Girders at the row CB

Note: In DCD, Flange PL: 400x 36, Web PL : 928 x 28



 WG3-U73-ERD-S-0004
 SH NO.198

 REV. 2
 of 219

#### Table A-12 Maximum Stress Ratio of Selected Girders at the rows CB (Continued)

Member	Name : C	B-1F-Girc	ler-45 (4e	nd)											
Section I	D : 2002		Se	ection Type	: H										CBAR ID : 21022
Flange P	L : 300 x	28	v	/eb PL : 64	4 x 19										i- edge
						NA3				· · ·			DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress		Allo	wable Stre	SS	Load			Load			
(N	/N, MNm	)		(MPa)			(MPa)		ID	Maximum F	Ratio	ID	Maximum R	atio	Maximum Ratio
P	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> , F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	Fv	1						
-0.73	-0.69		-25.3	-104.7		287.6	216.1		5201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.607	5201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.618	0.98
0.36	-0.73		12.3	-110.0	1	351.6	351.6		8101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.348	8101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.354	0.98
	ł	-0.36	ł		-27.1			193.1	8201	f₀/F₀	0.140	8201	f <sub>v</sub> /F <sub>v</sub>	0.136	1.03
Member	Name : C	B-2F-Girc	ier-23 (2e	end)								_			
Section II	D : 3003		s	ection Typ	e:H										CBAR ID : 31016
Flange P	L : 400 x4	10	v	Veb PL :12:	20 x 28										i- edge
		-				NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress		Allo	wable Stre	ss	Load			Load			
(1	/N, MNm	)		(MPa)			(MPa)		D	Maximum F	Ratio	!D	Maximum R	atio	Maximum Ratio
P	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv	1						
-3.40	-4.38		-51.4	-168.0		329.1	351.6		8201	fac/Fac+fbc/Fbc	0.726	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0,705	1.03
1.07	-4.34		16.2	-166.6		330.9	330.9	1	5101	$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.552	5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.531	1.04
		-1.41			-38.6			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.200	8201	f <sub>v</sub> /F <sub>v</sub>	0,192	1.04

Member	Name : C	B-B1F-Gi	irder-45 (4	lend)					_						
Section I	D : 3001		Se	ection Type	: H										CBAR ID : 31022
Flange P	L : 300 x	36	v	/eb PL :928	3 x 28										i- edge
						NA3	-						DCD		Ratio(NA3/DCD)
D	esign Loa	d		Stress		Allo	wable Stree	ss	Load			Load			
(1	MN, MNm	)		(MPa)			(MPa)		ID	Maximum F	Ratio	ID	Maximum Ra	atio	Maximum Ratio
P	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	F_v							
-2.23	-1.31		-46.8	-95.0		328.4	206.7		8201	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.686	8201	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.690	0.99
0.73 -0.53 15.4 -38.6 330.9 330.9 5101 f <sub>a</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub> 0.163 5							5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.165	0.99					
		-0.50			-17.8			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.092	8201	f <sub>v</sub> /F <sub>v</sub>	0.091	1.02



WG3-U73-ERD-S-0004	SH NO.199
REV. 2	of 219

Member	Name : Cl	B-RF-Gire	der-23 (2¢	end)											
Section I	D : 4003		S	ection Typ	e : H										CBAR ID : 41016
Flange P	L : 500 x4	0	v	Veb PL :12	20 x 28										i- edge
						NA3							DCD		Ratio(NA3/DCD)
D	esign Load	±		Stress		Allo	wable Stre	ss	Load			Load			
(1	MN, MNm)	)		(MPa)			(MPa)		ID	Maximum F	Ratio	ID	Maximum R	atio	Maximum Ratio
Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv							
-7.13	-4.10		-96.2	-132.3		329.6	351.6		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.841	8201	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.833	1.01
0.58	-3.46		7.8	-111.9		330.9	364.0		5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.331	5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.324	1.02
		-1.35			-37.0			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.192	8201	f <sub>v</sub> /F <sub>v</sub>	0.187	1.03

#### Table A-12 Maximum Stress Ratio of Selected Girders at the rows CB (Continued)

Member	Name : C	B-RF-Gir	der-45 (4e	end)											
Section I	D : 4001		s	ection Typ	e ; H										CBAR ID : 41022
Flange P	'L : 400 x4	0	v	Veb PL :92	0 x 28										i- edge
						NA3							DCD		Ratio(NA3/DCD)
D	esign Loa	d		Stress		Allo	wable Stre	ss	Load		_	Load			
(1	MN, MNm	)		(MPa)			(MPa)		ID	Maximum R	tatio	ID	Maximum Ra	atio	Maximum Ratio
Р	М	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	Fv							
-5.59	-2.30		-96.7	-125.1		329.3	306.2		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.876	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.877	1.00
0.87	-0.91		15.0	-49.5		330.9	330.9		5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.195	5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.197	0.99
		-0.74			-26.4			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.137	8201	f <sub>v</sub> /F <sub>v</sub>	0.135	1.01



WG3-U73-ERD-S-0004	SH NO.200
REV. 2	of 219

Section I	D:1002		S	ection Typ	e:H										CBAR ID : 10005
Flange P	L : 300 x2	28	v	Veb PL : 64	44 x 19										i- edge
						NA3							DCD	_	Ratio(NA3/DCD)
D	esign Loa	d		Stress		Alic	wable Stre	ss	Load			Load			
(1	MN, MNm	)		(MPa)			(MPa)		D	Maximum F	atio	ID	Maximum Ra	atio	Maximum Ratio
Р	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	Fv							
-1.56	-0.30		-53.9	-44.5		328.7	386.8		8101	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.375	8101	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.433	0.87
0.39	0.00		13.5	-0.4		330.9	364.0		5501	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.042	5501	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.078	0.54
		-0.10			-7.2			193.1	8101	f <sub>v</sub> /F <sub>v</sub>	0.037	8101	f <sub>v</sub> /F <sub>v</sub>	0.046	0.81

#### Table A-13 Maximum Stress Ratio of Selected Girders at the row C2

Member	Name : C	2-B1F-Gi	rder-BA (B	Bend)											
Section II	D : 1001		Se	ction Type	: H										CBAR ID : 10007
Flange P	L : 400 x 3	36	Ŵ	eb PL :628/	x 28										i- edge
						NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress		Allo	wable Stre	SS	Load			Load			
(N	IN, MNm	)		(MPa)			(MPa)		ID	Maximum F	Ratio	ID	Maximum R	atio	Maximum Ratio
P	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	$F_{ac}, F_{at}$	F <sub>bc</sub> ,F <sub>bt</sub>	Fv							
-2.21	-1.69		-47.6	-157.8		329.4	386.8		8101	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.638	8101	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.649	0.98
0.47	-1.01		10.2	-94.5		330.9	364.0		5601	$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.290	5601	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>b</sub> t	0.289	1.00
		-0.56			-28.6			137.9	3003	f <sub>v</sub> /F <sub>v</sub>	0.207	3003	f <sub>v</sub> /F <sub>v</sub>	0.207	1.00

Member	Name : C	2-1F-Gird	er-CB (Co	end)											
Section I	D : 2002		s	ection Typ	e:H										CBAR ID : 20005
Flange P	L :300 x2	8	V	Veb PL :64	4 x 19										i- edge
						NA3							DCD	_	Ratio(NA3/DCD)
De	esign Loa	d		Stress		Alla	wable Stre	SS	Load			Load			
(1	/N, MNm	)		(MPa)			(MPa)		ID	Maximum F	tio	ID	Maximum Ra	tio	Maximum Ratio
P	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> ,F <sub>bt</sub>	Fv							
-0.56	-0,33		-19.3	-49.2		287.6	364.0		5201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.229	5201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.259	0.88
0.56	-0.34		19.2	-50.7		351.6	386.8		8101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.186	8101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.204	0.91
		-0.15			-11.3			193.1	8201	f₀/F₀	0.059	8201	f₀/F₀	0.058	1.01



WG3-U73-ERD-S-0004 SH NO.201 REV. 2 of 219

.

Table A-13 Maximum Stress Ratio of Selected Girders at the rows CB (Co	ontinued)
--	-----------

Section II	D:2001		S	ection Typ	e : H										CBAR ID : 20007
Flange Pl	L:400 x 4	40	v	/eb PL :720	) x 28										i- edge
						NA3							DCD		Ratio(NA3/DCD)
De	esign Load	d		Stress		Allo	wable Stre	SS	Load			Load			
(N	IN, MNm)	)		(MPa)			(MPa)		D	Maximum F	Ratio	ID	Maximum R	atio	Maximum Ratio
Р	м	v	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> , F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	Fv	1						
-0.82	-1.89		-15.6	-137.4		288,2	364.0		5201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.453	5201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.467	0.97
0.91	-1.94		17.4	-141.5		351,6	386.8		8101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.415	8101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.420	0.99
		-0.87			-39.1			193.1	8201	f₀/F₀	0.202	8201	f <sub>v</sub> /F <sub>v</sub>	0.195	1.04

Womber															
Section I	D: 3002		S	ection Typ	e:H										CBAR ID : 30005
Flange P	L : 300 x2	8	v	Veb PL :94	4 x 19										i- edge
						NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress		Allo	wable Stre	ss	Load			Load			
(N	/N, MNm)	)		(MPa)			(MPa)		ID	Maximum R	Ratio	ID	Maximum Ra	atio	Maximum Ratio
Ρ	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	Fv							
-2.02	-0.44		-58.1	~41.8		328.5	351.6		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.400	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.396	1.01
0.46	-0.45		13.2	-42.8		330.9	364.0		5101	$f_{at}/F_{at}+f_{bt}/F_{bt}$	0.157	5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.154	1.02
		-0.18			-9.5			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.049	8201	f <sub>v</sub> /F <sub>v</sub>	0.049	1.01

Member	Name : C	2-2F-Gird	er-BA (Be	end)	-										
Section II	D:3001		s	ection Typ	e:H										CBAR ID : 30007
Flange P	L : 300 x3	6	v	veb PL :92	8 x 28										i- edge
						NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress		Allo	wable Stre	ss	Load			Load			
(N	IN, MNm	)		(MPa)			(MPa) ID Maximum Ratio ID							atio	Maximum Ratio
Р	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	Fv							
-2.23	-2.02		-46.9	-147.0		328.4	386.8		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.607	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.598	1.02
0.67	-1.52		14.0	-110.6		330.9	364.0		5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.346	5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.337	1.03
		-0.84			-30.1			193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.156	8201	f <sub>v</sub> /F <sub>v</sub>	0.152	1.03



WG3-U73-ERD-S-0004	SH NO.202
REV. 2	of 219

Member	Name : C	2-RF-Giro	der-CB (C	end)										_	
Section I	D : 4002		S	ection Type	e:H									_	CBAR ID : 40005
Flange P	L : 300 x2	28	v	Veb PL :94	4 x 19										i- edge
	NA3													_	Ratio(NA3/DCD)
De	esign Loa	d		Stress		Allo	wable Stre	ss	Load			Load			
(N	IN, MNm	)		(MPa)			(MPa)	_	ID	Maximum F	Ratio	ID	Maximum R	atio	Maximum Ratio
Р	M	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	fv	Fac, Fat	$F_{bc}, F_{bt}$	Fv							
-3.36	-0.81		-96.7	-76.2		328.5	351.6		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.684	8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.683	1.00
0.75	0.75 -0.48 21.7 -45.4 330.9 364.0							5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.190	5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.189	1.00	
	-0.17 -8							193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.046	8201	f <sub>v</sub> /F <sub>v</sub>	0.046	1.01

# Table A-13 Maximum Stress Ratio of Selected Girders at the rows CB (Continued)

Member	Name : C	2-RF-Gire	der-BA (B	end)										-	
Section ID : 4001 Section Type : H															CBAR ID : 40007
Flange P	'L : :400 x	40	v	Veb PL :92	0 x 28										i- edge
						NA3							DCD		Ratio(NA3/DCD)
De	esign Loa	d		Stress		Allo	wable Stre	SS	Load			Load			
(M	MN, MNm	)	ļ	(MPa)			(MPa)		ID	Maximum F	Ratio	ID	Maximum Ra	atio	Maximum Ratio
Р	м	V	f <sub>ac</sub> ,f <sub>at</sub>	f <sub>bc</sub> ,f <sub>bt</sub>	f <sub>v</sub>	F <sub>ac</sub> ,F <sub>at</sub>	F <sub>bc</sub> , F <sub>bt</sub>	Fv							
-5.56	-2.22		-96.2	-120.6		329.3	386.8		8201	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.777	8201	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.774	1.00
0.77	0.77 -1.25 13.3 -67.8 330.9 364.0					5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.226	5101	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.224	1.01			
-0.97 -34.7								193.1	8201	f <sub>v</sub> /F <sub>v</sub>	0.180	8201	f <sub>v</sub> /F <sub>v</sub>	0.177	1.02



 WG3-U73-ERD-S-0004
 SH NO.203

 REV. 2
 of 219

Section	n ID :500	2	5	Section T	ype :BO)	x				CBA	R ID :50006	
Flange	9 PL :800	x 70	V	Web PL :	660 x 70						j- edge	
NA3 DCD Ratio(NA3/DCD)												
	X-direct	ion	)	/-directio	n	Rat	tio	Ra	tio			
Load ID	R <sub>NS</sub>	R <sub>fa/Fa</sub>	Load 1D	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>tv/Fv</sub> )	R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>fv/Fv</sub> )	R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>fv/Fv</sub> )	
8201	0.513	0.317	8201	0.528	0.317	0.725		0.733		0.99		
5601	0.013	0.002	5601	0.028	0.002							
8101	0.006		8101	0.008			0.010		0.013		0.74	

Memb	er Name	:C2-CB-Cc	lumn-B2	2F (bot)							
Sectio	n ID :500	)2	5	Section T	ype :BO	<b>х</b> ·				CB	AR ID :50006
Flange	e PL :800	x 70	V	Neb PL :	660 x 70	1					i- edge
				NA	3		·	D(		Datio(N/	3/000
	X-direct	ion	<u>ا</u>	-directio	n	Ra	tio	Ra	itio		(3/DCD)
Load		р	Load			R <sub>NS</sub> + R <sub>EW</sub> -	Max (P)	R <sub>NS</sub> + R <sub>EW</sub> -	Max (P)	R <sub>NS</sub> + R <sub>EW</sub> -	Max (PL)
ID	RNS	⊂ r <sub>fa</sub> /Fa	ID	REW	⊂rfa/Fa	Min.(R <sub>fa/Fa</sub> )		Min.(R <sub>ta/Fa</sub> )	Widx.(Rfv/Fv)	Min.(R <sub>fa/Fa</sub> )	Wax.(Rfv/Fv)
8201	0.483	0.317	8201	0.483	0.317	0.649		0.625		1.04	_
5601	0.002	0.002	5601	0.002	0.002	0.002					
8101	0.006		8101	0.008				0.013		0.74	

Memb	er Name	: C2-CB-C	olumn-B	1F (top)			-				
Sectio	n ID :600	2	5	Section T	ype :BO	κ				CBA	R ID : 60003
Flange	e PL :800	x 70	١	Veb PL :	660 x 70					_	j- edge
NA3 DCD Ra											
	X-direct	ion		-directio	n	tio	Ratio Ratio(NA3/DCL				
Load ID	R <sub>NS</sub>	R <sub>fa/Fa</sub>	Load ID	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> + R <sub>EW</sub> - Min. (R <sub>fa/Fa</sub> )	Max.(R <sub>tv/Fv</sub> )	R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>tv/Fv</sub> )	R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>tv/Fv</sub> )
8201	0.501	0.275	8201	0.499	0.275	0.726		0.689		1.05	
5601	0.021	0.015	5601	0.016	0.015	0.022		0.024		0.89	
5001	0.017		8201	0.023			0.028		0.026		1.10



WG3-U73-ERD-S-0004	SH NO.204
REV. 2	of 219

Membe	er Name	: C2-CB-C	olumn-B	1F (bot)									
Section	n ID :600	2	5	Section T	ype :BO	<b>K</b>				CBA	R ID : 60003		
Flange	PL :800	x 70	۱	Neb PL :	660 x 70					i- edge			
NA3 DCD Ratio(NA3/DCD)													
	X-direct	ion		-directio	n	Ra	tio	Ra	itio	Railo(INA	3/000)		
Load ID	R <sub>NS</sub>	R <sub>fa/Fa</sub>	Load ID	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>tv/Fv</sub> )	R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>fv/Fv</sub> )	R <sub>NS</sub> + R <sub>EW</sub> - Min.(R <sub>fa/Fa</sub> )	Max.(R <sub>tv/Fv</sub> )		
8201	0.444	0.275	8201	0.506	0.275	0.675		0.625		1.08			
5601	0.038	0.015	5601	0.020	0.015	0.044		0.015		2.81			
5001	0.017		8201	0.023		0.028		0.026		1.10			

Table A-14	Column	Stress	Check	Results (	(Continued)	)
		~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~	~ ~ ~ ~ ~ ~ ~ ~			

Memb	er Name	: C2-CB-C	olumn-11	F (top)							
Sectio	n ID :700	)2	Se	ection Ty	pe :BOX	•				CBAI	R ID : 70004
Flange	PL:80	0 x 60	v	Veb PL :6	680 x 60						j- edge
	NA3 DCD										2/DCD)
	X-direct	ion	۱ ۱	-directio	n	Ra	tio	Ra	itio	Ralio(NA	3/000)
Load		P. a	Load	P	P	R <sub>NS</sub> + R <sub>EW</sub> -	Max (R)	R <sub>NS</sub> + R <sub>EW</sub> -	Max (R )	R <sub>NS</sub> + R <sub>EW</sub> -	Max (R)
ID	INNS	i Nta/Fa	ID	NEW	i \fa/⊦a	Min.(R <sub>fa/Fa</sub> )	WAX.(IN/////	Min.(R <sub>fa/Fa</sub> )	WIGA. (I (W/FV)	Min.(R <sub>fa/Fa</sub> )	INCA. (INW/FV)
8201	0.475	0.211	8201	0.402	0.211	0.667		0.639		1.04	
5601	0.024	0.020	5601	0.023	0.020	0.027		0.019		1.39	
8101	0.061		8201	0.032			0.069		0.065		1.06

Memb	er Name	: C2-CB-C	olumn-11	F (bot)								
Sectio	n ID :700	)2	Se	ection Ty	pe :BOX		-			CBA	R ID : 70004	
Flange	e PL : 80	0 x 60	v	Veb PL :6	680 x 60						i- edge	
	NA3 DCD										2/000	
	X-direction Y-direction Ratio								Ratio			
Load	Run	Rec.	Load	Rev	Rister	R <sub>NS</sub> + R <sub>EW</sub> -	Max (Rum)	R <sub>NS</sub> + R <sub>EW</sub> -	Max (Rever)	R <sub>NS</sub> + R <sub>EW</sub> -	Max (Rever)	
D	/ 1/05	• • <i>ta/r</i> -a	ID	I LEVV	· via/ra	Min.(R <sub>fa/Fa</sub> )	man (r (wrw	Min.(R <sub>fa/Fa</sub> )		Min.(R <sub>fa/Fa</sub> )		
8201	0.485	0.211	8201	0.414	0.211	0.688		0.661		1.04	-	
5601	0.034	0.020	5601	0.022	0.020	0.036		0.042		0.86		
8101	0.061		8201	0.032			0.069		0.065		1.06	



WG3-U73-ERD-S-0004 SH NO.205 **REV. 2** of 219

Memb	er Name	:C2-CB-	Column-	-2F (top)										
Sectio	n ID :800	)2					Sec	tion Typ	e :BOX					CBAR ID :80004
Flange	PL :800	) x 60						j- edge						
	NA3													Ratio(NA3/DCD)
	X-direction Y-direction													
Load ID	R <sub>NS</sub>	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> +R <sub>EW</sub> - R <sub>fa∕Fa</sub>	Load ID	R <sub>NS</sub>	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> +R <sub>EW</sub> - R <sub>fa/Fa</sub>	Maximum R	atio	Maximum Ra	atio	Maximum Ratio
5101	0.340	0.213	0.091	0.462	8201	0.298	0.368	0.126	0.541	$f_{ac}/F_{ac}+f_{bc}/F_{bc}$	0.541	fac/Fac+fbc/Fbc	0.521	, 1.04
5601	0.042	0.020	0.019	0.042 8601 0.031 0.038 0.003 0.066 $f_{at}/F_{at}+f_{bt}/F_{bt}$ 0.0							0.066	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.050	1.32
5101	5101 0.070 0.029 - 0.076 8201 0.036 0.057 - 0.067 f <sub>v</sub> /F <sub>v</sub> 0									0.076	f₀/F₀	0.072	1.04	

Table A-14 Column Stress Check Results (Continue
--

Memb	er Name	:C2-CB-	Column-	2F (bot)		-				-				
Sectio	n ID :800	)2					Se	ction Typ	be :BOX					CBAR ID :80004
Flange	e PL :800	x 60					We	b PL :68	80 x 60					i- edge
						NA3						DCD		Ratio(NA3/DCD)
		X-direc	tion				Y-direc	tion						
Load ID	R <sub>№s</sub>	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> +R <sub>EW</sub> - R <sub>fa/Fa</sub>	Load ID	R <sub>NS</sub>	R <sub>EW</sub>	R <sub>fa/Fa</sub>	R <sub>NS</sub> +R <sub>EW</sub> - R <sub>fa/Fa</sub>	Maximum Ra	atio	Maximum Ra	atio	Maximum Ratio
5101	0.282	0.189	0.091	0.380	8201	0.271	0.307	0.126	0.452	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.452	f <sub>ac</sub> /F <sub>ac</sub> +f <sub>bc</sub> /F <sub>bc</sub>	0.437	1.04
5601	0.030	0.020	0.019	0.031	8601	0.030	0.024	0.003	0.051	f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub> 0.051 f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>		f <sub>at</sub> /F <sub>at</sub> +f <sub>bt</sub> /F <sub>bt</sub>	0.034	1.51
5101	0.070	0.029	-	0.076	8201	0.036	0.057	-	0.067	7 f <sub>v</sub> /F <sub>v</sub> 0.076 f <sub>v</sub> /F <sub>v</sub> 0.072				1.04



Ι

WG3-U73-ERD-S-0004	SH NO.206
REV. 2	of 219

	Element		N/	A3		DCD				
Location	Element	Load	d	ρ	ρν	Load	d	ρ <sub>w</sub>	ρ,	
	ID	ID	(m)	(%)	(%)	ID	(m)	(%)	(%)	
Wall	6007	CB-9	0.679	1.485	0.355	CB-9	0.711	1.418	0.355	
EL-7.4m	4006	CB-9	0.672	1.500	0.355	CB-9	0.673	1.498	0.355	
	4010	CB-9	0.675	1.493	0.355	CB-9	0.676	1.491	0.355	
Wall	6043	CB-9	0.674	1.495	0.355	CB-9	0.672	1.500	0.355	
EL-2.0m	4036	CB-9	0.673	1.498	0.710	CB-9	0.672	1.500	0.710	
	4040	CB-9	0.677	1.489	0.355	CB-9	0.689	1.463	0.355	
Wali	6081	CB-9	0.673	1.497	0.000	CB-9	0.673	1.497	0.000	
EL4.65m	4066	СВ-9	0.672	1.500	0.000	CB-9	0.672	1.499	0.000	
PEL9.00III	4070	CB-9	0.694	1.452	0.000	CB-9	0.699	1.442	0.000	
Wall	6117	CB-9	0.493	1.533	0.000	CB-9	0.493	1.533	0.000	
EL9.06m	4096	CB-9	0.493	1.533	0.000	CB-9	0.493	1.533	0.000	
~EL13.8M	4100	CB-9	0.507	1.492	0.000	CB-9	0.507	1.490	0.000	

#### Table A-15 Transverse Shear of CB External Walls

#### Table A-15 Transverse Shear of CB External Walls(Continued)

	Flowert	NA3					DCD					Ratio						
Location	Clement	Load	S	hear Fo	rces (MN	/m)		Load Shear Forces (MN/m)				(NA3/DCD)						
	ID	ID	Vu	Vc	Vs	φVn	Vu∕φVn	ID	Vu	Vc	Vs	φVn	V <sub>u</sub> /φV <sub>n</sub>	Vu	Vc	Vs	φVn	Vu∕φVn
Wall EL-7.4m	6007	CB-9	0,553	0.638	0.998	1.391	0.397	CB-9	0.136	0.071	1.045	0.949	0.143	4.07	8.98	0.95	1.47	2.78
~EL-2.0m	4006	CB-9	1.160	1.488	0.988	2.104	0.551	CB-9	0.571	0.205	0.989	1.015	0.562	2.03	7.27	1.00	2.07	0.98
	4010	CB-9	0.559	0.539	0.992	1.301	0.430	CB-9	0.683	0.483	0.994	1.255	0.544	0.82	1.11	1.00	1.04	0.79
Wall EL-2.0m	6043	CB-9	0.164	0.608	0.991	1.359	0.121	CB-9	0.220	0.506	0.988	1.270	0.173	0.75	1.20	1.00	1.07	0.70
~EL4.65m	4036	CB-9	0.135	0.523	1.978	2.126	0.063	CB-9	0.579	0.251	1.975	1.892	0.306	0.23	2.09	1.00	1.12	0.21
	4040	CB-9	0.279	0.532	0.995	1.298	0.215	CB-9	0.276	0.118	1.013	0. <del>9</del> 61	0.288	1.01	4.52	0.98	1.35	0.75



 WG3-U73-ERD-S-0004
 SH NO.207

 REV. 2
 of 219

# APPENDIX B IN-PLANE SHEAR CHECK FOR THE CB ACCORDING TO ACI 349-01



 WG3-U73-ERD-S-0004
 SH NO.208

 REV. 2
 of 219

#### TABLE OF CONTENTS

B.1	Scope	209217
B.2	In-plane Shear Check	209217
B.3	Conclusions	

#### LIST OF TABLES

Table B-1 Maximum Stress Ratios for In-Plane Shear Check	
Table B-2 Maximum Stress Ratios for In-Plane Shear Check for East Wall	
EL-2.0m~EL0.22m	
Table B-3 Maximum Stress Ratios for In-Plane Shear Check for East Wall	
EL9.06m~EL10.61m	
Table B-4 Maximum Stress Ratios for In-Plane Shear Check for South Wall	
EL9.06m~EL10.61m	

LIST OF FIGURES

#### NONE



WG3-U73-ERD-S-0004 SH NO.209 REV. 2 of 219

#### B.1 SCOPE

This appendix describes In-plane Shear Check for the CB according to ACI 349-01.

#### **B.2** IN-PLANE SHEAR CHECK

According to Section 21.6.5.6 of ACI 349-01, the maximum shear strength of a horizontal wall segment per unit length is calculated as follows:

 $Vn_{\text{max}} = 8\sqrt{f_c}h$  (For all wall piers)  $Vn_{\text{max}} = 10\sqrt{f_c}h$  (For individual wall piers)

where,

h is wall thickness.

When  $f_c$ '=5000 psi and h=27.56 and 35.43 in (=0.7 m and 0.9 m) are substituted above equation for the typical CB walls,

For all wall piers
 h=0.7m: Vn<sub>max</sub> = 15590lb/in = 2.728MN/m
 h=0.9m: Vn<sub>max</sub> = 20042lb/in = 3.508MN/m

 For individual wall piers
 h=0.7m: Vn<sub>max</sub> = 19488lb/in = 3.411MN/m
 h=0.9m: Vn<sub>max</sub> = 25053lb/in = 4.384MN/m

The above values are less than the shear strength defined in Section 21.6.5.2 of ACI 349-01, since Section 21.6.5.2 of ACI 349-01 governs the in-plane shear capacity if the rebar ratio is less than 0.94% as shown below.

The limiting rebar ratio is obtained by calculating rebar ratio when the equations in Section 21.6.5.6 and Section 21.6.5.2 of ACI 349-01 are equal as shown below:

$$8\sqrt{f_c'}h = \left(2\sqrt{f_c'} + \rho_n f_y\right)h \quad \text{(For all wall piers)}$$
$$10\sqrt{f_c'}h = \left(2\sqrt{f_c'} + \rho_n f_y\right)h \quad \text{(For individual wall piers)}$$

When  $f_y$ =60000 psi and  $f_c$ '=5000 psi, the limiting rebar ratio is evaluated as follows:

$$\rho_n = 8\sqrt{f_c'} / f_y = 0.009428$$



The allowable shear force is evaluated by multiplying strength reduction factor  $\phi$  (=0.85) according to Section 9.3.2.3 of ACI 349-01.

For all wall piers
 *h*=0.7m: *φV<sub>n</sub>* = 13252*lb*/*in* = 2.320*MN*/*m h*=0.9m: *φV<sub>n</sub>* = 17036*lb*/*in* = 2.983*MN*/*m* 
 For individual wall piers
 *h*=0.7m: *φV<sub>n</sub>* = 16565*lb*/*in* = 2.900*MN*/*m h*=0.9m: *φV<sub>n</sub>* = 21295 *lb*/*in* = 3.729 *MN*/*m b*=0.9m: *φV<sub>n</sub>* = 3.729 *MN*/*m b*=0.9m: *φV<sub>n</sub> = 1.9m <i>b*=0.9m *b*=0.9m *b* 

# **B.3** CONCLUSIONS

The results of in-plane shear check for selected elements are shown in Table B-1. The allowable shear strength for all wall piers is used conservatively. It is confirmed that the inplane shear of all elements except for Elements 6043, 6117, and 4100 are lower than the allowable shear strength. The in-plane shear check according to Section 21.6.5.6 of ACI 349-01 for the entire East wall including Elements 6043 and 6117, and the entire South wall including Element 4100 are shown in Tables B-2 through B-4. The thermal reduction due to cracking is not considered except for Table B-3 conservatively. It is confirmed that the inplane shear for all walls are less than the allowable shear forces.



WG3-U73-ERD-S-0004	SH NO.211
REV. 2	of 219

Location	Element ID	Load ID	Total In- Plane Shear N <sub>xy</sub> (MN/m)	Thickness <i>h</i> (m)	Primary Reinforce -ment Ratio	Allowable Shear Strength $\phi V_n = \phi 8 h f'_c^{0.5}$ (MN/m)	N <sub>xy</sub> /¢V <sub>n</sub>
	6007	7011	2.244	0.90	2.236%	2.983	0.75
Wall EL-7.4m ~EL-2.0m	4006	7021	1.253	0.90	2.236%	2.983	0.42
	4010	7011	1.578	0.90	2.236%	2.983	0.53
	6043	7021	3.502	0.90	2.236%	2.983	1.17
Wall EL-2.0m ~EL4.65m	4036	7001	2.121	0.90	2.236%	2.983	0.71
	4040	7011	2.490	0.90	2.236%	2.983	0.84
	6081	7021	2.134	0.90	2.236%	2.983	0.72
Wall EL4.65m ~EL9.06m	4066	7011	1.829	0.90	2.236%	2.983	0.61
	4070	7021	2.881	0.90	2.236%	2.983	0.97
	6117	7021	2.410	0.70	1.797%	2.320	1.04
Wall EL9.06m ~EL13.8m	4096	7021	1.148	0.70	1.797%	2.320	0.50
~EE 13.0III	4100	7021	2.465	0.70	1.797%	2.320	1.06

#### Table B-1 Maximum Stress Ratios for In-Plane Shear Check

Note: Exceedance is highlighted.



WG3-U73-ERD-S-0004	SH NO.212
REV. 2	of 219

				E	L-2.0m~F	CL0.22m				
Locatio	Element ID	Load ID	Total In- Plane Shear N <sub>xy</sub> (MN/m)	Thickness <i>h</i> (m)	Primary Reinforce -ment Ratio	Allowable Shear Strength for individual wall $\phi V_n = \phi 10 h f'_c^{0.5}$ (MN/m)	N <sub>xy</sub> ∕¢V <sub>n</sub>	Total In- Plane Shear N <sub>xy_All</sub> (MN/m)	Allowable Shear Strength for all wall $\phi Vn = \phi 8 h f_c^{0.5}$ (MN/m)	N <sub>xy_All</sub> ∕∳V <sub>n</sub>
I	6037	7011	2.617	0.90	2.236%		0.70			
T	6038	7011	2.747	0.90	2.236%		0.74			
T	6039	7011	2.358	0.90	2.236%		0.63			
1	6040	7011	2.229	0.90	2.236%		0.60			
I.	6041	7011	2.433	0.90	2.236%		0.65			
East Wa EL-2.0m	6042	7021	2.847	0.90	2.236%	0.700	0.76			
~ EL-0.22r	6043	7021	3.502	0.90	2.236%	3.729	0.94	2.785	2.983	0.93
T	6044	7011	3.058	0.90	2.236%		0.82			
L	6045	7011	2.777	0.90	2.236%		0.75			
1	6046	7011	2.799	0.90	2.236%		0.75			
L	6047	7011	3.088	0.90	2.236%		0.83			
I	6048	7011	2.962	0.90	2.236%		0.79			

#### Table B-2 Maximum Stress Ratios for In-Plane Shear Check for East Wall EL-2.0m~EL0.22m



WG3-U73-ERD-S-0004	SH NO.213
REV.2	of 219

	Table B-3 Maximum Stress Ratios for In-Plane Shear Check for East Wall EL9.06m~EL10.61m									
Location	Element ID	Load 1D	Total In- Plane Shear N <sub>xy</sub> (MN/m) *	Thickness h (m)	Primary Reinforce -ment Ratio	Allowable Shear Strength for individual wall $\phi V_n = \phi 10 h f_c^{0.5}$ (MN/m)	N <sub>xy</sub> ∕¢V <sub>n</sub>	Total In- Plane Shear N <sub>xy_Alt</sub> (MN/m) *	Allowable Shear Strength for all wall $\phi V_n = \phi 8 h f_c^{0.5}$ (MN/m)	N <sub>xy_All</sub> ∕¢V <sub>n</sub>
1	6109	7021	1.394	0.70	1.797%		0.48	1.324	2.320	0.57
I	6110	7021	1.577	0.70	1.797%		0.54			
I	6111	7021	1.404	0.70	1.797%		0.48			
I	6112	7021	1.580	0.70	1.797%		0.55			
I	6113	7021	0.677	0.70	1.797%		0.23			
East Wall E_9.06m	6114	7011	1.310	0.70	1.797%	2 000	0.45			
~ EL10.61m	6115	7011	1.358	0.70	1.797%	2.900	0.47			
I	6116	7021	0.716	0.70	1.797%		0.25			
I	6117	7021	1.426	0.70	1.797%		0.49			
1	6118	7021	1.357	0.70	1.797%		0.47			
1	6119	7021	1.591	0.70	1.797%		0.55			
1	6120	7021	1.501	0.70	1.797%		0.52			

# Table B-3 Maximum Stress Ratios for In-Plane Shear Check for East Wall

Note\*: The reduction of thermal stress due to cracking is considered.



I

7

ł

WG3-U73-ERD-S-0004	SH NO.214
REV. 2	of 219

EL9.06m~EL10.61m										
Location	Element ID	Load ID	Total In- Plane Shear N <sub>xyl</sub> (MN/m)	Thickness <i>h</i> (m)	Primary Reinforce -ment Ratio	Allowable Shear Strength for individual wall $\phi V_n = \phi 10h T_c^{0.5}$ (MN/m)	N <sub>xy</sub> ∕¢Vn	Total In- Plane Shear N <sub>xy_All</sub> (MN/m)	Allowable Shear Strength for all wall ¢V <sub>n</sub> =¢8hf <sup>*</sup> c <sup>0.5</sup> (MN/m)	N <sub>xy_All</sub> ∕¢Vn
l	4091	7021	2.461	0.70	1.797%		0.85		2 220	
1	4092	7021	2.146	0.70	1.797%		0.74			
I	4093	7021	1.948	0.70	1.797%		0.67			
. 1	4094	7021	1.595	0.70	1.797%		0.55			
South Wall EL9.06m	4095	7021	1.182	0.70	1.797%		0.41			
~ EL10.61m	4096	7021	1.148	0.70	1.797%	2.900	0.40	1.924	2.320	0.03
Ι	4097	7021	1.578	0.70	1.797%		0.54	-		
Ι	4098	7021	1.950	0.70	1.797%		0.67			
Ι	4099	7021	2.162	0.70	1.797%		0.75			
I	4100	7021	2.465	0.70	1.797%		0.85			

# Table B-4 Maximum Stress Ratios for In-Plane Shear Check for South Wall EL 0.06 EL 10.61



### APPENDIX C | COMPRESSION LIMIT CHECK FOR THE CB ACCORDING TO ACI 349-01


 WG3-U73-ERD-S-0004
 SH NO.216

 REV. 2
 of 219

# **TABLE OF CONTENTS**

Scope	217
Compression Limit Per ACI 349-01	217
Conclusions	218
	Scope Compression Limit Per ACI 349-01 Conclusions

# LIST OF TABLES

## LIST OF FIGURES

### NONE



### C.1 SCOPE

Although the CB is not structurally integrated with the containment structure, its section design is conservatively taken to be the more limiting of ACI 349-01 (Reference 2.2-a) and 2004 ASME Section III, Division 2, Subsection CC (Reference 2.2-b) requirements and utilizes the existing code conformance check algorithm of the SSDP-2D computer code. A discussion of the SSDP-2D computer program is provided in Section 6.4.1.1.

The membrane compression check that is described in Section 6.4.1.2 is based on provisions outlined in Subsection CC-3420 of ASME-2004 (Reference 2.2-b). Table 7.3-11 summarizes the results of this ASME membrane compression check. The allowable stresses in Table 7.3-11 are equal to those in Table 6.4-4. In order to demonstrate that the CB design also satisfies the requirements of ACI 349-01 (Reference 2.2-a), this appendix describes the compression limit check for the CB according to ACI 349-01 provisions.

#### C.2 COMPRESSION LIMIT PER ACI 349-01

According to Section 10.3.5.2 of ACI 349-01 (Reference 2.2-a), the design axial load strength,  $\phi P_n$ , of nonprestressed compression members with the reinforcement shall not be taken greater than the following:

$$\phi P_{n(\max)} = 0.80 \phi \left[ 0.85 f_c' \left( A_g - A_{st} \right) + f_y A_{st} \right]$$
(C-1)

In the Equation C-1,  $A_g$  is defined as the gross area of section and  $A_{st}$  as the total area of longitudinal reinforcement. Section 10.0 of ACI 349-01 (Reference 2.2-a) defines the ratio of nonprestressed tension reinforcement,  $\rho$ , as follows:

$$\rho = \frac{A_s}{bd} \tag{C-2}$$

Where:

 $A_s$  = area of nonprestressed tension reinforcement

b = width of compression face of member

d = distance from extreme compression fiber to centroid of tension reinforcement

Assuming that  $A_g \approx bd$  and  $A_s = A_{st}$ , Equation C-2 can be re-written as follows:

$$A_{st} = \rho A_g \tag{C-3}$$

Since ACI 349-01 (Reference 2.2-a) provides allowable design strengths and not stresses, an equivalent allowable stress for compression,  $\sigma_a$ , is defined as follows:

$$\sigma_a = \frac{\phi P_{n(\max)}}{A_g} \tag{C-4}$$



WG3-U73-ERD-S-0004	SH NO.218
REV. 2	of 219

Combining Equations C-1, C-3, and C-4 results in the following equation for the allowable stress for compression,  $\sigma_a$ , used in the checks performed in this appendix:

$$\sigma_{a} = 0.80 \phi \left[ 0.85 f_{c}'(1-\rho) + \rho f_{y} \right]$$
(C-5)

Where:

- $\phi = 0.7$  (strength reduction factor for axial compression and axial compression with flexure per Section 9.3.2.2(b) of Reference 2.2-a)
- $f_c'$  = specified compressive strength of concrete from Table 6.4-1
- $\rho$  = sum of the primary reinforcement ratio at each face (top/inside and bottom/outside) for each Element ID in Table 7.2-1

 $f_y$  = specified yield strength of nonprestressed reinforcement from Table 6.4-1

#### C.3 CONCLUSIONS

The results of the ACI 349-01 compression limit check are shown in Table C-1. The results confirm that the calculated compressive stresses are less than the equivalent allowable stress calculated using Equation C-5. Therefore, the CB design meets the compression limit requirements of ACI 349-01 (Reference 2.2-a), as shown by the results of this appendix, as well as the membrane compression limit requirements of ASME-2004 (Reference 2.2-b), as shown by the results in Table 7.3-11.

HITACHI

WG3-U73-ERD-S-0004	SH NO.219
REV. 2	of 219

		1	Calculated Concrete Stress <sup>*1</sup>				Total Primary	Allowable	
Location	Element	Load	σχ	σγ	τ <sub>xy</sub>	σc	Ratio <sup>2</sup>	Stress <sup>3,4</sup>	$\sigma_c/\sigma_a$
		D	(MPa)	(MPa)	(MPa)	(MPa)	ρ(%)	Ga (INIT A)	
Basemat	67	3004	1.0	1.1	0.0	1.1	0.670	14.6	0.08
EL-7.4m	72	3001	1.3	0.3	0.0	1.3	0.670	14.6	0.09
	115	7001	1.9	0.6	-0.5	2.0	0.670	14.6	0.14
	120	3004	1.0	0.5	-0.1	1.0	0.670	14.6	0.07
SlabB1F	567	3002	3.4	0.7	0.0	3.4	2.012	18.6	0.18
EL-2.0m	572	3004	5.2	2.1	0.4	5.2	2.012	18.6	0.28
	615	7021	3.5	1.1	-2.2	4.8	2.012	18.6	0.26
	620	3004	2.4	1.2	3.1	5.0	2.012	18.6	0,27
Slab 1F	1067	4022	2.6	1.1	0.0	2.6	2.012	18.6	0.14
EL4.65m	1072	7021	2.1	4.4	-0.5	4.5	2.012	18.6	0.24
	1115	7021	3.8	0.5	0.9	4.0	2.012	18.6	0.22
	1120	7021	4.8	4.3	-4.1	8.6	2.012	18.6	0.46
Slab 2F	1567	7021	5.2	2.2	-0.1	5.2	2.012	18.6	0,28
EL9.06m	1572	7021	1.8	7.6	-1.1	7.8	2.012	18.6	0.42
	1615	7021	6.6	-1.0	-0.4	6.6	2.012	20.8	0.32
	1620	7021	6.6	6.6	-8.2	14.8	2.012	18.6	0.80
Slab RF	1867	7001	0.3	0.3	-0.1	0.4	2.156	18.6	0.02
EL13.8m	1872	7001	0.7	1.4	-0.9	2.0	2.156	18.6	0.11
	1915	7001	2.0	0.8	-0.7	2.3	2.156	18.6	0.12
	1920	7021	0.5	0.7	0.7	1.3	2.156	18.6	0.07
Wall	6007	7001	2.3	1.9	-2.3	4.4	2.236	21.2	0.21
EL-7.4m	4006	7001	1.3	2.2	-1.3	3.2	2.236	21.2	0.15
~EL-2.0m	4010	7001	0.9	1.6	-1.0	2.3	2.236	21.2	0.11
Wall	6043	7001	1.6	2.8	-3.1	5.4	2.236	21.2	0.25
EL-2.0m	4036	70Ó1	1.5	1.7	2.4	3.9	2.236	21.2	0.18
~EL4.65m	4040	7001	1.0	3.2	2.6	4.9	2.236	21.2	0.23
\A/all	6081	7011	3.1	1.6	2.1	4.6	2.236	18.6	0.25
EL4.65m	4066	7011	2.9	1.0	2.0	4.2	2.236	18.6	0.23
~EL9.06m	4070	7011	1.9	1.8	3.2	5.0	2.236	18.6	0.27
Wall EL9.06m ~EL13.8m	6117	7001	1.3	1.4	1.3	2.6	1.797	18.6	0.14
	4096	7001	1.1	0.8	1.4	2.4	1.797	18.6	0.13
	4100	7001	0.2	0.7	1.5	2.0	1.797	18.6	0.11

 Table C-1 Compression Limit Check According to ACI 349-01

Notes:

\*1: Calculated concrete stress values are obtained from Table 7.3-11.

\*2: Total primary reinforcement ratio is obtained by summing the primary reinforcement ratio at each face (top/inside and bottom/outside) for each Element ID in Table 7.2-1. As shown in Table 7.2-1, the ratios for Direction 1 and Direction 2 are the same for each Element ID.

\*3: The allowable stress is calculated according to Equation C-5 of this appendix.

\*4: For the section without shear tie, the reinforcement limit of 1% is applied according to Section 14.3.6 of ACI 349-01.

*g*E