

PUBLIC MEETING AGENDA

Public Meeting to Discuss the Draft Subsequent License Renewal Guidance Documents

April 26, 2016, 08:30 AM to 04:00 PM

NRC One White Flint North, Commission Hearing Room
11555 Rockville Pike
Rockville, MD

<i>Time</i>	<i>Topic</i>
08:30AM - 08:45AM	Opening Remarks
08:45AM - 10:45AM	<ul style="list-style-type: none"> ● Significant Issue No. 9: Fire Water System Blockage (AMP XI.M27, Fire Water System) ● Significant Issue No. 10: Surface Exams for Aluminum (AMP XI.M36, External Surface Monitoring of Mechanical Components, and AMP XI.M38, Inspection of Internal Surfaces in Miscellaneous Piping and Ducting Components) ● Attachment 2: Comment Nos. 4-6 – Aluminum and Stainless Steel Cracking and Loss of Material ● Attachment 2: Comment No. 7 – Stainless Steel and Nickel Alloy in Treated Water ● Attachment 2: Comment No. 3 – Long-term Loss of Material ● Attachment 2: Comment No. 16 – Stainless Steel, Nickel Alloy, Copper Alloy in Air Indoor Environment ● Attachment 2: Comment Nos. 37-41 – Air Definitions and AMP XI.M24, Compressed Air Monitoring ● Attachment 4: AMP XI.M36 and AMP XI.M38 – Acceptance Criteria (Staff seeking clarification) ● Attachment 4: AMP XI.M32, One-Time Inspection – Reduction in Site Wide Inspections ● Attachment 4: AMP XI.M33, Selective Leaching – Reduction in Destructive Examinations ● Attachment 4: AMP XI.M42, Internal Coatings/Linings for In-Scope Piping, Piping Components, Heat Exchangers, and Tanks – Acceptance of Blisters and FSAR Supplement
10:45AM - 11:00AM	Break
11:00AM - 12:30PM	<ul style="list-style-type: none"> ● Attachments 2 and 3: Managing Aging Effects of PWR Vessel Internals for SLR (AMP XI.M16A)
12:30PM - 01:30PM	Lunch
01:30PM - 02:30PM	<ul style="list-style-type: none"> ● Attachment 3: AMP X.M2, Neutron Fluence Monitoring ● Attachment 5: AMP XI.M31, Reactor Vessel Material Surveillance
02:30PM - 03:00PM	<ul style="list-style-type: none"> ● Attachment 3: AMP XI.M5, Boiling Water Reactor Feedwater Nozzle ● Attachment 3: AMP XI.M7, Boiling Water Reactor Stress Corrosion Cracking ● Attachment 3: AMP XI.M11B, Cracking of Nickel-Alloy Components and Loss of Material Due to Boric Acid-Induced Corrosion in Reactor Coolant Pressure Boundary Components (Pressurized Water Reactors Only)
03:00PM - 03:30PM	<ul style="list-style-type: none"> ● Attachment 3: AMP XI.M18, Bolting Integrity ● Attachment 3: AMP XI.M20, Open-Cycle Cooling Water System

The time of the meeting is local to the jurisdiction where the meeting is being held.

The NRC provides reasonable accommodation to individuals with disabilities where appropriate. If reasonable accommodation is needed to participate in this meeting, or if a meeting notice, transcript, or other information from this meeting is needed in another format (e.g., Braille, large print), please notify the NRC meeting contact. Determinations on requests for reasonable accommodation will be made on a case-by-case basis.

ADAMS Accession Number: ML16106A293

OFFICIAL RECORD COPY

Link to meeting details: <http://meetings.nrc.gov/pmns/mtg?do=details&Code=20160438>