

## **NRR-PMDAPem Resource**

---

**From:** George, Andrea  
**Sent:** Thursday, March 31, 2016 2:32 PM  
**To:** BICE, DAVID B (ANO)  
**Cc:** CLARK, ROBERT W  
**Subject:** DRAFT Request for Additional Information - License Amendment Request to Adopt TSTF-426 - CAC No. MF7213  
**Attachments:** MF7213 - Draft RAI.docx  
**Importance:** High

Mr. Bice,

By letter dated December 22, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15356A657), Entergy Operations, Inc. (the licensee), submitted a license amendment request (LAR) to adopt Technical Specification (TS) change traveler (TSTF)-426, "Revise or Add Actions to Preclude Entry into LCO 3.0.3 – RITSTF Initiatives 6b & 6," Revision 5, at Arkansas Nuclear One, Unit 2 (ANO-2). The proposed change would provide a short Allowable Outage Time to restore an inoperable system for conditions under which the current ANO-2 TSs would require a plant shutdown.

In the course of its review, the U.S. Nuclear Regulatory Commission (NRC) staff has determined that additional information is required in order to complete its evaluation. The draft request for additional information (RAI) is attached to this email. Please review the RAI and let me know if a clarification call is needed by April 6, 2016. If a call is needed, provide some days/times when your staff is available. Please confirm receipt of this email.

Sincerely,

Andrea George  
Project Manager  
U.S. Nuclear Regulatory Commission  
Division of Operating Reactor Licensing  
[andrea.george@nrc.gov](mailto:andrea.george@nrc.gov)  
301-415-1081

**Hearing Identifier:** NRR\_PMDA  
**Email Number:** 2784

**Mail Envelope Properties** (Andrea.George@nrc.gov20160331143200)

**Subject:** DRAFT Request for Additional Information - License Amendment Request to Adopt TSTF-426 - CAC No. MF7213  
**Sent Date:** 3/31/2016 2:32:13 PM  
**Received Date:** 3/31/2016 2:32:00 PM  
**From:** George, Andrea

**Created By:** Andrea.George@nrc.gov

**Recipients:**  
"CLARK, ROBERT W" <RCLARK@entergy.com>  
Tracking Status: None  
"BICE, DAVID B (ANO)" <DBICE@entergy.com>  
Tracking Status: None

**Post Office:**

| <b>Files</b>            | <b>Size</b> | <b>Date &amp; Time</b> |
|-------------------------|-------------|------------------------|
| MESSAGE                 | 1293        | 3/31/2016 2:32:00 PM   |
| MF7213 - Draft RAI.docx | 22795       |                        |

**Options**  
**Priority:** High  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**

# DRAFT

## REQUEST FOR ADDITIONAL INFORMATION

### LICENSE AMENDMENT REQUEST TO ADOPT TSTF-426

#### ENTERGY OPERATIONS, INC.

#### ARKANSAS NUCLEAR ONE, UNIT 1

#### DOCKET NO. 50-313

By letter dated December 22, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15356A657), Entergy Operations, Inc. (Entergy, the licensee) submitted a license amendment request (LAR) to adopt Technical Specification (TS) change traveler (TSTF)-426, "Revise or Add Actions to Preclude Entry into [Limiting Condition for Operation] LCO 3.0.3 – RITSTF Initiatives 6b & 6c," Revision 5, for Arkansas Nuclear One, Unit 2 (ANO-2). The proposed change would provide a short Allowable Outage Time to restore an inoperable system for conditions under which the current ANO-2 TSs would require a plant shutdown. In order for the U.S. Nuclear Regulatory Commission (NRC) staff to complete its review of the LAR, additional information is requested which is detailed below.

#### REGULATORY BASIS

Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50.36(c)(2)(i) states the following, in part:

Limiting conditions for operation are the lowest functional capability or performance levels of equipment required for safe operation of the facility. When a limiting condition for operation of a nuclear reactor is not met, the licensee shall shut down the reactor or follow any remedial action permitted by the technical specifications until the condition can be met.

#### REQUEST FOR ADDITIONAL INFORMATION

In the LAR dated December 22, 2015, the licensee requests to modify TS LCO 3.6.2.1, "Containment Spray System," in accordance with TSTF-426, according to the variation from the TSTF described in "Variation 2 – Containment Spray" in Section 2.2 of the LAR. The LAR states that the ANO-2 TSs diverge from the Standard TSs (STS) in that the Containment Spray System and Containment Cooling System each have their own TSs, as opposed to being combined in the STS. However, the LAR does not explain how the proposed changes to TS LCO 3.6.2.1 may affect TS LCO 3.6.2.3, "Containment Cooling System." Since the requirements of containment spray and containment cooling are separate in the ANO-2 TSs, it is unclear to the NRC staff how the TSs, as modified, would ensure containment pressure and temperature control is available during all the Modes of Applicability.

Please explain how the proposed changes to TS LCO 3.6.2.1, along with the current (unchanged) TS LCO 3.6.2.3 ensure containment pressure and temperature control is available during all the Modes of Applicability.