

# The Light company

Houston Lighting & Power South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

April 23, 1992

ST-HL-AE-4009  
File No.: G09.16  
P11.1  
M5.2

10CFR50

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

South Texas Project  
Units 1 and 2  
Docket Nos. STN 50-498, STN 50-499  
Revision of Commitment Regarding Use of Backing Rings

Reference: Correspondence from G. W. Oprea, Jr. (HL&P) to  
J. T. Collins (NRC) dated December 9, 1982  
(ST-HL-AE-918)

By correspondence referenced above, Houston Lighting & Power Company (HL&P) committed to revise welding procedures to be used for welds on the Essential Cooling Water (ECW) System. Based on recent operating experience at the South Texas Project (STP), HL&P has determined that revision of these commitments for new welds is necessary.

The previous commitments were as follows:

1. Bechtel and Ebasco procedures now require a backing ring configuration which improves root weldability and avoids root lack of fusion.
2. All welders are qualified by radiography to ASME Code, Section IX.
3. Additionally, all ECW welders are subjected to further skill demonstration tests on full-scale mock-ups in the horizontal and vertical positions. These welds are subjected to radiographic examination. Each welder's workmanship must produce x-ray quality welds prior to the performance of production welding.

290015  
MISC\92-042.003

A Subsidiary of Houston Industries Incorporated

9204300009 920423  
PDR ADDCK 05000498  
P PDR


4047 / 10

The earlier requirements for welding processes on the ECW System are being replaced as follows:

1. Use of permanent backing rings or temporary backing rings will be optional on new welds. Double welded or open butt welds may also be used. Weld joint types without backing rings have been determined to provide quality equivalent to or better than backing ring welds.
  
- 2&3) Skill demonstrations on a full-scale mock-up will not be required of welders. However, all welders will be qualified with radiographic examination. Experience gained during the construction phase and during operation indicates that the skill demonstrations, while consuming considerable material, do not enhance the performance beyond the Code performance test, provided the welder is qualified by radiography.

Welding processes for the ECW system will comply with the requirements of the ASME Code, Section III, Class 3, and ASME Code, Section IX.

If there are any questions on this matter, please contact either Mr. P. L. Walker at (512) 972-8392, or me at (512) 972-7205.

  
William J. Jump  
Manager,  
Nuclear Licensing

PLW/lf

Houston Lighting & Power Company  
South Texas Project Electric Generating Station

ST-HL-AE-4009  
File No.: G09.16  
Page 3

cc:

Regional Administrator, Region IV  
Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011

George Dick, Project Manager  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

J. I. Tapia  
Senior Resident Inspector  
c/o U. S. Nuclear Regulatory  
Commission  
P. O. Box 910  
Bay City, TX 77414

J. R. Newman, Esquire  
Newman & Holtzinger, P.C.  
1615 L Street, N.W.  
Washington, DC 20036

D. E. Ward/T. M. Puckett  
Central Power and Light Company  
P. O. Box 2121  
Corpus Christi, TX 78403

J. C. Lanier/M. B. Lee  
City of Austin  
Electric Utility Department  
P.O. Box 1088  
Austin, TX 78767

K. J. Fiedler/M. T. Hardt  
City Public Service Board  
P. O. Box 1771  
San Antonio, TX 78296

Rufus S. Scott  
Associate General Counsel  
Houston Lighting & Power Company  
P. O. Box 61867  
Houston, TX 77208

INPO  
Records Center  
1100 Circle 75 Parkway  
Atlanta, GA 30339-3064

Dr. Joseph M. Hendrie  
50 Bellport Lane  
Bellport, NY 11713

D. K. Lacker  
Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, TX 78756-3189

Revised 10/11/91

L4/NRC/