

---

---

## RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

### APR1400 Design Certification

Korea Electric Power Corporation / Korea Hydro & Nuclear Power Co., LTD

Docket No. 52-046

RAI No.: 183-8197  
SRP Section: 03.07.02 – Seismic System Analysis  
Application Section: 3.7.2  
Date of RAI Issue: 08/31/2015

---

### **Question No. 03.07.02-2**

10 CFR 50 Appendix S requires that the safety functions of structures, systems, and components (SSCs) must be assured during and after the vibratory ground motion associated with the safe shutdown earthquake (SSE) ground motion through design, testing, or qualification methods. In accordance with 10 CFR 50 Appendix S, the staff reviews the adequacy of the seismic analysis methods used to demonstrate that SSCs can withstand seismic loads and remain functional. Per the guidance in SRP Section 3.7.2.II.12, if both the time history analysis (THA) method and the response spectrum analysis (RSA) method are used to analyze an SSC, the peak responses obtained from these two methods should be compared, to demonstrate approximately equivalency between the two methods. The comparison of the RSA and the THA methods is also important since the RSA method only utilizes the translational response spectra at the basemat of the NI as input to the containment and containment internal structures without consideration of the rotational input at the basemat. Staff review finds that while DCD Sections 3.7.2.1.1 and 3.7.2.1.2 identify the RSA and THA methods, respectively, as methods used in the analysis/design of APR1400 standard plant structures, a comparison between the peak responses obtained from these methods is not provided. Further, the staff finds that DCD Section 3.7.2.11, Comparison of Responses, is inconsistent with DCD Section 3.7.2.1.1. Specifically, DCD Section 3.7.2.1.1 states that RSA is used to compute the seismic design forces of the containment structure and internal structure in the reactor containment building using the in-structure response spectra (ISRS) at the top of basemat generated from seismic soil-structure interaction (SSI) analysis. However, DCD Section 3.7.2.11 states that only the THA method based on complex frequency response method is used for seismic Category I structures, and comparison with the RSA method is not applicable. Further, DCD Table 3.7-9, Summary of Models and Analysis Methods, state that maximum member forces and moments for the Nuclear Island (NI) are obtained from SASSI. Additionally this table does not identify the RSA as an analysis method used for the APR1400 standard plant.

Staff review also finds inconsistent information regarding the description of the analysis methods used for the auxiliary building (AB) and emergency diesel generator building (EDGB)/diesel fuel oil tank (DFOT). Specifically, while DCD Table 3.7-9 states that maximum

member forces and moments for the NI (which includes the AB) and EDGB/DFOT are obtained from the SASSI analysis, DCD Sections 3.8A.2.3.1 and 3.8A.3.3.1, for the AB and EDGB respectively, indicate that an equivalent static method of analysis is performed to obtain the member forces for these structures. Further, DCD Table 3.7-9, does not identify the equivalent static method as an analysis method used for the APR1400 standard plant.

In addition, DCD Section 3.7.2.1 also describes the time history modal superposition method of analysis. However, DCD Table 3.7-9 does not identify such analysis. Based on the above, in order to assist the staff in assessing whether the acceptance criteria in SRP Section 3.7.2 II.12 have been adequately addressed, and to assist the staff in reviewing the adequacy of the analysis methods used for seismic Category I structures and the use of the respective analysis results, the applicant is requested to provide the following additional information.

- a) Per SRP Section 3.7.2 II.12, provide comparisons between time history and response spectrum analysis results for the containment structure and containment internal structure and correct the inconsistencies between DCD Sections 3.7.2.1 and 3.7.2.11 regarding the use of the RSA method.
- b) Update DCD Table 3.7-9 to show all the seismic analysis methods used for seismic Category I structures (including seismic analysis methods used for seismic design) and clearly identify the analysis model (including damping values used and consideration of uncracked and cracked stiffnesses), analysis method, computer program, purpose of the analysis, type of building response(s) (e.g., ISRS, member forces, displacements), and section in the DCD and/or technical reports where these are explained and figures are given for each respective model. This table should include the use of multiple models for structures such as the containment, which utilizes the global model, partial model, and containment basemat model. Further, correct inconsistencies between the information in Table 3.7-9 and respective DCD sections related to the NI and EDGB/DFOT structures, such as those mentioned above.
- c) As applicable, delete DCD descriptions of analysis methods that are not currently used in the analysis of seismic Category I SSCs. As an example, while DCD Section 3.7.2.1.2 describes the time history modal superposition method of analysis, the staff has not been able to identify in the DCD and/or technical reports where this method of analysis is used. If it is used or is a candidate for use in the analysis of seismic Category I systems and components, identify the applications.

## **Response**

- a) Time history analysis (THA) is used only for the seismic analysis subjected to the SSE ground motions to generate in-structure response spectra and story shear forces. As described in the end of DCD Tier 2, Subsection 3.7.2.1.1, the response spectrum analysis (RSA) method is used to compute the seismic design forces in DCD Tier 2, Section 3.8 using the in-structure response spectra generated from the seismic soil-structure interaction analysis results. Since the RSA method is not used in seismic analyses described in DCD Tier 2, Subsection 3.7.2, there is no inconsistency between DCD Tier 2, Subsections 3.7.2.1 and 3.7.2.11. To avoid confusion regarding the use of the RSA method, DCD Tier 2, Subsection 3.7.2.1 will be revised, as indicated in the attachment associated with this response.

The story shear forces of the containment structure and the containment internal structure obtained from RSA are compared to the THA (i.e., SASSI analysis) results in Table 1, below.

Table 1. Comparison of Story Shear Forces between RSA and THA Methods

Structure	Elevation (ft)	Story Shear Force (kips)						Difference Ratio (b/a)		
		THA Method (a)			RSA Method (b)			Fx	Fy	Fz
		Fx	Fy	Fz	Fx	Fy	Fz			
CS	307.5	11954	12241	11689	11901	12855	15346	1.00	1.05	1.31
	281	23050	23652	21865	23785	25697	29413	1.03	1.09	1.35
	254.5	30470	31470	28875	33974	36713	41720	1.12	1.17	1.44
	241	34593	35860	32942	38645	41774	47816	1.12	1.16	1.45
	220	45434	47225	41715	47353	51106	59609	1.04	1.08	1.43
	200	51174	53268	48421	52462	56667	66986	1.03	1.06	1.38
	178	55865	58228	54609	57699	62448	74805	1.03	1.07	1.37
	156	59594	62051	59996	61757	66790	80814	1.04	1.08	1.35
	136	61628	65537	63572	66018	71405	87120	1.07	1.09	1.37
	125	62546	67161	64893	67211	72710	88878	1.07	1.08	1.37
	114	64974	70071	67263	68705	74329	91092	1.06	1.06	1.35
	100	66601	72022	69076	69685	75374	92542	1.05	1.05	1.34
78	67954	73819	70984	70311	76021	93534	1.03	1.03	1.32	
CIS	191	241	264	139	533	574	331	2.21	2.17	2.38
	156	7466	9499	5140	12507	10218	13281	1.68	1.08	2.58
	136.5	15585	12707	12917	19687	15713	19331	1.26	1.24	1.50
	130	18693	14400	16558	23305	19028	23162	1.25	1.32	1.40
	114	22481	16947	21329	30378	25947	30014	1.35	1.53	1.41
	100	25806	20022	26346	36058	30668	34014	1.40	1.53	1.29
	78	34098	31075	39020	47110	39472	41051	1.38	1.27	1.05
66	34529	31630	39613	47434	39816	41728	1.37	1.26	1.05	

- b) The seismic analysis models/methods for the SSI analyses are different from the structural analysis models/methods for seismic load and design. For clarification, DCD Tier 2, Table 3.7-9 will be revised and Table 3.8A-40, with its description in Subsection 3.8A.1.4.1.3.1, will be added.
- c) DCD Tier 2, Subsection 3.7.2.1.2 describes seismic analysis methods that are used not only in the seismic Category I systems, but also in the seismic Category I subsystems, such as the RCS components and piping systems. DCD Tier 2, Subsection 3.7.2.1.2 will be revised to clarify that the time history modal superposition method is a candidate for use in the analysis of seismic Category I structures, systems, and components.

### Impact on DCD

DCD Tier 2, Subsections 3.7.2.1, 3.7.2.1.2, 3.8A.1.4.1.3.1 and Table 3.7-9 will be revised, and Table 3.8A-40 will be added, as indicated in the attachment associated with this response.

**Impact on PRA**

There is no impact on the PRA.

**Impact on Technical Specifications**

There is no impact on the Technical Specifications.

**Impact on Technical/Topical/Environmental Reports**

There is no impact on any Technical, Topical, or Environmental Report.

**APR1400 DCD TIER 2**

$\lambda_j$  = damping ratio for the jth mode expressed as fraction of critical damping

$\omega_j$  = circular frequency of the jth mode of the system

$\Gamma_j$  = modal participation factor of the jth mode =  $\frac{\{\phi_j\}^T \{M\} \{1\}}{\{\phi_j\}^T \{M\} \{\phi_j\}}$

The generalized maximum response of each mode is determined from:

$$Y_j(\max) = \Gamma_j \frac{S_{aj}}{\omega_j}$$

Where:

$S_{aj}$  is the spectral acceleration corresponding to frequency  $\omega_j$ .

The maximum displacement at node i relative to the base due to mode j is:

$$X_{ij}(\max) = \phi_{ij} Y_j(\max)$$

The modal response  $X_{ij}(\max)$  is used to determine other modal response quantities, such as forces. The modal combination method is used to obtain the final response by the methods described in Subsection 3.7.2.7.

in Subsection 3.8.1.4.4, 3.8.3.4.1, and Appendix 3.8A

Response spectrum analysis is used to compute only the seismic design forces of the containment structure and internal structure in the reactor containment building using the in-structure response spectra at the top of basemat generated from seismic soil-structure interaction analysis. The seismic response forces obtained from the response spectrum analysis are then combined with other design loads to design structural members of the containment structure and internal structure.


### 3.7.2.1.2 Time-History Methods

The solution of the equation of motion given in Subsection 3.7.2.1.1 is obtained using one of three methods: modal superposition, direct integration, or complex frequency response in the frequency domain.

**APR1400 DCD TIER 2**

The method utilizes mode superposition or direct integration for time-history analysis and is used for as an alternative analysis option for seismic Category I systems and subsystems. The seismic responses of the systems and subsystems that are seismic Category I SSCs are obtained using the finite element method. The analyses of all of the systems are performed for three orthogonal (two horizontal and one vertical) components of in-structure response time histories at the points of attachment.

Modal Superposition Method

The modal superposition method is used when the equations of motion can be decoupled as given in Subsection 3.7.2.1.1. Then the decoupled equation of motion for each mode is integrated using a proven technique, such as those listed in Table 3.2-1 of ASCE 4-98 (Reference 12) and the total response is obtained by superposition method. 

The modal superposition method may be used in dynamic analyses of seismic Category I SSCs.

Direct Integration Method

In this method, the direct integration of the equations of motion by implicit or explicit methods of numerical integration is used to solve the equations of motion. In general implicit methods,  $\Delta T$  is not larger than 1/10 of the shortest period of interest. The direct integration method is used to validate coarse mesh model to be used in the seismic analysis of the nuclear island structures versus fine mesh model under the fixed-base condition.

Complex Frequency Response Method

The equation of motion can also be solved in the frequency domain using the complex frequency response method. In this method, the transfer functions are first determined and the applied forces are then transformed into the frequency domain. The fast Fourier transform (FFT) algorithm is commonly used for the transformation between the time domain and frequency domain. To facilitate the FFT operation, the total number of digitized points of the excitation time history that is used is a power of 2, which can be achieved by a process known as zero padding, which involves adding trailing zeros to the input ground motion. For damped systems, the trailing zeros also serve as a quiet zone, which allows the transient response motions to die out at the end of the duration to avoid cyclic overlapping in the discrete Fourier transform procedure.

## APR1400 DCD TIER 2

Table 3.7-9 (1 of 2)

## Summary of Models and Analysis Methods

Revise to Table in page 4.

Model	Analysis Method	Program	Type of Dynamic Response/Purpose
Reactor containment building fine-mesh model	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Direct integration time-history analysis</li> </ul>	ANSYS	To verify the mesh sizes of reactor containment building coarse-mesh model
Auxiliary building fine-mesh model	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Direct integration time-history analysis</li> </ul>	ANSYS	To verify the mesh sizes of auxiliary building coarse-mesh model
Reactor containment building coarse-mesh model	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Direct integration time-history analysis</li> </ul>	ANSYS	To create and verify SASSI reactor containment building model
Auxiliary building coarse-mesh model	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Direct integration time-history analysis</li> </ul>	ANSYS	To create and verify SASSI auxiliary building model
SASSI reactor containment building model	<ul style="list-style-type: none"> <li>• Complex frequency response analysis</li> </ul>	ACS SASSI	To create SASSI combined nuclear island model
SASSI auxiliary building model	<ul style="list-style-type: none"> <li>• Complex frequency response analysis</li> </ul>	ACS SASSI	To create SASSI combined nuclear island model
SASSI combined nuclear island model	<ul style="list-style-type: none"> <li>• Complex frequency response analysis</li> </ul>	ACS SASSI	<ul style="list-style-type: none"> <li>• To perform seismic analyses for nine generic soils and one fixed-base case</li> <li>• To develop time histories for generating plant design in-structure response spectra</li> <li>• To obtain maximum absolute nodal acceleration</li> <li>• To obtain maximum displacements relative to basemat and free-field</li> <li>• To obtain maximum member forces and moments</li> </ul>

Table 3.7-9 (1 of 2)

Summary of Models and Analysis Methods

Model	Analysis Method/Damping	Program	Type of Dynamic Response/Purpose	DCD/TeR Subsections
Reactor containment building fine-mesh model for seismic analysis (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Direct integration time- history analysis</li> <li>• OBE damping</li> </ul>	ANSYS	To verify the mesh sizes of the reactor containment building coarse-mesh model for seismic analysis	Technical Reprot APR1400-E-S-NR-14002-P, Section 3
Auxiliary building fine-mesh model for seismic analysis (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Direct integration time- history analysis</li> <li>• OBE damping</li> </ul>	ANSYS	To verify the mesh sizes of the auxiliary building coarse-mesh model for seismic analysis	Technical Reprot APR1400-E-S-NR-14002-P, Section 4
Reactor containment building coarse-mesh model for seismic analysis (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Direct integration time- history analysis</li> <li>• OBE damping</li> </ul>	ANSYS	To create and verify the SASSI reactor containment building model for seismic analysis	Technical Reprot APR1400-E-S-NR-14002-P, Section 3
Auxiliary building coarse-mesh model for seismic analysis (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Direct integration time- history analysis</li> <li>• OBE damping</li> </ul>	ANSYS	To create and verify the SASSI auxiliary building model for seismic analysis	Technical Reprot APR1400-E-S-NR-14002-P, Section 4
SASSI reactor containment building model for seismic analysis (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Complex frequency response analysis</li> <li>• OBE damping</li> </ul>	ACS SASSI	To create the SASSI combined nuclear island model for seismic analysis	Technical Reprot APR1400-E-S-NR-14002-P, Section 5
SASSI auxiliary building model for seismic analysis (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Complex frequency response analysis</li> <li>• OBE damping</li> </ul>	ACS SASSI	To create the SASSI combined nuclear island model for seismic analysis	Technical Reprot APR1400-E-S-NR-14002-P, Section 5
SASSI combined nuclear island model for seismic analysis (Cracked and uncracked stiffness models)	<ul style="list-style-type: none"> <li>• Complex frequency response analysis</li> <li>• OBE damping for uncracked stiffness model</li> <li>• SSE damping for cracked stiffness model</li> </ul>	ACS SASSI	<ul style="list-style-type: none"> <li>• To perform seismic analyses for nine generic soil profiles and one fixed-base case</li> <li>• To develop time histories for generating plant design in-structure response spectra</li> <li>• To obtain maximum absolute nodal acceleration</li> <li>• To obtain maximum displacements relative to the basemat and the free-field</li> <li>• To obtain maximum story shear forces and moments</li> </ul>	Technical Reprot APR1400-E-S-NR-14002-P, Section 6



## APR1400 DCD TIER 2

Table 3.7-9 (2 of 2)

Revise to Table in page 6.

Model	Analysis Method	Program	Type of Dynamic Response/Purpose
EDG building (include DFOT room) model	Modal analysis	GTSTRU DL	<ul style="list-style-type: none"> <li>To create and verify SASSI EDG building (including DFOT room) model</li> </ul>
SASSI EDG building (include DFOT room) model	<ul style="list-style-type: none"> <li>Complex frequency response analysis</li> </ul>	ACS SASSI	<ul style="list-style-type: none"> <li>To perform seismic analyses for nine generic soils and one fixed-base case</li> <li>To develop time histories for generating plant design in-structure response spectra</li> <li>To obtain maximum absolute nodal acceleration</li> <li>To obtain maximum displacements relative to basemat and free-field</li> <li>To obtain maximum member forces and moments</li> </ul>

Table 3.7-9 (2 of 2)

Model	Analysis Method/Damping	Program	Type of Dynamic Response/Purpose	DCD/TeR Subsections
EDG building (include DFOT room) model for seismic analysis (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• OBE damping</li> </ul>	GTSTRU DL	<ul style="list-style-type: none"> <li>• To create and verify the SASSI EDG building (include DFOT room) model for seismic analysis</li> </ul>	DCD Tier 2, Subsection 3.7.2.3.3.2
SASSI EDG building (include DFOT room) model for seismic analysis (Cracked and uncracked stiffness models)	<ul style="list-style-type: none"> <li>• Complex frequency response analysis</li> <li>• OBE damping for uncracked stiffness model</li> <li>• SSE damping for cracked stiffness model</li> </ul>	ACS SASSI	<ul style="list-style-type: none"> <li>• To perform seismic analyses for nine generic soil profiles and one fixed-base case</li> <li>• To develop time histories for generating plant design in-structure response spectra</li> <li>• To obtain maximum absolute nodal acceleration</li> <li>• To obtain maximum displacements relative to the basemat and the free-field</li> <li>• To obtain maximum story shear forces and moments</li> </ul>	DCD Tier 2, Subsection 3.7.2.3.3.2

**APR1400 DCD TIER 2**

Table 3.8A-27	Required Reinforcement and Margins of Safety for the AB Basemat .....	3.8A-75
Table 3.8A-28	Enveloped Design Forces of the AB Shear Wall .....	3.8A-76
Table 3.8A-29	Required Reinforcement and Margins of Safety for the AB Shear Wall .....	3.8A-77
Table 3.8A-30	Enveloped Design Forces of the EDG Room Slab in AB .....	3.8A-78
Table 3.8A-31	Enveloped Design Forces of the SFP Slab in AB .....	3.8A-79
Table 3.8A-32	Enveloped Design Forces of the MSE Slab in AB.....	3.8A-80
Table 3.8A-33	Slab Reinforcement and Margins of Safety at Each Critical Section in AB .....	3.8A-81
Table 3.8A-34	Enveloped Design Forces of the EDG Building Basemat.....	3.8A-82
Table 3.8A-35	Enveloped Design Forces of the EDG Building Shear Wall.....	3.8A-83
Table 3.8A-36	Required Reinforcement and Margins of Safety for the EDG Building Shear Wall .....	3.8A-84
Table 3.8A-37	Required Reinforcement and Margins of Safety for the EDG Building Basemat .....	3.8A-85
Table 3.8A-38	Results on Factor of Safety for Basemat Stability.....	3.8A-86
Table 3.8A-39	EDG & DFOT buildings Differential Settlements According to Site Profiles (Static).....	3.8A-87

<b>Table 3.8A-40 Summary of Models and Analysis Methods</b>
---

**APR1400 DCD TIER 2**

liner plate is not designed as a structural member to resist structural loads on the containment. It is, therefore, not included in the FEM.

The acceptance criteria for the design of the containment wall and dome are defined based on the requirements in Article CC-3000 of ASME Section III, Division 2, and described in Subsection 3.8.1.5. Table 3.8A-1 shows the allowable stresses of concrete and reinforcing steel for service and factored loads, respectively.

Table 3.8A-40 summarizes the types of models, analysis methods, computer programs, and purposes of the structural analyses of the nuclear island structures, the emergency diesel generator building, and the diesel fuel oil storage tank building.

#### 3.8A.1.4.1.3.2 Analysis Model

##### Configuration of Containment Wall and Dome

The overall configuration of the containment wall and dome is shown in Figures 3.8-1 and 3.8-2. The representative dimensions of the containment wall and dome are as follows:

- a. Inside diameter of the containment wall: 45.72 m (150.0 ft)
- b. Inside height from the top of basemat to the dome apex: 76.66 m (251.5 ft)
- c. Height from the top of the basemat to the springline: 53.80 m (176.5 ft)
- d. Thickness of the containment wall: 1.37 m (4.5 ft)
- e. Thickness of the containment dome: 1.22 m (4.0 ft)

An equipment hatch, two personnel airlocks, main steam line penetrations, and three buttresses are included in the analysis model. The locally thickened sections around the equipment hatch and personnel airlock are shown in Figure 3.8-3.

##### Global Model

The global model consists of solid elements for the concrete, truss elements for the tendon, and shell elements for the brackets of the polar crane. An eight-node, linear, solid element (SOLID185) in the ANSYS program is used to model the concrete part of containment wall and dome, including large thickened penetration areas and buttresses. Figure 3.8A-1 shows the schematic view of equipment hatch and personnel airlocks in the FEM. The basemat of

Add Table.

Table 3.8A-40 (1 of 3)

Summary of Models and Analysis Methods

Model	Analysis Method	Program	Purpose	DCD/TeR Subsections
Reactor containment building analysis model (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Response spectrum analysis (SSE damping)</li> <li>• Static analysis</li> <li>• Heat transfer analysis</li> </ul>	ANSYS	To generate the design forces of the reactor containment building shell and dome	DCD Tier 2, Subsection 3.8.1.4.2
Reactor containment building internal structure model (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Response spectrum analysis</li> <li>• Static analysis</li> <li>• SSE damping</li> </ul>	ANSYS	To generate the design forces of the reactor containment building internal structure walls	DCD Tier 2, Subsection 3.8A.3.4.1
Reactor containment building - IRWST hydro-dynamic analysis model (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Direct integration time history analysis</li> </ul>	ANSYS	To generate the floor response spectrum due to the POSRV sparger discharge load	DCD Tier 2, Subsection 3.8A.1.4.3.1.3
NI building common basemat analysis model (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Static analysis</li> <li>• Nonlinear Analysis</li> </ul>	ANSYS	To generate the design forces of the NI common basemat	DCD Tier 2, Subsection 3.8.5.4
Auxiliary building structural analysis model	<ul style="list-style-type: none"> <li>• Static analysis</li> <li>• Equivalent static analysis</li> </ul>	ANSYS	To generate the design forces of the auxiliary building shear walls	DCD Tier 2, Subsection 3.8.4.4
Auxiliary building - SFP hydro-dynamic analysis model (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Static analysis</li> </ul>	ANSYS	To create the auxiliary building SFP hydro-dynamic force	DCD Tier 2, Subsection 3.8A.2.4.2
Auxiliary building - SFP, local analysis model (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Heat transfer analysis</li> <li>• Static analysis</li> </ul>	ANSYS	To generate the design forces of the auxiliary building SFP walls	DCD Tier 2, Subsection 3.8A.2.4.2
Auxiliary building - aux. feed water storage tank hydro-dynamic analysis model (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Modal analysis</li> <li>• Static analysis</li> </ul>	ANSYS	To create the auxiliary building AFWT hydro-dynamic force	DCD Tier 2, Subsection 3.8A.2.4.2

Add Table.

Table 3.8A-40 (2 of 3)

Model	Analysis Method	Program	Purpose	DCD/TeR Subsections
Emergency diesel generator building structural analysis model (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Static analysis</li> <li>• Equivalent static analysis</li> <li>• Nonlinear Analysis</li> </ul>	ANSYS	To generate the design forces of the emergency diesel generator building shear walls	DCD Tier 2, Subsection 3.8.4.4
Diesel fuel oil storage tank building structure analysis model (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Static analysis</li> <li>• Equivalent static analysis</li> <li>• Nonlinear analysis</li> </ul>	ANSYS	To generate the design forces of the diesel fuel oil storage tank building shear walls	DCD Tier 2, Subsection 3.8.4.4
Reactor containment building – combustible gas control inside containment analysis model (Uncracked stiffness model)	<ul style="list-style-type: none"> <li>• Static analysis</li> <li>• Nonlinear analysis</li> </ul>	ABAQUS	To evaluate the structural integrity of the reactor containment building under severe accident pressure in accordance with ASME CC-3720	DCD Tier 2, Subsection 3.8.1.4.12
Reactor containment building - ultimate pressure capacity analysis model	<ul style="list-style-type: none"> <li>• Static analysis</li> <li>• Nonlinear analysis</li> </ul>	ABAQUS	To evaluate the ultimate pressure capacity of the reactor containment building	DCD Tier 2, Subsection 3.8.1.4.11
Reactor containment building - reinforced concrete section model	<ul style="list-style-type: none"> <li>• Static analysis</li> </ul>	DARTEM	To calculate stress and strain of reinforced concrete sections under mechanical and temperature loads	DCD Tier 2, Subsection 3.8A.1.4.1.3.7, 3.8A.1.4.2.3
Auxiliary building - SFP reinforced concrete section model	<ul style="list-style-type: none"> <li>• Static analysis</li> </ul>	DARTEM	To calculate stress and strain of reinforced concrete sections under mechanical and temperature loads	DCD Tier 2, Subsection 3.8A.2.4.2, 3.8A.2.4.3
Reactor containment building - liner plate anchorage system model	<ul style="list-style-type: none"> <li>• Static analysis</li> </ul>	LBAP	To calculate maximum anchor forces and displacements in the liner anchorage systems attached to concrete walls	Not described in DCD
Reactor containment building - liner plate model	<ul style="list-style-type: none"> <li>• Static analysis</li> </ul>	GTSTRU DL	To calculate stresses of the liner plate system	Not described in DCD
Reactor containment building - liner plate model	<ul style="list-style-type: none"> <li>• Static analysis</li> </ul>	ABAQUS	To calculate stresses of the liner plate system	Not described in DCD

Add Table.

Table 3.8A-40 (3 of 3)

Model	Analysis Method	Program	Purpose	DCD/TeR Subsections
Reinforced concrete section model for Steam Generator pedestal	• Static analysis	PCACOL	To evaluate the capacity of concrete pedestal under axial and moment loads	Not described in DCD
Analysis model for Steam Generator bracket support	• Static analysis	GTSTRU DL	To calculate stress of bracket support under design and service level D condition	Not described in DCD
Eembedment plate analysis model for Steam Generator keyway support	• Static analysis	EPAAD	To evaluate the structural integrity of the embedment for Steam Generator keyway support	Not described in DCD
Eembedment plate analysis model for Pressurizer keyway support beam	• Static analysis	EPAAD	To evaluate the structural integrity of the embedment for Pressurizer keyway support beam	Not described in DCD
Reactor containment building – concrete slab analysis model	• Static analysis	GTSTRU DL	To generate the design forces for the concrete slabs of the reactor containment building	Not described in DCD
Auxiliary building – concrete slab analysis model	• Static analysis	GTSTRU DL	To generate the design forces for the concrete slabs of the auxiliary building	DCD Tier 2, Subsection 3.8A.2.4.3