
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

APR1400 Design Certification

Korea Electric Power Corporation / Korea Hydro & Nuclear Power Co., LTD

Docket No. 52-046

RAI No.: 420-8482
SRP Section: 19.03 – Beyond Design Basis External Event
Application Section:
Date of RAI Issue: 02/29/2016

Question No. 19.03-39

NRC Commission paper SECY-12-0025 stated that the NRC staff expected new reactor design certification applications to address the Commission-approved Fukushima actions in their applications to the fullest extent practicable. In performing its review of the APR1400 design certification application, the NRC staff followed the guidance for satisfying the Commission directives regarding BDBEE mitigation strategies in Japan Lesson-Learned Project Directorate JLD-ISG-2012-01, Revision 0, which endorsed with clarifications the methodologies described in NEI 12-06, Revision 0. The guidance in JLD-ISG-2012-01 describes one acceptable approach for satisfying the Commission directives regarding BDBEE mitigation strategies (i.e., Order EA-12-049). TR APR1400-E-P-NR-14005-P, Rev. 0 provides details regarding mitigating strategies and design enhancements to meet Near-Term Task Force (NTTF) recommendations, NRC orders, and agency guidance related mitigation strategy during Beyond Design Basis External Events (BDBEE).

TR, APR1400-E-P-NR-14005-P, Revision 0, Section 5.1.2.6.1.4, "Communications," states in part that portable communication devices will be used.

1. Please discuss how the portable communications equipment are recharged.

Response

Batteries of the portable communication devices are recharged through outlets powered from a power distribution panel for the communication systems. In case of an AAC GTG failure during either a LOOP or an SBO condition, the power distribution panel for the communication systems can be powered from a mobile generator.

Impact on DCD

There is no impact on the DCD.

Impact on PRA

There is no impact on the PRA.

Impact on Technical Specifications

There is no impact on the Technical Specifications.

Impact on Technical/Topical/Environmental Reports

There is no impact on any Technical, Topical, or Environmental Report.