

JPM A1a RO

Developed By: _____ **Date:** _____
Instructor/Developer

Concurred By: _____ **Date:** _____
Line Superintendent/Supervisor/SRO

Approved By: _____ **Date:** _____
Superintendent/Supervisor Training

Job Performance Measure Worksheet

Facility: Robinson

Task No.:

Task Title: Calculate QPTRJPM No.: 2016 Admin – JPM A1a
RO

K/A Reference: 2.1.7 (4.4)

Examinee:

NRC Examiner:

Facility Evaluator:

Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X
 Classroom X Simulator _____ Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Provide Operator with Initial Conditions/Cue (Last Page of this JPM), and Handout 1.

- Initial Conditions:
- The plant is in Mode 1 at 60% RTP.
 - ERFIS is inoperable.
 - The CRS has directed you to perform a Manual QPTR calculation and analyze the results of the calculation.
 - Detector Currents are as follows:
 - N41: Upper – 63 / Normalizing – 123
 - N41: Lower – 55 / Normalizing – 120
 - N42: Upper – 55 / Normalizing – 109
 - N42: Lower – 52 / Normalizing - 110
 - N43: Upper – 50 / Normalizing – 104
 - N43: Lower – 45 / Normalizing – 99
 - N44: Upper – 48 / Normalizing – 97
 - N44: Lower – 45 / Normalizing – 95

- Initiating Cue:
- The CRS has directed you to perform a MANUAL QPTR calculation IAW FMP-007, QUADRANT POWER TILT.
 - Identify any limits that are not being complied with.

Job Performance Measure Worksheet

Task Standard: The operator will complete the QPTR calculation in accordance with the provided KEY, and identify that Technical Specification LCO is NOT met.

Required Materials: Calculator
Robinson Technical Specifications and Basis must be available.

General References: FMP-007 (Quadrant Power Tilt), Rev 15
Robinson Technical Specification LCO 3.2.4 (Quadrant Power Tilt Ratio), Amendment 176

Handouts: Handout 1: Blank copy of FMP-007.

Time Critical Task: NO

Validation Time: 10 minutes

<u>Critical Step Justification</u>	
Step 6	This step is critical because identifying that the maximum Upper Normalized Detector Ratio is N41 (0.512), and dividing it by the Average Upper Normalized Detector Ratio is necessary to complete the QPTR calculation in accordance with the provided KEY.
Step 7	This step is critical because identifying that the maximum Lower Normalized Detector Ratio is N44 (0.474), and dividing it by the Average Lower Normalized Detector Ratio is necessary to complete the QPTR calculation in accordance with the provided KEY.
Step 8	This step is critical because identifying that the Upper QPTR is larger than the Lower QPTR is necessary to complete the QPTR calculation in accordance with the provided KEY.
Step 9	This step is critical because determining that LCO 3.2.4 permits a maximum QPTR of 1.02 when power level is greater than 50% is necessary to identify that Technical Specification LCO is NOT met.

PERFORMANCE INFORMATION

(Critical Steps are identified as such in right-hand column)

Provide Operator with Initial Conditions/Cue (Last Page of this JPM), and Handout 1.

START TIME: _____

<p><u>STEP 1:</u> Read the Upper (A) and the Lower (B) Indicated Detector Currents from the Detector Current meters of each operable Power Range channel and record on ATTACHMENT 10.2. (Step 8.2.4.1)</p> <p><u>STANDARD:</u> The operator records the provided Upper and Lower Detector Currents on Attachment 10.2 IAW the provided KEY.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 2:</u> Record the Upper and Lower Normalizing Detector Currents from the Control Room Status Board for each operable Power Range channel on ATTACHMENT 10.2. (Step 8.2.4.2)</p> <p><u>STANDARD:</u> The operator records the provided Upper and Lower Detector Currents on Attachment 10.2 IAW the provided KEY.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p style="text-align: center;">NOTE:</p> <p>Normalized Ratios, Average Ratios and QPTR values should be recorded to at least 3 decimal places.</p>	

PERFORMANCE INFORMATION

<p><u>STEP 3:</u> Divide each Indicated Detector Current by its corresponding Normalizing Detector Current and record the result as the Normalized Detector Ratio on ATTACHMENT 10.2. (Step 8.2.4.3)</p> <p><u>STANDARD:</u> The operator reads the Note, and proceeds.</p> <p>The operator divides each Indicated Detector Current by its corresponding Normalizing Detector Current and records the result as the Normalized Detector Ratio on ATTACHMENT 10.2 IAW the provided KEY.</p> <p>Upper N41 = <u>0.512</u> Lower N41 = <u>0.458</u> Upper N42 = <u>0.505</u> Lower N42 = <u>0.473</u> Upper N43 = <u>0.481</u> Lower N43 = <u>0.455</u> Upper N44 = <u>0.495</u> Lower N44 = <u>0.474</u></p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 4:</u> Average the Upper Normalized Detector Ratios and record the result as the Average Normalized Detector Ratio in the Upper column on ATTACHMENT 10.2. (Step 8.2.4.4)</p> <p><u>STANDARD:</u> The operator averages the Upper Normalized Detector Ratios and records the result as the Average Normalized Detector Ratio in the Upper column on Attachment 10.2 IAW the provided KEY.</p> <p>Upper Average Normalized Detector Ratio = <u>0.498</u></p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 5:</u> Average the Lower Normalized Detector Ratios and record the result as the Average Normalized Detector Ratio in the Lower column on ATTACHMENT 10.2. (Step 8.2.4.5)</p> <p><u>STANDARD:</u> The operator averages the Lower Normalized Detector Ratios and records the result as the Average Normalized Detector Ratio in the Lower column on Attachment 10.2 IAW the provided KEY.</p> <p>Lower Average Normalized Detector Ratio = <u>0.465</u></p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 6:</u> Determine the maximum Upper Normalized Detector Ratio and divide it by the Average Upper Normalized Detector Ratio and record the resulting Upper QPTR on ATTACHMENT 10.2. (Step 8.2.4.6)</p> <p><u>STANDARD:</u> The operator identifies that the maximum Upper Normalized Detector Ratio is N41 (0.512), and divides it by the Average Upper Normalized Detector Ratio from Performance Step 4 and records the resulting Upper QPTR on Attachment 10.2 IAW the provided KEY.</p> <p>Upper QPTR = $0.512 / 0.498 =$ <u>1.028</u></p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 7:</u> Determine the maximum Lower Normalized Detector Ratio and divide it by the Average Lower Normalized Detector Ratio and record the resulting Lower QPTR on ATTACHMENT 10.2 (Step 8.2.4.7)</p> <p><u>STANDARD:</u> The operator observes that the maximum Lower Normalized Detector Ratio is N44 (0.474), and divides it by the Average Lower Normalized Detector Ratio from Performance Step 5 and records the resulting Upper QPTR on Attachment 10.2 IAW the provided KEY.</p> <p style="text-align: center;">Lower QPTR = $0.474 / 0.465 = 1.019$</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p style="text-align: center;"><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 8:</u> Record larger of the Upper QPTR or the Lower QPTR as the Maximum QPTR on ATTACHMENT 10.2 along with the reactor power and any comments. (Step 8.2.4.8)</p> <p><u>STANDARD:</u> The operator identifies that the Upper QPTR is larger than the Lower QPTR and records the Maximum QPTR as 1.028 ± 0.005 IAW the provided KEY.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p style="text-align: center;"><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 9:</u> Identify any limits that are not being complied with.</p> <p><u>STANDARD:</u> The operator reviews Technical Specification LCO 3.2.4 and determines that with the plant in Mode 1 at greater than 50% power, a maximum QPTR of 1.02 is permitted.</p> <p>The operator identifies that LCO 3.2.4 is NOT met.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
---	--

Terminating Cue: Evaluation on this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

Job Performance Measure No.: 2016 Admin – JPM A1a RO

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Result: SAT _____ UNSAT _____

Examiner's Signature: _____ Date: _____

JPM CUE SHEET

- INITIAL CONDITIONS:
- The plant is in Mode 1 at 60% RTP.
 - ERFIS is inoperable.
 - The CRS has directed you to perform a Manual QPTR calculation and analyze the results of the calculation.
 - Detector Currents are as follows:
 - N41: Upper – 63 / Normalizing – 123
 - N41: Lower – 55 / Normalizing – 120
 - N42: Upper – 55 / Normalizing – 109
 - N42: Lower – 52 / Normalizing – 110
 - N43: Upper – 50 / Normalizing – 104
 - N43: Lower – 45 / Normalizing – 99
 - N44: Upper – 48 / Normalizing – 97
 - N44: Lower – 45 / Normalizing – 95
- INITIATING CUE:
- The CRS has directed you to perform a MANUAL QPTR calculation IAW FMP-007, QUADRANT POWER TILT.
 - Identify any limits that are not being complied with.

JPM A1a SRO

Developed By: _____ **Date:** _____
Instructor/Developer

Concurred By: _____ **Date:** _____
Line Superintendent/Supervisor/SRO

Approved By: _____ **Date:** _____
Superintendent/Supervisor Training

Job Performance Measure Worksheet

Facility: Robinson

Task No.:

Task Title: Calculate QPTRJPM No.: 2016 Admin – JPM A1a
SRO

K/A Reference: 2.1.7 (4.7)

Examinee:

NRC Examiner:

Facility Evaluator:

Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X
 Classroom X Simulator _____ Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Provide Operator with Initial Conditions/Cue (Last Page of this JPM), and Handout 1.

- Initial Conditions:
- The plant is in Mode 1 at 100% RTP.
 - ERFIS is inoperable.
 - The CRS has directed you to perform a Manual QPTR calculation and analyze the results of the calculation.
 - Detector Currents are as follows:
 - N41: Upper – 105 / Normalizing – 123
 - N41: Lower – 92 / Normalizing – 120
 - N42: Upper – 92 / Normalizing – 109
 - N42: Lower – 87 / Normalizing – 110
 - N43: Upper – 83 / Normalizing – 104
 - N43: Lower – 75 / Normalizing – 99
 - N44: Upper – 80 / Normalizing – 97
 - N44: Lower – 75 / Normalizing – 95

- Initiating Cue:
- The CRS has directed you to perform a MANUAL QPTR calculation IAW FMP-007, QUADRANT POWER TILT.
 - Identify whether or not any limitations have been exceeded, and if so, what, if any ACTION, is required.

Job Performance Measure Worksheet

Task Standard: The operator will complete the QPTR calculation in accordance with the provided KEY, identify that Technical Specification LCO is NOT met, and identify that all six ACTIONS (A.1-A.6) must be taken for Condition A of LCO 3.2.4.

Required Materials: Calculator
Robinson Technical Specifications and Basis must be available.

General References: FMP-007 (Quadrant Power Tilt), Rev 15
Robinson Technical Specification LCO 3.2.4 (Quadrant Power Tilt Ratio), Amendment 176

Handouts: Handout 1: Blank copy of FMP-007.

Time Critical Task: NO

Validation Time: 15 minutes

<u>Critical Step Justification</u>	
Step 6	This step is critical because identifying that the maximum Upper Normalized Detector Ratio is N41 (0.854), and dividing it by the Average Upper Normalized Detector Ratio is necessary to complete the QPTR calculation in accordance with the provided KEY.
Step 7	This step is critical because identifying that the maximum Lower Normalized Detector Ratio is N42 (0.791), and dividing it by the Average Lower Normalized Detector Ratio is necessary to complete the QPTR calculation in accordance with the provided KEY.
Step 8	This step is critical because identifying that the Upper QPTR is larger than the Lower QPTR is necessary to complete the QPTR calculation in accordance with the provided KEY.
Step 9	This step is critical because determining that LCO 3.2.4 permits a maximum QPTR of 1.02 when power level is greater than 50% is necessary to identify that Technical Specification LCO is NOT met; and identifying that ACTIONS A.1 through A.6 must be completed is necessary to identify all of the Technical Specification required ACTION.

PERFORMANCE INFORMATION

(Critical Steps are identified as such in right-hand column)

Provide Operator with Initial Conditions/Cue (Last Page of this JPM), and Handout 1.

START TIME: _____

<p><u>STEP 1:</u> Read the Upper (A) and the Lower (B) Indicated Detector Currents from the Detector Current meters of each operable Power Range channel and record on ATTACHMENT 10.2. (Step 8.2.4.1)</p> <p><u>STANDARD:</u> The operator records the provided Upper and Lower Detector Currents on Attachment 10.2 IAW the provided KEY.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 2:</u> Record the Upper and Lower Normalizing Detector Currents from the Control Room Status Board for each operable Power Range channel on ATTACHMENT 10.2. (Step 8.2.4.2)</p> <p><u>STANDARD:</u> The operator records the provided Upper and Lower Detector Currents on Attachment 10.2 IAW the provided KEY.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p style="text-align: center;">NOTE:</p> <p>Normalized Ratios, Average Ratios and QPTR values should be recorded to at least 3 decimal places.</p>	

PERFORMANCE INFORMATION

<p><u>STEP 3:</u> Divide each Indicated Detector Current by its corresponding Normalizing Detector Current and record the result as the Normalized Detector Ratio on ATTACHMENT 10.2. (Step 8.2.4.3)</p> <p><u>STANDARD:</u> The operator reads the Note, and proceeds.</p> <p>The operator divides each Indicated Detector Current by its corresponding Normalizing Detector Current and records the result as the Normalized Detector Ratio on ATTACHMENT 10.2 IAW the provided KEY.</p> <p>Upper N41 = <u>0.854</u> Lower N41 = <u>0.767</u> Upper N42 = <u>0.844</u> Lower N42 = <u>0.791</u> Upper N43 = <u>0.798</u> Lower N43 = <u>0.758</u> Upper N44 = <u>0.825</u> Lower N44 = <u>0.789</u></p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 4:</u> Average the Upper Normalized Detector Ratios and record the result as the Average Normalized Detector Ratio in the Upper column on ATTACHMENT 10.2. (Step 8.2.4.4)</p> <p><u>STANDARD:</u> The operator averages the Upper Normalized Detector Ratios and records the result as the Average Normalized Detector Ratio in the Upper column on Attachment 10.2 IAW the provided KEY.</p> <p>Upper Average Normalized Detector Ratio = <u>0.830</u></p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 5:</u> Average the Lower Normalized Detector Ratios and record the result as the Average Normalized Detector Ratio in the Lower column on ATTACHMENT 10.2. (Step 8.2.4.5)</p> <p><u>STANDARD:</u> The operator averages the Lower Normalized Detector Ratios and records the result as the Average Normalized Detector Ratio in the Lower column on Attachment 10.2 IAW the provided KEY.</p> <p>Lower Average Normalized Detector Ratio = <u>0.776</u></p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 6:</u> Determine the maximum Upper Normalized Detector Ratio and divide it by the Average Upper Normalized Detector Ratio and record the resulting Upper QPTR on ATTACHMENT 10.2. (Step 8.2.4.6)</p> <p><u>STANDARD:</u> The operator identifies that the maximum Upper Normalized Detector Ratio is N41 (0.854), and divides it by the Average Upper Normalized Detector Ratio from Performance Step 4 and records the resulting Upper QPTR on Attachment 10.2 IAW the provided KEY.</p> <p>Upper QPTR = $0.854 / 0.830 =$ <u>1.029</u></p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 7:</u> Determine the maximum Lower Normalized Detector Ratio and divide it by the Average Lower Normalized Detector Ratio and record the resulting Lower QPTR on ATTACHMENT 10.2 (Step 8.2.4.7)</p> <p><u>STANDARD:</u> The operator observes that the maximum Lower Normalized Detector Ratio is N42 (0.791), and divides it by the Average Lower Normalized Detector Ratio from Performance Step 5 and records the resulting Upper QPTR on Attachment 10.2 IAW the provided KEY.</p> <p style="text-align: center;">Lower QPTR = $0.791 / 0.776 = 1.019$</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p style="text-align: center;"><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 8:</u> Record larger of the Upper QPTR or the Lower QPTR as the Maximum QPTR on ATTACHMENT 10.2 along with the reactor power and any comments. (Step 8.2.4.8)</p> <p><u>STANDARD:</u> The operator identifies that the Upper QPTR is larger than the Lower QPTR and records the Maximum QPTR as 1.029 ± 0.005 IAW the provided KEY.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p style="text-align: center;"><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 9:</u> Identify whether or not any limitations have been exceeded, and if so, what, if any ACTION, is required.</p> <p><u>STANDARD:</u> The operator reviews Technical Specification LCO 3.2.4 and determines that with the plant in Mode 1 at greater than 50% power, a maximum QPTR of 1.02 is permitted.</p> <p>The operator identifies that LCO 3.2.4 is NOT met.</p> <p>The operator identifies that ACTIONS A.1 through A.6 must be taken for Condition A of LCO 3.2.4.</p> <ul style="list-style-type: none"> • Reduce THERMAL POWER \geq 3% from RTP for each 1% of QPTR > 1.00 within 2 hours (Minimum of 8.7% power reduction OR Maximum allowable power of 91.3%). • Determine QPTR and reduce THERMAL POWER \geq 3% from RTP for each 1% of QPTR > 1.00 once per 12 hours. • Perform SR 3.2.1.1 and SR 3.2.2.1 within 24 hours and once per 7 days thereafter. • Reevaluate safety analyses and confirm results remain valid for duration of operation under this condition prior to increasing THERMAL POWER above the limit of Required Action A.1. • Prior to increasing THERMAL POWER above the limit of Required Action A.1 prior to increasing THERMAL POWER above the limit of Required Action A.1 or A.2. • Perform SR 3.2.1.1 and SR 3.2.2.1 Within 24 hours after reaching RTP OR Within 48 hours after increasing THERMAL POWER above the limit of Required Action A.1 or A.2. <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
--	--

Terminating Cue: Evaluation on this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

Job Performance Measure No.: 2016 Admin – JPM A1a SRO

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Result: SAT _____ UNSAT _____

Examiner's Signature: _____ Date: _____

JPM CUE SHEET

- INITIAL CONDITIONS:
- The plant is in Mode 1 at 100% RTP.
 - ERFIS is inoperable.
 - The CRS has directed you to perform a Manual QPTR calculation and analyze the results of the calculation.
 - Detector Currents are as follows:
 - N41: Upper – 105 / Normalizing – 123
 - N41: Lower – 92 / Normalizing – 120
 - N42: Upper – 92 / Normalizing – 109
 - N42: Lower – 87 / Normalizing – 110
 - N43: Upper – 83 / Normalizing – 104
 - N43: Lower – 75 / Normalizing – 99
 - N44: Upper – 80 / Normalizing – 97
 - N44: Lower – 75 / Normalizing – 95
- INITIATING CUE:
- The CRS has directed you to perform a MANUAL QPTR calculation IAW FMP-007, QUADRANT POWER TILT.
 - Identify whether or not any limitations have been exceeded, and if so, what, if any ACTION, is required.

JPM A1b RO

Developed By: _____ **Date:** _____
Instructor/Developer

Concurred By: _____ **Date:** _____
Line Superintendent/Supervisor/SRO

Approved By: _____ **Date:** _____
Superintendent/Supervisor Training

Job Performance Measure Worksheet

Facility: Robinson

Task No.:

Task Title: Determine License StatusJPM No.: 2016 Admin – JPM A1b
RO

K/A Reference: 2.1.4 (3.3)

Examinee:

NRC Examiner:

Facility Evaluator:

Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X
 Classroom X Simulator _____ Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Provide Operator with Initial Conditions/Cue (Last Page of this JPM).

- Initial Conditions:
- You are a Licensed Reactor Operator who was assigned to the day shift staff for a special project, and not routinely standing watch in the Control Room.
 - Your last medical exam was on 11/17/14.
 - Your last SCBA quantitative and qualitative fit test was on 1/18/15.
 - You have attended all required LOCT training sessions, and passed all exams administered.
 - Your supervisor has directed you to maintain your license active AND qualified to stand watch.
 - Your Control Room work history in the last three months is as follows:
 - 11/26/15, BOP for 12 hours (Day Shift)
 - 11/2/16, RO for 8 hours (Night Shift 1800-2400)
 - 1/4/16, Extra Operator for 4 hours assigned to Monitor Feedwater Station during Reactor Startup (Day Shift).
 - 1/10/16, BOP for 12 hours (Day Shift)

Job Performance Measure Worksheet

Initiating Cue: Your supervisor has asked you to identify any requirements that must be met prior to the end of the year that are required to maintain your license ACTIVE; and any additional requirements that are required to maintain your qualification to stand watch in the Control Room.

Task Standard: The operator will evaluate their work history and identify that four 12-hour shifts must be completed as either the RO or the BOP prior to the end of the year to maintain their license ACTIVE, and that an SCBA quantitative and qualitative fit test must be completed prior to standing watch in the Control Room again.

Required Materials: Calculator

General References: OMM-001-5 (Training and Qualification), Rev 53
AD-OP-ALL-1000 (Conduct of Operations), Rev 4

Handouts: None

Time Critical Task: NO

Validation Time: 6 minutes

<u>Critical Step Justification</u>	
Step 1	This step is critical because identifying the watches that must be completed before the end of the year is necessary to maintain the license status ACTIVE.
Step 2	This step is critical because identifying the requirement to complete an annual fit test is necessary to maintain the ability to stand watch in the Control Room.

PERFORMANCE INFORMATION

(Critical Steps are identified as such in right-hand column)

Provide Operator with Initial Conditions/Cue (Last Page of this JPM).

START TIME: _____

<p><u>STEP 1:</u></p>	<p>Identify any requirements that must be met prior to the end of the year that are required to maintain your license ACTIVE.</p>	<p><u>CRITICAL STEP</u></p>
<p><u>STANDARD:</u></p>	<p>The operator identifies that ROs must stand a minimum number of hours in a Licensed position, satisfactorily participate in the Licensed Operator Continuing Training Program, and have a biennial medical exam; and concludes that the LOCT and Medical requirements have been met.</p> <p>The operator recognizes that Individuals with RO Licenses may maintain an active license by standing watch a minimum of five 12 hour shifts per calendar quarter as RO or BOP.</p> <p>The operator recognizes that the work on 11/26/15 does not count towards this calendar-quarter's number of watches.</p> <p>The operator recognizes that the work on 1/2/16 does not count towards the minimum of five 12-hour shifts.</p> <p>The operator recognizes that the work on 1/4/16 does not count towards the minimum of five 12-hour shifts; because it was not stood as the BOP or the RO.</p> <p>The operator recognizes that the work on 1/10/16 does count towards the minimum of five 12-hour shifts; and concludes that 4 additional 12-hour shifts as either the RO or BOP must be completed before the end of the year.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p>EXAMINER'S CUE:</p>	<p>NONE</p>	
<p>EXAMINER'S NOTE:</p>	<p>See Section 5.3 of OMM-001-5.</p>	
<p><u>COMMENTS:</u></p>		

PERFORMANCE INFORMATION

<p><u>STEP 2:</u> Identify the requirements that are required to maintain your qualification to stand watch in the Control Room.</p> <p><u>STANDARD:</u> The operator recognizes that in order to maintain qualification to stand watch in the Control Room, the operator must be Respirator Qualified as defined in the section on Maintaining License and Qualification Active Status; and that this section requires an SCBA quantitative and qualitative fit test annually.</p> <p>The operator recognizes that the last SCBA quantitative and qualitative fit test was over a year ago, and identifies that this fit test must be completed prior to standing a watch in the Control Room.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
---	--

Terminating Cue: Evaluation on this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

Job Performance Measure No.: 2016 Admin – JPM A1b RO

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Result: SAT _____ UNSAT _____

Examiner's Signature: _____ Date: _____

JPM CUE SHEET

INITIAL CONDITIONS:

- You are a Licensed Reactor Operator who was assigned to the day shift staff for a special project, and not routinely standing watch in the Control Room.
- Your last medical exam was on 11/17/14.
- Your last SCBA quantitative and qualitative fit test was on 1/18/15.
- You have attended all required LOCT training sessions, and passed all exams administered.
- Your supervisor has directed you to maintain your license active AND qualified to stand watch.
- Your Control Room work history in the last three months is as follows:
 - 11/26/15, BOP for 12 hours (Day Shift)
 - 11/2/16, RO for 8 hours (Night Shift 1800-2400)
 - 1/4/16, Extra Operator for 4 hours assigned to Monitor Feedwater Station during Reactor Startup (Day Shift).
 - 1/10/16, BOP for 12 hours (Day Shift)

INITIATING CUE:

Your supervisor has asked you to identify any requirements that must be met prior to the end of the year that are required to maintain your license ACTIVE; and any additional requirements that are required to maintain your qualification to stand watch in the Control Room.

Requirements that must be met before the end of the year to maintain an ACTIVE License:

Requirements that must be to maintain your qualification to stand watch in the Control Room:

JPM A1b SRO

Developed By: _____ **Date:** _____
Instructor/Developer

Concurred By: _____ **Date:** _____
Line Superintendent/Supervisor/SRO

Approved By: _____ **Date:** _____
Superintendent/Supervisor Training

Job Performance Measure Worksheet

Facility: Robinson

Task No.:

Task Title: Determine License StatusJPM No.: 2016 Admin – JPM A1b SRO

K/A Reference: 2.1.4 (3.3)

Examinee:

NRC Examiner:

Facility Evaluator:

Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X
 Classroom X Simulator _____ Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Provide Operator with Initial Conditions/Cue (Last Page of this JPM).

- Initial Conditions:
- You are a Licensed Senior Reactor Operator who was assigned to the day shift staff for a special project, and not routinely standing watch in the Control Room.
 - Your last medical exam was on 11/17/14.
 - Your last SCBA quantitative and qualitative fit test was on 1/18/15.
 - You have attended all required LOCT training sessions, and passed all exams administered.
 - Your supervisor has directed you to maintain your license active AND qualified to stand watch.
 - Your Control Room work history in the last three months is as follows:
 - 11/26/15, BOP for 12 hours (Day Shift)
 - 1/2/16, RO for 8 hours (Night Shift 1800-2400)
 - 1/4/16, Extra Operator for 4 hours assigned to Monitor Feedwater Station during Reactor Startup (Day Shift).
 - 1/10/16, CRS for 12 hours (Day Shift)

Job Performance Measure Worksheet

Initiating Cue: Your supervisor has asked you to identify any requirements that must be met prior to the end of the year that are required to maintain your license ACTIVE; and any additional requirements that are required to maintain your qualification to stand watch in the Control Room.

Task Standard: The operator will evaluate their work history and identify that four 12-hour shifts must be completed as either the SM, CRS, RO or the BOP prior to the end of the year to maintain their license ACTIVE, and that an SCBA quantitative and qualitative fit test must be completed prior to standing watch in the Control Room again.

Required Materials: Calculator

General References: OMM-001-5 (Training and Qualification), Rev 53
AD-OP-ALL-1000 (Conduct of Operations), Rev 4

Handouts: None

Time Critical Task: NO

Validation Time: 7 minutes

<u>Critical Step Justification</u>	
Step 1	This step is critical because identifying the watches that must be completed before the end of the year is necessary to maintain the license status ACTIVE.
Step 2	This step is critical because identifying the requirement to complete an annual fit test is necessary to maintain the ability to stand watch in the Control Room.

PERFORMANCE INFORMATION

(Critical Steps are identified as such in right-hand column)

Provide Operator with Initial Conditions/Cue (Last Page of this JPM).

START TIME: _____

<p><u>STEP 1:</u></p>	<p>Identify any requirements that must be met prior to the end of the year that are required to maintain your license ACTIVE.</p>	<p><u>CRITICAL STEP</u></p>
<p><u>STANDARD:</u></p>	<p>The operator identifies that SROs must stand a minimum number of hours in a Licensed position, satisfactorily participate in the Licensed Operator Continuing Training Program, and have a biennial medical exam; and conclude that the LOCT and Medical requirements have been met.</p> <p>The operator recognizes that Individuals with SRO Licenses may maintain an active license by standing watch a minimum of five 12 hour shifts in a License required position, at least one of which must be in the SM or CRS position in the Main Control Room.</p> <p>The operator recognizes that the work on 9/26/15 does not count towards this calendar-quarter's number of watches.</p> <p>The operator recognizes that the work on 11/2/15 does not count towards the minimum of five 12-hour shifts.</p> <p>The operator recognizes that the work on 11/4/15 does not count towards the minimum of five 12-hour shifts; and was not stood as the SM, CRS, BOP or the RO.</p> <p>The operator recognizes that the work on 11/10/15 does count towards the minimum of five 12-hour shifts; and concludes that 4 additional 12-hour shifts as either the SM, CRS, RO or BOP must be completed before the end of the year.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p>EXAMINER'S CUE:</p>	<p>NONE</p>	
<p>EXAMINER'S NOTE:</p>	<p>See Section 5.3 of OMM-001-5.</p>	
<p><u>COMMENTS:</u></p>		

PERFORMANCE INFORMATION

<p><u>STEP 2:</u> Identify the requirements that are required to maintain your qualification to stand watch in the Control Room.</p> <p><u>STANDARD:</u> The operator recognizes that in order to maintain qualification to stand watch in the Control Room, the operator must be Respirator Qualified as defined in the section on Maintaining License and Qualification Active Status; and that this section requires an SCBA quantitative and qualitative fit test annually.</p> <p>The operator recognizes that the last SCBA quantitative and qualitative fit test was over a year ago, and identifies that this fit test must be completed prior to standing a watch in the Control Room.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
---	--

Terminating Cue: Evaluation on this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

Job Performance Measure No.: 2016 Admin – JPM A1b SRO

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Result: SAT _____ UNSAT _____

Examiner's Signature: _____ Date: _____

JPM CUE SHEET

INITIAL CONDITIONS:

- You are a Licensed Senior Reactor Operator who was assigned to the day shift staff for a special project, and not routinely standing watch in the Control Room.
- Your last medical exam was on 11/17/14.
- Your last SCBA quantitative and qualitative fit test was on 1/18/15.
- You have attended all required LOCT training sessions, and passed all exams administered.
- Your supervisor has directed you to maintain your license active AND qualified to stand watch.
- Your Control Room work history in the last three months is as follows:
 - 11/26/15, BOP for 12 hours (Day Shift)
 - 1/2/16, RO for 8 hours (Night Shift 1800-2400)
 - 1/4/16, Extra Operator for 4 hours assigned to Monitor Feedwater Station during Reactor Startup (Day Shift).
 - 1/10/16, CRS for 12 hours (Day Shift)

INITIATING CUE:

Your supervisor has asked you to identify any requirements that must be met prior to the end of the year that are required to maintain your license ACTIVE; and any additional requirements that are required to maintain your qualification to stand watch in the Control Room.

Requirements that must be met before the end of the year to maintain an ACTIVE License:

Requirements that must be to maintain your qualification to stand watch in the Control Room:

JPM A2 RO

Developed By: _____ **Date:** _____

Instructor/Developer

Concurred By: _____ **Date:** _____

Line Superintendent/Supervisor/SRO

Approved By: _____ **Date:** _____

Superintendent/Supervisor Training

Job Performance Measure Worksheet

Facility: Robinson Task No.:

Task Title: Determine Proper Equipment Boundaries JPM No.: 2016 Admin – JPM A2 RO

K/A Reference: 2.2.41 (3.5)

Examinee: NRC Examiner:

Facility Evaluator: Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X

Classroom X Simulator _____ Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Provide Operator with Initial Conditions/Cue (Last Page of this JPM).

Initial Conditions:

- The plant is in Mode 1 at 100% power.
- Charging Pump "A" suction relief valve CVC-2080 has failed open.
- The operating crew has entered AOP-016, Excessive Primary Plant Leakage, to control the plant.

Initiating Cue: The CRS has directed you to use all available resources to identify the pump boundary valves needed to be closed to isolate the leak, and identify the motor breaker to electrically isolate the pump motor.

Task Standard: The operator will identify that the leak can be isolated by closing three valves; CVC-270, CVC-290 and CVC-291, and that the pump motor can be electrically isolated by racking out Breaker 52/34B.

Required Materials: Set of P&IDs available to the operator
Set of EDPs available to the operator

General References: P&ID 5379-685 Sheet 2 of 3 (Chemical and Volume Control System Purification and Makeup Flow Diagram), Rev 61

Job Performance Measure Worksheet

EDP-002 (480V AC Busses), Rev 16

OWP-005 (Chemical and Volume Control System (CVCS)), Rev 65

Handouts: None

Time Critical Task: NO

Validation Time: 5 minutes

Critical Step Justification

Step 1	This step is critical because closing CVC-270, CV-290 and CVC-291 is necessary to isolate the leak.
Step 2	This step is critical because racking out is necessary to electrically isolate the "A" Charging Pump.

PERFORMANCE INFORMATION

(Critical Steps are identified as such in right-hand column)

Provide Operator with Initial Conditions/Cue (Last Page of this JPM).

START TIME: _____

<p><u>STEP 1:</u> Review P&IDs to determine pump boundary valves.</p> <p><u>STANDARD:</u> The operator reviews the set of P&IDs, and determines that the boundary valves associated with the “A” Charging Pump and its relief valve are located on P&ID 5379-685 Sheet 2 of 3 (Chemical and Volume Control System Purification and Makeup Flow Diagram).</p> <p>As a MINIMUM, the operator identifies the following valves are required to be verified in the selected positions to ensure that the leak flow path is isolated :</p> <ul style="list-style-type: none"> • CVC-270, Charging Pump A Suction - CLOSED • CVC-290, Charging Pump A to Charging Line - CLOSED • CVC-291, Charging Pump A to Seal Injection - CLOSED <p>EXAMINER’S CUE: NONE</p> <p>EXAMINER’S NOTE: This JPM consists of identifying the boundaries necessary to isolate the leakage path from Charging Pump A suction relief valve CVC-2080. The sequence of the component isolation is NOT required for the performance of this JPM.</p> <p>Not required for credit. Additional isolation valves that can be included are as follows:</p> <ul style="list-style-type: none"> • CVC-465, Charging Pump A Suction Vent - CLOSED • CVC-275F, Charging Pump A Suction Line Vent – LOCKED CLOSED • CVC-280C, Charging Pump A Drain – CLOSED • CVC-400A, Charging Pump A Leakage Isolation - OPEN • CVC-277C, Charging Pump A Recirc Root – LOCKED CLOSED ▪ CVC-466, Charging Pump A Suction Stabilizer Drain - OPEN <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
--	--

PERFORMANCE INFORMATION

<p><u>STEP 2:</u> Determine the power supply to Charging Pump "A".</p> <p><u>STANDARD:</u> The operator reviews the EDPs and determines that EDP-002 must be addressed. As a MINIMUM the operator that Charging Pump A power supply is breaker 52/34B must be RACKED OUT.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: The sequence of the component isolation is NOT required for the performance of this JPM.</p> <p>Not required for credit. Additional breakers/switches that can be included are as follows:</p> <ul style="list-style-type: none">• RTGB Control switch for Charging Pump A – CAPPED• Power Panel 37 Circuit 2, Charging Pump A Suction Stabilizer Heater Breaker – OPEN <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
---	--

Terminating Cue: Evaluation on this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

Job Performance Measure No.: 2016 Admin – JPM A2 RO

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Result: SAT _____ UNSAT _____

Examiner's Signature: _____ Date: _____

JPM CUE SHEET

INITIAL CONDITIONS:

- The plant is in Mode 1 at 100% power.
- Charging Pump "A" suction relief valve CVC-2080 has failed open.
- The operating crew has entered AOP-016, Excessive Primary Plant Leakage, to control the plant.

INITIATING CUE:

The CRS has directed you to use all available resources to identify the pump boundary valves needed to be closed to isolate the leak, and identify the motor breaker to electrically isolate the pump motor.

JPM A2 SRO

Developed By: _____ **Date:** _____
Instructor/Developer

Concurred By: _____ **Date:** _____
Line Superintendent/Supervisor/SRO

Approved By: _____ **Date:** _____
Superintendent/Supervisor Training

Job Performance Measure Worksheet

Facility: Robinson Task No.:

Task Title: Determine if Mode Change is Permissible JPM No.: 2016 Admin – JPM A2 SRO

K/A Reference: 2.2.38 (4.5)

Examinee: NRC Examiner:

Facility Evaluator: Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X
 Classroom X Simulator _____ Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Provide Operator with Initial Conditions/Cue and the Available Equipment Inoperable List (Last Two Pages of this JPM), and Handout 1.

Initial Conditions:

- The plant is in Mode 5, returning from a refueling outage.
- RCS temperature is 165°F and there is a bubble in the PZR.
- RHR Loop "A" is maintaining RCS temperature.
- You are an extra SRO assigned to support the shift during re-start activities.
- An Inoperable Equipment List is available.

Initiating Cue:

- The SM has directed you to complete the attached partially completed OMM-001-12, MINIMUM EQUIPMENT LIST AND SHIFT RELIEF, Att. 2, 200°F to 350°F (MODE 4) MEL that was started on the previous shift and determine if any Mode 4 restrictions exist.
- The SM has indicated that it is expected to make the Mode change without reliance upon Technical Specification 3.0.4.b.

Job Performance Measure Worksheet

Task Standard: The operator will evaluate the Technical Specifications/Technical Requirements against the Inoperable Equipment List and listed parameters and determines that CCW Pump "C", V6-16B, WCCU-1A must be restored to operable prior to changing modes; that CVT 1 must be repaired and Instrument Bus 1 must be powered from MCC-5 prior to changing modes, and that DFO Storage tank level must be raised to > 19000 gallons prior to changing modes per the provided KEY.

Required Materials: Robinson Technical Specifications and Basis must be available.

General References: OMM-001-12 (Minimum Equipment List and Shift Relief), Rev 85
Technical Specifications for H. B. Robinson Steam Electric Plant Unit No. 2

Handouts: Handout 1: Attachment 2 of OMM-001-12 marked up for this JPM

Time Critical Task: NO

Validation Time: 10 minutes

<u>Critical Step Justification</u>	
Step 9	This step is critical because LCO 3.7.6 is NOT met, and meeting this LCO is necessary to change Modes.
Step 10	This step is critical because LCO 3.7.7 is NOT met, and meeting this LCO is necessary to change Modes.
Step 11	This step is critical because LCO 3.7.10 is NOT met, and meeting this LCO is necessary to change Modes.
Step 12	This step is critical because LCO 3.8.3 is NOT met, and meeting this LCO is necessary to change Modes.
Step 14	This step is critical because LCO 3.8.7 is NOT met, and meeting this LCO is necessary to change Modes.
Step 15	This step is critical because LCO 3.8.9 is NOT met, and meeting this LCO is necessary to change Modes.
Step 18	This step is critical because the report to the SM must be correct prior to changing Modes.

PERFORMANCE INFORMATION

(Critical Steps are identified as such in right-hand column)

Provide Operator with Initial Conditions/Cue and the Available Equipment Inoperable List (Last Two Pages of this JPM), and Handout 1.

START TIME: _____

<p><u>STEP 1:</u> Evaluate ITS LCO 3.4.17 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that 2 Charging Pumps must be OPERABLE, and that the “A” Charging Pump is inoperable.</p> <p>The operator determines minimum requirement is met with “B” and “C” Charging Pumps OPERABLE, and initials the appropriate block.</p> <p>The operator recognizes that the Seal Water Injection flow to EACH of the RCPs is greater than 6 gpm, and initials the appropriate block.</p> <p>EXAMINER’S CUE: NONE</p> <p>EXAMINER’S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 2:</u> Evaluate ITS LCO 3.5.4 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that the RWST level is greater than 91 %, and initials the appropriate block.</p> <p>The operator recognizes that the RWST Boron concentration is \geq 1950 ppm and \leq 2400 ppm, and initials the appropriate block.</p> <p>The operator recognizes that the RWST temperature is \geq 45°F and \leq 100°F, and initials the appropriate block.</p> <p>EXAMINER’S CUE: NONE</p> <p>EXAMINER’S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 3:</u> Evaluate ITS LCO 3.6.4 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that the Containment Pressure is ≥ -0.8 psig AND $\leq +1.0$ psig, and initials the appropriate block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 4:</u> Evaluate ITS LCO 3.6.5 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that the Containment Air Temperature is $\leq 120^{\circ}\text{F}$, and initials the appropriate block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 5:</u> Evaluate ITS LCO 3.6.7 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that the Spray Additive Tank Level is $\geq 32\%$, and initials the appropriate block. The operator recognizes that the Spray Additive Tank concentration is $\geq 30\%$ NAOH, and initials the appropriate block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 6:</u> Evaluate ITS LCO 3.6.8 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that the IVSW pressure is ≥ 49 psig as indicated locally on PI-1910, and initials the appropriate block. The operator recognizes that the IVSW tank level is $\geq 49\%$, and initials the appropriate block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 7:</u> Evaluate ITS LCO 3.7.4 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that 1 MDAFW Pump (LCO-3.0.4.b N/A) is required to be OPERABLE, and that the "B" MDAFW Pump is inoperable. The operator determines minimum requirement is met with the "A" MDAFW Pump OPERABLE, and initials the appropriate block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 8:</u> Evaluate ITS LCO 3.7.5 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that the Condensate Storage Tank level is $\geq 26\%$, and initials the appropriate block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 9:</u> Evaluate ITS LCO 3.7.6 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that 2 Trains powered from Emergency Power supplies ("B" and "C" pumps) are required to be OPERABLE, and that the "C" CCW Pump is inoperable.</p> <p>The operator determines that the "C" CCW Pump must be restored to OPERABLE prior to changing modes, and does NOT initial the associated block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 10:</u> Evaluate ITS LCO 3.7.7 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that the Turbine Bldg Loop Isolation valves are required to be OPERABLE, and that V6-16B is inoperable.</p> <p>The operator determines that V6-16B must be restored to OPERABLE prior to changing modes, and does NOT initial the associated block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 11:</u> Evaluate ITS LCO 3.7.10 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that 2 HVAC WCCU Trains are required to be OPERABLE, and that WCCU-1A is inoperable.</p> <p>The operator determines that WCCU-1A must be restored to OPERABLE prior to changing modes, and does NOT initial the associated block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 12:</u> Evaluate ITS LCO 3.8.3 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that $\geq 19,000$ gallons is NOT available from DFO Storage tank, and recognizes that tank level must be raised to > 19000 gallons prior to changing modes, and does NOT initial the associated block.</p> <p>The operator recognizes that $\geq 15,000$ gallons is available from Unit 1 IC Turbine Fuel Oil Storage tanks, and initials the appropriate block. (Not Critical)</p> <p>The operator recognizes that the "A" EDG Air receiver pressure is greater than 210 psig, and initials the appropriate block. (Not Critical)</p> <p>The operator recognizes that the "B" EDG Air receiver pressure is greater than 210 psig, and initials the appropriate block. (Not Critical)</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 13:</u> Evaluate ITS LCO 3.8.4 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that MCC-A Voltage is > 126 VDC, and initials the appropriate block.</p> <p>The operator recognizes that MCC-B Voltage is > 126 VDC, and initials the appropriate block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 14:</u> Evaluate ITS LCO 3.8.7 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that Inverter A Voltage is > 114 VAC, and initials the appropriate block. (Not Critical)</p> <p>The operator recognizes that Inverter B Voltage is > 114 VAC, and initials the appropriate block. (Not Critical)</p> <p>The operator recognizes that CVT 1, must be OPERABLE, and that that it is currently inoperable.</p> <p>The operator determines that CVT 1 must be restored to OPERABLE prior to changing modes, and does NOT initial the associated block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 15:</u> Evaluate ITS LCO 3.8.9 requirements.</p> <p><u>STANDARD:</u> The operator recognizes that 4KV Bus 2 Voltage is > 3.2 KV, and initials the appropriate block. (Not Critical)</p> <p>The operator recognizes that 4KV Bus 3 Voltage is > 3.2 KV, and initials the appropriate block. (Not Critical)</p> <p>The operator recognizes that 480V Bus E-1 Voltage (lowest phase) is > 440 VAC, and initials the appropriate block. (Not Critical)</p> <p>The operator recognizes that 480V Bus E-2 Voltage (lowest phase) is > 440 VAC, and initials the appropriate block. (Not Critical)</p> <p>The operator recognizes that MCC-5 breaker, CMPT NO. 4BL, FEED TO INSTRUMENT BUS 1, must be closed to be OPERABLE, and that that it is currently OPEN due to problem with No. 1 Constant Voltage Transformer.</p> <p>The operator determines that MCC-5 breaker, CMPT NO. 4BL, FEED TO INSTRUMENT BUS 1, must be closed prior to changing modes, and does NOT initial the associated block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
--	--

PERFORMANCE INFORMATION

<p><u>STEP 16:</u></p>	<p>Evaluate TRMS 3.6.b requirements.</p>	
<p><u>STANDARD:</u></p>	<p>The operator recognizes that the "A" Boric Acid Tank Level is > 42%, and initials the appropriate block.</p> <p>The operator recognizes that the "A" Boric Acid Tank boron concentration is between 20,000 ppm - 22,500 ppm, and initials the appropriate block.</p> <p>The operator recognizes that the "A" Boric Acid Tank temperature is > 145°F, and initials the appropriate block.</p> <p>The operator recognizes that the "B" Boric Acid Tank Level is > 42%, and initials the appropriate block.</p> <p>The operator recognizes that the "A" Boric Acid Tank boron concentration is between 20,000 ppm - 22,500 ppm, and initials the appropriate block.</p> <p>The operator recognizes that the "B" Boric Acid Tank temperature is > 145°F, and initials the appropriate block.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p>EXAMINER'S CUE:</p>	<p>NONE</p>	
<p>EXAMINER'S NOTE:</p>	<p>This evaluation can be made in ANY order. See provided KEY.</p>	
<p><u>COMMENTS:</u></p>		

PERFORMANCE INFORMATION

<p><u>STEP 17:</u> Evaluate TRMS 3.6.d requirements.</p> <p><u>STANDARD:</u> The operator recognizes that the Primary Water Storage Tank Level is > 45%, and initials the appropriate block.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: This evaluation can be made in ANY order. See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 18:</u> The operator reports findings to the Shift Manager.</p> <p><u>STANDARD:</u> The operator reports findings / provides applicable pages or all pages of Attachment 2 to Shift Manager.</p> <ul style="list-style-type: none"> • CCW Pump "C" must be restored to operable prior to changing modes. • V6-16B must be restored to operable prior to changing modes. • WCCU-1A must be restored to operable prior to changing modes. • CVT must be repaired and Instrument Bus 1 must be powered from MCC-5 prior to changing modes. • DFO Storage tank level must be raised to > 19000 gallons <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: See provided KEY.</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>

Terminating Cue: Evaluation on this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

Job Performance Measure No.: 2016 Admin – JPM A2 SRO

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Result: SAT _____ UNSAT _____

Examiner's Signature: _____ Date: _____

JPM CUE SHEET

Inoperable Equipment List

- Charging Pump "A"
- Component Cooling Water Pump "C"
- MDAFW Pump "B"
- V6-16B, SW TURB BLDG SUPPLY, is OPEN with the motor leads disconnected for control circuit troubleshooting.
- Instrument Bus 1 is being powered from MCC-8. MCC-5 feed is de-energized due to problem with No. 1 Constant Voltage Transformer.
- Control Room Water Cooled Condensing Unit, WCCU-1A

JPM CUE SHEET

INITIAL CONDITIONS:

- The plant is in Mode 5, returning from a refueling outage.
- RCS temperature is 165°F and there is a bubble in the PZR.
- RHR Loop "A" is maintaining RCS temperature.
- You are an extra SRO assigned to support the shift during re-start activities.
- An Inoperable Equipment List is available.

INITIATING CUE:

The SM has directed you to complete the attached partially completed OMM-001-12, MINIMUM EQUIPMENT LIST AND SHIFT RELIEF, Att. 2, 200°F to 350°F (MODE 4) MEL that was started on the previous shift and determine if any Mode 4 restrictions exist.

JPM A3 RO

Developed By: _____ **Date:** _____
Instructor/Developer

Concurred By: _____ **Date:** _____
Line Superintendent/Supervisor/SRO

Approved By: _____ **Date:** _____
Superintendent/Supervisor Training

Job Performance Measure Worksheet

Facility: Robinson Task No.:

Task Title: Evaluate Stay Time with Lowered SFP Level JPM No.: 2016 Admin – JPM A3 RO

K/A Reference: 2.3.7 (3.5)

Examinee: NRC Examiner:

Facility Evaluator: Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X
 Classroom X Simulator _____ Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Provide Operator with Initial Conditions/Cue (Last Page of this JPM).

Initial Conditions:

- A station wide accident has occurred due to an Earthquake.
- The plant is in Mode 6 with a full core off-load.
- The Spent Fuel Pool level has lowered to 10 feet above the top of the fuel, and has stabilized at this level.
- The crew is implementing AOP-036 (SFP Events).
- R-5, Spent Fuel Building Rad Monitor, reads 1.93E+2 mr/hr.
- A dose limit of 25 mrem has been placed on all personnel performing emergency tasks within the building.
- You have been assigned a repetitive task within AOP-036 which will require you to enter the Spent Fuel Building and proceed to the area around the Spent Fuel Pool, and remain there for 3 minutes, before exiting the building.
- The exposure traveling to and from the Spent Fuel Pool area results in no appreciable exposure.

Initiating Cue: The OSC Leader has directed you to estimate how many times you can perform this repetitive task before you must be replaced by another operator.

Job Performance Measure Worksheet

Task Standard: The operator will determine that the repetitive task can be performed 2 times before another operator will need to perform the task.

Required Materials: Calculator

General References: AOP-036 (SFP Events), Rev 48
OMM-014 (Radiation Monitor Setpoints), Rev 51

Handouts: None

Time Critical Task: NO

Validation Time: 7 minutes

Critical Step Justification

Step 3	This step is critical because it is necessary to determine how many times the task can be performed without exceeding a limit.
--------	--

PERFORMANCE INFORMATION

(Critical Steps are identified as such in right-hand column)

Provide Operator with Initial Conditions/Cue (Last Page of this JPM).

START TIME: _____

<p><u>STEP 1:</u> Determine dose rate in the Spent Fuel Pool Area</p> <p><u>STANDARD:</u> The operator evaluates the R-5 reading and determines that the area radiation levels are 193 mrem/hour.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 2:</u> Determine the accumulated Dose each time the repetitive task is performed.</p> <p><u>STANDARD:</u> The operator determines that 3 minutes in a radiation field of 193 mrem/hour will yield a dose of 9.65 mrem</p> <p>193 mrem/hr x 1hr/60 minutes x 3 minutes/task = 9.65 mrem/task</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>

PERFORMANCE INFORMATION

<p><u>STEP 3:</u> Determine how many times the repetitive task can be performed before allowable RWP limits have been reached.</p> <p><u>STANDARD:</u> The operator determines that a Task which accumulates 9.65 mrem can be performed <u>twice</u> without exceeding a dose limit of 25 mrem.</p> <p>25 mrem x task/9.65 mrem = 2.6 tasks</p> <p>Since the task cannot be partially performed, the task can be performed twice before the operator must be replaced with another operator.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
---	--

Terminating Cue: Evaluation on this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

Job Performance Measure No.: 2016 Admin – JPM A3 RO

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Result: SAT _____ UNSAT _____

Examiner's Signature: _____ Date: _____

JPM CUE SHEET

INITIAL CONDITIONS:

- A station wide accident has occurred due to an Earthquake.
- The plant is in Mode 6 with a full core off-load.
- The Spent Fuel Pool level has lowered to 10 feet above the top of the fuel, and has stabilized at this level.
- The crew is implementing AOP-036 (SFP Events).
- R-5, Spent Fuel Building Rad Monitor, reads $1.93E+2$ mr/hr.
- A dose limit of 25 mrem has been placed on all personnel performing emergency tasks within the building.
- You have been assigned a repetitive task within AOP-036 which will require you to enter the Spent Fuel Building and proceed to the area around the Spent Fuel Pool, and remain there for 3 minutes, before exiting the building.
- The exposure traveling to and from the Spent Fuel Pool area results in no appreciable exposure.

INITIATING CUE:

The OSC Leader has directed you to estimate how many times you can perform this repetitive task before you must be replaced by another operator.

JPM A3 SRO

Developed By: _____ **Date:** _____
Instructor/Developer

Concurred By: _____ **Date:** _____
Line Superintendent/Supervisor/SRO

Approved By: _____ **Date:** _____
Superintendent/Supervisor Training

Job Performance Measure Worksheet

Facility: Robinson

Task No.:

Task Title: Approve a Waste Gas Release PermitJPM No.: 2016 Admin – JPM A3 SRO

K/A Reference: 2.3.8 (3.7)

Examinee:

NRC Examiner:

Facility Evaluator:

Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X
 Classroom X Simulator _____ Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Provide Operator with Initial Conditions/Cue (Last Page of this JPM), and Handout 1.

Initial Conditions:

- The plant is in Mode 1 at 100% power.
- A Waste Gas Release Permit for the "A" WGDT has been presented to the Shift Manager for review and approval.

Initiating Cue:

- Review and Approve the Waste Gas Release Permit.
- Identify all issues found (if any) which would prevent approval.

Task Standard: The operator will review the WGDT Release Permit and identify that it cannot be approved because (1) it has been written for the wrong WGDT and (2) the R14C setpoint is less conservative than required.

Required Materials: None

General References: EMP-022 (Gaseous Waste Release Permits), Rev 56
 OMM-014 (Radiation Monitor Setpoints), Rev 51
 OP-706 (Waste Disposal – Gaseous Rad Waste Release), Rev 18

Job Performance Measure Worksheet

Handouts: Handout 1: Completed Attachment 10.3 of EMP-022 marked up for this JPM.

Time Critical Task: NO

Validation Time: 8 minutes

Critical Step Justification

Step 4	This step is critical because denial of permit approval, and identification of the reasons for this denial is necessary to prevent an uncontrolled release of "B" WGDT and/or a release with the radiation monitor setpoint at a non-conservative value.
--------	--

PERFORMANCE INFORMATION

(Critical Steps are identified as such in right-hand column)

Provide Operator with Initial Conditions/Cue (Last Page of this JPM), and Handout 1.

START TIME: _____

<p><u>STEP 1:</u> Review the Waste Gas Release Permit preliminary Information</p> <p><u>STANDARD:</u> The operator observes that the following preliminary information is completed on Attachment 10.3 of EMP-022:</p> <ul style="list-style-type: none"> • Release #: G-2016-015 • SSN (XXXX) • Date (of Permit preparation) • Printed Name (of Individual preparing the Permit) • Initial (of Individual preparing the Permit) • Signature (of Individual preparing the Permit) • Date (of Signature) <p>The operator recognizes that the preliminary information is acceptable and proceeds.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
--	---------------------------------

PERFORMANCE INFORMATION

<p>STEP 2: Review the Waste Gas Release Permit PART I Information</p> <p>STANDARD: The operator observes that the following PART I information is completed on Attachment 10.3 of EMP-022:</p> <ul style="list-style-type: none">• Waste Gas Decay Tank: B• Estimated Release Start Date/Time: 2/6/16 2100• Estimated Release Stop Date/Time: 2/6/16 2130• Monitor R14C Setpoint: 5.6E3• Basis: Activity Circled• CV Purge: Not In Service Circled• Maximum WGDT Flow Rate: 90 CFM• Prepared By: name of preparer• Peer Review: name of reviewer• Verified By: NA• Chemistry Supervisor: NA <p>The operator identifies that the Permit is for the "B" WGDT and the Permit was requested for the "A" WGDT, and identifies that this must be modified before approval.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
---	---------------------------------

PERFORMANCE INFORMATION

<p><u>STEP 3:</u> Review the Waste Gas Release Permit PART II Information</p> <p><u>STANDARD:</u> The operator observes that the following PART II information is completed on Attachment 10.3 of EMP-022:</p> <ul style="list-style-type: none">• PRIOR₁ (Channel Check): 19.9• SOURCE CHECK₂: Initialed• SETPOINT VERF. AT₃: 1.0E4• UPDATE STATUS BOARD₄: Initialed• DURING RELEASE: Left Blank• AFTER RELEASE: Left Blank• SETPOINT RETURNED TO_{3,5}: Left Blank• STATUS BOARD UPDATED₄: Left Blank <p>The operator identifies that the R14C setpoint is less conservative than required and identifies that this must be modified before approval.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
---	---------------------------------

PERFORMANCE INFORMATION

<p><u>STEP 4:</u> Approve the Waste Gas Release Permit or identify all issues found which would prevent approval</p> <p><u>STANDARD:</u> The operator identifies that the Waste Gas Permit cannot be approved until:</p> <ul style="list-style-type: none">• The Permit is identified with the correct WGDT in PART I (“A” WGDT)• The R14C setpoint is verified in PART II to be at or less conservative than the setpoint listed in PART I <p>EXAMINER’S CUE: NONE</p> <p>EXAMINER’S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
--	--

Terminating Cue: Evaluation on this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

Job Performance Measure No.: 2016 Admin – JPM A3 SRO

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Result: SAT _____ UNSAT _____

Examiner's Signature: _____ Date: _____

JPM CUE SHEET

INITIAL CONDITIONS:

- The plant is in Mode 1 at 100% power.
- A Waste Gas Release Permit for the "A" WGDT has been presented to the Shift Manager for review and approval.

INITIATING CUE:

- Review and Approve the Waste Gas Release Permit.
- Identify all issues found (if any) which would prevent approval.

JPM A4 SRO

Developed By: _____ **Date:** _____

Instructor/Developer

Concurred By: _____ **Date:** _____

Line Superintendent/Supervisor/SRO

Approved By: _____ **Date:** _____

Superintendent/Supervisor Training

Job Performance Measure Worksheet

Facility: H B Robinson

Task No.:

Task Title: Emergency ClassificationJPM No.: 2016 Admin – JPM A4
SRO

K/A Reference: 2.4.41 (4.4)

Examinee:

NRC Examiner:

Facility Evaluator:

Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X
 Classroom X Simulator _____ Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Provide Operator with Initial Conditions/Cue (Last Page of this JPM), and Handouts 1-2.

- Initial Conditions:
- The plant is operating at 100% power.
 - Protesters have illegally entered the plant, and have gained entry to the protected area.
 - Security has declared a Security Event (Confirmed Protected Area Intrusion).
 - Security has all intruders under restraint and has prevented further entry into the plant.
 - Other than minor damage to the security fences and protest slogans spray painted on some walls, there was no plant damage.

Initiating Cue: Classify the event in accordance with the Robinson Nuclear Plant Emergency Action Level Matrix and prepare an Emergency Notification Form.

THIS JPM IS TIME CRITICAL

Job Performance Measure Worksheet

Task Standard: The operator will declare an ALERT based on HA4.1, Confirmed Security event in a plant Protected Area or notification of either an airborne attack threat or hostile threat within the Owner Controlled Area. Then, the operator will prepare an Emergency Notification Form for this event in accordance with EPCLA-01 (Emergency Control) in accordance with the attached KEY, within 15 minutes.

Required Materials: None

General References: Robinson Nuclear Plant Emergency Action Level Matrix, Sheet 1 of 3, Rev 4
 Robinson Nuclear Plant Emergency Action Level Matrix, Sheet 2 of 3, Rev 7
 Robinson Nuclear Plant Emergency Action Level Matrix, Sheet 3 of 3, Rev 1
 EPCLA-01 (Emergency Control), Rev 43
 EPCLA-04 (Emergency Action Level Technical Basis Document), Rev 13

Handouts: Handout 1: Robinson Nuclear Plant Emergency Action Level Matrix Sheets 1-3
 Handout 2: Blank Copy of EPCLA-01

Time Critical Task: YES - 15 Minutes

Validation Time: 15 minutes

<u>Critical Step Justification</u>	
Step 1	This step is critical because accurately classifying the event is necessary to properly implement on-site and off-site response to an emergency event.
Step 2	This step is critical because the completion of the ENF is necessary to properly communicate to local, state and federal organizations the status of on-going emergency events.

PERFORMANCE INFORMATION

(Critical Steps are identified as such in right-hand column)

Provide Operator with Initial Conditions/Cue (Last Page of this JPM), and Handouts 1-2.

START TIME: _____

<p><u>STEP 1:</u> Classify the event in accordance with the Robinson Nuclear Plant Emergency Action Level Matrix</p> <p><u>STANDARD:</u> The operator will declare an ALERT based on HA4.1 due to threshold 1 (Security event in the plant Protected Area as determined and reported by Security shift supervision)</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 2:</u> Prepare an ENF</p> <p><u>STANDARD:</u> The operator completes Attachment 10.5, Page 9 of 10 (Or Equivalent ENF Form) of EPCLA-01 IAW the provided KEY.</p> <p>EXAMINER'S CUE: NONE</p> <p>EXAMINER'S NOTE: NONE</p> <p><u>COMMENTS:</u></p>	<p><u>CRITICAL STEP</u></p> <p>___ SAT</p> <p>___ UNSAT</p>

Terminating Cue: Evaluation on this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

Job Performance Measure No.: 2016 Admin – JPM A4 SRO

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Result: SAT _____ UNSAT _____

Examiner's Signature: _____ Date: _____

JPM CUE SHEET

INITIAL CONDITIONS:

- The plant is operating at 100% power.
- Protesters have illegally entered the plant, and have gained entry to the protected area.
- Security has declared a Security Event (Confirmed Protected Area Intrusion).
- Security has all intruders under restraint and has prevented further entry into the plant.
- Other than minor damage to the security fences and protest slogans spray painted on some walls, there was no plant damage.

INITIATING CUE:

Classify the event in accordance with the Robinson Nuclear Plant Emergency Action Level Matrix and prepare an Emergency Notification Form.

THIS JPM IS TIME CRITICAL