

**REQUEST FOR ADDITIONAL INFORMATION**  
**ALTERNATIVE REQUEST PRR-007, REVISION 1**  
**FERMI 2 POWER PLANT**  
**DTE ELECTRIC COMPANY**  
**DOCKET NUMBER 50-341**  
**(TAC NO. MF7573)**

**Reference:**

Letter from Keith J. Polson of DTE Electric Company to the U.S. Nuclear Regulatory Commission, "Submittal of Revised Relief Request No. PRR-007 for the Inservice Testing Program Third 10-Year Interval" dated April 5, 2016 (Agencywide Document Access and Management System (ADAMS) Accession Number ML16097A172).

**Request for Additional Information (RAI) EPNB-1**

Provide the start date and the scheduled end date for the third 10-year inservice test interval.

**RAI EPNB-2**

Provide the current classification (Group A or Group B) for each of the pumps associated with this alternative request.

**RAI EPNB-3**

In order to use the modified Group A test for pumps currently classified as Group B, the Group B pumps must be re-classified as Group A pumps. If any of the pumps associated with this alternative request are currently classified as Group B, please confirm that you reclassifying them as Group A pumps.

**RAI EPNB-4**

Confirm that you are requesting to use American Society of Mechanical Engineers (ASME) operations manager (OM) Code Case OMN-18 in its entirety, or if there are any exceptions, describe them.

**RAI EPNB-5**

In Section 1, "ASME Code Component(s) Affected," provide the type of pump for each pump (horizontal, vertical line shaft, positive displacement, reciprocating positive displacement).

**RAI EPNB-6**

Discuss whether or not you are requesting an alternative to ISTB-3400, "Frequency of Inservice Tests."

Enclosure