OUTSIDE FIRE DEPT STANDPIPE CONNECTION

OUTSIDE OSF

DRAIN

FS-V481

FS-V501 DRIP CHECK

LIMIT SW. ALARM

FS-V483

FS-V482

WATER MOTOR

FA-1127 MECHANICAL ALARM (GONG)

PS 1272

FS-S-2

FS-T-2 RETARDING CHAMBER

FS-V543

PS 1271

FS-V1436

FS-V1364

FS-V1435

FS-V1437

FS-1125 RESTRICTION ASSEMBLY

FS-V480

PS 1270

FS-V1383

FS-V1385

FS-S-1

FS-V1438

LIMIT ALARM

FS-V479

2" DRAIN

FLOOR

FOR CONTINUATION SEE DWG 302-23 (AREA D-5)

FS-V502

FS-V503

FS-V504

SECOND FLOOR ZONE TWO

AH-F-16

DRAIN TO FLOOR

FS-V485 DRIP CHECK

FS-V484

FILTRATION UNIT

FIELD

FS-V486

PS 1272

FIRST FLOOR ZONE ONE

NOTES:

1. VALVE POSITIONS SHOWN FOR REFERENCE ONLY. ACTUAL POSITIONS CONTROLLED BY PROCEDURES.
2. ALL INSTRUMENT TAG NUMBERS ARE PREFIXED BY SYSTEM DESIGNATOR UNLESS OTHERWISE NOTED.
3. SET POINT VALUES FOR RELIEF VALVES ARE NOMINAL AND FOR REFERENCE ONLY. ACTUAL DATA CONTROLLED BY QMS2.

LEGEND

= PENDENT SPRINKLER

= UPRIGHT SPRINKLER

= OPEN SPRAY NOZZLE

| | | |
|---|---|---|
| 3 | 302-003 | COMPONENT & SYS ID INDEX |
| 2 | 302-002 | SYMBOLS INSTRUMENTATION |
| 1 | 302-001 | SYMBOLS FLOW DIAGRAM |
| NO. | DOC. NO. | TITLE |

THIS S.A. COMPUTER GENERATED DRAWING DO NOT REVISE IT MANUALLY

Exelon. NUCLEAR

FIRE PROT.- SERV. WTR SYS.
FLOW DIAGRAM
OPERATIONS SUPPORT FACILITY

DRAWING NO. 302-232 | N/A | 8

UNIT TMI-1 | SCALE NONE

DRAWING NO. 302-232 | N/A