ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

FACIL:50	0-270 Oconee Nuclea: 0-287 Oconee Nuclea: AME AUTHOR A: H.B. Duke Powe: NAME RECIPIEN	r Stater	tion, tion, tion, ATION	90/07/09 NOTARIZED Unit 1, Duke Power Unit 2, Duke Power Unit 3, Duke Power ON Granch (Document Con	Co. Co.		DOCKET # 05000269 05000270 05000287]
SUBJECT: Application for amends to Licenses DPR-38,DPR-47 & DPR-55, changing TS 2.3 re reactor coolant pump monitor setpoint.]
DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR ENCL SIZE: 3+7 TITLE: OR Submittal: General Distribution								1
NOTES:								,
	RECIPIENT ID CODE/NAME PD2-3 LA WIENS,L	COPII LTTR 1 5	ES ENCL 1 5	RECIPIENT ID CODE/NAME PD2-3 PD	COPI LTTR 1			I
INTERNAL:	ACRS NRR/DOEA/OTSB11 NRR/DST/SELB 8D NRR/DST/SRXB 8E OC/LFMB REG FIBE 01	6 1 1 1 1	6 1 1 0 1	NRR/DET/ECMB 9H NRR/DST 8E2 NRR/DST/SICB 7E NUDOCS-ABSTRACT OGC/HDS2 RES/DSIR/EIB	1 1 1 1 1	1 1 1 0		•
EXTERNAL:	LPDR NSIC	1	1	NRC PDR	1	1		

D

D

D

S

D

D

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM PI-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 27 ENCL 25



DUKE POWER

July 9, 1990

U. S. Nuclear Regulatory Commission

ATTN: Document Control Desk Washington, D.C. 20555

Subject: Oconee Nuclear Station

Docket Nos. 50-269, -270, -287

Proposed Technical Specification 2.3 Revision

Reactor Coolant Pump Monitors Setpoint

Dear Sir:

Pursuant to 10 CFR 50, 50.90, please find attached (Attachment 1) a proposed amendment to the Oconee Nuclear Station (ONS) Facility Operating Licenses and revisions to the ONS Technical Specifications (TSs). The proposed amendment would revise TS 2.3 to establish Reactor Protective System (RPS) trip setpoint for the Reactor Coolant Pump monitors.

The proposed amendment includes two changes:

- A revision to TS 2.3 which would require pump monitors to produce a reactor trip when a loss of two pumps occurs and the reactor is at power operation greater than 2.0% full power instead of the current requirement which is at power levels greater than 0.0% of rated power.
- Table 2.3-1 is revised accordingly to require a pump monitor trip setpoint at power operation greater than 2.0% full power and loss of two reactor coolant pumps.

This proposed amendment is prompted due to a recent event (See LER 269/90-06 dated May 30, 1990) in which the pump monitor trip function generated a trip signal during the cooldown following Unit 1 End-of-Cycle 12. A reactor trip occurred when two pumps were operating and the reactor was subcritical. The trip appears to have been caused by electrical noise which resulted in indicated reactor power which exceeded the current 0.0% Full Power setpoint. This amendment would revise the pump monitor trip function setpoint in order to avoid future spurious reactor trips during cooldowns with two pumps operating.

I have determined the attached proposed amendment involves no significant hazards considerations. Attachments 2 and 3 provide the supporting

9007200257 900709 PDR ADOCK 05000269 P PDC

100

U. S. Nuclear Regulatory Commission July 9, 1990 Page 2

technical justification and the No Significant Hazards Consideration Evaluation, respectively. I am forwarding a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultation with the staff.

I respectfully request your review and approval of this proposed amendment prior to the upcoming refueling outage for Unit 2, currently scheduled to begin on September 6, 1990. This will enable us to implement the new pump monitor setpoint prior to the unit shutdown.

Very truly yours,

Hal B. Tucker

MAH/98/1cs

Attachments

xc: Mr. S. D. Ebneter
 Regional Administrator, RII
 U. S. Nuclear Regulatory Commission
 101 Marietta St., NW, Suite 2900
 Atlanta, Georgia 30323

Mr. L. A. Wiens, Project Manager U. S. Nuclear Regulatory Commission Division of Reactor Projects Washington, D.C. 20555

Mr. P. H. Skinner NRC Resident Inspector Oconee Nuclear Station

Mr. Heyward Shealy, Chief Bureau of Radiological Health S. C. Department of Health & Environmental Control 2600 Bull Street Columbia, South Carolina 29201 U. S. Nuclear Regulatory Commission July 9, 1990 Page 3

Hal B. Tucker, being duly sworn, states that he is Vice President of Duke Power Company, that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the Oconee Nuclear Station License Nos. DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.

Hal B. Tucker, Vice President

Subscribed and sworn to before me this _______day of _______, 1990.

Notary Public

My Commission Expires: