

February 19, 1992

Docket Nos. 50-269, 50-270  
and 50-287

Mr. J. W. Hampton  
Vice President, Oconee Site  
Duke Power Company  
P. O. Box 1439  
Seneca, South Carolina 29679

Dear Mr. Hampton:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION CONCERNING OCONEE NUCLEAR STATION -  
RELIEF REQUEST FROM ASME BOILER AND PRESSURE VESSEL CODE, SECTION XI,  
SUBSECTION IWP (TACS M8886, M8887, AND M8888)

The NRC staff is reviewing your submittal dated June 19, 1991, for Oconee Nuclear Station, Units 1, 2, and 3. Your submittal addresses the use of digital vibration instrumentation for pump vibration measurements. We find that additional information, as indicated in the enclosure, is required to complete our review. Your response to the enclosed questions is requested within 30 days of the date of this letter. If you have any questions regarding this matter, please contact Frank Rinaldi at (301) 504-1444.

This requirement affects fewer than ten respondents and, therefore, it is not subject to Office of Management and Budget review under P.L. 96-511.

Sincerely,

/s/

Leonard A. Wiens, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

9202270024 920219  
PDR ADDCK 05000269  
P PDR

Enclosure:  
As stated

cc w/enclosure:  
See next page

DISTRIBUTION:  
Docket File  
NRC & Local PDRs  
PD II-3 R/F  
Oconee R/F  
SVarga  
GLainas  
LWiens

LBerry  
FRinaldi  
DMatthews  
OGC, 15B18  
EJordan, MNBB3701  
ACRS (10), P-315  
LReyes, RII

PDII-3:LA  
LBerry  
2/12/92

PDII-3:PE  
FRinaldi: cw  
2/18/92

PDII-3:PM  
LWiens  
2/18/92

PDII-3  
DMatthews  
2/19/92

DOCUMENT NAME: RAI OCONEE M8886/7/8

210018  
FBI NEW YORK COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555  
February 19, 1992

Docket Nos. 50-269, 50-270  
and 50-287

Mr. J. W. Hampton  
Vice President, Oconee Site  
Duke Power Company  
P. O. Box 1439  
Seneca, South Carolina 29679

Dear Mr. Hampton:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION CONCERNING OCONEE NUCLEAR STATION -  
RELIEF REQUEST FROM ASME BOILER AND PRESSURE VESSEL CODE, SECTION XI,  
SUBSECTION IWP (TACS M8886, M8887, AND M8888)

The NRC staff is reviewing your submittal dated June 19, 1991, for Oconee Nuclear Station, Units 1, 2, and 3. Your submittal addresses the use of digital vibration instrumentation for pump vibration measurements. We find that additional information, as indicated in the enclosure, is required to complete our review. Your response to the enclosed questions is requested within 30 days of the date of this letter. If you have any questions regarding this matter, please contact Frank Rinaldi at (301) 504-1444.

This requirement affects fewer than ten respondents and, therefore, it is not subject to Office of Management and Budget review under P.L. 96-511.

Sincerely,

A handwritten signature in dark ink, appearing to read "LA Wiens", is positioned above the typed name of the Project Manager.

Leonard A. Wiens, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

Mr. J. W. Hampton  
Duke Power Company

Oconee Nuclear Station

cc:

Mr. A. V. Carr, Esq.  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242-0001

Mr. M. E. Patrick  
Compliance  
Duke Power Company  
Oconee Nuclear Site  
P.O. Box 1439  
Seneca, South Carolina 29679

J. Michael McGarry, III, Esq.  
Winston and Strawn  
1400 L Street, NW.  
Washington, DC 20005

Mr. Alan R. Herdt, Chief  
Project Branch #3  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, NW., Suite 2900  
Atlanta, Georgia 30323

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Division  
Suite 525  
1700 Rockville Pike  
Rockville, Maryland 20852

Ms. Karen E. Long  
Assistant Attorney General  
N. C. Department of Justice  
P.O. Box 629  
Raleigh, North Carolina 27602

Manager, LIS  
NUS Corporation  
2650 McCormick Drive, 3 Floor  
Clearwater, Florida 34619-1035

Mr. R. L. Gill, Jr.  
Licensing  
Duke Power Company  
P. O. Box 1007  
Charlotte, North Carolina 28201-1007

Senior Resident Inspector  
U. S. Nuclear Regulatory Commission  
Route 2, Box 610  
Seneca, South Carolina 29678

Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, NW., Suite 2900  
Atlanta, Georgia 30323

Mr. Heyward G. Shealy, Chief  
Bureau of Radiological Health  
South Carolina Department of Health  
and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Office of Intergovernmental Relations  
116 West Jones Street  
Raleigh, North Carolina 27603

County Supervisor of Oconee County  
Walhalla, South Carolina 29621

REQUEST FOR ADDITIONAL INFORMATION  
RELIEF REQUEST FROM ASME SECT. XI SUBSECT. IWP  
OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3  
DOCKET NOS. 50-269, 50-270, AND 50-287

1. In your submittal, you state that the loop accuracy of vibration instrument measurements will be  $\pm 6.56\%$  of the reading for velocity and  $\pm 7.37\%$  of the reading for displacement, and that this accuracy is the best that can be reasonably obtained from state-of-the-art instrumentation used to perform the enhanced testing. Further, you identify an acceptance criteria that will be based solely on displacement, with velocity vibration data having no effect.
  - a) Discuss the difference in the instruments used for velocity and displacement measurements and the bases for differences in the accuracy for each instrument.
  - b) Discuss whether the error introduced in the instrument readings could mask a degraded pump or cause a good pump to be declared inoperable by stretching or compressing the ASME Code Section XI allowable range. Provide the bases for the acceptability of the proposed instrument accuracies addressing the need for inservice testing to assess the operational readiness and detect degradation. Also, state and discuss whether instrumentation that meets Code accuracy is readily available for acquisition and field use.
  - c) Discuss the basis for selecting displacement measurement acceptance criteria in lieu of the more accurate velocity data, particularly for pumps operating at 600 rpm or greater. Also, discuss if and how instrumentation inaccuracy beyond Code allowable limits are evaluated along with the acceptance criteria during the final data review.
2. The ASME Section XI Code requires that the frequency response range of the readout system shall be from one-half the minimum speed to at least maximum pump shaft rotational speed. You state that the measurements for vibration displacement and velocity will be measured over a range, from one-half the minimum pump shaft rotational speed to at least four times shaft rotational speed, and that the vibration instrumentation will be calibrated over a range of 10 to 1000 Hz (600 to 60,000 RPM). The intent of monitoring the Code required frequency response range is to include low speed pumps (<600 RPM) and to detect any subharmonic conditions.

Discuss the basis or rationale for not calibrating the instrumentation in order to include the lower frequency response range (<600 RPM). Also, discuss the assumed instrument accuracy and repeatability and the bases for these assumptions for measurements made in the lower frequency response range. Further, discuss the licensee's experience and confidence in the validity of these measurements.