

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9311090122 DOC. DATE: 93/10/28 NOTARIZED: NO
FACIL: 50-269, Oconee Nuclear Station, Unit 1, Duke Power Co.
AUTH. NAME AUTHOR AFFILIATION
HAMPTON, J.W. Duke Power Co.
RECIP. NAME RECIPIENT AFFILIATION

DOCKET #
05000269

Document Control Branch (Document Control Desk)

SUBJECT: Discusses discrepancy discovered between NRC SER for facility & facility FSAR re high pressure SWS, per review of NRC SER.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME	LTR	ENCL		
	PD1-3 LA	1	1		
	WIENS, L	2	2		
INTERNAL:	ACRS	6	6		
	NRR/DORS/OTSB	1	1		
	NRR/DSSA/SPLB	1	1		
	NUDOCS-ABSTRACT	1	1		
	OGC/HDS2	1	0		
EXTERNAL:	NRC PDR	1	1		
	PD1-3 PD	1	1		
	NRR/DE/EELB	1	1		
	NRR/DRCH/HICB	1	1		
	NRR/DSSA/SRXB	1	1		
	OC/LFDCB	1	0		
	REG FILE 01	1	1		
	NSIC	1	1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 19

R
I
D
S
/
A
D
D
S
/
A
D
D
S
/
A
D
D
S

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER

October 28, 1993

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Site
Docket Nos. 50-269
NRC Safety Evaluation Report for Oconee Unit 1

During a review of the NRC Safety Evaluation Report for Oconee Unit 1, a discrepancy between the NRC SER and the Oconee FSAR was discovered concerning the High Pressure Service Water system.

The NRC SER for Oconee Unit 1 states that "the Class I (seismic) service water system consists of a low pressure service water (LPSW) system and a high pressure service water (HPSW) system." However, this is inconsistent with the FSAR which does not indicate that HPSW is Class 1 (seismic). The HPSW system was not originally designed to be Class I (seismic).

Very truly yours,

J. W. Hampton

cc: Mr. S. D. Ebnetter, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II

Mr. L. A. Wiens, Project Manager
Office of Nuclear Reactor Regulation

Mr. P. E. Harmon
Senior Resident Inspector
Oconee Nuclear Site

9311090122 93102B
PDR ADOCK 05000269
P PDR

Accol 1/10

Document Control Desk

Page 2

June 7, 1993

bcc: H. B. Barron
B. L. Peele
G. E. Rothenberger
D. V. Deatherage
R. L. Dobson
D. M. Jamil
B. J. Dolan
S. L. Nader
J. M. Davis
M. E. Patrick
S. C. Perry
S. C. Adams
A. V. Carr
W. M. Sample
R. C. Futrell - CNS
R. O. Sharpe - MNS
ELL - EC050
QA TS - EC05P
QVD - EC12A
NSRB - EC12A
OS-815.01