

# ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

. ACCESSION NBR: 9311170332      DOC. DATE: 93/11/11      NOTARIZED: YES      DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.      05000269  
       50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.      05000270  
       50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.      05000287

AUTH. NAME      AUTHOR AFFILIATION      R  
 HAMPTON, J.W.      Duke Power Co.  
 RECIP. NAME      RECIPIENT AFFILIATION      I  
                                  Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to licenses DPR-38, DPR-47 & DPR-55,  
 proposing rev to TS to provide interim acceptance criteria  
 for control rod drop time in unit 1.      D

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: S+11      /  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL	
	PD2-3 LA	1	1	PD2-3 PD	1	1	D
	WIENS, L	2	2				D
INTERNAL:	ACRS	6	6	NRR/DE/EELB	1	1	S
	NRR/DORS/OTSB	1	1	NRR/DRCH/HICB	1	1	
	NRR/DSSA/SPLB	1	1	NRR/DSSA/SRXB	1	1	
	NUDOCS-ABSTRACT	1	1	OC/LFDCB	1	0	
	OGC/HDS2	1	0	<u>REG FILE</u> 01	1	1	
EXTERNAL:	NRC PDR	1	1	NSIC	1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR    21    ENCL    19

Duke Power Company  
Oconee Nuclear Site  
P.O. Box 1439  
Seneca, SC 29679

J. W. HAMPTON  
Vice President  
(803)885-3499 Office  
(803)885-3564 Fax



**DUKE POWER**

November 11, 1993

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Subject: Oconee Nuclear Station  
Docket Nos. 50-269,-270,-287  
Control Rod Drop Time Testing  
Proposed Technical Specification Amendment

Pursuant to 10 CFR 50, Part 50.90, Attachment 1 provides a proposed amendment to the Oconee Nuclear Station (ONS) facility operating licenses and revisions to the ONS Technical Specifications. A markup of the current Technical Specifications is provided in Attachment 2. This amendment will provide an interim acceptance criteria for control rod drop time on Oconee Unit 1. Specifically, control rod Group 1, Rod 8 and Group 2, Rod 5 would be considered operable with an insertion time of  $\leq 3.00$  seconds provided that: 1) the average insertion time for the remaining rods in Group 1 and the average insertion time for the remaining rods in Group 2 is  $\leq 1.5$  seconds, and 2) the core average negative reactivity insertion rate is within the assumptions of the safety analysis. This acceptance criteria would apply until the end of the current fuel cycle for Oconee Unit 1 (end of cycle 15, currently scheduled for April 1994). This acceptance criteria for rod drop time would apply, for the two rods in question, rather than the existing TS 4.7.1 limit of 2.00 seconds from the fully withdrawn position to 3/4 insertion. In addition to establishing the interim acceptance criteria, these rods will be tested at the next available opportunity.

Technical justification for this amendment request is provided in Attachment 3. Briefly, assuming these two rods drop into the core within 3.00 seconds and the remainder of the rods in these groups drop within 1.5 seconds, then the negative reactivity insertion rate will remain within the assumptions of the safety analysis. Therefore, there is no safety significance associated with the possibility that these two control rods might have drop times not greater than the proposed 3.00 seconds.

Attachment 4 provides the No Significant Hazards Consideration Evaluation and Environmental Impact Statement.

9311170332 931111  
PDR ADOCK 05000269  
P PDR

D

A001  
11/11

Document Control Desk  
November 11, 1993  
Page 2

At present Group 2, Rod 5 for Unit 1 has been declared inoperable due to testing on November 3, 1993 which resulted in a drop time of 2.063 seconds. Unit 1 is operating at full power with adjusted control rod position limit curves which take into account additional shutdown margin requirements due to the inoperable rod. These limits reduce the operating flexibility of the unit to respond to transient situations without violating the new shutdown margin requirements. These curves will need to be revised again prior to the current fuel cycle exceeding 300 EFPD and will apply for the remainder of cycle 15 (430 +/- 10 EFPD). These curves will be very restrictive with Group 2 Rod 5 declared inoperable. Normal power maneuvering will be mostly via very slow boron adjustments to the RCS. Any transient conditions are more likely to result in violation of the imposed shutdown margin curves. Unit 1 is currently at 267 EFPD.

An additional burden will occur at 375 EFPD, when Axial Power Shaping Rods (APSR)-Group 8 are withdrawn from 35% to 100% as part of the normal fuel cycle. Group 7 rods are used to compensate for the reactivity change while withdrawal is in progress. The new CRD position limit curves will make this evolution very difficult.


As shown from the evaluation addressed in the technical justification for this proposed amendment, these restrictions are currently being imposed without any justified safety requirements.

Additionally, if another control rod on Unit 1 is declared inoperable for any reason, an unnecessary shutdown to hot standby must occur within 12 hours per Technical Specification 3.5.2.2.e.

Therefore, it is requested that this proposed amendment receive timely review and approval to prevent unnecessary operator burden and possible violation of current restrictive control rod position limits that are being imposed as a result of Unit 1, Group 2, Rod 5 being declared inoperable.

I am forwarding a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultation with the staff.

Very Truly Yours,

  
J. W. Hampton

U. S. Nuclear Regulatory Commission  
November 11, 1993  
Page 3

xc: L. A. Wiens, ONRR


S. D. Ebnetter  
Regional Administrator, Region II

P. E. Harmon  
Senior Resident Inspector


Heyward Shealy, DHEC

U. S. Nuclear Regulatory Commission  
November 11, 1993  
Page 4

J. W. Hampton, being duly sworn, states that he is Vice President of Duke Power Company, that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the Oconee Nuclear Station License Nos. DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.

  
\_\_\_\_\_  
J. W. Hampton, Vice President

Subscribed and sworn to before me this 11<sup>th</sup> day November, 1993.

  
\_\_\_\_\_  
Notary Public

My Commission Expires:

MY COMMISSION EXPIRES 7-9-1997

U. S. Nuclear Regulatory Commission  
November 11, 1993  
Page 5

bx: H. B. Barron, ONO1VP  
B. L. Peele, ONO1VP  
J. M. Davis, ONO1VP  
L. V. Wilkie, ONO1VP  
C. A. Little, ONO1VP  
G. E. Rothenberger, ONO101  
B. J. Dolan, ONO2ME  
R. L. Dobson, ONO2EE  
T. A. Ledford, ONO2EE  
D. B. Coyle, ONO1SE  
D. M. Hubbard, ONO1CP  
M. E. Patrick, ONO3RC  
NSRB, EC12A  
G. A. Copp, EC050  
T. A. Coutu, ONO102  
K. S. Canady, EC08H  
G. B. Swindlehurst, EC08H  
R. O. Sharpe, MG01RC  
R. C. Futrell, CNS  
BWOG Tech Spec Committee (6)  
T. D. Patterson, ONO3RC  
File