

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title:                   Advisory Committee on Reactor Safeguards  
                              Metallurgy and Reactor Fuels Subcommittee  
                              Open Session

Docket Number:       (n/a)

Location:               Rockville, Maryland

Date:                    Tuesday, May 3, 2016

Work Order No.:       NRC-2346

Pages 1-135

NEAL R. GROSS AND CO., INC.  
Court Reporters and Transcribers  
1323 Rhode Island Avenue, N.W.  
Washington, D.C. 20005  
(202) 234-4433

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

METALLURGY AND REACTOR FUELS SUBCOMMITTEE

OPEN SESSION

+ + + + +

TUESDAY, MAY 3, 2016

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear  
Regulatory Commission, Two White Flint North, Room  
T2B1, 11545 Rockville Pike, at 1:05 p.m., Ronald G.  
Ballinger, Chairman, presiding.

COMMITTEE MEMBERS:

RONALD G. BALLINGER, Chairman

CHARLES H. BROWN, JR. Member

DANA A. POWERS, Member

JOY L. REMPE, Member

PETER RICCARDELLA, Member-at-Large

GORDON R. SKILLMAN, Member

JOHN W. STETKAR, Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

DESIGNATED FEDERAL OFFICIAL:

DEREK WIDMAYER

ALSO PRESENT:

KATHRYN BROCK, RES

MARK KIRK, RES

MARVIN LEWIS, Public Participant\*

ANDREA D. VALENTIN, Executive Director, ACRS

\*Present via telephone

## TABLE OF CONTENTS

Introduction	
By Ronald Ballinger .....	4
Staff Introduction	
By Kathryn Brock.....	6
Pressurized Thermal Shock Regulatory Guide & Technical Basis (OPEN)	
By Mark Kirk .....	8
Public Comments.....	79
Adjourn to Closed Session.....	80

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

## P R O C E E D I N G S

(1:05

p.m.)

CHAIRMAN BALLINGER: Okay. Good afternoon. The meeting will now come to order. This is a meeting of the Advisory Committee on Reactor Safeguards Subcommittee on metallurgy and reactor fuels. I'm Ron Ballinger, Chairman of the Subcommittee.

MEMBER POWERS: What is wrong with you?

CHAIRMAN BALLINGER: ACRS members -- and I use that term lightly -- in attendance: Pete Riccardella, Gordon Skillman, Dana Powers, John Stetkar, Charlie Brown, and the esteemed Joy Rempe. Derek Widmayer of the ACRS staff is the Designated Federal Official for this meeting.

The purpose of today's meeting is for the NRC staff to discuss the final draft Regulatory Guide 1.230. Regulatory guidance on the alternate Pressurized Thermal Shock rule and draft final report NUREG-2163, technical basis for regulatory guidance on the alternate Pressurized Thermal Shock rule, otherwise known as 10 CFR 50.61a.

The Subcommittee considered this matter at a Subcommittee meeting held in October 2015 and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 many others but decided to meet again and hear from  
2 the staff after it received comments on the draft  
3 documents. The Subcommittee will gather  
4 information, analyze relevant issues and facts,  
5 formulate proposed positions and actions as  
6 appropriate, for consideration by the full  
7 Committee at the upcoming June 235th meeting of the  
8 ACRS.

9 Rules for participation in today's  
10 meeting were announced as part of the notice of the  
11 meeting published in the Federal Register.  
12 Detailed proceedings for conduct of the ACRS was  
13 previously published in the Federal Register on  
14 October 1, 2014. The meeting will be open to the  
15 public, except for a portion of the meeting at the  
16 end which will be closed in order to discuss public  
17 comments and the proposed NRC staff resolutions to  
18 those comments.

19 We have received no written comments or  
20 requests for time to make oral statement. A  
21 transcript of today's meeting is being kept and  
22 will be made available, as stated in the Federal  
23 Register Notice. Therefore, we request that  
24 meeting participants use the microphones located in  
25 the meeting room when addressing the Subcommittee

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and push the little green button when you need to  
2 talk. Participants should first identify  
3 themselves and speak with sufficient clarity and  
4 volume so that they may be readily heard.

5 A telephone bridgeline has been  
6 established for this meeting. To preclude  
7 interruption of this meeting, please mute your  
8 individual telephones and lines during  
9 presentations and the Subcommittee discussion. We  
10 ask that attendees in the room please silence all  
11 cell phones and things that beep and other devices  
12 that make noise to minimize disruptions.

13 And we'll now proceed with the meeting.  
14 I'll call on Mark Kirk. Whoa.

15 MS. BROCK: Good afternoon.

16 CHAIRMAN BALLINGER: Call on Kathryn  
17 Brock -- boy, that is a good entrance -- Deputy  
18 Director of the Office of Research, Division of  
19 Engineering, to make introductory remarks. Thank  
20 you.

21 MS. BROCK: Thank you very much. So  
22 it's my pleasure to introduce Dr. Mark Kirk, who is  
23 going to be presenting the NRC's response to public  
24 comments on what's now designated as Reg Guide  
25 1.230 and its supporting technical basis, NUREG-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 2163.

2                   These documents provide methods  
3 acceptable to the staff by which licensees could  
4 choose to implement the alternate Pressurized  
5 Thermal Shock rule, or PTS. As Mark will talk to  
6 you about in some detail, this issue on PTS goes  
7 back around two decades, and Mark has been always  
8 happy to come to ACRS to address this committee and  
9 your comments have always been very helpful to us,  
10 and we appreciate it.

11                   So at this stage, we're ready to move  
12 forward with the final reg guide, subject to this  
13 committee's approval. Thanks very much.

14                   CHAIRMAN BALLINGER: Okay. All yours.

15                   MS. BROCK: Okay, all right. Thank  
16 you. Well, hopefully, my closeout performance  
17 here. So in terms of an overview, I'll just give  
18 some background on the alternate PTS rule  
19 development, on the PTS rule regulatory guide,  
20 including the reg guide development process and its  
21 current status, and provide an overview of the  
22 contents of the tech basis and the reg guide. The  
23 tech basis is a companion NUREG that went out for  
24 public comment at the same time as the reg guide.

25                   I'll provide a few slides on plants

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that might possibly use 10 CFR 50.61a -- and I'll  
2 probably go back and forth between saying 50.61a  
3 and the alternate PTS rule, they both mean the same  
4 thing -- and Reg Guide 1.230 in the future. Then I  
5 believe, at that point, the meeting gets closed to  
6 discuss the staff's responses to public comments on  
7 the reg guide and tech basis.

8 And at the end, we're looking for this  
9 committee to either send a memo to NRC Research  
10 approving the reg guide and NUREG for publication  
11 or to send a letter to the EDO, of course,  
12 objecting to that. But you'll figure that out, I'm  
13 sure.

14 MEMBER POWERS: ACRS speaks only  
15 through its letters.

16 MR. KIRK: Yes.

17 CHAIRMAN BALLINGER: And that's up to  
18 the full Committee.

19 MR. KIRK: Okay, okay.

20 MEMBER REMPE: And if we were to issue  
21 a memo, like a Hackett-Gram or a Valentine memo, it  
22 would not be an approving thing. It would just say  
23 we have no comments on this thing.

24 MR. KIRK: Okay, okay, thank you. So  
25 the first topic is just to set the scene, the quick

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 overview -- I say quick in a bit of quotation marks  
2 -- on the development and background of the  
3 alternate rule. This is the last 18 years of my  
4 life. I was thinking of including a picture of  
5 myself in 1998, but the contrast to my current  
6 state of decrepitude was too horrible for me to  
7 reconcile, so I went without pictures. You're  
8 welcome.

9 CHAIRMAN BALLINGER: They had film back  
10 in those days. Is there any film left?

11 MR. KIRK: I think it was a  
12 Daguerreotype, but I'm not really sure. Anyway,  
13 this project started shortly before I joined the  
14 NRC staff in 1998, and I quickly got involved in it  
15 and it's been very interesting. And the first two  
16 years or so, we spent a lot of time meeting among  
17 ourselves, having public meetings, interacting with  
18 our industry counterparts to develop a PFM Code to  
19 simulate what would happen to a nuclear reactor  
20 pressurized water reactor in the unlikely event of  
21 a Pressurized Thermal Shock Event.

22 Once we had a code, of course it didn't  
23 work perfectly the first time, so there were  
24 several modifications to the code. And we were  
25 briefing the ACRS all along the way. We used to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 come here about twice a year, as I recall.

2 And, finally, at the end of the phase  
3 that I've called building the technical case in the  
4 2005 - 2006 time frame, the technical reports were  
5 all given a favorable nod by this committee. And  
6 about a year later, the Commission directed the  
7 staff to begin rulemaking.

8 The rulemaking process itself, in this  
9 case, took about two and a half years, as my  
10 colleague sitting in the back, Matt Mitchell,  
11 remembers. I believe he had hair at that time.

12 We went out for two rounds of public  
13 comments and, ultimately, arrived at what was  
14 published on, I believe, January the 3rd, 2010 as  
15 the alternate PTS rule. As government printing  
16 goes, it then took about six more months and three  
17 re-publications to get everything correct.

18 Since that time, we've been working on  
19 guidance for using the rule. The industry,  
20 however, works a little bit quicker than the  
21 government and, actually, two submittals came in to  
22 use the rule before we get the draft guidance  
23 released for public comment.

24 Beaver Valley submitted in the middle  
25 of, in the summer of 2013. Palisades submitted in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the summer of 2014. I'll tell you the rest of the  
2 story later, but "Beaver Valley submits" is crossed  
3 out because they later elected to withdraw their  
4 submittal for reasons I'll explain later. But the  
5 Palisades submittal was fully reviewed by the  
6 staff, went through several rounds of RAIs, two as  
7 I recall, and was eventually approved a little  
8 before Christmastime of last year.

9 Pertinent to the discussions here,  
10 Draft Guide 1299, which is subject to the favorable  
11 ratings from this committee and the printing press  
12 is still working will become Reg Guide 1.230, was  
13 released for public comment at the end of 2014 or  
14 early 2015, and today we're talking about those  
15 public comments and I'll say the relatively small  
16 ways in which they've changed the draft reg guide  
17 and how we plan on moving forward.

18 A little bit of background. What's in  
19 10 CFR 50.61a and why was it developed? And as  
20 it's indicated on the slide, this was explained in  
21 Chapter 1 of NUREG-2163, which you'll also hear me  
22 call the tech basis document.

23 So the path to 50.61a, we'll talk a  
24 little bit about the motivation for doing this at  
25 all, the overall approach that the staff employed,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the key results, and a brief discussion of the  
2 provisions of the alternate rule.

3 So, of course, the original PTS rule,  
4 to which this is an alternate, was developed in the  
5 early 1980s and promulgated, I always get this  
6 wrong and I shouldn't, I think in 1986. At the  
7 time, there was, I think, broad recognition  
8 throughout the nuclear community and among the NRC  
9 staff that the calculations and the data that  
10 supported the original PTS rule, 50.61, had within  
11 it a lot of embedded conservatisms that, at the  
12 time, were not seen as being necessary to be made  
13 better because the nuclear industry was a lot  
14 younger then, plants weren't coming up on 40-year  
15 licenses or going for 60 or 80, so the  
16 conservatisms that were embedded in the  
17 embrittlement screening criteria that are still  
18 part of the original PTS rule 50.61 weren't seen to  
19 be in any way limiting or excessively conservative.

20 I should say, from that time, there was  
21 talk among various parties of an interest in  
22 revising the rule or doing a better job. That  
23 finally culminated with staff interest pushed  
24 forward by Mike Mayfield in the late 1990s and was  
25 motivated by several things. One was, just looking

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 at it from a technical viewpoint, was a desire to  
2 do a better job, to treat everything more  
3 realistically. But, of course, just technically  
4 doing a better job isn't enough reason to do  
5 something. There are also some key regulatory  
6 motivations, and they're listed here. One is that  
7 doing a better job would reduce unnecessary burden  
8 associated with the original rule. As I said, the  
9 technical insights indicated that the then existing  
10 screening criteria were more conservative than were  
11 needed to maintain safety and that those screening  
12 criteria don't necessarily increase the overall  
13 plant safety and, in fact, could divert resources  
14 on other more risk-significant matters.

15 Part of the reason motivating the  
16 alternate rule was the experience, and I'll say, I  
17 think, routinely bad experience, from the early  
18 1990s with plant-specific analysis using PRA and  
19 PFM as a means of showing that operating beyond the  
20 then existent 50.61 screening criteria was  
21 acceptable, otherwise known as Yankee Row. So  
22 there was an interest in doing something more  
23 generically for the fleet with the hope that things  
24 like Yankee Row and the associated uncertainties  
25 associated with that process would not be repeated.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And also, as we got into the late 1990s  
2                   - early 2000s, things that weren't apparent in the  
3                   mid-1980s, like license renewal, and now I've been  
4                   around long enough I can say license renewal-  
5                   renewal or the NRC's acronym for that is SOR, those  
6                   things weren't even thought of. Now they're  
7                   thought of. Now license renewal has happened, and  
8                   we're talking about subsequent license renewal. So  
9                   having screening limits that are overly  
10                  conservative creates an artificial impediment to  
11                  those processes.

12                  MEMBER SKILLMAN: Mark, before you  
13                  change that slide, for those who have been around  
14                  for a long time, 300 degrees Fahrenheit and 270  
15                  Fahrenheit are numbers that we've all come to know  
16                  and trust. For instance, that's about where you go  
17                  ahead and give permit to the fourth pump start, so  
18                  you don't lift your fuel. That's where the density  
19                  has become low enough that starting a fourth  
20                  reactor coolant pump doesn't cause your fuel to  
21                  chatter. It's married to the springs. 270 is  
22                  commonly a run back. The secondary dumps or the  
23                  atmospheric dumps might bring the plant back to 270  
24                  automatically.

25                  Those numbers were chosen many years

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ago based on knowing how a P will operate. And I  
2 think if one were to check the Westinghouse, the  
3 Babcock, and the CEs, all used approximately those  
4 same numbers. And so I'm wondering if simply by  
5 anointing them as too conservative, the baby being  
6 thrown out with the bath water, something is being  
7 lost.

8 MR. KIRK: I'd like to just clarify  
9 what I think you told me. You're saying that, in  
10 plant operation, those numbers mean something?

11 MEMBER SKILLMAN: Certain events have  
12 been associated with these numbers.

13 MR. KIRK: Yes.

14 MEMBER SKILLMAN: And I'm not  
15 suggesting that they, in themselves, represent a  
16 conservatism that should be retained. All I'm  
17 saying is, when you look at those numbers and if  
18 you're an old P handler, you say I know what those  
19 numbers mean.

20 MR. KIRK: Yes, in tech specs, they're  
21 all over the place. And I'm, well, I'm not a plant  
22 operations person, but I certainly wouldn't be  
23 suggesting that that operational practice should  
24 change. And, in fact, I can say for certain that,  
25 to the analyses that we did reflected current plant

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 operating procedures. So to the extent that we  
2 analyzed transients involving the things that  
3 you've said, and I'll just have to plead ignorance  
4 because, again, that's not my specialty, the  
5 assumption moving forward is that those operational  
6 events would not be changing as a result in the  
7 change in the embrittlement screening criteria.

8 I'll just say I haven't personally,  
9 before you mentioned this which probably reflects  
10 that I should get out more often, heard anybody  
11 say, oh, now, we change these plant operational  
12 procedures because the NRC has put out a new --

13 MEMBER SKILLMAN: No, you can't because  
14 you still have those other thermal hydraulic issues  
15 that you have to deal with --

16 MR. KIRK: Right, right.

17 MEMBER SKILLMAN: -- that is like when  
18 the density is appropriate, so you don't lift your  
19 fuel if you start the fourth --

20 MR. KIRK: So I think there are other,  
21 I mean, I think you've maybe provided a better  
22 answer than I have. There are other reasons to  
23 keep those operating procedures in place that are  
24 completely different than screening limits related  
25 to plant integrity.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Thank you.

2 MR. KIRK: Okay. So our overall  
3 approach was that we started with commissioned  
4 guidance in the form of the Safety Goal Policy  
5 Statement, the June 1990 Safety Requirements  
6 Memorandum and Reg Guide 1.174 to derive a  
7 performance metric in terms of -- well, basically,  
8 here the conservative assumption was that large  
9 early release frequency was equal to yearly  
10 frequency of through-wall cracking, and so that was  
11 set at a one times seven to the minus six level,  
12 and then we performed a number of probabilistic  
13 fracture mechanics analyses driven by PRA at the  
14 start to define the sequence of things that could  
15 go wrong that could lead to a Pressurized Thermal  
16 Shock or excessive cool-down and the frequency with  
17 which they happen. The PRA then fed the thermal  
18 hydraulic analyses to define the pressure  
19 temperature and heat transfer boundary conditions  
20 that go into the structural mechanics and fracture  
21 mechanics analysis. There are a bunch of other  
22 inputs that aren't shown here.

23 But that then gives us a conditional  
24 probability of through-wall cracking. It's then  
25 multiplied, matrix multiplied by the event

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 frequencies, to estimate the yearly frequency of  
2 through-wall cracking. We did that analysis for  
3 three plants, or I should say models of three  
4 plants, that we studied in detail, those being the  
5 Palisades plant, the Beaver Valley plant, and  
6 Oconee; developed from that this relationship  
7 between vessel damage as quantified by vessel  
8 transition temperature, showed that, of course, as  
9 that increases, as embrittlement increases, the  
10 yearly frequency of through-wall cracking  
11 increased. Used that to develop a screening  
12 criteria consistent with defense-in-depth  
13 principles and then looked at what were the key  
14 things driving these values to see if we could  
15 generalize those results to all plants in the  
16 fleet. And I'll talk a little bit more about that  
17 as we go on, which is now.

18 So in terms of some of the key results  
19 I'd like to highlight: What are the operational  
20 transients that most influence the PTS risk?  
21 Similarly, what are the material features that most  
22 influence the PTS risk? And then sort of the key  
23 question to our development of a rule that could  
24 apply to all PWRs is to see if these dominant  
25 material features and transients are, more or less,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 similar across the fleet or do they vary by a  
2 plant-by-plant or designer-by-designer basis? And  
3 then talk about finally the new embrittlement --  
4 well, then new, this is a slide from I think 2007 -  
5 - embrittlement screening criteria based on these  
6 calculations.

7 So we did a pretty thorough job at  
8 modeling, I'll just say all the classes of cool-  
9 down transients that could occur under postulated  
10 accident conditions. So we had a spectrum of pipe  
11 breaks from very small to very large, stuck-open  
12 valves that later re-closed. On the secondary  
13 side, we had main steam line breaks and basically  
14 tried to model the plant as accurately as we could  
15 for things that could go wrong and ruin your day,  
16 from a plant operations perspective.

17 Looking at all of that, so we modeled  
18 all these different variations of cool-down events  
19 with and without pressure. But then when we got to  
20 looking at the results, things pretty much fall  
21 into one of three categories, which I've depicted  
22 here. I should say things fell into one of three  
23 categories for cool-down events that had risk  
24 significance.

25 In the end in this project, we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 calculated an awful lot of zeros, so one category  
2 with significant cool-downs is medium- and large-  
3 diameter pipe breaks. The second category is  
4 stuck-open primary side valves. So a stuck-open  
5 valve is something like a small-diameter pipe  
6 break, but the key thing there is the valve re-  
7 closes later in the transient and leads to a  
8 pressurization spike.

9 And then the third is main steam line  
10 breaks, and all of these are plotted versus  
11 embrittlement and degrees Rankine, and everybody  
12 always asks me why I use degrees Rankine, and I  
13 think I had a good technical reason years ago and,  
14 in the fullness of time, it's been revealed that it  
15 just annoys people. So as Candidate Clinton said,  
16 it seemed like a good idea at the time, but now I  
17 realize it was a mistake.

18 So this slide 16 is pretty much the  
19 same as slide 15 but easier to look at because I've  
20 re-expressed the through-wall cracking frequencies  
21 as ratios of each other. And this really more  
22 better communicates the message, which is -- and  
23 now I've gone back to degrees Fahrenheit just to  
24 confuse everyone -- at lower levels of  
25 embrittlement, the stuck-open valves that re-close

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 late in the transient and lead to a re-  
2 pressurization spike, they're the transients that  
3 are dominating a risk because you need that light  
4 pressure spike to get a crack going in, admittedly  
5 an embrittled but a not too embrittled material.

6           However, as you embrittle the material  
7 more and more, of course all of these through-wall  
8 cracking frequencies are going up, but the rate of  
9 increase per increment of embrittlement, if you  
10 will, for the medium- and large-diameter pipe  
11 breaks is larger, such that when you get out to  
12 reference temperatures in the range where we're  
13 setting our screening criteria, it's actually the  
14 medium- and large-diameter pipe breaks that are  
15 dominating the risk, that are making up 70 to 80-  
16 percent of the risk.

17           Sort of interesting change from the  
18 results from the early 1980s is the main steam line  
19 breaks, which in the first analysis of PTS in the  
20 80s were seen to be the risk dominant transient,  
21 now become almost a bit player, and so you ask why.  
22 And this is where modeling assumptions become  
23 important, and actually there are two illustrations  
24 here where modeling assumptions become important.  
25 In the original PTS analysis, there was no risk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 significance to medium- and large-diameter pipe  
2 breaks because they were eliminated from the  
3 analysis a priori. It was assumed that you needed  
4 pressure, you needed the "P" in PTS to get a  
5 through-wall crack.

6 Since the events weren't analyzed, of  
7 course they couldn't be risk significant because  
8 they were assumed to be zero. When we actually  
9 analyzed them, we found that when you get out to  
10 sufficient levels of embrittlement, there's not  
11 enough crack risk capacity in the material, and  
12 they did indeed go through-wall.

13 So a big, you know, sort of change in  
14 perspective for what transients matter in PTS and  
15 what don't come in this analysis when we learned  
16 that, well, when we analyzed something that we had  
17 previously eliminated based on, shall I say,  
18 engineering judgment, we find out that it really  
19 was risk significant, so it should have been  
20 analyzed before.

21 Conversely, the opposite is true of  
22 main steam line break. In the circa 1980s  
23 analysis, the main steam line break was analyzed as  
24 a whopping fast cool-down, which, of course, it has  
25 to be because you're breaking a huge diameter pipe,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 so you're creating a big heat transfer area. But  
2 to be conservative, the steam line break was  
3 assumed to go down to essentially ambient  
4 temperature water, something in the 50 - 60-degree  
5 Fahrenheit range. Of course, that can't happen in  
6 the primary because the main steam lines are  
7 secondary, so the cold is the primary when the main  
8 steam line breaks is the boiling point of water,  
9 212 Fahrenheit or 100 degrees Celsius.

10 When we included that more realistic model in this  
11 set of analysis, we found out that, yes, the main  
12 steam line break contributes something but not  
13 nearly as much as we saw before.

14 So, you know, this graph I think  
15 illustrates some lessons learned in building these  
16 models, but it also, I think, provides a very  
17 useful lesson moving forward that your perception  
18 of reality of course depends on what you model and  
19 what you model depends on how you decide to model  
20 it. And that drives plant decisions, so we should  
21 take care.

22 MEMBER RICCARDELLA: Mark, the new  
23 limits, they have separate limits for axial weld  
24 plate, circ weld, and forging, and, yet, the last  
25 two slides you just said maxed our T. Is that any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 specific --

2 MR. KIRK: In here, I've just added it  
3 versus the axial weld reference temperature just  
4 really for purposes of --

5 MEMBER RICCARDELLA: All right.  
6 Because that governs --

7 MR. KIRK: -- for purposes of  
8 illustration, but the reason, I think I've said all  
9 this so I'll skip this slide, but since you've  
10 raised it, the reason for the maximum, the  
11 differences in the maximum reference temperature  
12 limits, depending upon, essentially, the product  
13 form is best illustrated on this slide now, slide  
14 18 in your pack, is that -- I'm sorry. I should  
15 back up just a little bit.

16 In the probabilistic fracture mechanics  
17 models, we see different flaw size populations and  
18 different flaw orientations, depending upon what  
19 product form in the RPV shell it's going into. So  
20 welds get flaws drawn from particular flaw  
21 distribution, but they have the orientation of the  
22 weld itself because they're all nominally lack of  
23 fusion flaws. So axial welds get axially-oriented  
24 flaws, circumferential welds get circumferentially-  
25 oriented flaws.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           So we just compare on your screen the  
2 left most and right most slides. You're seeing  
3 here flaws from the same population, but the  
4 orientation has turned 90. And that makes a major  
5 difference when you're trying to propagate a crack  
6 through the wall of a pressurized sander in that,  
7 as you grow the axial flaw, the deeper the axial  
8 flaw gets as it goes through the cylinder, the  
9 driving force to fracture just keeps going up and  
10 up and up and so, essentially, it just gets pushed  
11 out the back of the cylinder.

12           MEMBER RICCARDELLA: Part of it is  $P$   
13 over  $T$  versus  $P$  over  $2T$ , right? That's one part of  
14 it.

15           MR. KIRK: Well, that's one part of it.

16           MEMBER RICCARDELLA: The other part is  
17 the --

18           MR. KIRK: But, I mean, so the  
19 magnitude is certainly higher for the axial flaw,  
20 but there's also, due to just the geometry of the  
21 cylinder, as you make the circumferential flaw  
22 deeper --

23           MEMBER RICCARDELLA: The  $K$  equations  
24 are different.

25           MR. KIRK: Yes, the  $K$  equations are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 different, and so the circ flaw equations hit a  
2 peak K somewhere around 30 to 40 percent of the way  
3 through the wall under the fixed script conditions  
4 that you get in a thermally-driven event. So  
5 there's a very natural crack arrest mechanism for  
6 circumferential flaws, and, as a result, if you  
7 look at any given reference temperature level, if  
8 you take your 750 Rankine -- forgive me -- and you  
9 go to the curve for the axial flaws, you've got  
10 about a 10 to the minus 6 through-wall cracking  
11 frequency, whereas that same embrittlement in a  
12 circ weld, you're down nearly two decades lower.

13 And the curves you see here is the  
14 reason why the reference temperature screening  
15 limit, screening criteria I should say, in the rule  
16 are so significantly different for the different  
17 product forms. The plates are, you're drawing from  
18 a different population than the welds. And, also,  
19 since there's no preferred orientation in plates  
20 for flaws, they're seated 50-percent  
21 circumferentials, 50-percent axial. So they wind  
22 up being intermediate.

23 MEMBER RICCARDELLA: But, in general,  
24 you have smaller flaws --

25 MR. KIRK: Yes. And, in general, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 flaws are much, yes, much smaller. But, you know,  
2 an interesting -- well, in the original, in 50.61,  
3 of course there's a difference in the screening  
4 criteria for axial welds and circ welds, a  
5 difference between 270 and 300. You can't see the  
6 screening criteria here, so that difference is  
7 reflective of this difference in driving force.  
8 But in the new calculations, the difference in  
9 temperature screening criteria is much, much more  
10 than 30 degrees.

11 MEMBER SKILLMAN: Excuse me. Can you  
12 explain what the first bullet means, please?

13 MR. KIRK: So the primary side fault.  
14 So of the three dominant or sort of dominant  
15 transient classes of primary side pipe breaks,  
16 there's primary side pipe breaks, there's stuck-  
17 open valves in the primary side that re-close  
18 later, and there's main steam line breaks. So only  
19 one of those is the secondary side fault, the first  
20 two being primary side faults, and they together  
21 are responsible for pretty much 95 percent of the  
22 calculated risk.

23 MEMBER SKILLMAN: And a 35-degree  
24 Fahrenheit is your ECCS tank in-flow temperature  
25 minimum?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KIRK: Yes, if you have storage on  
2 the outside.

3 MEMBER SKILLMAN: Okay, thank you. Now  
4 I understand.

5 MR. KIRK: Yes, okay. Sorry. It was  
6 that point you were focused on, yes. And I should  
7 say in the analysis we did look at differences  
8 between ECCS injection temperature, and it, of  
9 course, does make a difference.

10 MEMBER RICCARDELLA: Was that a random  
11 variable?

12 MR. KIRK: No, we modeled both, and now  
13 you're asking me to go back over a decade in my  
14 memory. But we modeled both, and it was weighted  
15 by an event frequency. You modeled hot, cold and  
16 hot?

17 MR. KIRK: Cold and hot, yes.

18 MEMBER RICCARDELLA: Okay, got it.

19 MR. KIRK: But, you know, as an  
20 example, if somebody wanted to come in -- so in the  
21 screening criteria, the significance of that  
22 particular variable doesn't really come out.  
23 That's been, I'll say, sort of mushed into the  
24 screening criteria by the fact the screening  
25 criteria are based on upper bounds to these three

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 curves here. So we're taking the worst of the  
2 conditions modeled, whereas, say if somebody wanted  
3 to come in and do a plant-specific analysis and  
4 that plan happened to be say in the southern part  
5 of the United States where it never gets that cold  
6 or they happen to have indoor refueling water  
7 storage, they could make that argument and show  
8 that the specific calculations for their plant  
9 would not be as severe as we've assumed here.

10 And this just shows, again, slide 19  
11 shows, and I think a little bit of an easier  
12 format, the same message as 18, that, for all  
13 intents and purposes, it's the axial weld flaws and  
14 the properties of the belt line materials that can  
15 be associated with axial weld flaws that drive the  
16 PTS risk and that the flaws and plates and the  
17 circumferential weld flaws -- excuse me -- play a  
18 much more minor role.

19 So we've already talked through this.  
20 The axial cracks dominate risk due to their  
21 orientation and, well, due to their orientation,  
22 and so it's the properties of the materials  
23 associated with the actual cracks that dominate the  
24 screening criteria, which would be the axial weld  
25 properties or the properties of the adjacent plate,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       whichever is worse.

2               This is now, you know, sort of one of  
3 two ways of looking at the results, and this is, in  
4 fact, the way it was codified into the reference  
5 temperature limits in 50.61a. Since I like graphs  
6 better than tables, this is a graph that depicts  
7 I'll say a portion of the tables in 50.61a.

8               So if we had a plant that was made of  
9 axial welds and plates, you know, here would be the  
10 screening criteria in the table for the axial weld  
11 on the horizontal axis, the screening criteria on  
12 the plate on the vertical axis, and then you'll  
13 also see in the tables that there's a combination,  
14 a limit on the combination of those two. And  
15 really all those are in the tables is an attempt to  
16 depict, I'll say, the ISO through-wall cracking  
17 frequency surface that came out of curve-fitting  
18 these three curves. So what we're saying here, and  
19 I think I must have that slide, yes, I have that  
20 slide, unfortunately, some place else, what we're  
21 saying here is that the through-wall cracking  
22 frequency is limited to 10 to the minus 6. It then  
23 arises due to the sum of the part due to the axial  
24 weld reference temperature, the plate reference  
25 temperature, and the circ weld reference

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 temperature, and you can invert that equation and  
2 express it in terms of reference temperatures, as  
3 we've done in the rule.

4 The graphs also depict the fact that  
5 the rule, that these screening criteria in the rule  
6 depend on the thickness of the wall of the vessel.  
7 And that's simply a reflection that this is a  
8 thermally-driven event, so the thicker wall  
9 supports higher stresses during thermal shock so  
10 more driving force.

11 MEMBER RICCARDELLA: The thermal  
12 stress?

13 MR. KIRK: Right, right.

14 MEMBER RICCARDELLA: Not the flaw size?

15 MR. KIRK: Well, the flaw size, I mean,  
16 the flaw sizes are, there's a lot reflected in  
17 here. But the differences based on thickness are a  
18 reflection of the thermal stress effects.

19 So what you see here, this is a graph  
20 actually from NUREG-1807 where, based on plant-wide  
21 data we had available at the time and based on, I  
22 must say, a now defunct view of capacity factor --  
23 here we used a capacity factor of 80 percent to  
24 represent 60 years. Of course, we know it's higher  
25 now. But this showed that all the dots represent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the operating PWRs, and they're all, at least based  
2 on this generic analysis -- of course, people have  
3 to do a plant-specific analysis, but based on a  
4 simple examination of the fleet, it seemed that  
5 everybody would remain compliant with 50.61a if  
6 they chose to use it through the end of 60 years.

7 Just another way to look at these same  
8 data is to look at histograms of the distributions  
9 of reference temperatures in the fleet, again using  
10 the same 48 EFP-wide data, and overlay those  
11 histograms on the results, the through-wall  
12 cracking frequency results that set the screening  
13 limits. And, you know, just to show you how to  
14 read one of these, you look at the, in this  
15 analysis, the highest estimated axial weld -- I'm  
16 sorry -- the highest estimated reference  
17 temperature in an axial weld was a little bit under  
18 740 Rankine, so that's what that bar represents.  
19 And if you go up and over, that's getting you a  
20 through-wall cracking frequency a little bit less  
21 than 10 to the minus 7. Obviously, these graphs  
22 would need to be revised today, but this is just  
23 what was published in NUREG-1807.

24 So in both cases, both slides 21 and 22  
25 are showing you a consistent picture that the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 plants that were operating at the time are bid  
2 inside the 50.61a screening criteria in terms of  
3 reference temperature. And, of course, that also  
4 means that the estimated through-wall cracking  
5 frequency is below 10 to the minus 6.

6 So everything I've done so far gives  
7 you a very quick overview of the information that  
8 we've developed to support the alternate PTS rule.  
9 Now we'll do a whirlwind tour through the alternate  
10 PTS rule itself. You need to meet three gating  
11 criteria to use the rule. You need to have a plant  
12 whose construction permit was issued before 2010,  
13 and I'm going to talk about the reasons for each of  
14 these in detail. You need to show that the  
15 embrittlement trends, as revealed by the plant-  
16 specific surveillance program for your plant,  
17 follow those assumed in the calculation of these  
18 through-wall cracking frequencies, and you also  
19 need to show that the flaw population in your  
20 plant, as revealed by ISI, is represented well or  
21 bounded by that assumed in the calculation.

22 Having made all those checks, you then  
23 demonstrated that, yes, the screening criteria in  
24 50.61a would be appropriate to use for your plant.

25 CHAIRMAN BALLINGER: There's a mention

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of ASME code also, right? It says that the plant  
2 was designed in accordance with a particular  
3 revision of the ASME code --

4 MR. KIRK: Yes, or earlier, I think.

5 CHAIRMAN BALLINGER: Yes, or earlier.  
6 I forget. 1989 or something like that? I don't --

7 MR. KIRK: You're right. I'm not  
8 exactly sure how that --

9 CHAIRMAN BALLINGER: Yes, that was one  
10 of the checkmarks.

11 MR. KIRK: Yes, yes, yes.

12 MEMBER SKILLMAN: 1998 edition or  
13 earlier.

14 CHAIRMAN BALLINGER: 1998 edition or  
15 earlier.

16 MR. KIRK: Okay. And, again, that was  
17 simply a reflection of the population of plants  
18 that formed the basis for the calculations that led  
19 to these screening limits. So let's take that in  
20 the construction permit. In practical terms,  
21 there's not a lot of changes in the ASME code pre-  
22 '98 or post-'98 that's going to affect these  
23 calculations. But all we're saying in the rule is  
24 if you want to apply these limits to a newer plant  
25 or to a later ASME code-version plant, it's the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 responsibility of the licensee to make the case  
2 that these same screening criteria apply, the NRC  
3 isn't taking it on itself.

4 MEMBER RICCARDELLA: But you'd have to  
5 assume that a newer plant would be pretty smart  
6 about their chemistry that they put in the --

7 MR. KIRK: You would assume that.  
8 Certainly, I would not expect somebody to be  
9 building a high-copper plant nowadays, unless  
10 they're Rip Van Winkle.

11 So a quick comparison of 10 CFR 50.61  
12 to 10 CFR 50.61a. You know, it must be said that  
13 50.61a has less restrictive reference temperature  
14 or embrittlement screening criteria, and that  
15 enables longer operations licensable to this  
16 provision of the rules. But a gating criteria must  
17 be satisfied to use that alternative rule.

18 So there's sort of three steps here.  
19 There's the reference temperature screening  
20 criteria, which we said is less restrictive in the  
21 voluntary rule. We have a similar somewhat more  
22 stringent plant-specific -- sorry, my language is  
23 bad -- plant-specific surveillance data check. You  
24 need to go through a larger battery of statistical  
25 tests, but, frankly, that's a few more columns in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 your spreadsheet. That's really not a big deal.

2 The more significant hurdle to using  
3 the voluntary rule versus 50.61 is 50.61 doesn't  
4 have an inspection requirement, whereas 50.61a  
5 does. And the purpose of the inspection  
6 requirement is, of course, acknowledging that the  
7 population of flaws that went into the  
8 probabilistic fracture mechanics calculation  
9 significantly drives the results of that  
10 calculation. We want to have a common-sense check  
11 to see that the flaw population assumed in the  
12 calculation well represents or bounds that found in  
13 any particular plant. And that's why the  
14 inspection requirement is in 50.61a.

15 MEMBER RICCARDELLA: I mean, all the  
16 plants have inspection requirements from --

17 MR. KIRK: Well, yes, yes, yes.

18 MEMBER RICCARDELLA: It's just that --

19 MR. KIRK: But not as --

20 MEMBER RICCARDELLA: -- your inspection  
21 relative to the flaw assumption.

22 MR. KIRK: Right, right. I was just  
23 speaking in terms of the PTS rules --

24 MEMBER RICCARDELLA: And help me --

25 MR. KIRK: -- not the ASME

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 requirements.

2 MEMBER RICCARDELLA: How is for axial  
3 welds 222 less restrictive than 270? In the new  
4 rule, for axial welds, if it's a thick wall, it's  
5 222 degrees.

6 MR. KIRK: Every time I do this,  
7 somebody asks a question I haven't had before, and  
8 I think this is the one for today. Thick welds?  
9 Well, okay, first, one thing that might get me out  
10 of this -- 222? Oh, good. 222 plus 60 is still  
11 higher. Because in the alternate rule, there's no  
12 margin because the margin has already been included  
13 in the limit.

14 MEMBER RICCARDELLA: I remember.  
15 Thanks.

16 MR. KIRK: Good. Not a new question.  
17 Okay. We'll keep going. So now we'll get into the  
18 provisions of the regulatory guide, which, you  
19 know, tell you in a little bit more detail than is  
20 practical to include in the rule a method that the  
21 staff finds acceptable to comply with the rule. So  
22 the bureaucratic slide on time line, and I have to  
23 keep reminding myself of this -- oh, see, there's  
24 the arrow on the slides. Reg Guide 1.230 is equal  
25 to Draft Guide 1299.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           So in September 2013, draft guide  
2 development begins, and I should credit here my  
3 former colleague, Gary Stevens, who, with me, did a  
4 lot of this, but he found greener pastures back in  
5 industry, not much thanks to Member Riccardella.  
6 So that's why I'm alone up here.

7           MEMBER RICCARDELLA: I had nothing to  
8 do with it.

9           MR. KIRK: I'm sure you didn't.  
10 Anyway, Gary Stevens worked with me a lot on this  
11 and a lot of the credit for this goes to him. We  
12 had our first briefing with you when Gary was  
13 sitting beside me in October 2014. Since that  
14 time, in March 2015, we sent out the draft guide  
15 and the NUREG for public comments. We received  
16 those public comments in May 2015. In another era,  
17 sorry. In February 2016. We didn't get  
18 concurrence before we received the comments. We  
19 got final staff concurrence, I should say from the  
20 technical offices. NRR, RES, and NRO have all  
21 concurred on the resolution of the public comments.  
22 OGC has not. We'll explain this a little more,  
23 I'll explain this in a little more detail later.  
24 We just ran up against a timing issue here. OGC  
25 had some comments about format and needing more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 details and responses to certain comments. I don't  
2 think they had anything fundamental that they found  
3 wrong with it, but we still haven't cycled it back  
4 through OGC to get their final approval. We will  
5 do that after this meeting.

6 Obviously, May 3, 2016 -- I finally got  
7 the year right -- is today's briefing. And then,  
8 in the future, we hope to incorporate any  
9 recommendations that you have into the reg guide  
10 and NUREG, send this and the public, and the  
11 resolution to the public comments, through the  
12 Office of General Counsel for a no legal objection  
13 finding, and then, finally, publish the reg guide  
14 and the NUREG on the Federal Register with the most  
15 optimistic time frame for doing that, assuming no  
16 significant bumps along the way, being about two  
17 months from now.

18 MEMBER STETKAR: Mark, I always feel  
19 compelled to do this, and you've done it a few  
20 times, both on the slides and orally. This is an  
21 ACRS Subcommittee, so you're not briefing the ACRS.

22 MR. KIRK: Yes, I'm sorry, I'm sorry.

23 MEMBER STETKAR: Any comments made  
24 during this meeting are strictly individual  
25 comments, so they have no bearing on an ACRS

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 opinion. Dr. Powers mentioned that briefly  
2 earlier, but you're perpetuating this notion that  
3 you're briefing the ACRS. You're not.

4 MR. KIRK: It shows my total ineptitude  
5 with --

6 MEMBER STETKAR: Well, it's only  
7 important because this is a meeting that's on the  
8 public record, and we don't want there to be any  
9 confusion about comments that are made by  
10 individuals in the meeting versus conveyance of an  
11 ACRS opinion on the matter.

12 MR. KIRK: I'll try to remember to  
13 correct that before I say it the next time, but I  
14 might still get it wrong.

15 Okay. So the regulatory guidance.  
16 Criteria regarding data construction, I think we  
17 already touched on this. The rule and the related  
18 reference temperature screening criteria were based  
19 on analysis of three currently operating PWRs, so  
20 we got our insights from plants in current  
21 operation designed on past editions of the ASME  
22 code.

23 We did not assess the effect of new  
24 reactor designs and new materials of construction  
25 on those screening criteria. Therefore, if a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 licensee wanted to use the alternate PTS rule for  
2 one of those newer plants, it would be up to them  
3 to demonstrate the applicability of this rule to  
4 the newer plants.

5 MEMBER POWERS: Would that include  
6 experimental data?

7 MR. KIRK: It could. There's no --

8 MEMBER POWERS: What would be the  
9 criterion, do you suppose, if the staff would come  
10 back and say you've done an admirable job trying to  
11 extrapolate from what we have to what you have, but  
12 we'd really like to see experimental data to  
13 validate this or something like the equivalent of  
14 this 60 effective full-power years?

15 MR. KIRK: Well, one thing I've learned  
16 in my nearly two decades with the NRC staff is  
17 saying that Mark's opinion is a surrogate for all  
18 the staff is --

19 MEMBER POWERS: I didn't say --

20 MR. KIRK: However, if it was me and  
21 knowing what I think I know, what I would  
22 personally be interested in is, quite frankly, more  
23 on the reactor operations side than on the  
24 materials side. And maybe that reflects too much  
25 confidence in my part of the materials side. On

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the materials side, we're using basically the same  
2 grades of steel, same welding techniques, except we  
3 don't have copper. Copper is limited. So the  
4 amount of embrittlement is limited, and we've been  
5 through this extensively within ASTM and looking at  
6 embrittlement trends on high-copper versus low-  
7 copper material and we've got trend curves that  
8 track all that.

9 So from my perspective and, again, my  
10 personal perspective, I think the materials side is  
11 well dealt with if we know the composition of the  
12 material. Then we can get on to base how well it's  
13 done and how well it's demonstrated, and I'll leave  
14 that aside.

15 But I think, you know, to me, the  
16 bigger, the potential bigger differences between,  
17 say, an AP1000, to pick a new design plant, and the  
18 three much older plants that we analyzed come in  
19 the possible challenge events, the possible  
20 transients that could lead to --

21 MEMBER POWERS: Okay. Let me seek more  
22 of the Kirk definitive statement of all things done  
23 by the staff here. Suppose I told you that my new  
24 modern plant is going to be a load following plant?

25 MR. KIRK: A low?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER POWERS: Load following. That I  
2 will follow the load demands, rather than being a  
3 baseline plant. How does that change your  
4 analysis?

5                   MR. KIRK: Well, I mean, obviously, it  
6 changes. Obviously. I would think it would change  
7 the frequency with which the transients occur or  
8 the likelihood that they would occur.

9                   MEMBER RICCARDELLA: But on the other  
10 hand, you wouldn't accumulate doses rapidly.

11                  MR. KIRK: That's true. I think there  
12 are a lot of things to consider there, which is  
13 why, which is why we didn't want to provide a  
14 blanket endorsement of things we hadn't analyzed.

15                  MEMBER RICCARDELLA: But is there a  
16 similar restriction on using 61, the original PTS  
17 rule?

18                  MR. KIRK: No, which is a little bit  
19 counter -- no, I don't want to use that word. I  
20 don't like --

21                  MEMBER RICCARDELLA: So anybody, you  
22 know, if you build the vessel properly, you're  
23 going to be able to operate it under 61 and you  
24 wouldn't go here.

25                  MR. KIRK: Yes. And it is a little bit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       ironic that we haven't put a similar restriction on  
2       the use of the older rule for the newer plants, and  
3       the only reason for that remaining so is the  
4       perception that the older rule was more  
5       conservative. So if a licensee chooses to comply  
6       with the more conservative rule, from an  
7       embrittlement standpoint, it's up to them.

8                   MEMBER STETKAR: Well, I mean, some of  
9       this is kind of interesting because I don't know  
10      anything about materials, but what I do know about  
11      newer plants, at least in licensing space, they're  
12      going to give you more large LOCAs because they're  
13      designed to blow you down, whether it's a  
14      pressurized water reactor or whether it's a boiling  
15      water reactor. I call it a large LOCA and  
16      everybody thinks of a pipe break. I think of de-  
17      pressurization valves. They're designed to get you  
18      down to low pressure really fast, and, therefore,  
19      the frequency of what you're now characterizing as  
20      the predominant thermal transient, that being a  
21      large primary blow-down, might be different for new  
22      plants, despite their materials differences, than  
23      the older designs. And that's strictly  
24      operational, you know, the way they're designed, at  
25      least in licensing space.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BALLINGER: And in a load  
2 following plant you get more fatigue cycles. I  
3 don't know what the accumulated dose would be. It  
4 would be lower on average, I suppose; but they'd be  
5 operating longer anyway.

6 MEMBER POWERS: Well, everything is  
7 cast in effective full-power year, so you take care  
8 of the dose issue. You do not take care of the  
9 more frequent transient issue.

10 MEMBER RICCARDELLA: Heat cycles.

11 CHAIRMAN BALLINGER: And that's  
12 something that's embedded in this rule, and I don't  
13 know how you handle that.

14 MEMBER RICCARDELLA: But you still are  
15 required to do an NDE every ten years, and so,  
16 presumably, if these cracks are growing, you're  
17 going to see them in those periodic inspections.

18 CHAIRMAN BALLINGER: The ten-year  
19 inspection would characterize the flaw distribution  
20 anyway.

21 MEMBER POWERS: Yes, and the trouble is  
22 you still have this component of the flaw  
23 distribution that counts for your ignorance and  
24 blindness.

25 CHAIRMAN BALLINGER: Yes, but they have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to be pretty big before they're problematic, like  
2 bigger than we've ever seen.

3 MEMBER RICCARDELLA: Yes, that kind of  
4 bigger.

5 CHAIRMAN BALLINGER: But, again, he's  
6 going to get to the requirement you have to  
7 validate your flaw distribution against your  
8 inspection results.

9 MR. KIRK: Right. And in any event, I  
10 mean, I think -- and I was going to apologize for  
11 not having all the answers, but these are hard  
12 questions. I mean, I think these hard questions  
13 point out why we included this provision in the  
14 rule that, if somebody wants to use this rule to  
15 apply to a newer plant, it's up to them to answer  
16 all these difficult questions.

17 MEMBER STETKAR: But do we know that 61  
18 remains assumedly conservative?

19 MR. KIRK: What I can tell you, which  
20 is absolutely correct, is that the 50.61  
21 embrittlement limits are more restrictive, more  
22 conservative, than the 50.61a limits. Whether  
23 that's -- what I can also tell you, which is  
24 factually correct, is that a detailed analysis of  
25 how much that greater conservatism of embrittlement

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 would make up for possible increases in load, the  
2 staff hasn't done that analysis and I don't want to  
3 represent --

4 MEMBER POWERS: I mean, that's the  
5 inherent difficulty with 61 is that it's difficult  
6 to go in and say if I term the assumptions out how  
7 does the outcome change, and that was one of the  
8 objectives in "a" is to -- I mean, you never get  
9 rid of that problem but to reduce that problem  
10 down.

11 MEMBER RICCARDELLA: Presumably, the  
12 licensees, like for the AP1000, have done an  
13 evaluation on embrittlement before my time, so I  
14 haven't looked at them. But I assume that the  
15 staff has reviewed their analyses of reactor  
16 pressure vessel embrittlement, right?

17 MR. KIRK: I'm sorry. Where did you --

18 MEMBER RICCARDELLA: Well, an AP1000.

19 MR. KIRK: Oh, yes.

20 MEMBER RICCARDELLA: A new licensee  
21 come in and --

22 MEMBER POWERS: And I would not presume  
23 that things like using it as a load following plant  
24 had been examined at all.

25 CHAIRMAN BALLINGER: I think I remember

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Gary saying, when I asked him last time how many  
2 plants would be forced into 61a for 60 years, and I  
3 think the number -- do I remember the number three?

4 MR. KIRK: Well, we'll get to that, but  
5 I'm going to have to object to your use of the word  
6 "force" because nobody is forced to use 50.61a.

7 MEMBER RICCARDELLA: Which effectively  
8 means shut it down.

9 CHAIRMAN BALLINGER: So then the  
10 question is what about 80 years?

11 MR. KIRK: Well, that's coming up, if I  
12 can get away from the load following plant  
13 question.

14 MR. WIDMAYER: Will be at 80 years.  
15 Never mind.

16 CHAIRMAN BALLINGER: Remember, just  
17 it's made good.

18 MR. KIRK: From the beginning, Dr.  
19 Powers is always asking questions that I can't  
20 answer, and this is the one for this briefing.  
21 Thank you.

22 MEMBER POWERS: You have no idea how  
23 much work it takes me to plan these questions.

24 MR. KIRK: No, that's good. I look  
25 forward to it. Okay. So I'm going to move on and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 try to get out of this.

2 CHAIRMAN BALLINGER: He's going to try  
3 to get out of here.

4 MEMBER STETKAR: They're still talking.  
5 Yes, that's okay.

6 MEMBER RICCARDELLA: I said the bigger  
7 question about load follow would be when existing  
8 plants decide to go to load follow because they're  
9 the ones that are going to be, you know, some of  
10 them might be pretty far out on the embrittlement  
11 curve. But, again, I think the ISI is what covers  
12 that.

13 MEMBER POWERS: I think it's cumulative  
14 you use each factor and certainly get them in  
15 trouble on load following.

16 MR. KIRK: Okay. We're going to try to  
17 talk about the non-controversial subject of  
18 surveillance data. So the goal of the statistical  
19 checks that are required by the alternate rule and  
20 are described by the reg guide draft guide is to  
21 ensure that the surveillance data for the  
22 particular plant being assessed is either well or  
23 conservatively represented by the embrittlement  
24 trend equation that was both used as a module in  
25 the probabilistic fracture mechanics calculations

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that provided the basis for the reference  
2 temperature screening criteria and also that's  
3 given in the rule.

4 So just schematically, the statistical  
5 tests are looking for three things. They're  
6 looking for how well does the embrittlement trend  
7 code represent the mean of the data, the slope or  
8 better to say the evolution of embrittlement with,  
9 I'm sorry, the evolution of transition temperature  
10 shift with embrittlement, and it's also looking for  
11 outliers in the data set.

12 Plants are required to perform these  
13 checks if they have three or more transition  
14 temperature shift values, which pretty much boils  
15 down to three or more capsules. They are required  
16 to consider all belt line plates, welds, and  
17 forgings for which data is available, not just for  
18 the so-called limiting welds. And they're also  
19 required to consider data from sister plants if  
20 it's available. And if you're not into the  
21 material geek lexicon, sister plant means that,  
22 say, Member Riccardella owns a plant that happens  
23 to have the same weld wire as my plant, so the data  
24 that he gets influences my plant and vice versa.

25 Being regulators, we've construed these

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 statistical tests only flagged underestimates. If  
2 the generic equations overestimate things, well,  
3 that's okay with us because an overestimate of  
4 transition temperature shift will be conservative.  
5 And as I've said, we're essentially doing three  
6 consistency checks to see that the plant-specific  
7 data here represented schematically by the green  
8 dots is well represented by the embrittlement trend  
9 curve represented by the red curve.

10 If the plant-specific data fail the  
11 test, well, then what next? Well, the general  
12 answer is the licensee, the general answer is the  
13 licensee needs to make a case to the director of  
14 NRR as to what that means and what they need to do  
15 about it. There were two cases that we saw to be  
16 simple enough that we could provide guidance, sort  
17 of a recipe if you will, in the regulatory guide.  
18 One is in the case of a mean test failure where the  
19 data are systematically above the embrittlement  
20 trend curve, one method that's acceptable to the  
21 staff is to simply add a factor on to the predicted  
22 curve to better represent your data. And the  
23 second case which we sometimes see -- excuse me --  
24 is, oftentimes with the old surveillance capsule  
25 withdrawal schedule, you'll withdraw a capsule

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 after the first or second operating cycle, so it's  
2 got very little dose on it. And in those cases,  
3 oftentimes you'll essentially be sampling the  
4 inherent material variability and you can see  
5 things like uncharacteristically higher low shifts  
6 or the often amazing case of increasing your upper  
7 shelf energy, not that that's considered here.

8 In any event, the guidance indicates  
9 that, if you happen to have an outlier at a very  
10 low fluence, less than 10 percent of that of your  
11 evaluation fluence, you could eliminate that data  
12 point from consideration.

13 If you don't happen to fall in these  
14 two categories, you're left doing your own  
15 engineering evaluation and trying to convince the  
16 NRR staff and director of NRR that you've done a  
17 good job.

18 The next regulatory guidance gets to  
19 the whole -- oh, sorry.

20 MEMBER RICCARDELLA: Are there any  
21 plants that are going to fall in this less than two  
22 capsules?

23 MR. KIRK: Yes, there are. I mean --

24 MEMBER RICCARDELLA: Eventually,  
25 they're going to get to three capsules, right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MR. KIRK:    Yes, yes.    I mean, the --  
2                   yes, the requirements, the ASTME-185 requirements  
3                   for -- I hesitate to say this a little bit because  
4                   if you go back far enough in ASTME-185, there  
5                   wasn't a specific number of capsules required.  
6                   That was back in the 1960s, and I'm not sure that  
7                   any plants that were originally licensed in the  
8                   1960s are still operating.

9                   If they were licensed to a version of  
10                  E-185 from the mid-70s and beyond, they would be  
11                  required to have at least three capsules, and that  
12                  would be for a low-shift material, if not more.  So  
13                  --

14                 MEMBER RICCARDELLA:    If you read the  
15                 rule, it almost seems a little backwards that,  
16                 well, if you don't have the data, if you don't have  
17                 the data, then you don't need to evaluate whether  
18                 the generic trend is applicable or not.  I mean,  
19                 that's kind of what you're saying.

20                 MR. KIRK:    Yes, that is what the rule  
21                 says.

22                 MEMBER RICCARDELLA:    All right.  But  
23                 I'd assume anybody that's out there and approaching  
24                 --

25                 MR. KIRK:    I'm not -- all I can say is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I'm not personally aware of any plant -- well,  
2 there's only one plant that's used this, and  
3 certainly that wasn't the case -- of any plant  
4 that's used this or that is considering using it  
5 that would fall into the category of not having at  
6 least three capsules pulled by the time they're  
7 considering using it.

8 MEMBER RICCARDELLA: That's what I  
9 would assume.

10 MR. KIRK: It was really a condition  
11 put in. And you're right, it doesn't fully make  
12 sense, but it was just a condition put in to make  
13 sure that everything was covered.

14 Okay. Getting to the regulatory  
15 guidance on in-service inspection, the reason for  
16 the requirement is quite simply stated. As I said,  
17 you know, you go back to the sort of basic fracture  
18 mechanics equation that driving force equals stress  
19 times square root of pi times crack size. So,  
20 obviously, the crack sizes that we have used in the  
21 analysis to set the screening limits are really  
22 important to what those screen limits wound up  
23 being. So we wanted to include a check to make  
24 sure that the flaws or the indications that are  
25 found in the plant are well represented by that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       flaw population that was assumed in making those  
2       limits. And that's the intent of what's going on  
3       here.

4               So the examination requirements. We  
5       require a qualified examination be performed in  
6       accordance with ASME Code, Section XI, Mandatory  
7       Appendix VIII. And we also require, and this goes  
8       beyond as required by the code, a requirement  
9       that's, I'll say, unique to this rule is a  
10      verification that any axial flaws found at greater  
11      than 0.075 inch through-wall extent at the clad  
12      interface don't open to the inside RPV service. So  
13      what we want to do, the intent of this is the  
14      recognition that a surface-breaking flaw to the ID  
15      would be significant, so we want the licensees to  
16      affirm that they don't exist.

17             An optional thing that licensees could  
18      pursue if they want to is they can account for NDE  
19      uncertainty. So if you, say if you went through  
20      and tried to meet the flaw tables in the rule using  
21      your straight-out NDE results from a Section XI,  
22      Appendix VIII exam and you didn't meet the  
23      requirements, if you go through and account for NDE  
24      uncertainty, it may be possible that you then  
25      satisfy the tables because the at least now current

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 NDE techniques tend to oversize smaller flaws,  
2 which tends to characterize them more  
3 conservatively than they need to be. All I can say  
4 is in the one application that's gone through, that  
5 being the Palisades application, that optional path  
6 did not need to be followed.

7 MEMBER SKILLMAN: Mark, before you  
8 change that slide, what change, if any, to the NDE  
9 equipment has been obligated by an applicant that  
10 would want to use 50.61a?

11 MR. KIRK: Well, there's no change here  
12 because there is, as Pete's pointed out already,  
13 they're already doing the ASME exam. I could just  
14 speak to the one that's done it because I was there  
15 watching the exam. In the case of Palisades, they  
16 put on their inspection sled also transducers to do  
17 any current at the same time as they were doing the  
18 regular Section XI, Appendix VIII exam because they  
19 knew going in that they were doing, the one point  
20 of doing this inspection was to provide input to  
21 50.61a. So they knew they would need to verify --  
22 what the rule says is that they need to verify that  
23 axial flaws that I'll say are close to the  
24 cladding, the rule doesn't use that language, but  
25 are close to the cladding or not surface connected,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the NDE inspector I talked to said, yes, it's just  
2 easier for us, the sled is in the vessel, I have to  
3 dose people up to go in and change this out, so  
4 we've just put eddy current probes on the sled, as  
5 well, and so we're going to eddy current the whole  
6 inside. Every indication they found, because, of  
7 course, they do the analysis offline later,  
8 basically every indication they found they also  
9 eddy-currented, if that's the right way to say it,  
10 a patch on the ID in the vicinity of that so that  
11 they would have the data later that they needed.

12 That's the only plant that's done it.  
13 So that's what they did.

14 CHAIRMAN BALLINGER: So that -- I'm  
15 trying to remember now. Did that help get rid of  
16 these ghost kind of indications that looked like  
17 flaws that weren't? If I recall. Maybe I'm just  
18 not remembering correctly.

19 MR. KIRK: I don't, I couldn't comment  
20 on that. I don't know.

21 MEMBER RICCARDELLA: I think the idea  
22 is the flaws are much worse if they penetrate for  
23 this analysis than if they penetrate the cladding,  
24 and the UT doesn't really inspect the cladding.  
25 They inspect the base metal, so, this way, they can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 say, well, if I had an indication, I also inspected  
2 the ID surface of the cladding and I'm confident  
3 that there's no surface breaking flaw there.

4 CHAIRMAN BALLINGER: I thought there  
5 were some plants that had indications that turned  
6 out not to be indications.

7 MR. KIRK: Oh, I'm sure there are.

8 CHAIRMAN BALLINGER: But it's a problem  
9 here because of the flaw size distribution  
10 requirement.

11 MR. KIRK: Okay. I think this gets  
12 into a little more detail. We're looking for flaws  
13 or -- I'm sorry I'm not a good NDE guy.  
14 Indications. We're looking for indications in a  
15 number of categories, and I'll work up from the  
16 bottom from the least risk significant to the most.  
17 Embedded indications beyond 3/8t from the ID,  
18 embedded between one inch and 3/8t from the ID,  
19 embedded within one inch of the inner-diameter and  
20 surface connected. And the reason why the risk  
21 significance goes as indicated by the arrow is  
22 simply that this is a thermally-driven event. So  
23 the tensile stresses are nearest the ID, and so you  
24 want to be looking for those because they're the  
25 ones that are driving the risk.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           In terms of the guidance in the  
2 regulatory guide and the requirements of the rule  
3 for how flaws in these different bins are assessed  
4 -- I'm back to flaws again. Sorry. For surface,  
5 if you found a surface-connected flaw, a flaw  
6 that's surface connected to the ID, you would have  
7 to do a plant flaw-specific assessment of the  
8 through-wall cracking frequency because that's  
9 beyond the scope of what was systematically  
10 considered in the tech basis calculations.

11           If they're embedded within an inch of  
12 the inner diameter, that's where you use the flaw  
13 tables. If they're between an inch and 3/8t,  
14 that's where you use ASME Section XII code, and  
15 beyond 3/8t, again, you're deferring to the code  
16 requirements.

17           So the PTS-specific requirements that  
18 go beyond the code really come from in these first  
19 two categories of the surface-connected flaw and  
20 embedded flaws within one inch of the inner  
21 diameter of the vessel. All the rest is the same  
22 as for any vessel complying with ASME Section XI.

23           This is probably more detailed than we  
24 need here. We recognize that sometimes the  
25 language that gets into the Code of Federal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Regulations is a little bit difficult to follow for  
2 engineers. It's probably very easy for lawyers.  
3 So Gary and I turned that language into a flow  
4 chart with references to the different parts, the  
5 different invoking languages of the code.

6 But this is essentially walking you  
7 through, and this is part of the reg guide now or  
8 will be part of the reg guide. You do your ASME  
9 Section XI inspection. You're asked do you have  
10 surface-connected flaws. You go through the flaw  
11 table. You account for NDE uncertainty, and you  
12 eventually come to either the conclusion that you  
13 need to do a plant-specific assessment, that you  
14 can't use directly the provisions of the alternate  
15 rule or the alternate rule is applicable for your  
16 use. And the reg guide steps you through it.

17 Again, I should just emphasize there's  
18 nothing on this flow chart that's in any way  
19 different from what's in the rule. The flow chart  
20 is in the reg guide, and it's just an attempt to  
21 explain more clearly to engineers what the  
22 provisions of the rule are.

23 MEMBER SKILLMAN: Mark, if the  
24 inspection finds an indication and further NDE  
25 demonstrate that there really is a connected crack

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of significance, does that automatically trigger a  
2 repair?

3 MR. KIRK: No. Well, I have to defer  
4 to people that know about the code. I don't think  
5 size of indications that we're talking about here  
6 you would be forced into a repair by the code, and  
7 certainly the alternate PTS rule doesn't force you  
8 into a repair. The alternate PTS rule would force  
9 you into a plant-specific through-wall cracking  
10 frequency evaluation.

11 MEMBER SKILLMAN: Would that enhance  
12 the next inspection interval into a five year  
13 instead of a ten?

14 MEMBER RICCARDELLA: Yes, what happens  
15 is, in the code parlance, these are the standards  
16 for evaluation, which are just a set of tables you  
17 go and look at. If you exceed those tables, you  
18 have the option to repair or do a detailed fracture  
19 mechanics evaluation. And if you do do the  
20 detailed fracture mechanics evaluation, then you do  
21 get kicked into more frequent exams.

22 MEMBER SKILLMAN: Thank you.

23 MR. KIRK: Okay. And also there's a  
24 part of the -- excuse me -- there's a part of the  
25 alternate rule that talks about alternate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 embrittlement screening criteria, meaning alternate  
2 to the reference temperature tables in the  
3 alternate rule. Too many alternates. Sorry.

4 So why are they needed? Paragraph  
5 (c)(3) of 50.61a allows for a plant-specific  
6 analysis just by operation if the RT max values  
7 exceed the PTS screening criteria. We've provided  
8 here one method, there are certainly other ways to  
9 do this, that a plant could demonstrate that, and  
10 that's simply to say that the reference temperature  
11 screening criteria that are in the table are based  
12 on bounding curve fits to the PFM results, which  
13 you saw earlier.

14 And what you get, as I indicated  
15 before, the screening limits are determined by  
16 saying -- and the bounds aren't shown here. That's  
17 a bad slight on my part. But if you add up the  
18 three bounding curves, they should be limited to 10  
19 to the minus 6. What that gets you is this three-  
20 dimensional surface that's almost a box but not  
21 quite. It's a box with rounded edges.

22 In order to easily put that into a  
23 table that could be put in a federal regulation, we  
24 had to simplify the box somewhat, which meant that  
25 we had to say that the reference temperature max

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 for the circ weld, because we knew that circ welds  
2 would hardly ever be limiting, wouldn't go above a  
3 certain value. So we essentially set the screening  
4 criteria for the circ weld to be 10 to the minus 8  
5 just to make the plate and axial weld screening  
6 easier in a simple table look-up format. We felt  
7 that was a reasonable thing to do simply because we  
8 didn't know at the time of any plants that were  
9 circ weld limited or would be circ weld limited in  
10 the foreseeable future. However, we wanted to  
11 provide this alternate means, should a circ weld  
12 plant experience high embrittlement, that they  
13 could be then held to a 10 to the minus 6 screening  
14 criteria, rather than a 10 to the minus 8, which is  
15 inherent to the tables. That's really all this is  
16 doing. Going through this set of equations is the  
17 equivalent to the technical basis information on  
18 which the reference temperature values in the table  
19 in the alternate rule were based.

20 Now we get to the question I know Ron  
21 has been wanting to ask, which is potential future  
22 use of 50.61a, and I think I should emphasize here  
23 "potential" because foretelling the future is not  
24 very easy and if I could do that I would have hit  
25 the lotto a long time ago.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER POWERS:       A famous quote,  
2                   "Prognostication is difficult, especially about the  
3                   future."

4                   MR. KIRK:    Yes, it is.

5                   CHAIRMAN BALLINGER:   That's got to be  
6                   Yogi Berra.

7                   MEMBER POWERS:    I think it was Mark  
8                   Twain.

9                   MR. KIRK:    I think I should probably  
10                  quote Yogi Berra in preference to more my style.  
11                  Anyway, this is just a reminder of what we told you  
12                  in October 2014, in case you forgot.   These were  
13                  the plants that were then on the list.   That's  
14                  changed somewhat, as I'll reflect here, and we'll  
15                  just go down it.

16                  And now responding to the question that  
17                  Ron had asked us before the meeting, I talked about  
18                  potentials 50.61a use both during license renewal,  
19                  which is NRC code for within 60 years, or during  
20                  subsequent license renewal, meaning 60 to 80 years.

21                  So Beaver Valley Unit 1, the last time  
22                  we talked, the plate in Beaver Valley Unit 1 had  
23                  been projected to exceed the 50.61 screening  
24                  criteria before the end of their license renewal  
25                  period; and, therefore, they had made an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 application to use 50.61a in 2013. However, after  
2 they made that application and while the staff was  
3 still conducting its review, they found data on  
4 their limiting materials that they weren't aware  
5 that they had, and that allowed them to both  
6 recalculate their embrittlement trends -- they got  
7 a new chemistry factor, essentially, using Reg  
8 Guide 199 -- and also get a better estimate of  
9 their underrated RTNDT. Based on those two  
10 improvements to their data, they found out that  
11 they were no longer projecting that they would  
12 exceed the 50.61 screening criteria and so withdrew  
13 the application.

14 So based on a conventional 50.61  
15 analysis, Beaver Valley is now showing that it's  
16 not projected to exceed those screening limits  
17 within license renewal, so use of 50.61a during  
18 license renewal is unlikely. It's possible during  
19 subsequent license renewal, but I think the thing  
20 I'm going to say on the next slide is, right now,  
21 the staff is not aware of any plant that has short-  
22 term plans to use 50.61a. These are just ones that  
23 could be coming up.

24 Diablo Canyon Unit 1, axial weld is  
25 projected to exceed the 50.61 screening criteria

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 before the end of license renewal. And so, you  
2 know, definitely possible that they could use it,  
3 but there are other things they could do we'll talk  
4 about on the next slide.

5 Fort Calhoun. So I'm focusing here on  
6 plants that are known to be high embrittlement.  
7 Axial weld is projected to have an RTPTS of 268 at  
8 end of license renewal, so they'll remain compliant  
9 with 50.61 based on current projections by two  
10 degrees. Two degrees is important. So they're not  
11 going to use it during license renewal. They could  
12 possibly use it during subsequent license renewal.

13 Palisades, we already know the answer.  
14 They use it during license renewal. I'm not aware  
15 that Palisades is pursuing subsequent license  
16 renewal, but if they did they might use it again.

17 Point Beach Unit 2 and Three Mile  
18 Island I'd like to talk about together. They're  
19 both plants that are known to have reference  
20 temperatures approaching the RTPTS screening limits  
21 of 50.61. However, they're both plants that are  
22 covered by the Babcock and Wilcox 2308 approach,  
23 which essentially uses master curve data, true  
24 fracture toughness data to reset the initial RTNDT.  
25 That's an approach that's been pursued for pretty

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 much all Babcock and Wilcox fabricated plants that  
2 had lineated welds. It's used routinely, and  
3 that's why those two high-embrittlement plants --  
4 by high embrittlement, I mean approaching the 50.61  
5 screening criteria -- have not and probably will  
6 not use 10 CFR 50.61a because they've got another  
7 means that worked well for them.

8 Finally on the list, Salem Unit 1. Its  
9 axial weld is projected to have an RTPTS of 267,  
10 three degrees less, at the end of license renewal.  
11 So they would not be, see no reason why they would  
12 use 50.61a during license renewal, but they could  
13 possibly use it during subsequent license renewal.

14 MEMBER RICCARDELLA: Did you skip over  
15 Indian Point in Unit 3?

16 MR. KIRK: I think I did. Yes, so we  
17 see -- sorry about that. We see possible use by  
18 Indian Point Unit 3, before the end of license  
19 renewal, because they're projected to exceed the,  
20 the 50.61 limit before 2025. I didn't mean to skip  
21 them.

22 That all said, I mean, the two dates on  
23 here are 2025 and 2033, so a decade to a  
24 decade-and-a-half from now, which means it might be  
25 only my colleague, Matt Gordon, who's left here to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 talk about it. I'll be retired.

2 So no licensees have indicated any  
3 short-term plans, by short-term, I mean in the, in  
4 the next three to five years, to use 50.61a. Just  
5 a disclaimer, the list on the previous page may not  
6 include all plans that are considering the use,  
7 it's a due diligence effort.

8 And also should point out, the plans  
9 may elect to use 50.61a, not for compliance  
10 reasons, but for economic reasons. Say, somebody  
11 was considering buying a new steam generator and  
12 wanted to make, wanted to get as many things off  
13 the regulatory problem list, as they could, they  
14 might decide to use 50.61a and we would have no way  
15 of knowing, before they, they brought that case to  
16 us, so clearly that's not included.

17 And also, just a reminder, and this  
18 right-most column is nothing other than a statement  
19 of the facts of our current regulatory structure is  
20 that, plants have options, other than 50.61a and  
21 other than annealing, to address and manage  
22 embrittlement.

23 They have various physical options,  
24 fuel management, changing operational  
25 characteristics and annealing. They have data

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 options. They can look more to plant-specific  
2 surveillance data, they can get Master Curve data,  
3 using the BAW-2308 approach.

4 And, I should also point out that there  
5 is now ongoing, within the industry, renewed  
6 interest in pursuing Master Curve and direct  
7 fracture toughness measurements being pursued by  
8 the PWR Owners Group and also going through ASME  
9 Code and the guise of a revised version of ASME  
10 Code Case N-830.

11 So Master Curve use, in general, beyond  
12 the BNW plants, has not been, I'll say, pursued in  
13 earnest for about the last decade, but within the  
14 last year to two years there's been renewed  
15 interest in that, so a number of plants are looking  
16 at that, again, no plant-specific applications, but  
17 general industry study programs and work within the  
18 Code to enable that type of analysis.

19 And, of course, there are always  
20 analytical options, meaning plant-specific PRA  
21 and/or PFM, like we talked about before, to  
22 demonstrate compliance with, to demonstrate vessel  
23 safety.

24 MEMBER POWERS: I -- my presumption is  
25 that you are relatively confident in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       probabilistic fracture mechanics and you have  
2       indicated a confidence in the knowledge and  
3       material properties, when a licensee comes to you  
4       with a new approach, at what point, in what area  
5       would you require experimental validation of his  
6       approach?

7               MR. KIRK: I thought I'd gotten rid of  
8       that question. Experiment of validation of any  
9       aspect, or --

10              MEMBER POWERS: Some aspect. I mean, I  
11       get the feeling that you would not require it for  
12       the probabilistic fracture mechanics, which in my  
13       mind, is little more than witchcraft. Oh that was  
14       just for you. And you've indicated a confidence in  
15       understanding material properties, so I'm sitting  
16       here saying, what, what would provoke into saying,  
17       gee, I really need to see some experiments here,  
18       to, to give me confidence in this, this alternate  
19       approach?

20              MR. KIRK: I mean, I find it, I find it  
21       really personally hard to speculate. I mean,  
22       getting into any of these reviews, and, you know, I  
23       should point out, you know, I'm not, I don't really  
24       work for the regulatory part of the agency, I --

25              MEMBER POWERS: And that --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KIRK: -- I work for the research  
2 part.

3 MEMBER POWERS: We're just holding you  
4 accountable for --

5 MR. KIRK: Thank you.

6 MEMBER POWERS: -- speaking for that  
7 person.

8 MR. KIRK: I appreciate it. And the  
9 guy that's left up here. I think it really depends  
10 on, and I'm -- you know, this is an evasive answer  
11 and I'll just label it, as such. It really depends  
12 upon the specifics of the case at hand and how  
13 strong, strongly the case has been supported.

14 MEMBER POWERS: Well, where would you,  
15 where would you look most diligently?

16 MR. KIRK: Well, again, the loads  
17 full-size embrittlement. And, and, and, and, I  
18 think, also, a lot of us depends on how road  
19 full-size embrittlement and that's axiomatic, but  
20 it depends on how close somebody is to some  
21 perceived regulatory limit.

22 MEMBER POWERS: Well, I mean, we  
23 presume that he is --

24 MR. KIRK: Okay, I mean, --

25 MEMBER POWERS: -- comes to you with a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 new technique, because he's getting very, very  
2 close, if not exceeding, --

3 MR. KIRK: Yes. Well, let's get back  
4 to the, if, if you had a plant, if you had a new  
5 plant that we hadn't analyzed yet, and there was,  
6 you know, concern from staff experienced, you know,  
7 in the operational side that the plant operational  
8 characteristics wouldn't lead to the same challenge  
9 events, as we had analyzed here, I think that would  
10 be a, you know, a ripe area for, you know, for  
11 study.

12 And, and, you know, I'll throw a stone  
13 at materials, while I'm at it. If there was  
14 something unusual in the surveillance data, if you  
15 had -- okay, I'll give you a good example that,  
16 fortunately, is not in this country.

17 The Genkai Power Plant in, in Japan,  
18 pulled its four surveillance capsule, some years  
19 ago, and while the previous three surveillance  
20 capsules had been, pretty much, following the  
21 generic trend, it had an out wire, not at the low  
22 fluency end, but at the high fluency end, and in  
23 the case of Japan, that provoked an extremely  
24 detailed study getting into more measurements, more  
25 mechanical property measurements, diagnosis of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 mechanical property measurements, more  
2 micro-structural property measurements, to try to  
3 understand the basis for that one out wire.

4 So I think, you know, you got to, you  
5 got to look for something, I'll say, strange,  
6 unusual, outside of your experience that doesn't  
7 seem quite right, before, as a regulator, or as an  
8 advisor to the regulator, you say, and maybe you  
9 should bring me something more. I'm struggling,  
10 because I'm not good with hypotheticals, so I have  
11 to, I have to think of things that have actually  
12 happened. So I think those, you know, those would  
13 be good categories for, for more, you know, more  
14 detailed inquiry.

15 MEMBER POWERS: Oh I understand that  
16 what I'm thinking about is the codicil in the  
17 guidance that says these are the things that go  
18 beyond the scope of our experience, and when you  
19 encounter them, please don't, please come talk to  
20 us, before you rely on this guidance.

21 MR. KIRK: Yes. Right, but we haven't,  
22 and I think that's, that's a prudent thing to say,  
23 we haven't then prejudged exactly where that  
24 conversation will go.

25 MEMBER POWERS: Yes, and --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KIRK: Yes.

2 MEMBER POWERS: -- but, while I'm  
3 interested in where this guidance -- you would not  
4 be confident if somebody was using this guidance.

5 MR. KIRK: No. I mean, I think that's,  
6 and again, sort of statistics 101 when you get  
7 outside of your experience, you start looking for  
8 more evidence --

9 MEMBER POWERS: The --

10 MR. KIRK: -- to backup.

11 MEMBER POWERS: -- the trouble is that  
12 this guidance will be used by people who use it, as  
13 a prescription, and so it's, it's incumbent upon  
14 you with a great deal of experience to communicate  
15 them, not only how to use it, but when not to use  
16 it.

17 MR. KIRK: Yes. And are you  
18 suggesting, or asking, if we've done that  
19 well-enough to --

20 MEMBER POWERS: I am.

21 MR. KIRK: -- to say when it's not a  
22 prescription?

23 MEMBER POWERS: I am.

24 MR. KIRK: I mean, --

25 MEMBER POWERS: I'm asking you to think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 about it for a little bit.

2 MR. KIRK: Okay. We should think about  
3 that.

4 MEMBER POWERS: I think that's, I think  
5 that's going to be increasingly important, as you  
6 think about migrating to New Hampshire.

7 CHAIRMAN BALLINGER: You might force  
8 him to migrate to New Hampshire early.

9 MR. KIRK: The --

10 MEMBER POWERS: I've tried that for  
11 years and failed miserably, so --

12 (Simultaneous speaking.)

13 MR. KIRK: The part of New Hampshire  
14 I'm considering migrating to have electric rates  
15 that almost doubled when Vermont and Yankee closed.

16 MEMBER POWERS: Yes.

17 MR. KIRK: So --

18 MEMBER POWERS: Very foolish on your  
19 part.

20 MR. KIRK: Now I'm getting my exercise  
21 cutting wood.

22 MEMBER POWERS: Helping the  
23 environment, no doubt.

24 MR. KIRK: No doubt.

25 MEMBER SKILLMAN: Mark, let me ask two

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 questions. They're similar to what Dana just  
2 asked, but in my own work for preparation for  
3 today's meeting, I've written them down, so I think  
4 this is the best time to ask them.

5 How do you handle the variability in  
6 chemistry? And here's why I'm asking the question.  
7 Like Dana said, this is a very prescriptive  
8 approach. Equations five, six, and seven, guide a  
9 user to take action to develop a delta T --

10 MR. KIRK: Right.

11 MEMBER SKILLMAN: -- integer. And the  
12 ingredients in those calculations include copper  
13 content, effective copper content, nickel content,  
14 manganese content and phosphorus content, in the,  
15 in the other comments from the public and others,  
16 it says, these are the soft metals that's giving us  
17 a problem here. How do you handle, or how do you  
18 anticipate a licensee is going to handle  
19 uncertainties in those --

20 MR. KIRK: Yes.

21 MEMBER SKILLMAN: -- ingredient  
22 concentrations in their plates and their foragings?

23 MR. KIRK: Well in that case, we have  
24 attempted, and I think done as good a job, as  
25 possible, based on the information we've got, to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 handle it for them and that the, the uncertainties  
2 in those, in the chemistry inputs were sampled, as  
3 part of the favor analyses.

4 Because, it's very, it would be very  
5 unusual for a licensee to say, have enough  
6 measurements of any of these copper, nickel, what  
7 have you, to form a statistical distribution.

8 So in the favor analyses, we took the,  
9 and that's actually documented in the appendix of  
10 NUREG-1807, I think, we went out and looked for  
11 data that was available where people had done  
12 repeated measurements, developed statistical  
13 distributions to represent them, and that was  
14 sampled within the PFM analyses that then gave rise  
15 to the reference temperature limits.

16 So I would say that that part of the  
17 uncertainty is explicitly covered by the reference  
18 temperature limits, themselves, and for that  
19 reason, we ask the licensees only to come in with  
20 so called best estimate values of each of those  
21 variables, which would be the same type of input  
22 that we look for, for 50.61 applications, for PT  
23 limits analysis and, and so on.

24 MEMBER SKILLMAN: Okay. Let me ask  
25 another one, similar-type question. And I draw

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 this from almost 45 years ago, the, those of us who  
2 were doing the systems in the ACCS analysis in  
3 Babcock were right next to the reactor vessel and  
4 the internals people, so we heard them struggling  
5 with where to place the surveillance vestment  
6 holder, tubes and the geometry and the concerns  
7 about the fluency, too, the SSHTs and to the  
8 specimens, surveillance specimen holder tubes and  
9 the specimens.

10 And this has to do with the uncertainty  
11 of the fluency on the specimen. How do you address  
12 in this, in this set of equations, the variability,  
13 or the uncertainty in the absorbed dose to the  
14 specimen, itself?

15 MR. KIRK: Again, that's, that's the  
16 same answer. That's an uncertainty that we sampled  
17 within the original calculations of -- well, the  
18 thought, at the time, much like the chemistry, is  
19 it wasn't realistic to ask somebody to do that on a  
20 plant-specific basis, so we included that  
21 uncertainty in the basis calculation, so it's  
22 reflected in the referenced temperature limits.  
23 And again, we just look for the input of the best  
24 estimate fluency for the location on the ID of the,  
25 of the various vessel materials.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER SKILLMAN:       Okay.       Final  
2 question.   In Table 1, which is on Page 6 of the  
3 Guide, the terms include neutron fluency and  
4 effective neutron fluency and copper content and  
5 effective copper content.   Could you explain what  
6 --

7                   MR. KIRK:   Yes.

8                   MEMBER SKILLMAN:   -- effective means,  
9 in the --

10                  MR. KIRK:   Yes, those are, and in, you  
11 know, now that I see that, I'm sorry they're there.  
12 I mean, those are terms that are used in the, in  
13 the embrittlement equations that is Equations five,  
14 six, and seven, in the guide and corresponding  
15 equations in the Rule, itself.

16                  But, be that as it may, those are  
17 values that are fitting parameters, if you will, --

18                  MEMBER SKILLMAN:   I was wondering if  
19 they were, they were averages, or means, or --

20                  MR. KIRK:   No, they're --

21                  MEMBER SKILLMAN:   -- aggregated --

22                  MR. KIRK:   -- they're just --

23                  MEMBER SKILLMAN:   -- aggregated values  
24 from some other --

25                  MR. KIRK:   No they're -- well, in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 case, and maybe the easiest one to explain is --  
2 well I can explain them both. Effective copper  
3 content reflects the fact that, above a certain  
4 limit, copper is ineffective, as an embrittlement  
5 element, and so it caps the copper at a, at a  
6 copper max value, but that's taken care of in the  
7 equation.

8 The effective fluency reflects the fact  
9 that, at least, in terms of this embrittlement  
10 equation, the neutron flux has a second order  
11 effect on the degree of embrittlement, and again  
12 that's accounted for in the equation.

13 So those aren't, you know, again,  
14 looking at this again, those aren't direct inputs  
15 to the equation, they're calculated from other  
16 inputs, so I think it would have probably been  
17 clearer to, to take them out, but they're not  
18 something that's separate, you input copper,  
19 nickel, phosphorus, manganese, fluency and  
20 temperature and everything else is calculated.

21 MEMBER SKILLMAN: Okay. Mark, thank  
22 you.

23 MR. KIRK: Okay. Thank you, sir.

24 MEMBER SKILLMAN: Thanks.

25 CHAIRMAN BALLINGER: Is this a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 convenient point we're going to shift to another --

2 MR. KIRK: I think it is, yes.

3 CHAIRMAN BALLINGER: All right. I have  
4 one question before we, before we do that and it's  
5 probably a dumb one, but on Page 7 --

6 MR. KIRK: Of the Guide?

7 CHAIRMAN BALLINGER: -- of the Guide,  
8 Paragraph B-I.

9 MR. KIRK: Yes.

10 CHAIRMAN BALLINGER: Can you tell me  
11 what that means?

12 MR. KIRK: Oh no. This seems, to me,  
13 to be one of those that we might have revised,  
14 because it was unclear.

15 CHAIRMAN BALLINGER: Okay.

16 MR. KIRK: What it's trying to say, we  
17 talked about earlier, is that, you need three  
18 measurements of Delta T-33 transition temperature  
19 shift values at three different fluency values, in  
20 order to do the surveillance check. If you don't  
21 have, at least, that, you just use the equation.

22 CHAIRMAN BALLINGER: Right. I  
23 understand that part.

24 MR. KIRK: It --

25 CHAIRMAN BALLINGER: I understand what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you said and I understand what it --

2 MR. KIRK: Good.

3 CHAIRMAN BALLINGER: -- read before,  
4 but for the life of me --

5 MR. KIRK: Yes, well I, I --

6 CHAIRMAN BALLINGER: -- I don't  
7 understand what that means.

8 MR. KIRK: Well I have the original,  
9 unmarked-up version. I'll have to check. I think  
10 that was one where many people made the comment of,  
11 what are you trying to say?

12 CHAIRMAN BALLINGER: Okay.

13 MR. KIRK: So hopefully we've clarified  
14 that, but I can, I can check that.

15 CHAIRMAN BALLINGER: Okay. Does  
16 anybody around the table have any questions? But,  
17 I think, we're going to, I'm going to propose that  
18 we take a 15-minute break now.

19 MEMBER REMPE: Right now we're going to  
20 the closed session.

21 CHAIRMAN BALLINGER: Oh, we're going to  
22 a closed session, after this, right?

23 MR. WIDMAYER: Right.

24 CHAIRMAN BALLINGER: Okay, so you're  
25 right. Are there any comments from anybody in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 room? Derek, do we need to get the line open?

2 MR. WIDMAYER: There is, yes, we need  
3 to get the line open.

4 CHAIRMAN BALLINGER: Can we get the  
5 line open?

6 MR. WIDMAYER: It should be one person.

7 CHAIRMAN BALLINGER: One person. Yes,  
8 I must have read that, that little paragraph a  
9 dozen times, could not figure out --

10 MR. KIRK: Yes.

11 CHAIRMAN BALLINGER: -- what we're  
12 saying.

13 MR. WIDMAYER: Okay, it's on, it's  
14 open.

15 CHAIRMAN BALLINGER: Yes are there, I  
16 don't hear any crackling, or popping, either.

17 MR. WIDMAYER: Try.

18 CHAIRMAN BALLINGER: Try? Is there  
19 anybody out there on the line?

20 MR. LEWIS: Marvin Lewis, member of the  
21 public.

22 CHAIRMAN BALLINGER: Good afternoon,  
23 Marvin.

24 MR. LEWIS: Thank you. Look, I'm just  
25 wondering, you know, we've use justifications to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 forget about outliers that, sort of, go against the  
2 grain, of course outliers go against the grain,  
3 that's why they're outliers, right?

4 My problem is this, are you forgetting  
5 a lot of experience, not only in the U.S., but  
6 outside the United States that might show what  
7 you're, show that there's a problem there that  
8 you're not looking at, like, for instance, Belgian  
9 reactors that has shown a lot of micro cracks.

10 And I'm wondering, you did reference a  
11 couple of other ones, and I'm just wondering if  
12 there is a trend somewhere that you're missing on,  
13 on this toughness subject?

14 I'm, I'm not saying there is, I'm just  
15 wondering, because I, you know, you're using  
16 justification here, justification there, and I'm  
17 just wondering if there is a trend that you're just  
18 getting around with justifications? Thank you.

19 CHAIRMAN BALLINGER: Thank you. Are  
20 there any other folks out there, who would like to  
21 make a comment?

22 (No response.)

23 CHAIRMAN BALLINGER: Hearing none, can  
24 we close the line? Okay, so I think we can take  
25 now a 15-minute recess, until just before quarter

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 after.

2 (Whereupon, the meeting in the above-  
3 entitled matter was concluded at 2:57 p.m.)

4

5

6

7

# **Advisory Committee on Reactor Safeguards Materials Subcommittee Meeting**

*review of*

- Draft Reg Guide (DG-1299 / RG 1.230) ←
- Draft Tech Basis Document (NUREG-2163) ←  
[ *both concerning the Alternate PTS Rule (10 CFR 50.61a)* ]



**Mark Kirk, Senior Materials Engineer**

*Office of Nuclear Regulatory Research  
Component Integrity Branch*

Tuesday May 3, 2016  
NRC Headquarters  
Rockville, MD

# Presentation Overview

- Alternate PTS rule (10 CFR 50.61a) development & background
- PTS Rule Regulatory Guide
  - Reg guide process development summary & current status
  - Overview of tech basis & reg guide
- Possible future use of 10 CFR 50.61a & RG 1.230
- Public Comments on reg guide and tech basis
  - Summary of responses
  - Summary of changes to RG & NUREG
  - Path forward / next steps
- **NRC staff request of ACRS**
  - **Memo to NRC/RES approving RG & NUREG, or**
  - **Letter to EDO objecting to RG & NUREG**


# Presentation Overview

- Alternate PTS rule (10 CFR 50.61a) development & background
- PTS Rule Regulatory Guide
  - Reg guide process development summary & current status
  - Overview of tech basis & reg guide
- Possible future use of 10 CFR 50.61a & RG 1.230
- Public Comments on reg guide and tech basis
  - Summary of responses
  - Summary of changes to RG & NUREG
  - Path forward / next steps
- **NRC staff request of ACRS**
  - **Memo to NRC/RES approving RG & NUREG, or**
  - **Letter to EDO objecting to RG & NUREG**

# Overall Alt-PTS Timeline

## Simplified

- Development, approval, & current use spans nearly 2 decades
- Includes extensive reviews & opportunities to comment
  - ACRS
  - External review panel
  - Internal NRC
  - Public meetings
  - Public comments
- Current task: issuing regulatory guidance



# BACKGROUND

What is 10 CFR 50.61a?

Why was it developed?

(Chapter 1 of NUREG-2163)

# The Path to 10 CFR 50.61a


- **Motivations for alternate rule development**
- **Overall approach**
- **Key results**
- **The Alternate PTS Rule (10 CFR 50.61a)**

# Technical Motivations

**Developments since the 1980s suggested the overall conservatism of the rule**


## ■ PRA

- Use of latest PRA/HRA data
- More refined binning
- Operator action credited
- Acts of commission considered
- External events considered
- Medium and large-break LOCAs considered




## ■ TH

- Many more TH sequences modeled
- TH code improved



## ■ PFM

- Significant conservative bias in toughness model removed
- Spatial variation in fluence recognized
- Most flaws now embedded rather than on the surface, also smaller
- Material region dependent embrittlement props.
- Non-conservatisms in arrest and embrittlement models removed




# Regulatory Motivations

- **Produces unnecessary burden**
  - Technical improvements suggest strongly that current  $RT_{NDT}$  screening criteria of 300 °F and 270 °F are more conservative than needed to maintain safety.
- **Does not necessarily increase overall plant safety**
  - Focus on unnecessarily conservative  $RT_{NDT}$  screening criteria can divert resources from other more risk-significant matters.
- **Plant-specific analysis not a practical option**
  - Difficult to perform and review. Completeness and success criteria unclear.
- **Creates an artificial impediment to license renewal**
  - Unnecessarily conservative  $RT_{NDT}$  screening criteria alter perception of the safe operational life of a nuclear power plant.


*→ Causes work that produces no real benefit ←*

# PTS Project – Overall Approach



**#1. Commission guidance drives performance metric, and screening criteria.**




# PTS Project – Overall Approach



**#2. Staff develops model to estimate performance metric.**

# PTS Project – Overall Approach

## Probabilistic Estimation of Through-Wall Cracking Frequency





**#3. Metric estimated based on detailed analysis of 3 plants.**

# PTS Project – Overall Approach

Acceptance Criterion for TWC Frequency

Established consistent with

- 1986 Commission safety goal policy statement
- June 1990 SRM
- RG1.174



**Generalization to all U.S. PWRs**

**#4. These results + other insights motivate generalization to all plants.**

# Key Results

- **What operational transients most influence PTS risk?**
- **What material features most influence PTS risk?**
- **Are these dominant material features / transients common across the fleet?**
- **New embrittlement screening criteria based on RI calculations**

# Transient Classes Modeled


## Primary System Faults

- **Pipe breaks**
  - Large
  - Medium
  - Small
- **Stuck open valves that later re-close**
- **Feed and bleed**


## Secondary System Faults

- **Main steam line break**
- **Stuck open valves**
- **Steam generator tube rupture**
- **Pure overfeed**

# Important Transient Classes




# Important Transient Classes




# Important Transient Classes

- **Primary side faults dominate risk**
  - Due to low temperature on primary side (35°F)
- **Very severe secondary faults (MSLB) make a minor contribution**
  - Primary side temperature cannot fall below 212 °F, so material still tough even at high embrittlement
- **All other transient classes produce no significant risk**
  - Challenge is low even if transient occurs

# Important Material Features





# Important Material Features



# Important Material Features


- **Axial cracks dominate risk, circumferential cracks do not**
  - Circ cracks arrest due to vessel geometry
  - Axial cracks are much less likely to arrest
- **Thus, the properties of materials associable with axial flaws dominate**
  - Axial weld properties
  - Plate properties
- **A 3-parameter characterization of RPV embrittlement unifies results across all study plants**
  - Failure probabilities are associated with the responsible material/flaw features

# 10 CFR 50.61a RT Limits Compared to Plant RT<sub>NDT</sub> Values



# Plant Embrittlement Related to TWCF

## Fig 3.12 from NUREG-1874



# **OVERVIEW OF THE ALTERNATE PTS RULE**

(Chapter 2 of NUREG-2163)

# Conditions for Use of 10 CFR 50.61a




TABLE 1—PTS SCREENING CRITERIA

Product form and RT <sub>MAX-X</sub> Values	RT <sub>MAX-X</sub> limits [°F] for different vessel wall thicknesses <sup>6</sup> (T <sub>WALL</sub> )		
	T <sub>WALL</sub> ≤ 9.5 in.	9.5 in. < T <sub>WALL</sub> ≤ 10.5 in.	10.5 in. < T <sub>WALL</sub> ≤ 11.5 in.
Axial Weld RT <sub>MAX-AW</sub> .....	269	230	222
Plate RT <sub>MAX-PL</sub> .....	356	305	293
Forging without underclad cracks RT <sub>MAX-FO</sub> <sup>7</sup> .....	356	305	293
Axial Weld and Plate RT <sub>MAX-AW</sub> + RT <sub>MAX-PL</sub> .....	538	476	445
Circumferential Weld RT <sub>MAX-CW</sub> <sup>8</sup> .....	312	277	269
Forging with underclad cracks RT <sub>MAX-FO</sub> <sup>9</sup> ...	246	241	239

# Comparison of 10 CFR 50.61 to 10 CFR 50.61a

**Less restrictive reference temperature (embrittlement) screening criteria enable longer operations, but gating criteria must be satisfied to use the alternate rule.**

	<b>10 CFR 50.61 <i>REQUIRED</i></b>	<b>10 CFR 50.61a <i>VOLUNTARY</i></b>
<b>Reference Temperature Screening Criteria</b>	<b>More restrictive</b>	<b>Better informed, Less restrictive</b>
<b>Plant-specific surveillance data check</b>	<b>Required – 1 test</b>	<b>Required – 3 tests</b>
<b>Plant specific inspection for flaws</b>	<b>Not required</b>	<b>Required</b>

# Presentation Overview

- Alternate PTS rule (10 CFR 50.61a) development & background
- PTS Rule Regulatory Guide
  - Reg guide process development summary & current status
  - Overview of tech basis & reg guide
- Possible future use of 10 CFR 50.61a & RG 1.230
- Public Comments on reg guide and tech basis
  - Summary of responses
  - Summary of changes to RG & NUREG
  - Path forward / next steps
- **NRC staff request of ACRS**
  - **Memo to NRC/RES approving RG & NUREG, or**
  - **Letter to EDO objecting to RG & NUREG**

# DG/RG Development Timeline

DG 1.230 = DG 1299

Date	Event
September 2013	Draft Guide development begins
October 2014	1 <sup>st</sup> ACRS briefing
March 2015	DG & NUREG sent out for public comments
May 2015	Public comments received
February 2015	Staff concurrence (except for OGC final no-legal objection (NLO) finding) on responses to public comments & revisions of RG complete
May 3, 2016	Today's ACRS Briefing
Future	<ul style="list-style-type: none"><li>• Incorporate ACRS recommendations into RG &amp; NUREG</li><li>• Send to OGC for NLO</li><li>• Publish final RG &amp; NUREG on Federal Register (within ≈ 2 months)</li></ul>

# REGULATORY GUIDANCE

Criteria Relating to the Date of Construction and Design Requirements  
(Chapter 4 of NUREG-2163, Position 1 of DG-1299)

# Construction Date

- **Rule & RT screening criteria based on analysis of three currently operating PWRs**
  - Risk-dominant transients
  - Materials of construction
- **The effect of new reactor designs & new materials of construction on these screening criteria have not been assessed**
- **Therefore the applicability of the Alternate PTS Rule restricted to construction permits issued before February 2010**
- **Licensees may choose to demonstrate applicability to specific reactor designs of their interest**

# REGULATORY GUIDANCE




Criteria Relating to the Evaluation of Plant-Specific Surveillance Data  
(Chapter 5 of NUREG-2163, Position 2 of DG-1299)

## Goal

- **Goal: Ensure that surveillance data for the plant being assessed is well, or conservatively, represented by the embrittlement trend equation**
  - Used in the probabilistic fracture mechanics (PFM) calculations that provide the basis for the  $RT_{MAX-X}$  screening criteria, and
  - That is given by the Rule

## 3 Statistical Tests


- Must have 3 or more  $\Delta T_{30}$  values
- Must consider
  - All beltline plates/welds/forgings for which data is available (not just “limiting” data)
  - Data from “sister plants” if available
- Only flags under-estimates
- 3 tests determine different deviations from expected trends




## What if the data fail the test?

- Before considering adjustments, consider the accuracy & appropriateness of the input data
  - $RT_{NDT(u)}$ , # of Charpy values, composition & exposure variables, notch orientation, comparative trends analysis

### Mean Test Failure




### Low Fluence Outlier Test Failure



- Adjustment Procedures

- Mean test: Add ADJ
- Slope test: Use greater slope indicated by the surveillance data
- Outlier test: Can ignore a failure at a fluence < 10% of that for the PTS evaluation provided 3 or more data remain



# REGULATORY GUIDANCE

Inservice Inspection (ISI) Data and Nondestructive Examination (NDE)  
Requirements

(Chapter 6 of NUREG-2163, Position 3 of DG-1299)

# NDE Requirements

## Reason for Requirements

TABLE 2—ALLOWABLE NUMBER OF FLAWS IN WELDS

Through-wall extent, TWE [in.]		Maximum number of flaws per 1000-inches of weld length in the inspection volume that are greater than or equal to $TWE_{MIN}$ and less than $TWE_{MAX}$
$TWE_{MIN}$	$TWE_{MAX}$	
0 .....	0.075 .....	No Limit
0.075 .....	0.475 .....	166.70
0.125 .....	0.475 .....	90.80

TABLE 3—ALLOWABLE NUMBER OF FLAWS IN PLATES AND FORGINGS

Through-wall extent, TWE [in.]		Maximum number of flaws per 1000 square-inches of inside surface area in the inspection volume that are greater than or equal to $TWE_{MIN}$ and less than $TWE_{MAX}$ . This flaw density does not include underclad cracks in forgings.
$TWE_{MIN}$	$TWE_{MAX}$	
0 .....	0.075 .....	No Limit
0.075 .....	0.375 .....	8.05
0.125 .....	0.375 .....	3.15
0.175 .....	0.375 .....	0.85
0.225 .....	0.375 .....	0.29
0.275 .....	0.375 .....	0.08
0.325 .....	0.375 .....	0.01
0.375 .....	Infinite .....	0.00

Satisfying the tables ensures that the population of flaws in the vessel is well represented, or bounded, by the population of flaws assumed in the tech-basis calculations.

# NDE Requirements

## Examination Requirements

<b>REQUIRED</b>	<b>OPTIONAL</b>
<p><b>Qualified examination in accordance with ASME Code, Section XI, Mandatory Appendix VIII</b></p>	<p><b>NDE uncertainty</b>  (NDE techniques tend to oversize smaller flaws, thereby distributing detected flaws into larger bins where the allowed number of flaws is smaller)</p>
<p><b>Verification that axial flaws greater than 0.075" TWE at the clad/base metal interface do not open to the RPV inside surface</b></p>	

# NDE Requirements

## How Requirements are Invoked





Description of Flaws	How are they Assessed
Surface connected on ID, depth greater than 0.075-in. beyond the cladding	Flaw specific assessment of TWCF contribution
Embedded, within 1-inch of inner-diameter	<ul style="list-style-type: none"><li>Assess compliance with flaw tables</li><li>If flaw tables are exceeded assess TWCF contribution</li></ul>
Embedded, between 1-inch and 3/8t from ID	<ul style="list-style-type: none"><li>Assess to ASME Code, Section XI, Table IWB-3510-1</li><li>Assess for TWCF contribution if flaw exceeds Table IWB-3510-1</li></ul>
Embedded, beyond 3/8t from ID	No assessment required if flaw acceptance criteria of ASME Code, Section XI, Table IWB-3510-1 is satisfied.

Thermally-driven stresses produce greater risk-significance for flaws closer to the ID. Assessment requirements are more stringent for these flaws.

# NDE Requirements

## NDE Results Evaluation Process



# REGULATORY GUIDANCE


Criteria Relating to Alternate Limits on Embrittlement  
(Chapter 7 of NUREG-2163, Position 4 of DG-1299)

# Alternate Embrittlement Screening Criteria

## Why Are They Needed?

- Paragraph (c)(3) of 10 CFR 50.61a allows for plant-specific analyses to justify operation if projected  $RT_{MAX-X}$  values exceed the PTS screening criteria
- NRC staff elected to develop one method of acceptable guidance for meeting this provision
- Similar feedback was provided by stakeholders


# Alternate Screening Criteria on Embrittlement



RT screening criteria based on bounding curve fits to PFM results

# Alternate Screening Criteria on Embrittlement

- RT screening criteria table in 10 CFR 50.61a established by inverting this equation
- Simplifications needed to express equation in tabular form
- Licensees can use formula instead of table



$$TWCF_{Limit} = 10^{-6} > TWCF_{AWF} + TWCF_{PF} + TWCF_{CWF} + TWCF_{FO}$$

Axial Weld Flaws
Plate Flaws
Circ Weld Flaws
Forging Flaws

# Presentation Overview

- Alternate PTS rule (10 CFR 50.61a) development & background
- PTS Rule Regulatory Guide
  - Reg guide process development summary & current status
  - Overview of tech basis & reg guide
- Possible future use of 10 CFR 50.61a & RG 1.230
- Public Comments on reg guide and tech basis
  - Summary of responses
  - Summary of changes to RG & NUREG
  - Path forward / next steps
- **NRC staff request of ACRS**
  - **Memo to NRC/RES approving RG & NUREG, or**
  - **Letter to EDO objecting to RG & NUREG**

# Future Use Perspective

## Repeat of status from 10/2014 ACRS Brief

- **Four plants are currently projected to reach 10 CFR 50.61 screening criteria during their 60-year operating periods:**
  - **Beaver Valley 1 (2033)**
    - Submitted July 2013; under staff review
  - **Palisades (2017)**
    - Submitted August 2014; under staff review
  - **Diablo Canyon (2033)**
  - **Indian Point 3 (2025)**
- **Several plants would likely require 10 CFR 50.61a for 80 years of operation**
- **Other plants may elect to use 10 CFR 50.61a for economic reasons**

# Future Use Perspective

## Updated Status

Plant Name	Notes	10 CFR 50.61a use?	
		During LR	During SLR
Beaver Valley Unit 1	<ul style="list-style-type: none"> <li>Plate projected to exceed 50.61 screening criteria before the end of LR.</li> <li>Made 50.61a application in 2013.</li> <li>Withdrew application in 2015 based on <math>RT_{NDT}</math> recalculation and new surveillance data.</li> </ul>	Unlikely	Possible
Diablo Canyon Unit 1	<ul style="list-style-type: none"> <li>Axial weld projected to exceed 50.61 screening criteria before end of LR.</li> <li>Use of 50.61a possible by 2033 (before end of LR)</li> </ul>	Possible	Possible
Ft. Calhoun	<ul style="list-style-type: none"> <li>Axial weld projected to have <math>RT_{PTS}=268^{\circ}</math> F at end of LR.</li> </ul>	No	Possible
Indian Point Unit 3	<ul style="list-style-type: none"> <li>Plate projected to exceed 50.61 screening criteria before end of LR.</li> <li>Use of 50.61a possible by 2025 (before end of LR)</li> </ul>	Possible	Possible
Palisades	<ul style="list-style-type: none"> <li>Axial weld projected to exceed 50.61 screening criteria before end of LR. Addressed in 2015 using 10CFR50.61a for LR.</li> </ul>	Yes	Possible
Point Beach Unit 2	<ul style="list-style-type: none"> <li>Circ weld projected to exceed 50.61 screening criteria before end of LR. Addressed in 2014 using <b>BAW-2308 approach</b> through LR.</li> </ul>	No	Likely not
Salem Unit 1	<ul style="list-style-type: none"> <li>Axial weld projected to have <math>RT_{PTS} = 267^{\circ}</math> F at end of LR.</li> </ul>	No	Possible
TMI Unit 1	<ul style="list-style-type: none"> <li>Axial weld projected to have <math>RT_{PTS} = 264^{\circ}</math> F at end of LR using <b>BAW-2308 approach</b>.</li> </ul>	No	Likely not

LR = License renewal to 60 years

SLR = Subsequent license renewal to 80 years

# Future Use Perspective

## Updated Status, Cont.

- No licensees have indicated short term plans to use 50.61a
- List on previous page may not include all plants considering use of 50.61a
- Plants may elect to use 50.61a for economic reasons – NRC cannot anticipate this use
- Plants have options other than 50.61a to address & manage embrittlement:
  - **Physical options**
    - Fuel management
    - Changing operational characteristics (e.g., heating make-up water)
    - Annealing
  - **Data options**
    - Plant-specific surveillance data
    - BAW 2308
    - Master Curve (PWROG project, CC N-830)
  - **Analytical options**
    - Plant-specific PRA &/or PFM

# DG/RG Development Timeline

DG 1.230 = DG 1299

Date	Event
September 2013	Draft Guide development begins
October 2014	1 <sup>st</sup> ACRS briefing
March 2015	DG & NUREG sent out for public comments
May 2015	Public comments received
February 2015	Staff concurrence (except for OGC final no-legal objection (NLO) finding) on responses to public comments & revisions of RG complete
May 3, 2016	Today's ACRS Briefing
<b>Path Forward and Next Steps</b>	<ul style="list-style-type: none"><li>• <b>Incorporate ACRS recommendations into RG &amp; NUREG</b></li><li>• <b>Send to OGC for NLO</b></li><li>• <b>Publish final RG &amp; NUREG on Federal Register (within ≈ 2 months)</b></li></ul>

# **CLOSURE & DISCUSSION**