

Docket File



REGULATORY DOCKET FILE COPY  
UNITED STATES

NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

AUG 15 1979

Docket Nos.: 50-269, 270, 287, 289, 302, 312, 313, 346

FACILITIES: Oconee Nuclear Station, Units No. 1, 2 & 3  
Three Mile Island Nuclear Station, Unit No. 1  
Crystal River Unit No. 3, Nuclear Generating Station  
Rancho Seco Nuclear Generating Station  
Arkansas Nuclear One, Unit No. 1  
Davis-Besse Nuclear Power Station, Unit No. 1

LICENSEES: Duke Power Company  
Metropolitan Edison Company  
Florida Power Corporation  
Sacramento Municipal Utility District  
Arkansas Power & Light Company  
Toledo Edison Company

SUBJECT: SUMMARY OF MEETING HELD ON JULY 18, 1979 TO DISCUSS BABCOCK  
& WILCOX (B&W) SMALL BREAK LOSS-OF-COOLANT ACCIDENT (LOCA)  
ANALYSES (REACTOR COOLANT PUMPS OPERATING VERSUS TRIPPED)

On July 18, 1979, members of the NRC staff met with B&W and representatives of the B&W Owners' Group (TMI-2 Follow-up Subcommittee) in Bethesda, Maryland to discuss preliminary calculations performed by B&W which indicated that, for a certain spectrum of small breaks in the reactor coolant system, continued operation of the reactor coolant pumps (RCPs) can increase the mass lost through the break and prolong or aggravate the uncovering of the reactor core. A list of attendees is provided as Enclosure 1 to this summary.

#### BACKGROUND

Subsequent to the accident at Three Mile Island, Unit No. 2 (TMI-2) on March 28, 1979, the Office of Inspection and Enforcement (IE) issued several Bulletins requiring certain actions to be taken by all holders of operating licenses for each operating reactor. Item 4.c of IE Bulletin 79-05A required the licensees for B&W designed pressurized water reactors (PWRs) to revise their operating procedures to specify that, in the event of high pressure injection (HPI) initiation with RCPs running, at least one RCP per loop would remain operating. Similar requirements, applicable to reactors designed by other PWR vendors, were contained in other IE Bulletins.

Prior to the accident at TMI-2, Westinghouse and its licensees generally adopted the position that the operator should promptly trip all operating RCPs in the LOCA situation. This Westinghouse position, led to a series of meetings between the NRC staff and Westinghouse, as well as with the other PWR vendors, to discuss this issue. In addition, more detailed analyses concerning this matter were requested by the staff. This meeting was arranged to discuss B&W's preliminary calculations concerning the effect of continued operation of the RCPs during a small break LOCA.

7909100644

K.B.  
MEMG

DISCUSSION

As discussed above, the current emergency procedures being used by all B&W operating plants direct the operators to keep at least one RCP per loop operating in the event of a LOCA, provided offsite power is available. B&W previously presented analyses which demonstrated that the reactor core would be adequately cooled during a small break LOCA provided either the RCPs remained operating during the entire course of the event or were tripped at the beginning of the accident. At the request of the NRC staff, B&W performed additional analyses, for various break sizes, assuming that the RCPs were operating at the beginning of the accident and were then inadvertently tripped a short time into the accident. These calculations were performed using a six node CRAFT-2 model.

B&W's calculations showed that for a range of breaks between  $0.025 \text{ ft}^2$  and  $0.2 \text{ ft}^2$ , if RCPs remained operating until the reactor coolant system (RCS) contained a high void fraction and were then tripped, the core would be uncovered for an extended period of time (approximately 600 seconds assuming RCP trip at 90% void fraction and two HPI trains operating). B&W explained that with RCPs operating, more liquid would be lost through the break than could be injected with the HPI system, thus leading to high void fractions in the RCS. As long as RCPs remained operating, pumping a two-phase mixture of water and steam, cooling of the core would be insured. However, once the RCPs were tripped (either manually or through loss of offsite power) the liquid and steam would separate. If the void fraction in the RCS was approximately 63% or greater at the time the RCPs were tripped, the liquid remaining in the reactor vessel, following the liquid/steam separation, would not be sufficient to cover the core. A period of time would be needed for the HPI system to pump enough water into the vessel to recover the core. B&W's calculations assumed an adiabatic heat-up of the core of  $50^\circ\text{F}/\text{Sec}$ . during the period the core was uncovered. Under certain conditions, these calculations indicated that 10 CFR Part 50 Appendix K limits would be exceeded.

B&W stated that the critical break size was bounded by these analyses. Below  $0.025 \text{ ft}^2$  the void fraction would not exceed the 63% value, and thus, if RCPs were tripped, the core would remain covered. Above  $0.2 \text{ ft}^2$ , the system would depressurize rapidly enough to insure low pressure injection (LPI) initiation for continued core cooling.

The NRC staff expressed several concerns with the model used for the B&W calculations:

- (1) the six node CRAFT-2 model was found to produce void fractions several percent lower than the 23 node model normally used for small break analyses,
- (2) no liquid carryout was assumed to occur from the core during the reflooding period,
- (3) a homogeneous void distribution model was used in CRAFT-2 during the time the RCPs were operating. This assumption maximizes the liquid lost through the break and may be overly conservative, and
- (4) the adiabatic heat-up model used when the core is uncovered may also be overly conservative.

B&W stated that on all of the B&W plants no RCS penetrations exist in that range of break sizes and therefore, felt the probability of a break within the bounds of the analyses was highly unlikely. The staff felt that enough uncertainty existed within the analyses that the bounds of the break size could be greater than that presented in the analyses. In addition, the staff asked B&W if having two pressurizer safety valves stick open would put the plant into a small break LOCA situation that was within the critical break size. B&W stated they would look into this matter.

B&W stated that it would continue to do additional analyses in this area to confirm its preliminary calculations; in addition, if prompt tripping of the RCPs during a LOCA situation would be required, it was investigating the possibility of designing a hard-wired RCP trip which would trip the pumps on initiation of HPI (low RCS pressure-indicative of a LOCA) in conjunction with low RCP current (indicative of a high void fraction in the RCS).

The NRC staff stated that it would review the calculations presented and determine the advisability of tripping the RCPs upon indication of a LOCA. The slides used in the presentation are included as Enclosures 2 through 15 of this summary.

A similar analysis was presented by B&W for a main steam line break. The results of that analysis showed that the time RCPs were tripped had little effect on the severity of the accident.

Two additional areas were discussed at the end of the meeting:

(1) Outstanding Information Requirements

The list of outstanding information requirements, tabulated by B&W in a letter from J. Taylor (B&W) to R. Mattson (NRC) dated June 13, 1979, was compared to a list compiled by the NRC staff. The staff stated that it needed information in three areas which were not covered in the B&W letter. These include:

- (A) NRC concerns regarding the presence of non-condensable gas within the RCS following a small break LOCA,
- (B) responses to questions concerning the CRAFT-2 code small break analyses raised by the ACRS (ECCS Subcommittee) June 19, 1979, and
- (C) the ability of the RCPs to operate in a highly voided reactor coolant system.

The staff agreed that a letter formalizing these commitments would be sent in the near future.

(2) Analyses Required in the Next 3 to 6 Months

A subgroup of members of the Bulletins & Orders and the Lessons Learned Task Forces has determined that, in addition to the evaluation of small break LOCAs, two additional tasks should be undertaken:

- (A) an assessment of the symptoms of inadequate core cooling, and
- (B) an evaluation of accidents and transients beyond current design analyses.

In both cases, the emphasis should be on information needed for operator training, and information needed for the preparation of improved emergency procedures. The staff suggested that these programs be completed by December 1, 1979. The B&W Owner's Group stated they would have difficulty meeting this schedule. They plan to meet with the staff in mid-August to discuss progress on the two additional analyses.

CONCLUSIONS

Following this meeting, the staff held discussions with the other PWR vendors to pass on the information presented by B&W. Analyses performed by all the vendors (B&W, Westinghouse and Combustion Engineering) supported the tripping of RCPs immediately under LOCA conditions. On July 26, 1979, IE Bulletin Nos. 79-05C & 79-06C was issued requiring certain actions to be taken by all holders of operating licenses for PWR facilities. This Bulletin required, as immediate action for all PWR licensees, to revise their operating procedures such that upon reactor trip and initiation of HPI caused by low reactor coolant system pressure the operator will immediately trip all operating RCPs. A copy of this Bulletin is attached as Enclosure 16 to this summary.



R. A. Capra, Project Manager  
Bulletins & Orders Task Force

Enclosures:  
As stated

Distribution:  
See attached pages

ENCLOSURE 1

LIST OF ATTENDEES

Duke Power Company

D. C. Holt (Systems Engineer, Licensing)  
K. Conody (Manager, Projects & Licensing)  
R. Gill (Oconee Head - Licensing)  
P. M. Abraham (Nuclear Engineer)

General Public Utilities  
Service Corporation

L. Lanese (Control & Safety Analysis Engineer)

Florida Power Corporation

P. Y. Baynard (Assistant Manager - Nuclear Support Services)

Sacramento Municipal  
Utility District

S. Anderson (Nuclear Engineer)

Arkansas Power & Light  
Company

D. H. Williams (Production Engineer)  
D. G. Mardis (Production Engineer - Licensing)

Toledo Edison Company

F. Miller (Nuclear Systems Engineer)

Consumers Power

T. J. Sullivan (Executive Engineer)


Babcock & Wilcox

H. Bailey (Licensing Engineer)  
R. E. Ham (Product Line Manager, Engineering Services)  
D. Hallman (Manager, Plant Performance Services)  
E. R. Kane (Manager, Operating Plant Licensing)  
C. E. Parks (Adv. Eng.)  
M. A. Haghi (Nuclear Engineer)  
G. O. Geissler (Manager, Generic Licensing Unit)  
E. A. Womack (Manager, Plant Design)

NRC

B. Sheron (Bulletins & Orders Task Force - Analysis)  
R. F. Audette " " " " "  
P. S. Tam (ACRS)  
J. G. Stampels (ACRS)  
E. J. Brown (Structures & Components Standards Branch)  
S. L. Wookey (Operating Reactors Branch No. 4)  
D. Garner (Project Manager, Rancho Seco)  
M. B. Fairtile (Project Manager, Oconee 1, 2, 3)  
G. Kelley (Bulletins & Orders Task Force - Systems)  
P. E. Norian (Bulletins & Orders Task Force - Analysis)  
W. L. Jensen " " " " "  
Z. R. Rosztoczy (Bulletins & Orders Task Force Group Leader  
Analysis)  
T. H. Novak (Deputy Director, Bulletins & Orders Task Force)  
R. A. Capra (B&W Project Manager, Bulletins & Orders Task  
Force)

Figure 1. CRAFT2 Coding Diagram for Small Breaks



Break No.

- 1
- 2
- 3
- 4, 14
- 5, 15
- 6, 16
- 7, 17
- 8, 18
- 9, 11, 19
- 10, 12, 20
- 13
- 21
- 22
- 23

Identification

- Downcomer
- Lower Plenum
- Core
- Hot Leg Piping
- SG & Upper Head
- Steam Generator Tubes
- Secondary, SG
- SG Lower Head
- Cold Leg Piping
- Cold Leg Piping
- Upper Downcomer
- Pressurizer
- Containment
- Upper Plenum


Patch No.

- 1, 2
- 3, 4, 18, 19
- 5, 20
- 6, 21
- 7, 22
- 8
- 9, 13, 24
- 10, 14, 25
- 11, 12, 15, 16, 26, 27
- 17, 31
- 23
- 24, 29
- 30
- 32
- 33, 34
- 35, 36
- 37

Identification

- Core
- Hot Leg Piping
- Hot Leg, Upper
- SG Tubes
- SG Lower Head
- Core Bypass
- Cold Leg Piping
- Pumps
- Cold Leg Piping
- Downcomer
- LPI
- Upper Downcomer
- Pressurizer
- Vent Valve
- Leak & Return Patch
- ERT
- Containment Spray


CRAFT2 NODING DIAGRAM FOR SMALL BREAKS  
(6 NODE MODEL)



SUBJECT  
NO.

3M

CATALOG NO.  
3M CENTER S






# CORE PRESSURE VS TIME PUMPS ON

CORE PRESSURE, PSIA ( $\times 10^2$ )


0.025 FT<sup>2</sup>

----- 23 NODES


- . - . - 6 NODES




# EFFECT OF EQUIPMENT WITH PUMPS OPERATIVE



# EFFECT OF EQUIPMENT WITH PUMPS OPERATIVE



# BREAK SPECTRUM EFFECTS, PUMPS ON




SUBJECT  
NO.

Enclosure 8

3M

CATALOG NO.  
3M CENTER, S

# BREAK SPECTRUM EFFECT - PUMPS ON



SUBJECT  
NO.

Enclosure 9

3M

CATALOG  
3M CENTER

Pumps

FIGURE 11: RC Pressure for 0.075 FT<sup>2</sup> Break  
Sensitivity Study




FIGURE 15: Percent System Void fraction for 0.05 FT<sup>2</sup>  
Break with 1.0 and 1.2 ANS








FIGURE 14: RC Pressure Vs Time for 0.05 FT<sup>2</sup>  
Break With 1.0 and 1.2 ANS




# BREAK SPECTRUM EFFECT - PUMPS

OFF @ 90% VOID



# SYSTEM VOID VS TIME



SUBJECT  
NO.

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D.C. 20555

July 26, 1979

• IE Bulletin Nos. 79-05C & 79-06C

NUCLEAR INCIDENT AT THREE MILE ISLAND - SUPPLEMENT

Description of Circumstances:

Information has become available to the NRC, subsequent to the issuance of IE Bulletins 79-05, 79-05A, 79-05B, 79-06, 79-06A, 79-06A (Revision 1) and 79-06B, which requires modification to the "Action To Be Taken By Licensees" portion of IE Bulletins 79-05A, 79-06A and 79-06B, for all pressurized water reactors (PWRs).

Item 4.c of Bulletin 79-05A required all holders of operating licenses for Babcock & Wilcox designed PWRs to revise their operating procedures to specify that, in the event of high pressure injection (HPI) initiation with reactor coolant pumps (RCPs) operating, at least one RCP per loop would remain operating. Similar requirements, applicable to reactors designed by other PWR vendors, were contained in Item 7.c of Bulletin 79-06A (for Westinghouse designed plants) and in Item 6.c of Bulletin 79-06B (for Combustion Engineering designed plants).

Prior to the incident at Three Mile Island Unit 2 (TMI 2), Westinghouse and its licensees generally adopted the position that the operator should promptly trip all operating RCPs in the loss of coolant accident (LOCA) situation. This Westinghouse position, has led to a series of meetings between the NRC staff and Westinghouse, as well as with other PWR vendors, to discuss this issue. In addition, more detailed analyses concerning this matter were requested by the NRC. Recent preliminary calculations performed by Babcock & Wilcox, Westinghouse and Combustion Engineering indicate that, for a certain spectrum of small breaks in the reactor coolant system, continued operation of the RCPs can increase the mass lost through the break and prolong or aggravate the uncovering of the reactor core.

The damage to the reactor core at TMI 2 followed tripping of the last operating RCP, when two phase fluid was being pumped through the reactor coolant system. It is our current understanding that all three of the nuclear steam system suppliers for PWRs now agree that an acceptable action under LOCA symptoms is to trip all operating RCPs immediately, before significant voiding in the reactor coolant system occurs.

Action To Be Taken By Licensees:

In order to alleviate the concern over delayed tripping of the RCPs after a LOCA, all holders of operating licenses for PWR facilities shall take the following actions:

### Short-Term Actions

1. In the interim, until the design change required by the long-term action of this Bulletin has been incorporated, institute the following actions at your facilities:
  - A. Upon reactor trip and initiation of HPI caused by low reactor coolant system pressure, immediately trip all operating RCPs.
  - B. Provide two licensed operators in the control room at all times during operation to accomplish this action and other immediate and followup actions required during such an occurrence. For facilities with dual control rooms, a total of three licensed operators in the dual control room at all times meets the requirements of this Bulletin.
2. Perform and submit a report of LOCA analyses for your plants for a range of small break sizes and a range of time lapses between reactor trip and pump trip. For each pair of values of the parameters, determine the peak cladding temperature (PCT) which results. The range of values for each parameter must be wide enough to assure that the maximum PCT or, if appropriate, the region containing PCTs greater than 2200 degrees F is identified.
3. Based on the analyses done under Item 2 above, develop new guidelines for operator action, for both LOCA and non-LOCA transients, that take into account the impact of RCP trip requirements. For Babcock & Wilcox designed reactors, such guidelines should include appropriate requirements to fill the steam generators to a higher level, following RCP trip, to promote natural circulation flow.
4. Revise emergency procedures and train all licensed reactor operators and senior reactor operators based on the guidelines developed under Item 3 above.
5. Provide analyses and develop guidelines and procedures related to inadequate core cooling (as discussed in Section 2.1.9 of NUREG-0578, "TMI 2 Lessons Learned Task Force Status Report and Short-Term Recommendations") and define the conditions under which a restart of the RCPs should be attempted.

### Long-Term Action

1. Propose and submit a design which will assure automatic tripping of the operating RCPs under all circumstances in which this action may be needed.

### Schedule

The schedule for the short-term actions of this Bulletin is:

- Item 1: Effective upon receipt of this Bulletin,
- Item 2: Within 30 days of receipt of this Bulletin,
- Item 3: Within 30 days of receipt of this Bulletin,
- Item 4: Within 45 days of receipt of this Bulletin,
- Item 5: October 31, 1979 (as noted in Table B-2 of NUREG-0578, under Item 3).

A schedule for the long-term action required by this Bulletin should be developed and submitted within 30 days of receipt of this Bulletin.

Reports should be submitted to the Director of the appropriate NRC Regional Office with copies forwarded to the Director, Office of Inspection and Enforcement and the Director, Office of Nuclear Reactor Regulation, Washington, D. C. 20555.

Approved by GAO (R0072): clearance expires 7/31/80. Approval was given under a blanket clearance specifically for generic problems.

## Babcock & Wilcox Principal Contacts Listing

Mr. William Cavanaugh, III  
Vice-President, Generation and  
Construction  
Arkansas Power & Light Company  
P. O. Box 551  
Little Rock, Arkansas 72203

Mr. W. P. Stewart  
Manager, Nuclear Operations  
Florida Power Corporation  
P. O. Box 14042, Mail Stop C-4  
St. Petersburg, Florida 33733

Mr. Lowell E. Roe  
Vice-President, Facilities Development  
Toledo Edison Company  
Edison Plaza  
300 Madison Avenue  
Toledo, Ohio 43652

Mr. William O. Parker, Jr.  
Vice-President - Steam Production  
Duke Power Company  
P. O. Box 2178  
422 South Church Street  
Charlotte, North Carolina 28242

Mr. J. J. Mattimoe  
Assistant General Manager &  
Chief Engineer  
Sacramento Municipal Utility District  
6201 S Street  
P. O. Box 15830  
Sacramento, California 95813

Mr. J. G. Herbein, Vice-President  
Metropolitan Edison Company  
P. O. Box 542  
Reading, Pennsylvania 19640

Mr. James Taylor, Licensing Manager  
Babcock & Wilcox Company  
P. O. Box 1260  
Lynchburg, Virginia

Arkansas Power & Light Company

cc w/enclosure(s):

Phillip K. Lyon, Esq.  
House, Holms & Jewell  
1550 Tower Building  
Little Rock, Arkansas 72201

Mr. David C. Trimble  
Manager, Licensing  
Arkansas Power & Light Company  
P. O. Box 551  
Little Rock, Arkansas 72203

Mr. James P. O'Hanlon  
General Manager  
Arkansas Nuclear One  
P. O. Box 608  
Russellville, Arkansas 72801

Mr. William Johnson  
U. S. Nuclear Regulatory Commission  
P. O. Box 2090  
Russellville, Arkansas 72801

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 420, 7735 Old Georgetown Road  
Bethesda, Maryland 20014

Troy B. Conner, Jr., Esq.  
Conner, Moore & Corber  
1747 Pennsylvania Avenue, N.W.  
Washington, D.C. 20006

Arkansas Polytechnic College  
Russellville, Arkansas 72801

Honorable Ermil Grant  
Acting County Judge of Pope County  
Pope County Courthouse  
Russellville, Arkansas 72801

Director, Technical Assessment  
Division

Office of Radiation Programs  
(AW-459)

U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection Agency  
Region VI Office  
ATTN: EIS COORDINATOR  
1201 Elm Street  
First International Building  
Dallas, Texas 75270

cc w/enclosure(s) and incoming  
dtd.:

Director, Bureau of Environmental  
Health Services  
4815 West Markham Street 27603  
Little Rock, Arkansas 72201



Duke Power Company

cc w/enclosure(s):

Mr. William L. Porter  
Duke Power Company  
Post Office Box 2178  
422 South Church Street  
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esquire  
DeBevoise & Liberman  
700 Shoreham Building  
806 15th Street, N.W.  
Washington, D. C. 20005

Oconee Public Library  
201 South Spring Street  
Walhalla, South Carolina 29691

Honorable James M. Phinney  
County Supervisor of Oconee County  
Walhalla, South Carolina 29621

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection Agency  
Region IV Office  
ATTN: EIS COORDINATOR  
345 Courtland Street, N.E.  
Atlanta, Georgia 30308

U. S. Nuclear Regulatory Commission  
Region II  
Office of Inspection and Enforcement  
ATTN: Mr. Francis Jape  
P. O. Box 85  
Seneca, South Carolina 29678

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 420, 7735 Old Georgetown Road  
Bethesda, Maryland 20014

Manager, LIS  
NUS Corporation  
2536 Countryside Boulevard  
Clearwater, Florida 33515

cc w/enclosure(s) and incoming  
dtd.:

Office of Intergovernmental Relations  
116 West Jones Street  
Raleigh, North Carolina 27603

Florida Power Corporation

cc w/enclosure(s):

Mr. S. A. Brandimore  
Vice President and General Counsel  
P. O. Box 14042  
St. Petersburg, Florida 33733

Mr. Wilbur Langely, Chairman  
Board of County Commissioners  
Citrus County  
Iverness, Florida 36250

U. S. Environmental Protection Agency  
Region IV Office  
ATTN: EIS COORDINATOR  
345 Courtland Street, N.E.  
Atlanta, Georgia 30308

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

Crystal River Public Library  
Crystal River, Florida 32629

Mr. J. Shreve  
The Public Counsel  
Room 4 Holland Bldg.  
Tallahassee, Florida 32304

Administrator  
Department of Environmental Regulation  
Power Plant Siting Section  
State of Florida  
Montgomery Building  
2562 Executive Center Circle, E.  
Tallahassee, Florida 32301

Attorney General  
Department of Legal Affairs  
Capitol  
Tallahassee, Florida 32304

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 420, 7735 Old Georgetown Road  
Bethesda, Maryland 20014

cc w/enclosures & incoming  
dtd:  
Bureau of Intergovernmental  
Relations  
660 Apalachee Parkway  
Tallahassee, Florida 32304

Metropolitan Edison Company

cc w/enclosure(s):

G. F. Trowbridge, Esquire  
Shaw, Pittman, Potts & Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

GPU Service Corporation  
Richard W. Heward, Project Manager  
Mr. T. Gary Broughton, Safety and  
Licensing Manager  
260 Cherry Hill Road  
Parsippany, New Jersey 07054

Pennsylvania Electric Company  
Mr. R. W. Conrad  
Vice President, Generation  
1001 Broad Street  
Johnstown, Pennsylvania 15907

Miss Mary V. Southard, Chairman  
Citizens for a Safe Environment  
Post Office Box 405  
Harrisburg, Pennsylvania 17108

Government Publications Section  
State of Library of Pennsylvania  
Box 1601 (Education Building)  
Harrisburg, Pennsylvania 17126

Dr. Edward O. Swartz  
Board of Supervisors  
Londonderry Township  
RFD-1 - Geyers Church Road  
Middletown, Pennsylvania 17057

U. S. Environmental Protection Agency  
Region III Office  
ATTN: EIS COORDINATOR  
Curtis Building (Sixth Floor)  
6th and Walnut Streets  
Philadelphia, Pennsylvania 19106

Dauphin County Office Emergency  
Preparedness  
Court House, Room 7  
Front & Market Streets  
Harrisburg, Pennsylvania 17101

Department of Environmental Resources  
ATTN: Director, Office of Radiological  
Health  
Post Office Box 2063  
Harrisburg, Pennsylvania 17105

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

Mr. Robert B. Eorsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 420, 7735 Old Georgetown Road  
Bethesda, Maryland 20014

cc w/enclosure(s) and incoming  
dtd.:

Governor's Office of State Planning  
and Development  
ATTN: Coordinator, Pennsylvania  
State Clearinghouse  
P. O. Box 1323  
Harrisburg, Pennsylvania 17120

Sacramento Municipal Utility  
District

cc w/enclosure(s):

David S. Kaplan, Secretary and  
General Counsel  
6201 S Street  
P. O. Box 15830  
Sacramento, California 95813

Sacramento County  
Board of Supervisors  
827 7th Street, Room 424  
Sacramento, California 95814

California Energy Commission  
ATTN: Librarian  
1111 Howe Avenue  
Sacramento, California 95825

Business and Municipal Department  
Sacramento City-County Library  
828 I Street  
Sacramento, California 95814

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection Agency  
Region IX Office  
ATTN: EIS COORDINATOR  
215 Fremont Street  
San Francisco, California 94111

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 420, 7735 Old Georgetown Road  
Bethesda, Maryland 20014

Christopher Ellison, Esquire  
Dian Grueneich, Esquire  
California Energy Commission  
1111 Howe Avenue  
Sacramento, California 95825

Mr. Frank Hahn  
California Energy Commission  
1111 Howe Avenue  
Sacramento, California 95825

Ms. Eleanor Schwartz  
California State Office  
600 Pennsylvania Avenue, S.E., Rm. 201  
Washington, D.C. 20003

Docketing and Service Section  
Office of the Secretary  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Michael L. Glaser, Esq.  
1150 17th Street, N.W.  
Washington, D.C. 20036

Dr. Richard F. Cole  
Atomic Safety and Licensing Board  
Panel  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Mr. Frederick J. Shon  
Atomic Safety and Licensing Board  
Panel  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Timothy V. A. Dillon, Esq.  
Suite 380  
1850 K Street, N.W.  
Washington, D.C. 20006

James S. Reed, Esquire  
Michael H. Remy, Esquire  
Reed, Samuel & Remy  
717 K Street, Suite 405  
Sacramento, California 95814

Sacramento Municipal Utility  
District

cc w/enclosure(s):

Atomic Safety and Licensing Board  
Panel  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Atomic Safety and Licensing Appeal  
Board Panel  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Mr. Richard D. Castro  
2231 K Street  
Sacramento, California 95814

Mr. Gary Hursh, Esq.  
520 Capital Mall  
Suite 700  
Sacramento, California 95814

cc w/enclosure(s) and incoming  
dtd.:

California Department of Health  
ATTN: Chief, Environmental  
Radiation Control Unit  
Radiological Health Section  
714 P Street, Room 498  
Sacramento, California 94814

Toledo Edison Company

cc w/enclosure(s):

Mr. Donald H. Hauser, Esq.  
The Cleveland Electric  
Illuminating Company  
P. O. Box 5000  
Cleveland, Ohio 44101

Gerald Charnoff, Esq.  
Shaw, Pittman, Potts  
and Trowbridge  
1800 M Street, N.W.  
Washington, D.C. 20036

Leslie Henry, Esq.  
Fuller, Seney, Henry and Hodge  
300 Madison Avenue  
Toledo, Ohio 43604

Mr. Robert B. Borsum  
Rabcock & Wilcox  
Nuclear Power Generation Division  
Suite 420, 7735 Old Georgetown Road  
Bethesda, Maryland 20014

Ida Rupp Public Library  
310 Madison Street  
Port Clinton, Ohio 43452

President, Board of County  
Commissioners of Ottawa County  
Port Clinton, Ohio 43452

Attorney General  
Department of Attorney General  
30 East Broad Street  
Columbus, Ohio 43215

Harold Kahn, Staff Scientist  
Power Siting Commission  
361 East Broad Street  
Columbus, Ohio 43216

Docketing and Service Section  
Office of the Secretary  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection Agency  
Federal Activities Branch  
Region V Office  
ATTN: EIS COORDINATOR  
230 South Dearborn Street  
Chicago, Illinois 60604

Mr. Samuel J. Chilk, Secretary  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

The Honorable Tim McCormack  
Ohio Senate  
Statehouse  
Columbus, Ohio 43216

The Honorable Tim McCormack  
170 E. 209th Street  
Euclid, Ohio 44123

Mr. Lowell E. Roe  
Vice President, Facilities  
Development  
Toledo Edison Company  
Edison Plaza  
300 Madison Avenue  
Toledo, Ohio 43652

Bruce Churchill, Esq.  
Shaw, Pittman, Potts & Trowbridge  
1800 M Street, N.W.  
Washington, D.C. 20036

Atomic Safety & Licensing Board Panel  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Atomic Safety and Licensing Appeal Panel  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Toledo Edison Company

cc w/enclosure(s):

Ivan W. Smith, Esq.  
Atomic Safety and Licensing Board Panel  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dr. Cadet H. Hand, Jr.  
Director, Bodega Marine Laboratory  
University of California  
P. O. Box 247  
Bodega Bay, California 94923

Dr. Walter H. Jordan  
881 W. Outer Drive  
Oak Ridge, Tennessee 37830

Ms. Jean DeJuljak  
381 East 272  
Euclid, Ohio 44117

Mr. Rick Jagger  
Industrial Commission  
State of Ohio  
2323 West 5th Avenue  
Columbus, Ohio 43216

cc w/enclosure(s) and incoming  
dtd.:

Ohio Department of Health  
ATTN: Director of Health  
450 East Town Street  
Columbus, Ohio 43216