



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
SEP 25 1979

Docket 50-287

Docket Nos.: 50-269, 50-270, 50-287,
50-302, 50-312, 50-313,
50-346

MEMORANDUM FOR: Z. Rosztoczy, Leader, Analysis Group, B&OTF
S. Israel, Leader, Systems Group, B&OTF

FROM: C. J. Heltemes, Jr., Leader, Project Management Group, B&OTF

SUBJECT: TECHNICAL ASSISTANCE REQUEST - RESPONSES TO
IE BULLETIN 79-06C FOR B&W OPERATING PLANTS

REFERENCE: Memorandum for Z. Rosztoczy and S. Israel from C. J. Heltemes
dated September 5, 1979 of the same subject

By reference above, I forwarded the initial responses to IE Bulletin 79-06C and requested that a joint review by the Analysis and Systems Groups of the B&OTF be conducted.

The following additional information has been received and is enclosed with this memorandum for review.

DUKE POWER COMPANY (Oconee 1, 2, and 3)

1. Supplemental analysis to complete response to item 2 of the Bulletin:
 - a. The analysis to determine the time available for the operator to trip RCPs such that, under Appendix K assumptions, the criteria of 10 CFR 50.46 would not be violated.
 - b. The RCP trip times for a spectrum of breaks for which the peak cladding temperature, evaluated with Appendix K assumptions, will exceed 10 CFR 50.46 limits.
 - c. A realistic analysis of a typical worst case to demonstrate that the consequences of a RCP trip at any time will not exceed the 10 CFR 50.46 limits.
2. A revised impact assessment of RCP trip on non-LOCA events.

FLORIDA POWER CORPORATION (Crystal River 3)

1. Same as item 1 under Duke Power Company.
2. Same as item 2 under Duke Power Company.
3. Response to item 4 of the Bulletin.

Memo

CRP

79101 00 052

ARKANSAS POWER & LIGHT COMPANY (ANO-1)

1. Same as item 1 under Duke Power Company.
2. Same as item 2 under Duke Power Company.

Responses from Sacramento Municipal Utility District (Rancho Seco) and Toledo Edison Company (Davis-Besse 1) have not been received to date. I will forward them to you as soon as they are received.

Additional copies of all the B&W operating plant licensees' responses are being made and will be distributed through normal distribution channels.

/s/

C. J. Heltemes, Jr., Leader
Project Management Group
Bulletins & Orders Task Force

Enclosures:

1. DPCO letter dated 9/14/79
2. FPC letter dated 9/14/79
3. AP&L letter dated 9/14/79

cc w/o enclosures:

D. Ross
T. Novak
G. Mazetis
R. Reid
C. Nelson
G. Vissing
M. Fairtile
B. Wilson
R. Capra

Distribution: (w/o enclosures)

Docket Files (7)
B&OTF R/F
NRR Reading File

OFFICE	B&O T/F	B&O T/F				
SURNAME	RACapra:gt	CJHeltemes				
DATE	9/24/79	9/24/79				