ACCELERATED DISTRIBUTION DEMONSTRATION_SYSTEM

-					
• 	REGULATORY	INFORMATION	DISTRIBUTION SYSTE	M (RIDS)	
					DOCKET # 05000287 R
SUBJECT: Submits written follow-up of info provided during 940104					
telcon w/NRC re second 10-vr ISI interval request for relief					
telcon w/NRC re second 10-yr ISI interval request for relief 92-12,submitted on 921110 for welds on Unit 3 which did not [] meet 90% criteria of Code Case N-460.					
DISTRIBUTION CODE: A047D COPIES RECEIVED:LTR $\int encl \theta$ size: 2 S					
TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code					
NOTES:					Α
	RECIPIENT	COPIES	RECIPIENT	COPIES	
	ID CODE/NAME		ID CODE/NAME	LTTR ENCL	D
	PD2-3 LA WIENS,L		PD2-3 PD	1 1	D
	WIENS, D	2 4			D
INTERNAL:		6 6	AEOD/DSP/ROAB	1 1	S
	NRR/DE/EMEB	1 1	NRR/EMCB	1 1	
	NUDOCS-ABSTRACT		OC/LFDCB	1 1 1 1 1 0 1 1	
	OGC/HDS2 RES/DSIR/EIB		(REG_FILE) 01	⊥ +	
	RES/DSIR/EIB	- +			
EXTERNAL:	EG&G BROWN, B	1 1	EG&G RANSOME,C	1 1	
	NRC PDR	1 1	NSIC	1 1	
		l		-	

NOTE TO ALL "RIDS" RECIPIENTS:

, • ⁻¹

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 19 0

MA

R

I

D

S

/

Α

D

D

S

Duke Power Company Oconee Nuclear Site "P.O. Box 1439 Seneca, SC 29679

T

J. W. HAMPTON Vice President (803)885-3499 Office (803)885-3564 Fax



DUKE POWER

February 3, 1994

U.S. Nuclear Regulatory Commission Attention Document Control Desk Washington, DC 20555

Subject: Duke Power Company Oconee Nuclear Station Docket No. 50-287 Second Ten Year Inservice Inspection Interval Request for Relief No. 92-12 Supplemental Information

On November 10, 1992 Duke submitted Relief Request 92-12 for several welds on Oconee Unit 3 which did not meet the 90% criteria of Code Case N-460. As a result of your review of this Relief Request, additional information was requested for weld identified as Item # B03.130.002 on the "A" Steam Generator. On January 4, 1994 a phone conference between Duke and NRC was held to provide the additional information requested. The following is a written follow-up of the information provided during the January 4, 1994 phone conference.

Duke's Relief Request reflects only 15.6% of the weld was covered during the examination. This percentage reflects only the coverage meeting the Code requirements for calculating examination coverage. The weld actually received a total of 53.3% coverage in at least one direction from one side. In addition it was pointed out this weld is included in the Class 1 hydrostatic test performed at the end of each refueling outage.

If you have any questions or need further information you may contact D. W. Dalton at (803) 885-3372.

Very truly yours,

W. Hampton Site Vice President



Printed on recycled paper

A047 1

U. S. Nuclear Regulatory Commission Page 2

xc: Mr. L. A. Wiens Office of Nuclear Reactor Regulation U. S. Nuclear Regulatory Commission Washington, DC 20555

> Mr. S. D. Ebneter Regional Administrator, Region II U. S. Nuclear Regulatory Commission

Mr. P. E. Harmon Senior NRC Resident Inspector Oconee Nuclear Station

Mr. Virgil R. Autry Bureau of Radiological Health SC Dept. of Health & Environmental Control 2600 Bull St. Columbia, SC 29201