

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9601260156 DOC. DATE: 95/12/07 NOTARIZED: YES DOCKET #
FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
HAMPTON, J.W. Duke Power Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-38, DPR-47 & DPR-55,
revising secondary sys decay heat removal.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+28
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 1	PD2-2 PD	1 1
	MILANO, P	1 1		
INTERNAL:	ACRS	6 6	FILE CENTER ON	1 1
	NRR/DE/EMCB	1 1	NRR/DRCH/HICB	1 1
	NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
	NUDOCS-ABSTRACT	1 1	OGC/HDS2	1 0
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 17

AA2

C
A
T
E
G
O
R
Y
1
D
O
C
U
M
E
N
T

Duke Power Company
Oconee Nuclear Generation Department
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER

December 7, 1995

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Proposed Revision to the Secondary System Decay Heat Removal
Specifications
Cost Beneficial Licensing Action Item

Pursuant to 10 CFR 50.90, Attachment 1 provides a proposed amendment to the Oconee Nuclear Station (ONS) Facility Operating Licenses and Technical Specifications. Attachment 2 provides a marked up copy of the current Technical Specifications. The proposed amendment deletes the requirements for main feedwater pump discharge pressure switch input to ARTS (Anticipatory Reactor Trip System) and EFDW (Emergency Feedwater). This amendment request is considered a CBLA with an estimated cost saving of \$300,000 over the life of the plant. This cost saving is based on the deletion of calibration requirements and replacement costs for these switches.

It has been determined that the proposed amendment has no significant hazards considerations. Attachment 3 provides the Technical Justification for the proposed amendment and Attachment 4 provides the No Significant Hazards Consideration Evaluation. The Environmental Impact Analysis is provided in Attachment 5.

I am forwarding a copy of this application to the South Carolina Department of Health and Environmental Control for review and, as appropriate, subsequent consultation with the staff.

Very Truly Yours,

J. W. Hampton, Site Vice President
Oconee Nuclear Site

NTC
Attachments

9601260156 951207
PDR ADOCK 05000269
P PDR

260038

ADD 1


xc: L. A. Wiens, ONRR
Project Manager

S. D. Ebnetter
Regional Administrator, Region II

P. E. Harmon
Senior Resident Inspector


M. Batavia
DHEC

J. W. Hampton, being duly sworn, states that he is Site Vice President of Duke Power Company, that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the Oconee Nuclear Station License Nos. DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



J. W. Hampton, Site Vice President

Subscribed and sworn to before me this 7th day of December, 1995.



Notary Public

My Commission Expires:

2-12-2003