

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9704080362 DOC. DATE: 97/03/31 NOTARIZED: YES DOCKET #:

FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269

50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270

50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION

HAMPTON, J.W. Duke Power Co.

RECIP. NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

*see Rapped
Change To
Tech specs*

SUBJECT: TS Change 96-10 to Liceses DPR-38, DPR-47 & DPR-55, correcting previously identified re HPI sys.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4+51

TITLE: OR Submittal: General Distribution

NOTES:

| | RECIPIENT | | COPIES | | RECIPIENT | | COPIES | |
|-----------|---------------|-----|--------|---------------------------|-----------|------|--------|--|
| | ID CODE/NAME | LTR | ENCL | ID CODE/NAME | LTR | ENCL | | |
| | PD2-2 LA | 1 | 1 | PD2-2 PD | 1 | 1 | | |
| | LABARGE, D | 1 | 1 | | | | | |
| INTERNAL: | ACRS | 1 | 1 | FILE CENTER-01 | 1 | 1 | | |
| | NRR/DE/ECGB/A | 1 | 1 | NRR/DE/EMCB | 1 | 1 | | |
| | NRR/DRCH/HICB | 1 | 1 | NRR/DSSA/SPLB | 1 | 1 | | |
| | NRR/DSSA/SRXB | 1 | 1 | NUDOCS-ABSTRACT | 1 | 1 | | |
| | OGC/HDS2 | 1 | 0 | | | | | |
| EXTERNAL: | NOAC | 1 | 1 | NRC PDR | 1 | 1 | | |

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTR 14 ENCL 13

AAE

C
A
T
E
G
O
R
Y
1
D
O
C
U
M
E
N
T

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(864)885-3499 Office
(864)885-3564 Fax



DUKE POWER

March 31, 1997

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
High Pressure Injection System Requirements
Technical Specification Change # 96-10

Pursuant to 10 CFR 50.90, Attachment 1 provides a proposed amendment to the Oconee Nuclear Station (ONS) Facility Operating Licenses and Technical Specifications. Attachment 2 provides a marked up copy of the current Technical Specifications. The proposed amendment request corrects previously identified deficiencies in the Technical Specifications related to the High Pressure Injection (HPI) System. The proposed amendment specifies operability requirements for the HPI System as a function of power level. Additional operability requirements are imposed above 75% rated power. Currently, all three HPI pumps and the crossover valves are administratively required to be operable whenever the RCS temperature is greater than 350°F.

The small break LOCA analyses which support this proposed license amendment are based on Framatome Technologies Incorporated topical report BAW-10192P, Rev. 0, "BWNT LOCA EM for OTSG Plants." This topical report was approved by the staff in a safety evaluation dated February 18, 1997. To support the planned conversion to Improved Technical Specifications at Oconee Nuclear Station, Duke Power requests that the NRC review of this proposed license amendment be completed by July 1997. The small break LOCA

9704080362 970331
PDR ADOCK 05000269
P PDR



1/1
A001

Document Control
March 31, 1997
Page 2

analyses which support this license amendment credit enhanced steam generator heat transfer by depressurizing the steam generators. As a result, a new Technical Specification is being proposed to address operability requirements for the main steam atmospheric dump valves.


It has been determined that the proposed amendment has no significant hazards considerations. Attachment 3 provides the Technical Justification for the proposed amendment and Attachment 4 provides the No Significant Hazards Consideration Evaluation. The Environmental Impact Analysis is provided in Attachment 5.

This proposed Technical Specification amendment change has been reviewed by both the Plant Operations Review Committee and the Nuclear Safety Review Board. This licensing amendment will result in changes to Chapters 10 and 15 of the Oconee UFSAR. Based on the expected training and other implementation activities associated with the proposed changes to Technical Specifications, an implementation period of 75 days is requested following approval of the license amendment.

A copy of this application is being forwarded to the South Carolina Department of Health and Environmental Control for their review and, as appropriate, subsequent consultation with the staff.

Please address any questions to J. E. Burchfield, Jr., at (864) 885-3292.

Very Truly Yours,



J. W. Hampton, Site Vice President
Oconee Nuclear Site

NRC Document Control
March 31, 1997
Page 3

Attachments

xc: D. E. LaBarge, ONRR
Project Manager

L. A. Reyes
Regional Administer, Region II

M. A. Scott
Senior Resident Inspector

M. Batavia
DHEC

March 31, 1997

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

J. W. Hampton, being duly sworn, states that he is Site Vice President of Duke Power Company, that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the Oconee Nuclear Station License Nos. DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



J. W. Hampton, Site Vice President

Subscribed and sworn to before me 3/31/97
Date



Notary Public

My Commission Expires:

2-12-2003