

3.3.1C(2)(c)T (Temporary Technical Specification)

For Oconee 2, HPI pump B the requirements of Specification 3.3.1.C(2)(b) are amended as follows:

Conditions where upon Oconee Unit 2 may be escalated to 100% FP in order to meet expected peak demand.

1. All Duke system generation capability has been utilized to the maximum extent available.
2. All available purchases from other VACAR utilities have been utilized.
3. All available purchases from outside the VACAR subregion have been utilized.

If all of the above conditions are satisfied and the total available generation capacity is not expected to be sufficient to meet the expected peak load and the required spinning reserve, then Oconee 2 will be escalated in power up to 100% FP.

This Temporary Technical Specification will expire at 11:59 p.m. August 15, 1980.