

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8009030605 DOC. DATE: 80/08/27 NOTARIZED: YES DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
 AUTH. NAME AUTHOR AFFILIATION
 THIES, A.C. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 O'REILLY, J.P. Region 2, Atlanta, Office of the Director

SUBJECT: Submits Revision 3 to util 90-day response to IE Bulletin 79-01B re Class IE equipment environ qualification, Raychem heat shrink tubing, scotch Cast-9, transmitter o-ring seals & lubricating grease to be replaced during refueling outage.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: General Distribution for after Issuance of Operating Lic

NOTES: M Cunningham: all amends to FSAR & changes to Tech Specs. 05000269
~~M Cunningham: all amends to FSAR & changes to Tech Specs. 05000270~~
~~M Cunningham: all amends to FSAR & changes to Tech Specs. 05000287~~

ACTION:	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME		LTR	ENCL
	REID, R.	04	13	13				
INTERNAL:	D/DIR, HUM FAC	08	1	1	DIR, HUM FAC	07	1	1
	I&E	06	2	2	NRC PDR	02	1	1
	QELD	11	1	0	OR ASSESS BR	10	1	0
	REG FILE	01	1	1				
EXTERNAL:	ACRS	09	16	16	LPDR	03	1	1
	NSIC	05	1	1				

SEP 4 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 39 ENCL 37

DUKE POWER COMPANY

P. O. Box 33189

CHARLOTTE, N. C. 28242

A. C. THIES
SENIOR VICE PRESIDENT
PRODUCTION AND TRANSMISSION

August 27, 1980

(704) 373-4249

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Re: Oconee Nuclear Station
50-269, 50-270, 50-287
IE Bulletin 79-01B

Dear Mr. O'Reilly:


Please consider this August 27, 1980, Revision 3, to Duke Power Company's "90-day" response to IE Bulletin 79-01B. This revision should be placed with our July 4, 1980, Revision 2 submittal. Duke Power Company, with this submittal, has now met the intent of the IE Bulletin 79-01B except for the four items listed in paragraph three on page 1 of 3 in Duke's Response to IE Bulletin 79-01B.

- Raychem Heat Shrink Tubing
- Scotch Cast-9
- Transmitter O-Ring Seals
- Lubricating Grease

We will replace these four items at the next unit refueling outage unless the items are determined to be qualified in the interim.

With this submittal, it is considered that all information initially required by IE Bulletin 79-01B has been provided to the Staff.

Very truly yours,



A. C. Thies

ACT:scs

cc: Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8009030605

A001
5
1/1

Mr. James P. O'Reilly, Director
August 27, 1980
Page Two

A. C. THIES, being duly sworn, states that he is a Senior Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this response to a bulletin requested under provisions of 10CFR 50.54(f); and that all statements and matters set forth herein are true and correct to the best of his knowledge.

A. C. Thies

A. C. Thies, Senior Vice President

Subscribed and sworn to before me this 27th day of August, 1980.

Joe C. Sherrill

Notary Public

My Commission Expires:

September 20, 1984