

ENCLOSURE 1

NOTICE OF VIOLATION

Duke Power Company
Oconee

Docket Nos. 50-269, 50-270, 50-287
License Nos. DPR-38, DPR-47, DPR-55

During an NRC inspection conducted on April 19-23, 1993, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

Technical Specification 6.4.6 required the licensee to implement a program conforming with 10 CFR 50.36(a) for the control of radioactive effluents and for maintaining the doses to members of the public from radioactive effluents as low as reasonably achievable. The program was required (1) to be contained in Chapter 16 of the Final Safety Analysis Report (FSAR), (2) to be implemented by operating procedures, and (3) to include remedial actions to be taken whenever the program limits were exceeded. The licensee's procedure for performing daily surveillances in the control room to verify effluent instrumentation operability (PT/2/A/600/01 "Periodic Instrument Surveillance") specified the "required condition" for the Unit 2 ventilation system radiation monitor (2-RIA-45) as "indicating on scale."

Contrary to the above, the licensee failed to follow the control room daily surveillance procedure on March 12-14, 1993. On those dates the licensee indicated on the control room surveillance logs that the Unit 2 ventilation system radiation monitor met the "required condition," as specified in the procedure, of being "on scale," which signified that the monitor was operable. The monitor was, in fact, inoperable on those dates and indicated a zero count rate.

This is a Severity Level IV violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, Duke Power Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or Demand for

9306020115 930521
PDR ADOCK 05000269
Q PDR

Duke Power Company
Oconee

2 Docket Nos. 50-269, 50-270, 50-287
License Nos. DPR-38, DPR-47, DPR-55

Information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia
this ~~21st~~ day of ~~MAY~~ 1993