

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9203020124 DOC. DATE: 92/02/19 NOTARIZED: NO DOCKET #

FACIL: 50-269	Oconee Nuclear Station, Unit 1, Duke Power Co.	05000269
50-270	Oconee Nuclear Station, Unit 2, Duke Power Co.	05000270
50-287	Oconee Nuclear Station, Unit 3, Duke Power Co.	05000287
50-369	William B. McGuire Nuclear Station, Unit 1, Duke Power	05000369
50-370	William B. McGuire Nuclear Station, Unit 2, Duke Power	05000370
50-413	Catawba Nuclear Station, Unit 1, Duke Power Co.	05000413
50-414	Catawba Nuclear Station, Unit 2, Duke Power Co.	05000414

AUTH. NAME	AUTHOR AFFILIATION
TUCKER, H.B.	Duke Power Co.
RECIP. NAME	RECIPIENT AFFILIATION
	Document Control Branch (Document Control Desk)

SUBJECT: Submits info that reflects methodology used by plants to resolve concerns identified in Generic Ltr 91-11 re Generic Issues 48 & 49. Info inadvertently omitted from 920131 cover ltr.

DISTRIBUTION CODE: A027D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Generic Ltr 91-11 - Resolutions of Generic Issues 48 & 49

NOTES: LPDR 2cys AMDTS to FSAR. ASLB lcy. 05000413
 LPDR 2cys AMDTS to FSAR. ASLB lcy. 05000414

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD2-3 LA		1	1		PD2-3 PD		1	1
	WIENS, L		2	2		REED, T		2	2
	MARTIN, R		2	2					
INTERNAL:	ACRS		6	6		NRR CHOPRA, O		1	1
	NRR HOFFMAN, S		1	1		NRR/DET/ESGB		1	1
	NRR/DOEA/OTSB11		1	1		NRR/DST 8E2		1	1
	NRR/DST/SELB 7E		1	1		NRR/DST/SICB8H7		1	1
	NRR/DST/SRXB 8E		1	1		NUDOCS-ABSTRACT		1	1
	OC/LFMB		1	0		OGC/HDS2		1	0
	REG FILE		1	1		RES/DSIR/EIB		1	1
EXTERNAL:	NRC PDR		1	1		NSIC		1	1
NOTES:			3	3					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 32 ENCL 20

MA
CH

Duke Power Company
Wachovia Center
P.O. Box 1007
Charlotte, N.C. 28201-1007



DUKE POWER

February 19, 1992

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
McGuire Nuclear Station
Docket Nos. 50-369, 370
Catawba Nuclear Station
Docket Nos. 50-413, -414
Generic Letter 91-11

Gentlemen:

The following information was inadvertently included in the McGuire Attachment (Attachment 2) and omitted from the January 31 cover letter. This information reflects the methodology used by all three stations to resolve concerns identified by Generic Letter 91-11.

Generic Issue 48 (LCOs for Class 1E Vital Instrument Buses):

1. Identify all VIBs, inverters connected to VIBs, and other on-site power sources that can provide power to VIBs.
2. Determine if design considerations, technical specifications, or procedures provide limitations on the number of VIBs that may be connected to non-battery backed power sources.
3. Determine if technical specifications or procedures provide limitations on the time a VIB may be connected to non-battery backed power sources.
4. Determine if technical specifications or procedures provide surveillances for identified VIBs and power sources.
5. If appropriate limits or other design considerations do not exist, either develop them or justify that they are not required.

Generic Issue 49 (Interlocks and LCOs for Class 1E tie breakers):

1. Identify all manually actuated tie breakers that can connect normally independent, redundant Class 1E buses (AC or DC) at one unit or that can connect Class 1E buses between units at the same site.
2. Determine if interlocks, technical specifications, or procedures restrict use of the subject tie breakers.
3. Determine if technical specifications or procedures provide surveillances for the subject tie breakers.
4. If appropriate limits or other design considerations do not exist, either develop them or justify that they are not required.


9203020124 920219
PDR ADOCK 05000269
P PDR

AD27 1/0

Document Control Desk
February 19, 1992
Page 2

If there are any questions or clarifications necessary, please contact the applicable Station Compliance Manager: Oconee/ ME Patrick (803-885-3292), McGuire/ RO Sharpe (704-875-4447), Catawba/ RC Futrell (803-831-3665).

Very Truly Yours,



H. B. Tucker, Senior Vice President
Nuclear Generation Department

PHD

cc: S. D. Ebnetter, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II
101 Marietta Street, NW Suite 2900
Atlanta, GA 30323

L. A. Wiens, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 9H3
Washington, D. C. 20555

P. E. Harmon, Resident Inspector
Oconee Nuclear Station

R. E. Martin, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 9H3
Washington, D. C. 20555

P. K.. VanDoorn, Resident Inspector
McGuire Nuclear Station

T. Reed, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 9H3
Washington, D. C. 20555

W. T. Orders, Resident Inspector
Catawba Nuclear Station