

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8310270079      DOC. DATE: 83/10/20      NOTARIZED: NO      DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.      05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.      05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.      05000287

AUTH. NAME      AUTHOR AFFILIATION  
 TUCKER, H. B.      Duke Power Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
 DENTON, H. R.      Office of Nuclear Reactor Regulation, Director  
 STOLZ, J. F.      Operating Reactors Branch 4

SUBJECT: Forwards response to Action Item 3 of IE Bulletin 80-11,  
 "Masoning Wall Design." Design assumptions appropriate  
 considering physical condition of boundary joints.

DISTRIBUTION CODE: IE11S      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3  
 TITLE: Bulletin Response (50 DKT)

NOTES: AEOD/Ornstein:1cy.      05000269  
 AEOD/Ornstein:1cy.      05000270  
 AEOD/Ornstein:1cy.      05000287

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	NRR ORB4 BC	1 1	SUERMANN, J	1 1
INTERNAL:	AEOD	1 1	<del>REG FILE</del> 01	1 1
	IE/DEPER/EGCB	1 1	IE/DEPER/EGCB/S	2 2
	NRR/DE/MEB	2 2	NRR/DE/MTEB	1 1
	NRR/DL/ORAB	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1	NTIS	1 1
NOTES:		1 1		

*Add: Reg Files - Original*

TOTAL NUMBER OF COPIES REQUIRED: LTR 17 ENCL 17

**DUKE POWER COMPANY**

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

October 20, 1983

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Chief  
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287

Dear Sir:

A letter dated July 20, 1983 from J. F. Stolz transmitted a request for additional information concerning the on-going review of Oconee Nuclear Station's response to IE Bulletin 80-11. The request for additional information was a result of a May 25-27, 1983 site visit and corporate headquarters meeting by members of your staff and Franklin Research Center (NRC consultants). My letter of September 7, 1983 had transmitted our response to seven of the eight action items requested in J. F. Stolz's July 20, 1983 letter.

My letter of August 10, 1983 addressed our concern with Action Item 3, which required confirmation and clarification in regard to the validation question by your staff. Based upon subsequent discussion with your staff, our response to Action Item 3 is attached.

Very truly yours,

*H. B. Tucker / HT*

Hal B. Tucker

PFQ/php

Attachment

cc: Mr. James P. O'Reilly, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30303

Mr. J. C. Bryant  
NRC Resident Inspector  
Oconee Nuclear Station

Mr. John F. Suermann  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

*IE11  
/11*

*Add: Reg Files - Original*

8310270079 831020  
PDR ADDCK 05000269  
Q PDR

### ITEM 3

Duke commits to provide positive shear transfer to the boundaries of walls qualified based on stress allowables as stated in the Staff criteria, or to demonstrate to the Staff's satisfaction that the existing boundary joint is capable of transferring the design load. If arching action is validated and demonstrates shear transfer, this can be extrapolated to walls qualified using stress allowables. If arching action validation is not considered, Duke shall submit an implementation scheduled by August 31, 1983, for Staff approval.

### RESPONSE 3

The computation of the boundary shear stress is based upon the face shell thickness and the maximum support reaction. The resulting maximum shear stress for this rectangular area is calculated using the relationship:

$$f_{v_{\max}} = \frac{3V}{2A}$$

where:

$f_{v_{\max}}$  is the maximum shear stress

V is the maximum support reaction per unit length

A is the support area per unit length

The normal allowable shear stress, in accordance with ACI 531-79, Table 10.1 is  $1.1\sqrt{f'_m}$ . Using the in-place  $f'_m$  and the SGEB criteria seismic increase factor of 1.3, the allowable shear stress would be 61.7 psi. The allowable shear stress per the Duke Power criteria, based on the assumed lower material properties, is 58.1 psi.

Using the method described above the worst case maximum shear stress is calculated to be 23.7 psi. Typically, the calculated shear stresses are less than 15 psi. The maximum calculated shear stresses are considerably less by factors of at least 2.4 and typically by 4 or greater than the allowable permitted in either the SGEB criteria or the Duke Power criteria.

The boundary shear for all eight inch hollow core masonry was computed based upon the face shell thickness of regular block ( $t_f = 1 \frac{1}{4}$ "). This results in a conservative area for the fired blocks which have a minimum face shell thickness of  $1 \frac{3}{4}$ ".

In the reevaluation program an assumed value of  $f'_m$  was used for the analysis. Subsequent testing of masonry samples removed from Ocone indicates that the value of  $f'_m$  is considerably higher than the assumed value of 1000 psi. The testing also indicated that the actual mass of the masonry is appreciably lower than that which was assumed. Neither of these facts was considered in the analysis. This would result in higher allowables and lower support reactions, thereby, increasing the overall factor of safety.

During the recent field surveillance, conducted in response to item 2, the masonry wall boundaries were inspected with respect to the design assumptions. This inspection was for the purpose of insuring that the boundary condition assumed in the analysis was appropriate and/or conservative. The masonry walls in question are in-fill panels, built into and confined between relatively rigid reinforced concrete support frames with well constructed mortar joints. Some mortar joints at the boundaries were identified as having hairline cracking between the concrete face and masonry. These mortar joints were examined closely for looseness or poor construction. The cracking in the mortar was extremely fine. All joints were found to have solid mortar. It was concluded the design assumptions are appropriate considering the physical condition of the boundary joints.

Duke has reviewed the support conditions and found them to be acceptable of transferring the masonry wall boundary reaction loads. A further conservatism that may be considered when evaluating the ultimate capacity of the wall is arching action.