

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8412170254 DOC.DATE: 84/12/11 NOTARIZED: NO DOCKET #
 FACIL:50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-27 Washington State Univ. Research Reactor 05000027
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
 AUTH.NAME AUTHOR AFFILIATION
 TUCKER,H.B. Duke Power Co.
 RECIP.NAME RECIPIENT AFFILIATION
 DENTON,H.R. Office of Nuclear Reactor Regulation, Director
 STOLZ,J.F. Operating Reactors Branch 4

SUBJECT: Forwards requests for relief from ASME Code Section XI inservice insp requirements for hydrostatic testing of valves to suppl 840913 & 1116 requests,Hydrostatic testing of valves impractical & uneconomical.

DISTRIBUTION CODE: A047D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 6
 TITLE: OR Submittal: Inservice Inspection/Testing

NOTES:AEOD/Ornstein:1cy. 05000269
 UL:02/06/73
 AEOD/Ornstein:1cy. 05000287
 UL:07/19/74

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR ORB4 BC 01		7	7	NRR SSPB BC 01		7 7
INTERNAL:	ACRS 16		10	10	ADM/LFMB		1 0
	ELD/HDS4		1	0	ELD/HDS1		1 0
	ELD/HDS4		1	0	NRR/DE/MEB 15		1 1
	<u>NRR/DE/MTEB</u> 14		1	1	NRR/DL/TAPMG		1 1
	<u>REG FILE</u> 04		1	1	RGN2		1 1
	RGN4		1	1			
EXTERNAL:	LPDR 03		1	1	NRC PDR 02		1 1
	NSIC 05		1	1	NTIS		1 1
NOTES:			1	1			

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

December 11, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Sir:


Pursuant to 10 CFR 50, 50.55a, please find attached two requests for relief from the requirements of Section XI of the ASME Boiler and Pressure Vessel Code (with Addenda through Winter 1980). These requests are submitted due to the impracticality of hydrostatically testing specific valves as required by the code following maintenance or modification.

By letter dated November 16, 1984, Duke Power submitted a general request for exemption from the requirements of hydrostatic testing following maintenance or modification for cases in which such testing is deemed impractical. The November 16th letter specifically identified alternate methods of Non Destructive Examination (NDE) to be performed for these cases. The general request, within context of the November 16th letter, is applicable to the two relief requests referred to in the preceding paragraph; however, for remaining work associated with the recently concluded Unit 1, Cycle 9 refueling outage, Duke will submit any necessary relief requests on an individual basis.

In the future, for cases where hydrostatic testing following maintenance or modification is required, and Duke has been determined such testing to be impractical, Duke contends that the November 16th letter provides sufficient basis for such exemptions. Duke, therefore, will not submit any individual relief requests for such cases. Unless informed to the contrary, Duke considers this course of action is acceptable to the NRC.

This request is considered to supplement the request made by my letter of September 13, 1984, as supplemented by my November 16th letter. As such, no additional fees are required.

Very truly yours,



Hal B. Tucker

RFH:s1b

8412170254 841211
PDR ADOCK 05000269
Q PDR

A047
11

Mr. Harold R. Denton, Director
December 11, 1984
Page Two

Attachment

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. J.C. Bryant
NRC Resident Inspector
Oconee Nuclear Station

Ms. Helen Nicolaras
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

DUKE POWER COMPANY
OCONEE NUCLEAR STATION
(WITH ADDENDA THROUGH WINTER 1980)
INSERVICE INSPECTION REQUIREMENTS

A. 1. Component for Which Exemption is Requested:

(a) Name and Number:

1SD43, 3/4" Gate Valve
Velan Model WH-254B-2TY
P. O. Drawing #122.A1

(b) Function:

Controls the flow in the Turbine Driven Emergency Feedwater Pump steam drain going to the trench.

(c) ASME Section III Code Class:

III

(d) Valve Category:

Manual Gate Valve

2. Reference Code Requirement That Has Been Determined To Be Impractical:

Inservice requirements per IWD-5000 of Section XI of ASME Code. Specifically, the requirement for hydrostatic testing following maintenance or modification.

3. Basis for Requesting Relief:

Hydrostatic testing of this valve is impractical and uneconomical; since the valve cannot be isolated, testing would require pressurization of both the auxiliary steam header and the Turbine Driven Emergency Feedwater Pump.

4. Alternate Examination:

Liquid penetrant testing will be performed on the welds, and a leak check will be performed at system temperature and pressure (495 psig and 310°F).

5. Implementation Schedule:

Valve 1SD43 was replaced 11/27/84. The liquid penetrant test was done after the installation, and leak check was performed at system temperature and pressure.

DUKE POWER COMPANY
OCONEE NUCLEAR STATION
REQUEST FOR RELIEF FROM ASME CODE SECTION XI
(WITH ADDENDA THROUGH WINTER 1980)
INSERVICE INSPECTION REQUIREMENTS

- A. 1. Component for Which Exemption is Requested:
- (a) Name and Number: 1 LP-46, 1½" check valve
P.O. Drawing #100A-1
 - (b) Function: Prevents backflow from pressurizer to auxiliary spray system.
 - (c) ASME Section III Code Class: I
 - (d) Valve Category: N/A
2. Reference Code Requirement That Has Been Determined To Be Impractical:
Inservice requirements per IWB-5000 of Section XI of ASME Code. Specifically, the requirement for hydrostatic testing following maintenance or modification.
3. Basis for Requesting Relief: Hydrostatic testing is impractical and uneconomical because the entire pressurizer would have to be pressurized to perform the test.
4. Alternate Examination: Liquid penetrant test the stainless steel socket welds that replaced valve 1LP46. This was performed and accepted. Additionally, visual examination for leakage at system operating temperature and pressure will be performed.
5. Implementation Schedule: Valve 1LP46 was replaced 11/10/84, Visual inspection of welds will be performed at hot shutdown.

System # 53A(9) UNIT # 1 R.B.

CLASS B & C


Size	WALL THICKNESS	CLASS	MAT.	WELD NUMBER	Weld Procedure Code	W.D.T Code
1 1/2"	.281"	B	304H	2-4, 7, 8, 28, 29, 8AA, 8BA, 22, 23, 30, 31, 10-12, 13A, 14, 15B, 16A, 16B, 16-19, 20A, 21A	P-7 L-251	6 6
1"	.250	C	304H	34	L-204	0
1"	.250	C	304H	24	P-7	0
1"	.250	C	316	32, 33	L-201	0 6
Attachments				4A, 8A, 8B, 11A, 15A	P-7	

B31.7
 P.S. 1501.2
 Sect II - Cl. 1

OMIT WELDS	ADDED WELDS
9, 7, 25	REPUNCH: 3, 4, 28, 29
5, 6, 14	REPUNCH: 24 to 1"
15, 13	30, 31
26, 27	10, 11A, 8B, 11A, 15A
21	11A, 8AA, 8BA
	14
	Relocate #4A
	16A, 16B, 15B, 13A
	Correct Size
	Note 1 & 2
	Repunch 15" to B
	Repunch 6" all to 304H

CLASS B - 100% RT ALL BUTT WELDS AND BRANCH WELDS OVER 4" NPS. 100% MT / PT ALL FILLET, SOCKET, SEAL ATTACHMENT, AND BRANCH WELDS. NOTE, ANY WELD 1" AND LESS IN DIAMETER IS CLASS C OR E.

CLASS C - 100% RT ALL BUTT WELDS A WELDER MAKES OVER 4" DIAMETER. 100% MT / PT 1 WELD FOR EVERY 10 FILLET, SOCKET, OR BRANCH WELDS A WELDER MAKES OVER 4" DIAMETER.



ADDED WELDS	
32-34	100%
ADD W.P. 204	100%
21A	100%

Note 1 - All SW fittings are 304H, 6000#
 Note 2 - All flanges are 316H, 9s
 Note 3 - 316" MATL

REF. DRUGS. 481A

WR. 969868

✓ by K.W. Young 11 Dec 72

