

October 6, 1989

Docket Nos. 50-269
50-270
50-287

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

SUBJECT: ATWS (10 CFR 50.62) IMPLEMENTATION SCHEDULE FOR OCONEE
NUCLEAR STATION (TAC NOS. 59119/59120/59121)

We have reviewed your letter dated August 4, 1989, in which you documented your proposed schedule to install the ATWS Mitigating System Actuation Circuitry (AMSAC). This hardware implementation is required in compliance with the Anticipated Transient Without Scram (ATWS) rule contained in 10 CFR 50.62.

Based on our review of the justification you provided for your proposed schedule, we find your schedule for Oconee Units 2 and 3 acceptable. However, we cannot agree with your proposed implementation schedule for Unit 1 until you commit to installing the ATWS modification in Oconee Unit 1 during an outage of sufficient length which may occur prior to the scheduled August, 1991 refueling outage but after completion of the ATWS implementation in Oconee Unit 2. Included in your commitment should be the acceleration of the schedule for installation of those parts of the ATWS modification which can be done on-line for Oconee Unit 1. Please provide your written commitment to us within 60 days of the date of this letter.

Please contact me at (301) 492-1493 if you have any questions regarding this matter.

Sincerely,

/s/

Leonard A. Wiens, Project Manager
Project Directorate II-3
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File

NRC PDR

Local PDR

PDII-3 Reading

S. Varga

14-E-4

G. Lainas

14-H-3

D. Matthews

14-H-25

S. Newberry

7-E-12

M. Rood

14-H-25

L. Wiens

14-H-25

OGC (For inform. Only)

15-B-18

E. Jordan

MNBB-3302

B. Grimes

9-A-2

ACRS (10)

P-315

[Oconee Plant File]

M. Lynch

13-E-21

[TUCKER LTR 8/15]

PDII-3

MRood

9/28/89

PDII-3

LWiens

9/28/89

PDII-3

MLynch

10/02/89

SICB

SNewberry

10/2/89

PDII-3

DMatthews

10/2/89

8910180024 891006
PDR ADOCK 05000269
PDC

DFOL
1/0

MAY

Mr. H. B. Tucker
Duke Power Company

Oconee Nuclear Station
Units Nos. 1, 2 and 3

cc:

Mr. A. V. Carr, Esq.
Duke Power Company
P. O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Mr. Paul Guill
Duke Power Company
Post Office Box 33189
422 South Church Street
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.
Bishop, Cook, Purcell & Reynolds
1400 L Street, N.W.
Washington, D.C. 20005

Mr. Alan R. Herdt, Chief
Project Branch #3
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Division
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852

Ms. Karen E. Long
Assistant Attorney General
N. C. Department of Justice
P.O. Box 629
Raleigh, North Carolina 27602

Manager, LIS
NUS Corporation
2536 Countryside Boulevard
Clearwater, Florida 34623-1693

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Route 2, Box 610
Seneca, South Carolina 29678

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Office of Intergovernmental Relations
116 West Jones Street
Raleigh, North Carolina 27603

County Supervisor of Oconee County
Walhalla, South Carolina 29621

October 4, 1989

DISTRIBUTION:
Docket File
PDII-3 r/f
RIngram
LWiens

DOCKET NO(S). 50-269, 50-270,
and 50-287

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

SUBJECT: OGONEE NUCLEAR STATION, UNITS 1, 2 and 3

The following documents concerning our review of the subject facility are transmitted for your information.

	DESCRIPTION OF DOCUMENT	DATED
	Notice of Receipt of Application	
	Draft/Final Environmental Statement	
	Notice of Availability of Draft/Final Environmental Statement	
	Safety Evaluation Report, or Supplement No. _____	
	Environmental Assessment and Finding of No Significant Impact	
	Notice of Issuance of Environmental Assessment	
	Notice of Consideration of Issuance of Facility Operating License or Amendment to Facility Operating License	
X	Biweekly Notice; Applications and Amendments to Operating Licenses Involving No Significant Hazards Conditions See Page(s) 37045	09/06/89
	Exemption	
	Construction Permit No. CPPR- _____, Amendment No. _____	
	Facility Operating License No. _____, Amendment No. _____	
	Order	
	Monthly Operating Report for _____ transmitted by Letter	
	Annual/Semi-Annual Report: _____ transmitted by Letter	
	Other _____	

Office of Nuclear Reactor Regulation

Enclosures:
As Stated

MA-4

cc: See next page

OFFICE▶	PDII-3	PDII-3				
SURNAME▶	RIngram:cb	LWiens				
DATE▶	09/26/89	09/1/89				