

FORD 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9402280098 DOC. DATE: 94/02/17 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 HERDT, A.R. Region 2 (Post 820201)
 RECIP. NAME RECIPIENT AFFILIATION
 HAMPTON, J.W. Duke Power Co.

SUBJECT: Forwards insp repts 50-269/94-01, 50-270/94-01 & 50-287/94-01
 & NOV. Violation is of concern because licensee did not
 require adequate procedural guidance or oversight of vendor
 installation of steam generator tube plugs.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+15
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD2-3 PD		1	1		WIENS, L		1	1
INTERNAL:	ACRS		2	2		AEOD/DEIB		1	1
	AEOD/DSP/ROAB		1	1		AEOD/DSP/TPAB		1	1
	AEOD/TTC		1	1		DEDRO		1	1
	NRR/DORS/OEAB		1	1		NRR/DRCH/HHFB		1	1
	NRR/DRIL/RPEB		1	1		NRR/DRSS/PEPB		1	1
	NRR/PMAS/ILPB1		1	1		NRR/PMAS/ILPB2		1	1
	NUDOCS-ABSTRACT		1	1		OE-DIR		1	1
	OGC/HDS2		1	1		<u>REG FILE</u> 02		1	1
	RES/HFB		1	1		RGN2-FILE 01		1	1
EXTERNAL:	EG&G/BRYCE, J.H.		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 24 ENCL 24

FEB 17 1994

Docket Nos. 50-269, 50-270, 50-287 and 72-4
License Nos. DPR-38, DPR-47,
DPR-55 and SNM-2503

Duke Power Company
ATTN: Mr. J. W. Hampton
Vice President
Oconee Site
P. O. Box 1439
Seneca, SC 29679

Gentlemen:

SUBJECT: NOTICE OF VIOLATION
(NRC INSPECTION REPORT NOS. 50-269/94-01, 50-270/94-01 AND
50-287/94-01)

This refers to the inspection conducted by P. E. Harmon of this office on January 2 through January 29, 1994. The inspection included a review of activities authorized for your Oconee facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed inspection report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

Based on the results of this inspection, certain activities appeared to be in violation of NRC requirements, as specified in the enclosed Notice of Violation (Notice). The violation is of concern because you did not require adequate procedural guidance or oversight of vendor installation of steam generator tube plugs, an activity important to safety.

You are required to respond to this letter and should follow the instructions specified in the enclosed Notice when preparing your response. In your response, you should document the specific actions and any additional actions you plan to prevent recurrence. After reviewing your response to this Notice, including your proposed corrective actions and the results of future inspections, the NRC will determine whether further NRC enforcement action is necessary to ensure compliance with the NRC regulatory requirements.

In accordance with 10 CFR 2.970 of the NRC's "Rules of Practice", a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

The responses directed by this letter and the enclosed Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, Pub. L. No. 96-511.

9402280098 940217
PDR ADOCK 05000269
G PDR

FEB 17 1994

Should you have any questions concerning this letter, please contact us.

Sincerely,

ORIGINAL SIGNED BY
ALAN R. HERDT

Alan R. Herdt, Chief
Reactor Projects Branch 3
Division of Reactor Projects

Enclosures:

1. Notice of Violation
2. NRC inspection Report

cc w/encls:

Steve Benesole
Compliance
Duke Power Company
P. O. Box 1439
Seneca, SC 29679

A. V. Carr, Esq.
Duke Power Company
422 South Church Street
Charlotte, NC 28242-0001

County Supervisor of
Oconee County
Walhalla, SC 29621

Robert B. Borsum
Babcock and Wilcox Company
Nuclear Power Generation Division
1700 Rockville Pike, Suite 525
Rockville, MD 20852

J. Michael McGarry, III, Esq.
Winston and Strawn
1400 L Street, NW
Washington, D. C. 20005

Office of Intergovernmental Relations
116 West Jones Street
Raleigh, NC 27603

cc w/encls: See page 3

Duke Power Company

3

FEB 17 1994

cc w/encls: Continued
Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, SC 29201

Manager, LIS
NUS Corporation
2650 McCormick Drive
Clearwater, FL 34619-1035

G. A. Copp
Licensing - EC050
Duke Power Company
P. O. Box 1006
Charlotte, NC 28201-1006

Karen E. Long
Assistant Attorney General
N. C. Department of Justice
P. O. Box 629
Raleigh, NC 27602

bcc w/encl:
L. A. Wiens, NRR
W. Miller, RII
M. S. Lesser, RII
A. R. Herdt, RII
Document Control Desk

NRC Resident Inspector
U.S. Nuclear Regulatory Commission
Route 2, Box 610
Seneca, SC 29678

RII
W Miller
W Miller
02/16/94

RII
M Lesser
M Lesser *AK 2/16/94*
02/16/94