

ENCLOSURE

NOTICE OF DEVIATION

Duke Power Company
Oconee 1, 2, and 3

Docket Nos. 50-269, 270, and 287
License Nos. DPR-38, 47, and 55

During an NRC inspection conducted on June 5 - July 2, 1994, deviations from written commitments were identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Action," 10 CFR Part 2, Appendix C, the deviations are listed below:

- A. Final Safety Analysis Report, section 3.2.2.1, "System Classifications," states in part that those portions of Engineered Safeguards Systems which may see recirculated reactor building sump water following a Loss of Coolant Accident are required to be Class II (Duke Class B).

Contrary to the above, the portions of the Unit 1 and Unit 3 low pressure injection systems between check valves LP-29/30 and motor operated valves LP-21/22 are classified as Class III (Duke Class C), even though this piping may see recirculated reactor building sump water following a Loss of Coolant Accident.

This Deviation is applicable to Units 1 and 3.

- B. Final Safety Analysis Report, section 3.2.2.1, "System Classifications," states in part that welds between classes of systems (Class I to II, I to III, or II to III) are performed and inspected in accordance with the rules for the higher class.

Contrary to the above, welds between classes of systems are not performed and inspected in accordance with the rules of the higher class. The licensee program performs and inspects welds between classes of systems in accordance with the rules for the lower class.

This Deviation is applicable to Units 1, 2 and 3.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, in writing within 30 days of the date of this Notice, the reason for the deviation, the corrective steps that have been taken and the results achieved, the corrective steps which will be taken to avoid further deviations, and the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia
this 25th day of July 1994

9408090146 940727
PDR ADOCK 05000269
G PDR