

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9509250261 DOC. DATE: 95/09/21 NOTARIZED: NO DOCKET #
FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269 P
50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270 R
50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
AUTH. NAME AUTHOR AFFILIATION
HAMPTON, J.W. Duke Power Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Corrects calculation number in insp repts 50-269/95-10,
50-270/95-10 & 50-287/95-10 to reflect Calculation KC-2024.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME		LTR	ENCL	
	PD2-2 PD		1	1	
INTERNAL:	ACRS		2	2	
	AEOD/SPD/RAB		1	1	
	DEDRO		1	1	
	NRR/DISP/PIPB		1	1	
	NRR/DRCH/HHFB		1	1	
	OE DIR		1	1	
	RGN2 FILE 01		1	1	
EXTERNAL:	LITCO BRYCE, J H		1	1	
	NRC PDR		1	1	
	WIENS, L		1	1	
	AEOD/DEIB		1	1	
	AEOD/TTC		1	1	
	FILE CENTER		1	1	
	NRR/DORS/OEAB		1	1	
	NUDOCS-ABSTRACT		1	1	
	OGC/HDS2		1	1	
	NOAC		1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 19 ENCL 19

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER

September 21, 1995

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Site
Docket Nos. 50-269, -270, -287
NRC Inspection Report No. 50-269, 270, 287/95-10

During the inspection conducted on June 5-16, 1995, NRC inspectors reviewed calculation KC-0107, Analysis of Keowee Lockout Relay Trip Signals. The inspection report contained a summary of the calculation and determined that the calculation was adequate. This letter is written to correct the calculation number referenced in the inspection report. Following the inspection, the calculation was issued to document management for placement in the master files. At this time, the calculation number was determined to be redundant and a new number was assigned to the calculation. The revised number for the Analysis of Keowee Lockout Relay Trip Signals calculation is KC-2024.

If there are any questions, please contact Michael Bailey at (803) 885-4390

Very truly yours,

J. W. Hampton, Site Vice President
Oconee Nuclear Station

cc: Mr. S. D. Ebnetter, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II

Mr. L. A. Wiens, Project Manager
Office of Nuclear Reactor Regulation

Mr. P. E. Harmon
Senior Resident Inspector
Oconee Nuclear Site

9509250261 950921
PDR ADOCK 05000269
Q PDR

DEC 11/0