

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9403170027 DOC. DATE: 94/03/10 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 HAMPTON, J.W. Duke Power Co. R
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk) I

SUBJECT: Forwards "Pressure-Temp Limits for 19 EPFY for Oconee Unit 2 Nuclear Plant PTS Evaluation for Oconee Units 1, 2 & 3." D

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 7 S
 TITLE: OR Submittal: General Distribution /

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL	
	PD2-3 LA		1	1		PD2-3 PD		1	1	
	WIENS, L		2	2						
INTERNAL:	ACRS		6	6		NRR/DE/EELB		1	1	S
	NRR/DORS/OTSB		1	1		NRR/DRCH/HICB		1	1	
	NRR/DRPW		1	1		NRR/DSSA/SPLB		1	1	
	NRR/DSSA/SRXB		1	1		NUDOCS-ABSTRACT		1	1	
	OC/LEDCEB		1	0		OGC/HDS2		1	0	
	<u>REG FILE</u> 01		1	1						
EXTERNAL:	NRC PDR		1	1		NSIC		1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 20

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER


March 10, 1994

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Pressurized Thermal Shock Evaluation

By letter dated July 14, 1993, Duke Power Company indicated that an evaluation of the reactor vessel inside surface end-of-life RT_{PTS} based on 10 CFR 50.61 had been performed. Results of this evaluation concluded that the Oconee Unit 1, 2, and 3 reactor pressure vessels will remain below the 10 CFR 50.61 pressurized thermal shock screening criteria. A copy of the B&W pressurized thermal shock evaluation is attached to this letter for your review.

Very truly yours,


J. W. Hampton

cc: Mr. S. D. Ebnetter, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II

Mr. L. A. Wiens, Project Manager
Office of Nuclear Reactor Regulation

Mr. P. E. Harmon
Senior Resident Inspector
Oconee Nuclear Site

9403170027 940310
PDR ADDCK 05000269
P PDR

A001
111