

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7902060188 DOC. DATE: 79/02/02 NOTARIZED: NO
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.
 AUTH. NAME AUTHOR AFFILIATION
 LEWIS, S.R. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 O'REILLY, J.P. Region 2, Atlanta, Office of the Director

DOCKET #
 0500026

SUBJECT: LER 79-001/03L-0 on 790102:RPS Channel C Loop A flow
 Transmitter indicated high due to malfunctioning amplifier
 in transmitter. Amplifier replaced; transmitter recalibrated &
 returned to service.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3x1
 TITLE: INCIDENT REPORTS

NOTES: M. CUNNINGHAM - ALL AMENDS TO FSAR & CHANGES TO TECH SPECS.

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL	ID	CODE/NAME	LTR	ENCL
ACTION:	05	BC ORB#4	4	4				
INTERNAL:	01	REG FILE	1	1	02	NRC PDR	1	1
	09	I&E	2	2	11	MPA	3	3
	14	TA/EDO	1	1	15	NOVAK/KNIEL	1	1
	16	EEB	1	1	17	AD FOR ENGR	1	1
	18	PLANT SYS BR	1	1	19	I&C SYS BR	1	1
	20	AD PLANT SYS	1	1	21	A) SYS/PROJ	1	1
	22	REAC SAFT BR	1	1	23	ENGR BR	1	1
	24	KREGER	1	1	25	PWR SYS BR	1	1
	26	AD/SITE ANAL	1	1	27	OPERA LIC BR	1	1
	28	ACDENT ANLYS	1	1	E	JORDAN/IE	1	1
EXTERNAL:	03	LPDR	1	1	04	NSIC	1	1
	29	ACRS	16	16				

6656

TOTAL NUMBER OF COPIES REQUIRED: LTR 45 ENCL 45