

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7903150282 DOC. DATE: 79/03/08 NOTARIZED: NO
 FACIL: 50-269 OCONEE NUCLEAR STATION, UNIT 1, DUKE POWER CO.
 AUTH. NAME: LEWIS, S.R. AUTHOR AFFILIATION: DUKE POWER CO.
 RECIP. NAME: REGION 2, ATLANTA, OFFICE OF THE DIRECTOR

DOCKET #
05000269

SUBJECT: LER 79-005/03L-1 ON 790212: HOLDING POWER SUPPLY BREAKER CB-1
 FAILED TO TRIP DURING ON-LINE TEST. CAUSED BY FAULTY
 MECHANICAL LINKAGE. MINOR TRIP MECHANISM ADJUSTMENT
 PERFORMED.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+3
 TITLE: INCIDENT REPORTS

NOTES: M. CUNNINGHAM - ALL AMDTS TO FSAR & CHANGES TO TECH SPECS.

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
ACTION:	05 BC ORB #4	4	4			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	14 TA/EDO	1	1	15 NOVAK/KNIEL	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	21 AD SYS/PROJ	1	1
	22 REAC SAFT BR	1	1	23 ENGR BR	1	1
	24 KREGER	1	1	25 PWR SYS BR	1	1
	26 AD/SITE ANAL	1	1	27 OPERA LIC BR	1	1
	28 ACCIDENT ANLYS	1	1	29 AUX SYS BR	1	1
	E JORDAN/IE	1	1			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

404
T

MAR 19 1979