

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7907110557 DUC. DATE: 78/05/19 NOTARIZED: NO
 *FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.

DOCKET #
 05000269
 05000270
 05000287

AUTH. NAME WILSON, K.R.
 RECIP. NAME
 AUTHOR AFFILIATION Duke Power Co.
 RECIPIENT AFFILIATION Region 2, Atlanta, Office of the Director

Reportable Occurrence

SUBJECT: ~~LER~~ 78-012/03L-0 on 780417: instrumented relay in Keowee Unit 2 in field flasing breaker trip circuitry activated. Cause possibly due to spurious trip signal. Corrective actions include monitoring of field flash breaker circuitry

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+3
 TITLE: INCIDENT REPORTS

NOTES: M. CUNNINGHAM - ALL AMENDS TO FSAR & CHANGES TO TECH SPECS.

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
	05 BC <u>ARRAY</u>	4	4			
INTERNAL:	01 <u>REG FILE</u>	1	1	02 NRC PDR	1	1
	09 ICE	2	2	11 MPA	3	3
	14 TA/EDO	1	1	15 NOVAK/KNIEL	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	21 AD SYS/PROJ	1	1
	22 REAC SAFT BR	1	1	23 ENGR BR	1	1
	24 KREGER	1	1	25 PWR SYS BR	1	1
	26 AD/SITE ANAL	1	1	27 OPERA LIC BR	1	1
	28 ACCENT ANLYS	1	1	29 AUX SYS BR	1	1
	E JORDAN/IE	1	1	HANAUER, S.	1	1
	TMI DOC CENTER	1	1			
EXTERNAL:	03 LPDR	1	1	04 MSIC	1	1
	29 ACKS	16	16			

Handwritten initials/signature

TOTAL NUMBER OF COPIES REQUIRED: LTR 48 ENCL 48